

SECTION I

INSPECTION OBJECTIVES

1. Ensure that the test procedure is technically adequate.
2. Ensure that the described test is consistent with regulatory requirements, guidance and licensee commitments.

SECTION II
INSPECTION REQUIREMENTS

The inspector shall:

1. Obtain and review an approved copy of the test procedure(s) for technical adequacy prior to the date scheduled for the test.
2. Review the FSAR, docketed correspondence, SER, Technical Specifications, and Regulatory Guide 1.68. Verify that the procedure adequately address NRC requirements and licensee commitments relating to the Auxiliary Feedwater System.
3. Review the test procedure(s) in accordance with inspection procedure MC 70300B.

SECTION III
INSPECTION GUIDANCE

1. This review should insure that important system performance functions are adequately reflected in this test procedure. Items which should be adequately tested as part of the test procedure include (but are not limited to):
 - a. proper operation of system components at or near normal system parameters, including steam supply to the turbine-driven pump, pump capacity and hydraulic performance,
 - b. proper instrumentation verification,
 - c. proper system control local and remote, and
 - d. system control interlocks and alarms.

NOTE: Specific items may be part of other systems tests.