

November 19, 2008

LICENSEE: PPL Susquehanna, LLC

FACILITY: Susquehanna Steam Electric Station, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON NOVEMBER 13, 2008, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND PPL SUSQUEHANNA, LLC., CONCERNING THE RESPONSES TO REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of PPL Susquehanna, LLC (PPL), held a telephone conference call on November 13, 2008, to discuss PPL's responses to the requests for additional information (RAIs), concerning the Susquehanna Steam Electric Station, Units 1 and 2, license renewal application (LRA). By letter dated July 3, 2008, the NRC staff sent PPL RAIs on the metal fatigue time-limited aging analysis. In a letter dated August 1, 2008, PPL responded to RAI 4.3-4 by reference to Boiling Water Reactor Vessel and Internals Program (BWRVIP)-183. The BWRVIP-183 titled "Inspection Guidelines and Flaw Evaluation of Top Guide Grid Beams," has not been reviewed by the staff for approval. The staff asked PPL to amend its response to remove reference to BWRVIP-183.

The Enclosure provides a listing of the participants.

The applicant had an opportunity to comment on this summary.

IRAI

Evelyn Gettys, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-387 and 50-388

Enclosure:
As stated

cc w/encl: See next page

November 19, 2008

LICENSEE: PPL Susquehanna, LLC

FACILITY: Susquehanna Steam Electric Station, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON NOVEMBER 13, 2008, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND PPL SUSQUEHANNA, LLC., CONCERNING THE RESPONSES TO REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of PPL Susquehanna, LLC (PPL), held a telephone conference call on November 13, 2008, to discuss PPL's responses to the requests for additional information (RAIs), concerning the Susquehanna Steam Electric Station, Units 1 and 2, license renewal application (LRA). By letter dated July 3, 2008, the NRC staff sent PPL RAIs on the metal fatigue time-limited aging analysis. In a letter dated August 1, 2008, PPL responded to RAI 4.3-4 by reference to Boiling Water Reactor Vessel and Internals Program (BWRVIP)-183. The BWRVIP-183 titled "Inspection Guidelines and Flaw Evaluation of Top Guide Grid Beams," has not been reviewed by the staff for approval. The staff asked PPL to amend its response to remove reference to BWRVIP-183.

The Enclosure provides a listing of the participants.

The applicant had an opportunity to comment on this summary.

IRAI

Evelyn Gettys, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-387 and 50-388

Enclosure:
As stated

cc w/encl: See next page

DISTRIBUTION: See next page

ADAMS Accession No.: **ML083230786**

OFFICE	LA:DLR	PM:RPB1:DLR	BC: RPB1:DLR
NAME	IKing	EGettys	DPelton
DATE	11/18/08	11/19/08	11/19/08

OFFICIAL RECORD COPY

**TELEPHONE CONFERENCE CALL
SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2
LICENSE RENEWAL APPLICATION**

LIST OF PARTICIPANTS
November 13, 2008

PARTICIPANTS

Evelyn Gettys

Erach Patel

Duane Filchner

Dave Flyte

Jeff Weik

Bruce Swoyer

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)

ATL

PPL Susquehanna, LLC (PPL)

PPL

PPL

PPL

ENCLOSURE

Letter to PPL Susquehanna, LLC from E. Gettys, dated November 19, 2008

DISTRIBUTION:

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON NOVEMBER 13, 2008, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND PPL SUSQUEHANNA, LLC., CONCERNING THE RESPONSES TO REQUESTS FOR ADDITIONAL INFORMATION PERTAINING TO THE SUSQUEHANNA STEAM ELECTRIC STATION, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

RidsNrrDlr

RidsNrrDlrRlra

RidsNrrDlrRlrb

RidsNrrDlrRlrc

RidsNrrDlrReba

RidsNrrDlrRebb

RidsNrrDciCvib

RidsNrrDciCpnb

RidsNrrDraAfpb

RidsNrrDeEmcb

RidsNrrDeEeeb

RidsNrrDssSrxb

RidsNrrDssSbpb

RidsNrrDssScvb

RidsOgcMailCenter

EGettys

FJaxheimer

Susquehanna Steam Electric Station,
Units 1 and 2

cc:

Cornelius J. Gannon
Vice President - Nuclear Operations
PPL Susquehanna, LLC
769 Salem Blvd., NUCSB3
Berwick, PA 18603-0467

Robert M. Paley
General Manager - Plant Support
PPL Susquehanna, LLC
769 Salem Blvd., NUCSB2
Berwick, PA 18603-0467

Rocco R. Sgarro
Manager - Nuclear Regulatory Affairs
PPL Susquehanna, LLC
Two North Ninth Street, GENPL4
Allentown, PA 18101-1179

Supervisor - Nuclear Regulatory Affairs
PPL Susquehanna, LLC
769 Salem Blvd., NUCSA4
Berwick, PA 18603-0467

Michael H. Crowthers
Supervisor - Nuclear Regulatory Affairs
PPL Susquehanna, LLC
Two North Ninth Street, GENPL4
Allentown, PA 18101-1179

Ronald E. Smith
General Manager - Site Preparedness
and Services
PPL Susquehanna, LLC
769 Salem Blvd., NUCSA4
Berwick, PA 18603-0467

Michael H. Rose
Manager - Quality Assurance
PPL Susquehanna, LLC
769 Salem Blvd., NUCSB2

Joseph J. Scopelliti
Community Relations Manager,
Susquehanna
PPL Susquehanna, LLC
634 Salem Blvd., SSO
Berwick, PA 18603-0467

Bryan A. Snapp, Esq.
Associate General Counsel
PPL Services Corporation
Two North Ninth Street, GENTW3
Allentown, PA 18101-1179

Document Control Services
PPL Susquehanna, LLC
Two North Ninth Street, GENPL4
Allentown, PA 18101-1179

Richard W. Osborne
Allegheny Electric Cooperative, Inc.
212 Locust Street
P.O. Box 1266
Harrisburg, PA 17108-1266

Director, Bureau of Radiation Protection
Pennsylvania Department of
Environmental Protection
Rachel Carson State Office Building
P.O. Box 8469
Harrisburg, PA 17105-8469

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 35, NUCSA4
Berwick, PA 18603-0035

Susquehanna Steam Electric Station,
Units 1 and 2

- 2 -

cc:

Regional Administrator, Region 1
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406
Berwick, PA 18603-0467

Board of Supervisors
Salem Township
P.O. Box 405
Berwick, PA 18603-0035

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
443 Orlando Avenue
State College, PA 16803