

Aux. Bldg. Heat/Cool/Vent. Sys. Test
Preoperational Test Procedure Review
Procedure No.: 70346B
Issue Date: 1/1/79

SECTION I

INSPECTION OBJECTIVES

1. Ensure that the test procedure is technically adequate.
2. Ensure that the described test is consistent with regulatory requirements, guidance, and licensee commitments.

SECTION II
INSPECTION REQUIREMENTS

The inspector shall:

1. Obtain and review an approved copy of the test procedure(s) for technical adequacy prior to the date scheduled for the test.
2. Review the FSAR, SER, Technical Specifications, docketed correspondence, and Regulatory Guide 1.68. Verify that the test procedure adequately addresses NRC requirements and licensee commitments relating to the Auxiliary Building Heating, Cooling and Ventilation Systems.
3. Review the test procedure(s) in accordance with inspection procedure MC 70300B.

SECTION III
INSPECTION GUIDANCE

1. The review should insure that important system performance functions are adequately reflected in this test procedure. Examples of items which should be adequately tested as part of the test procedure include (but are not limited to):
 - a. system component operation (fans, filters, etc.),
 - b. system protective and logic functions,
 - c. system instrumentation,
 - d. system operating parameters (flow, pressure, etc.),
 - e. component operation in different modes of control, and
 - f. system operation in each area including other buildings.

NOTE: Items may be part of other systems tests.