

PMVogtleCOLPEm Resource

From: Tanya Simms
Sent: Thursday, November 20, 2008 1:16 PM
To: 'wasparkm@southernco.com'; 'AGAUGHTM@SOUTHERNCO.COM'
Cc: Christian Araguas; PMVogtleCOLPEm Resource
Subject: Draft RAIs 1396 and Draft RAI 1400 Related SRP Section 9.5.1 for Vogtle Units 3 and 4
Attachments: RAI 1396 draft.pdf; RAI 1400 draft.pdf

To All,

Attached is Draft RAI 1396 and Draft RAI 1400 related to SRP Sections 9.5.1 for Vogtle Units 3 and 4. Please contact me if you desire a phone conference regarding these RAIs. If no response is heard by close of business November 25, 2008, the final RAI will be issued.

Thank you,
Tanya

Hearing Identifier: Vogtle_COL_Public
Email Number: 22

Mail Envelope Properties (B4ECC0E252653F48B3F57C3B833465E8089DBC5375)

Subject: Draft RAIs 1396 and Draft RAI 1400 Related SRP Section 9.5.1 for Vogtle Units 3 and 4
Sent Date: 11/20/2008 1:16:29 PM
Received Date: 11/20/2008 1:16:30 PM
From: Tanya Simms
Created By: Tanya.Simms@nrc.gov

Recipients:

"Christian Araguas" <Christian.Araguas@nrc.gov>
Tracking Status: None
"PMVogtleCOLPEm Resource" <PMVogtleCOLPEm.Resource@nrc.gov>
Tracking Status: None
""wasparkm@southernco.com" <wasparkm@southernco.com>
Tracking Status: None
""AGAUGHTM@SOUTHERNCO.COM" <AGAUGHTM@SOUTHERNCO.COM>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	322	11/20/2008 1:16:30 PM
RAI 1396 draft.pdf	14123	
RAI 1400 draft.pdf	14024	

Options

Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 1396 Revision 0
Vogtle
Southern Nuclear Operating Co.
Docket No. 52-0025 and 52-0026
SRP Section: 09.05.01 - Fire Protection Program
Application Section: 9.2.11

QUESTIONS for Fire Protection Team (SFPT)

09.05.01-***

RG 1.206, Regulatory Position C.III.1, Section C.I.9.5.1.1 identifies that the applicant should provide site specific information on the fire water supply system. RG 1.189 states that fire water supply should be filtered and treated as necessary to prevent or control bio-fouling or microbiologically-induced corrosion of the fire water system. Since the Vogtle COL application identifies the well water subsystem of the raw water system as the water source for filling and makeup to the primary and secondary fire water storage tanks, the applicant should describe the program to monitor and maintain an acceptable level of quality of the fire water supply.

Request for Additional Information No. 1400 Revision 0
Vogtle
Southern Nuclear Operating Co.
Docket No. 52-0025 and 52-0026
SRP Section: 09.05.01 - Fire Protection Program
Application Section: 9.5.1.8.7

QUESTION for Fire Protection Team (SFPT)

09.05.01-***

RG 1.189, Regulatory Position 1.6.1 states that the engineer in charge of the fire protection program (FPP) should have training and experience in fire protection and in nuclear plant safety to provide a comprehensive approach in directing the FPP for the nuclear plant. These qualification requirements were not included in FSAR Subsection 13.1.1.2.10 as referenced in Subsection 9.5.1.8.7 of the Vogtle COL application. The applicant should revise the COL application to include the above qualification requirements for the engineer in charge of fire protection.