

November 12, 2008

ULNRC-05561

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Stop P1-137  
Washington, DC 20555-0001



Ladies and Gentlemen:

**DOCKET NUMBER 50-483  
CALLAWAY PLANT UNIT 1  
UNION ELECTRIC CO.  
FACILITY OPERATING LICENSE NPF-30  
CORE OPERATING LIMITS REPORT**

Attached is the Callaway Plant Cycle 17 Core Operating Limits Report (COLR), Revision 0. This report is provided to the NRC Staff for information. It has been prepared in accordance with the requirements of Technical Specification 5.6.5.

If you have any questions concerning this report, please contact us.

Sincerely,

A handwritten signature in black ink, appearing to read "Luke H. Graessle".

Luke H. Graessle  
Manager, Regulatory Affairs

DJW/nls

Attachment: Callaway Cycle 17 Core Operating Limits Report, Rev. 0

4001  
NRR

ULNRC-05561  
November 12, 2008  
Page 2

cc: Mr. Elmo E. Collins, Jr.  
Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region IV  
612 E. Lamar Blvd., Suite 400  
Arlington, TX 76011-4125

Senior Resident Inspector  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
8201 NRC Road  
Steedman, MO 65077

Mr. Mohan C. Thadani (2 copies)  
Licensing Project Manager, Callaway Plant  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Mail Stop O-8G14  
Washington, DC 20555-2738

Deputy Director  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, MO 65102

**Index and send hardcopy to QA File A160.0761**

**Hardcopy:**

Certrec Corporation  
4200 South Hulen, Suite 422  
Fort Worth, TX 76109  
(Certrec receives ALL attachments as long as they are non-safeguards and may be publicly disclosed.)

**Electronic distribution for the following can be made via Other Situations  
ULNRC Distribution:**

A. C. Heflin  
F. M. Diya  
T. E. Herrmann  
L. H. Graessle  
S. A. Maglio  
S. L. Gallagher  
L. M. Belsky (NSRB)  
T. B. Elwood  
D. J. Walker  
J. W. Knaup  
Ms. Diane M. Hooper (WCNOC)  
Mr. Dennis Buschbaum (TXU)  
Mr. Scott Bauer (Palo Verde)  
Mr. Stan Ketelsen (PG&E)  
Mr. Wayne Harrison (STPNOC)  
Mr. John O'Neill (Pillsbury Winthrop Shaw Pittman LLP)  
Missouri Public Service Commission

**Callaway Cycle 17**  
**Core Operating Limits Report**  
**Revision 0**

September 2008

Edited by:

G. E. Hauck  
P. Schueren

Approved:                     \*\*                      
T. Rodack, Director  
Quality and Licensing Programs



**\*\* Electronically Approved Records Are Authenticated in the Electronic Document Management System**

---

Westinghouse Electric Company LLC  
P.O. Box 355  
Pittsburgh, PA 15230-0355  
©2008 Westinghouse Electric Company LLC  
All Rights Reserved

---

NF-SCP-08-54

Reviewed by: James W. Krump <sup>10958</sup> / 11/1/08  
Approved by: B. McIl <sup>9245</sup> / 11/3/08

1.0 CORE OPERATING LIMITS REPORT

This Core Operating Limits Report (COLR) for Callaway Plant Cycle 17 has been prepared in accordance with the requirements of Technical Specification 5.6.5.

The Core Operating Limits affecting the following Technical Specifications are included in this report.

- 3.1.1, 3.1.4, 3.1.5, 3.1.6, 3.1.8      Shutdown Margin
- 3.1.3      Moderator Temperature Coefficient
- 3.1.5      Shutdown Bank Insertion Limits
- 3.1.6      Control Bank Insertion Limits
- 3.2.1      Heat Flux Hot Channel Factor
- 3.2.2      Nuclear Enthalpy Rise Hot Channel Factor
- 3.2.3      Axial Flux Difference
- 2.1.1      Reactor Core Safety Limits (SLs)
- 3.3.1      Reactor Trip System (RTS) Instrumentation
- 3.4.1      RCS Pressure and Temperature  
Departure from Nucleate Boiling (DNB) Limits

## 2.0 OPERATING LIMITS

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the subsections which follow. These limits have been developed using the NRC-approved methodologies specified in Technical Specification 5.6.5.

### 2.1 Shutdown Margin (Specifications 3.1.1, 3.1.4, 3.1.5, 3.1.6, and 3.1.8)

- 2.1.1 The Shutdown Margin in MODES 1-4 shall be greater than or equal to 1.3%  $\Delta k/k$ .
- 2.1.2 The Shutdown Margin prior to blocking Safety Injection below P-11 in MODES 3 and 4 shall be greater than 0%  $\Delta k/k$  as calculated at 200°F.
- 2.1.3 The Shutdown Margin in MODE 5 shall be greater than or equal to 1.0%  $\Delta k/k$ .

### 2.2 Moderator Temperature Coefficient (Specification 3.1.3)

- 2.2.1 The Moderator Temperature Coefficient shall be less positive than the limits shown in Figure 1. These limits shall be referred to as upper limit.  
  
The Moderator Temperature Coefficient shall be less negative than -47.9 pcm/°F. This limit shall be referred to as the lower limit.
- 2.2.2 The MTC 300 ppm surveillance limit is -40.4 pcm/°F (all rods withdrawn, Rated Thermal Power condition).
- 2.2.3 The MTC 60 ppm surveillance limit is -45.5 pcm/°F (all rods withdrawn, Rated Thermal Power condition).




Figure 1

Callaway Cycle 17  
Moderator Temperature Coefficient  
Versus Power Level

2.3      Shutdown Bank Insertion Limits  
(Specification 3.1.5)

The shutdown banks shall be withdrawn to at least 225 steps.

2.4      Control Bank Insertion Limits  
(Specification 3.1.6)

2.4.1      Control Bank insertion limits are specified by Figure 2.

2.4.2      Control Bank withdrawal sequence is A-B-C-D. The insertion sequence is the reverse of the withdrawal sequence.

2.4.3      The difference between each sequential Control Bank position is 115 steps when not fully inserted and not fully withdrawn.






Figure 2

Callaway Cycle 17  
Rod Bank Insertion Limits  
Versus Rated Thermal Power - Four Loop Operation

2.5 Heat Flux Hot Channel Factor -  $F_Q(Z)$   
(Specification 3.2.1)

$$F_Q(Z) \leq \frac{F_Q^{RTP}}{P} * K(Z) \quad \text{for } P > 0.5$$

$$F_Q(Z) \leq \frac{F_Q^{RTP}}{0.5} * K(Z) \quad \text{for } P \leq 0.5$$

where:  $P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$

2.5.1  $F_Q^{RTP} = 2.50.$

2.5.2  $K(Z)$  is provided in Figure 3.

2.5.3 The  $W(z)$  functions that are to be used in Technical Specification 3.2.1 and Surveillance Requirement 3.2.1.2 for determining  $F_Q^W(z)$  are shown in Table A.1. \*\*

The  $W(z)$  values have been determined for several burnups up to 20000 MWD/MTU in Cycle 17. This permits determination of  $W(z)$  at any cycle burnup up to 20000 MWD/MTU through the use of three point interpolation. For cycle burnups greater than 20000 MWD/MTU, use of 20000 MWD/MTU  $W(z)$  values without interpolation or extrapolation is conservative. The  $W(z)$  values were determined assuming Cycle 17 operates with RAOC strategy.

The  $W(z)$  values are provided for 73 axial points within the core height boundaries of 0 and 12 feet at intervals of 0.17 feet.

The  $W(z)$  values are generated assuming that they will be used for a full power surveillance. When a part power surveillance is performed, the  $W(z)$  values should be multiplied by the factor  $1/P$ , when  $P$  is  $> 0.5$ . When  $P$  is  $\leq 0.5$ , the  $W(z)$  values should be multiplied by the factor  $1/(0.5)$ , or 2.0. This is consistent with the adjustment in the  $F_Q(z)$  limit at part power conditions.

Table A.2 shows the burnup dependent  $F_Q$  penalty factors for Cycle 17. These values shall be used to increase  $F_Q^W(z)$  when required by Technical Specification Surveillance Requirement 3.2.1.2. A 2% penalty factor should be used at all cycle burnups that are outside the range of Table A.2.

\*\* Refer to Table A.1a of Addendum 1 for  $w(z)$  values for evaluating the startup testing flux map at 150 MWD/MTU burnup and 45 +/- 5% RTP.

- 2.5.4 The uncertainty,  $U_{FQ}$ , to be applied to measured  $F_Q(Z)$  shall be calculated by the following

$$U_{FQ} = U_{qu} * U_e$$

where:

$U_{qu}$  = Base  $F_Q$  measurement uncertainty = 1.05 when PDMS is inoperable  
( $U_{qu}$  is defined by PDMS when OPERABLE)

$U_e$  = Engineering uncertainty factor = 1.03

Table A.1  
W(z) versus Core Height  
(Top and Bottom 8% Excluded)

Height (feet)	150 MWD/MTU	4000 MWD/MTU	10000 MWD/MTU	20000 MWD/MTU
0.00 (bottom)	1.0000	1.0000	1.0000	1.0000
0.17	1.0000	1.0000	1.0000	1.0000
0.33	1.0000	1.0000	1.0000	1.0000
0.50	1.0000	1.0000	1.0000	1.0000
0.67	1.0000	1.0000	1.0000	1.0000
0.83	1.0000	1.0000	1.0000	1.0000
1.00	1.4854	1.4726	1.3149	1.3095
1.17	1.4738	1.4591	1.3070	1.3024
1.33	1.4594	1.4423	1.2966	1.2928
1.50	1.4427	1.4232	1.2845	1.2818
1.67	1.4245	1.4024	1.2713	1.2701
1.83	1.4051	1.3804	1.2574	1.2579
2.00	1.3847	1.3583	1.2427	1.2451
2.17	1.3636	1.3363	1.2277	1.2319
2.33	1.3420	1.3141	1.2125	1.2185
2.50	1.3203	1.2918	1.1972	1.2052
2.67	1.2977	1.2690	1.1819	1.1910
2.83	1.2748	1.2463	1.1681	1.1764
3.00	1.2585	1.2276	1.1607	1.1675
3.17	1.2489	1.2151	1.1581	1.1651
3.33	1.2415	1.2080	1.1554	1.1666
3.50	1.2339	1.2002	1.1526	1.1702
3.67	1.2252	1.1928	1.1500	1.1766
3.83	1.2159	1.1897	1.1480	1.1833
4.00	1.2080	1.1868	1.1469	1.1895
4.17	1.2016	1.1826	1.1462	1.1947
4.33	1.1958	1.1780	1.1448	1.1990
4.50	1.1894	1.1729	1.1430	1.2024
4.67	1.1824	1.1671	1.1408	1.2046
4.83	1.1749	1.1608	1.1380	1.2055
5.00	1.1667	1.1539	1.1347	1.2058
5.17	1.1581	1.1465	1.1309	1.2060
5.33	1.1492	1.1387	1.1267	1.2059
5.50	1.1393	1.1298	1.1211	1.2044
5.67	1.1321	1.1211	1.1171	1.2040
5.83	1.1342	1.1156	1.1212	1.2096
6.00	1.1388	1.1157	1.1293	1.2195
6.17	1.1466	1.1210	1.1434	1.2305
6.33	1.1534	1.1287	1.1557	1.2395
6.50	1.1593	1.1377	1.1673	1.2477
6.67	1.1648	1.1470	1.1788	1.2552
6.83	1.1701	1.1552	1.1898	1.2608

Table A.1  
W(z) versus Core Height  
(Top and Bottom 8% Excluded)

Height (feet)	150 MWD/MTU	4000 MWD/MTU	10000 MWD/MTU	20000 MWD/MTU
7.00	1.1746	1.1623	1.1997	1.2646
7.17	1.1778	1.1683	1.2083	1.2666
7.33	1.1797	1.1730	1.2156	1.2667
7.50	1.1804	1.1766	1.2214	1.2647
7.67	1.1797	1.1786	1.2257	1.2608
7.83	1.1777	1.1786	1.2286	1.2551
8.00	1.1734	1.1800	1.2289	1.2466
8.17	1.1684	1.1843	1.2285	1.2369
8.33	1.1667	1.1865	1.2316	1.2294
8.50	1.1654	1.1882	1.2350	1.2244
8.67	1.1632	1.1905	1.2374	1.2234
8.83	1.1637	1.1930	1.2428	1.2285
9.00	1.1732	1.1967	1.2532	1.2375
9.17	1.1901	1.2028	1.2671	1.2462
9.33	1.2025	1.2114	1.2797	1.2518
9.50	1.2124	1.2224	1.2918	1.2563
9.67	1.2223	1.2348	1.3024	1.2610
9.83	1.2303	1.2467	1.3078	1.2649
10.00	1.2381	1.2542	1.3173	1.2752
10.17	1.2494	1.2601	1.3352	1.2933
10.33	1.2679	1.2768	1.3531	1.3093
10.50	1.2881	1.2977	1.3686	1.3224
10.67	1.3062	1.3154	1.3818	1.3342
10.83	1.3247	1.3308	1.3934	1.3454
11.00	1.3357	1.3409	1.3986	1.3489
11.17	1.0000	1.0000	1.0000	1.0000
11.33	1.0000	1.0000	1.0000	1.0000
11.50	1.0000	1.0000	1.0000	1.0000
11.67	1.0000	1.0000	1.0000	1.0000
11.83	1.0000	1.0000	1.0000	1.0000
12.00 (top)	1.0000	1.0000	1.0000	1.0000


Table A.2

$F_Q$  Penalty Factors as a Function of Cycle Burnup

<u>Cycle 17 Burnup</u>	<u><math>F_Q^W(z)</math> Penalty Factor (%)</u>
5131	2.27
5303	2.35
5475	2.24
5647	2.12

Note: All cycle burnups not in the range of the above table shall use a 2.0% penalty factor for compliance with Surveillance Requirement 3.2.1.2.

For values of burnup between two of those listed in the first column, the greater of the two corresponding penalty factors shall be used for compliance with Surveillance Requirement 3.2.1.2.



**Figure 3**

**Callaway Cycle 17**  
**K(z) - Normalized F<sub>Q</sub>(z)**  
**as a Function of Core Height**

2.6      Nuclear Enthalpy Rise Hot Channel Factor -  $F_{\Delta H}^N$   
(Specification 3.2.2)

$$F_{\Delta H}^N \leq F_{\Delta H}^{RTP} [1 + PF_{\Delta H}(1-P)]$$

where:       $P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$

2.6.1       $F_{\Delta H}^{RTP} = 1.59$

2.6.2       $PF_{\Delta H} = 0.3$

2.7      Axial Flux Difference  
(Specification 3.2.3)

The Axial Flux Difference (AFD) Limits are provided in Figure 4.







Figure 4

Callaway Cycle 17  
Axial Flux Difference Limits as a Function  
of Rated Thermal Power for RAOC

2.8 Reactor Core Safety Limits  
(Safety Limit 2.1.1)

In MODES 1 and 2, the combination of THERMAL POWER, Reactor Coolant System (RCS) highest loop average temperature, and pressurizer pressure shall not exceed the limits in Figure 5.



**Figure 5**

**Callaway Cycle 17  
Reactor Core Safety Limits**

2.9 Reactor Trip System Overtemperature  $\Delta T$  Setpoint Parameter Values  
(Specification 3.3.1)

<u>Parameter</u>	<u>Value</u>
Overtemperature $\Delta T$ reactor trip setpoint	$K_1 = 1.1950$
Overtemperature $\Delta T$ reactor trip setpoint $T_{avg}$ coefficient	$K_2 = 0.0251/^{\circ}\text{F}$
Overtemperature $\Delta T$ reactor trip setpoint pressure coefficient	$K_3 = 0.00116/\text{psig}$
Nominal $T_{avg}$ at RTP	$T' \leq 585.3 ^{\circ}\text{F}$
Nominal RCS operating pressure	$P' = 2235 \text{ psig}$
Measured RCS $\Delta T$ lead/lag time constants	$\tau_1 \geq 8 \text{ sec}$ $\tau_2 \leq 3 \text{ sec}$
Measured RCS $\Delta T$ lag time constant	$\tau_3 = 0 \text{ sec}$
Measured RCS average temperature lead/lag time constants	$t_4 \geq 28 \text{ sec}$ $t_5 \leq 4 \text{ sec}$
Measured RCS average temperature lag time constant	$\tau_6 = 0 \text{ sec}$
$f_1(\Delta I) = -0.0325 \{21\% + (q_t - q_b)\}$	when $(q_t - q_b) < -21\% \text{ RTP}$
0	when $-21\% \text{ RTP} \leq (q_t - q_b) \leq 8\% \text{ RTP}$
$0.02973 \{(q_t - q_b) - 8\%\}$	when $(q_t - q_b) > 8\% \text{ RTP}$

Where,  $q_t$  and  $q_b$  are percent RTP in the upper and lower halves of the core, respectively, and  $q_t + q_b$  is the total THERMAL POWER in percent RTP.

2.10 Reactor Trip System Overpower  $\Delta T$  Setpoint Parameter Values  
(Specification 3.3.1)

<u>Parameter</u>	<u>Value</u>
Overpower $\Delta T$ reactor trip setpoint	$K_4 = 1.1073$
Overpower $\Delta T$ reactor trip setpoint $T_{avg}$ rate/lag coefficient	$K_5 = 0.02/^{\circ}\text{F}$ for increasing $T_{avg}$ $= 0/^{\circ}\text{F}$ for decreasing $T_{avg}$
Overpower $\Delta T$ reactor trip setpoint $T_{avg}$ heatup coefficient	$K_6 = 0.0015/^{\circ}\text{F}$ for $T > T''$ $= 0/^{\circ}\text{F}$ for $T \leq T''$
Nominal $T_{avg}$ at RTP	$T'' \leq 585.3^{\circ}\text{F}$
Measured RCS $\Delta T$ lead/lag time constants	$\tau_1 \geq 8 \text{ sec}$ $\tau_2 \leq 3 \text{ sec}$
Measured RCS $\Delta T$ lag time constant	$\tau_3 = 0 \text{ sec}$
Measured RCS average temperature lag time constant	$\tau_6 = 0 \text{ sec}$
Measured RCS average temperature rate/lag time constant	$\tau_7 \geq 10 \text{ sec}$
$f_2(\Delta I) = 0$ for all $\Delta I$ .	

2.11 RCS Pressure and Temperature Departure from Nucleate Boiling (DNB) Limits  
(Specification 3.4.1)

<u>Parameter</u>	<u>Indicated Value</u>
Pressurizer pressure	$\geq 2223 \text{ psig}$
RCS average temperature	$\leq 590.1 ^{\circ}\text{F}$

## APPENDIX A

### Approved Analytical Methods for Determining Core Operating Limits

The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:

1. WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.  
  
NRC letter dated May 28, 1985, "Acceptance for Referencing of Licensing Topical Report WCAP-9272(P)/9273(NP), "Westinghouse Reload Safety Evaluation Methodology"."
2. WCAP-10216-P-A, Revision 1A, "Relaxation of Constant Axial Offset Control -  $F_Q$  Surveillance Technical Specification," February 1994.  
  
NRC Safety Evaluation Report dated November 26, 1993, "Acceptance for Referencing of Revised Version of Licensing Topical Report WCAP-10216-P, Rev. 1, Relaxation of Constant Axial Offset Control -  $F_Q$  Surveillance Technical Specification" (TAC No. M88206).
3. WCAP-10266-P-A, Revision 2, "The 1981 Version of the Westinghouse ECCS Evaluation Model Using the BASH Code," March 1987.  
  
NRC letter dated November 13, 1986, "Acceptance for Referencing of Licensing Topical Report WCAP-10266 'The 1981 Version of the Westinghouse ECCS Evaluation Model Using the BASH Code.'"  
  
WCAP-10266-P-A, Addendum 1, Revision 2, "The 1981 Version of the Westinghouse ECCS Evaluation Model Using the BASH Code Addendum 1: Power Shape Sensitivity Studies," December 1987.  
  
NRC letter dated September 15, 1987, "Acceptance for Referencing of Addendum 1 to WCAP-10266, BASH Power Shape Sensitivity Studies."  
  
WCAP-10266-P-A, Addendum 2, Revision 2, "The 1981 Version of the Westinghouse ECCS Evaluation Model Using the BASH Code Addendum 2: BASH Methodology Improvements and Reliability Enhancements," May 1988.  
  
NRC letter dated January 20, 1988, "Acceptance for Referencing Topical Report Addendum 2 to WCAP-10266, Revision 2, "BASH Methodology Improvements and Reliability Enhancements."
4. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Reference Core Report," April 1995.

NRC Safety Evaluation Reports dated July 1, 1991, "Acceptance for Referencing of Topical Report WCAP-12610, 'VANTAGE+ Fuel Assembly Reference Core Report' (TAC NO. 77258)."

NRC Safety Evaluation Report dated September 15, 1994, "Acceptance for Referencing of Topical Report WCAP-12610, Appendix B, Addendum 1, 'Extended Burnup Fuel Design Methodology and ZIRLO Fuel Performance Models' (TAC NO. M86416)."

5. WCAP-11397-P-A, "Revised Thermal Design Procedure," April 1989.

NRC Safety Evaluation Report dated January 17, 1989, "Acceptance for Referencing of Licensing Topical Report WCAP-11397, "Revised Thermal Design Procedure."

6. WCAP-14565-P-A, "VIPRE-01 Modeling and Qualification for Pressurized Water Reactor Non-LOCA Thermal-Hydraulic Safety Analysis," October 1999.

NRC letter dated January 19, 1999, "Acceptance for Referencing of Licensing Topical Report WCAP-14565, 'VIPRE-01 Modeling and Qualification for Pressurized Water Reactor Non-LOCA Thermal/Hydraulic Safety Analysis' (TAC No. M98666)."

7. WCAP-10851-P-A, "Improved Fuel Performance Models for Westinghouse Fuel Rod Design and Safety Evaluations," August 1988.

NRC letter dated May 9, 1988, "Westinghouse Topical Report WCAP-10851, 'Improved Fuel Performance Models for Westinghouse Fuel Rod Design and Safety Evaluations.'"

8. WCAP-15063-P-A, Revision 1, with Errata, "Westinghouse Improved Performance Analysis and Design Model (PAD 4.0)," July 2000.

NRC letter dated April 24, 2000, "Safety Evaluation Related to Topical Report WCAP-15063, Revision 1, 'Westinghouse Improved Performance Analysis and Design Model (PAD 4.0)' (TAC NO. MA2086)."

9. WCAP-8745-P-A, "Design Bases for the Thermal Overpower  $\Delta T$  and Thermal Overtemperature  $\Delta T$  Trip Functions," September 1986.

NRC Safety Evaluation Report dated April 17, 1986, "Acceptance for Referencing of Licensing Topical Report WCAP-8745(P)/8746(NP), 'Design Bases for the Thermal Overpower and Thermal Overtemperature  $\Delta T$  Trip Functions.'"

10. WCAP-10965-P-A, "ANC: A Westinghouse Advanced Nodal Computer Code," September 1986.

NRC letter dated June 23, 1986, "Acceptance for Referencing of Topical Report WCAP 10965-P and WCAP 10966-NP."

11. WCAP-11596-P-A, "Qualification of the Phoenix-P/ANC Nuclear Design System for

Pressurized Water Reactor Cores," June 1988.

NRC Safety Evaluation Report dated May 17, 1988, "Acceptance for Referencing of the Westinghouse Topical Report WCAP-11596 - Qualification of the Phoenix-P/ANC Nuclear Design System for Pressurized Water Reactor Cores."

12. WCAP-13524-P-A, Revision 1-A, "APOLLO: A One Dimensional Neutron Diffusion Theory Program," September 1997.

NRC letter dated June 9, 1997, "Acceptance for Referencing of Licensing Topical Reports WCAP-13524 and WCAP-13524, Revision 1, 'APOLLO - A One-Dimensional Neutron Diffusion Theory Program.'"

13. WCAP-12472-P-A, "BEACON Core Monitoring and Operations Support System," August 1994.

NRC letter dated February 16, 1994, "ACCEPTANCE FOR REFERENCING OF LICENSING TOPICAL REPORT WCAP-12472-P, 'BEACON: CORE MONITORING AND OPERATIONS SUPPORT SYSTEM' (TAC NO. M80078)"



## Addendum 1

NF-SCP-08-69

**\*\*The  $W(z)$ 's are not increased by the nominal power ratio. In order to be applicable, the  $W(z)$ 's must be divided by the relative power at the time of the surveillance.**

Table A.1a  
 $W(z)$  versus Core Height for Partial Power Operation (45% Power, 150 MWD/MTU)  
(Top and Bottom 8% Excluded)

Height (feet)	$W(z)^{**}$
0.00 (bottom)	1.0000
0.17	1.0000
0.33	1.0000
0.50	1.0000
0.67	1.0000
0.83	1.0000
1.00	1.6267
1.17	1.6046
1.33	1.5800
1.50	1.5534
1.67	1.5250
1.83	1.4957
2.00	1.4659
2.17	1.4355
2.33	1.4052
2.50	1.3749
2.67	1.3440
2.83	1.3129
3.00	1.2890
3.17	1.2721
3.33	1.2576
3.50	1.2431
3.67	1.2275
3.83	1.2115
4.00	1.1971
4.17	1.1842
4.33	1.1720
4.50	1.1594
4.67	1.1462
4.83	1.1327
5.00	1.1188
5.17	1.1045
5.33	1.0899
5.50	1.0747

## Addendum 1

NF-SCP-08-69

Table A.1a  
W(z) versus Core Height for Partial Power Operation (45% Power, 150 MWD/MTU)  
(Top and Bottom 8% Excluded)

Height (feet)	W(z)**
5.67	1.0622
5.83	1.0585
6.00	1.0574
6.17	1.0593
6.33	1.0602
6.50	1.0603
6.67	1.0603
6.83	1.0605
7.00	1.0604
7.17	1.0591
7.33	1.0564
7.50	1.0524
7.67	1.0473
7.83	1.0415
8.00	1.0339
8.17	1.0259
8.33	1.0210
8.50	1.0168
8.67	1.0120
8.83	1.0099
9.00	1.0155
9.17	1.0278
9.33	1.0368
9.50	1.0427
9.67	1.0498
9.83	1.0576
10.00	1.0697
10.17	1.0871
10.33	1.1109
10.50	1.1377
10.67	1.1633
10.83	1.1873
11.00	1.2005
11.17	1.0000
11.33	1.0000
11.50	1.0000
11.67	1.0000
11.83	1.0000
12.00 (top)	1.0000