

General Information or Other (PAR)

Event # 44670

Rep Org: FISHER CONTROLS INTERNATIONAL, LLC	Notification Date / Time: 11/20/2008 17:20 (EST)
Supplier: FISHER CONTROLS INTERNATIONAL, LLC	Event Date / Time: 10/28/2008 (CST)
	Last Modification: 11/20/2008
Region: 3	Docket #:
City: MARSHALLTOWN	Agreement State: Yes
County:	License #:
State: IA	
NRC Notified by: DAVE SUK	Notifications: EUGENE GUTHRIE R2
HQ Ops Officer: MARK ABRAMOVITZ	PART 21 GROUP
Emergency Class: NON EMERGENCY	
10 CFR Section:	
21.21	UNSPECIFIED PARAGRAPH

PART 21 - 18" VALVE ASSEMBLY BEARINGS NOT DEDICATED PARTS

The following report was received via facsimile:

"Items provided to Duke Energy - Oconee per Fisher Order Number 033-B800163810, Items 010A- 10L (Duke Energy Order DP16655). This equipment included 18" CL150 Fisher A31A valve assemblies (quantity 12). The equipment is identified by Fisher Serial Numbers 16986219 through 16986230 (Duke Energy Item Number DMV-1409).

"Fisher Controls has determined that the subject items were provided with parts that were not properly processed per active valve requirements specified by the Duke Energy Order DP16655. Specifically, Fisher provided commercial grade bearings and thrust bearings instead of commercial grade dedicated items per EPRI 5652.

"We are reviewing the situation and will pursue a corrective action investigation to prevent problems like this in the future.

"Arrangements have been made with Duke Energy to retrofit the correctly processed parts on the subject serial numbers. This is a formal notification; Duke Energy was notified of this situation on October 28, 2008."

JEI9
WRR



Facsimile

301 South First Avet
Marshalltown, IA 50158

T 641-754-2888
F 641-754-2608

To: NRC Operations Center

Fax: 301-816-5151

Dave A. Suk
From: Director, Quality Valves Worldwide

Date: November 20, 2008

Pages: 2
(incl cover)

Attached is a copy of the Nuclear FIN Notice - FIN 2008-03 issued November 19, 2008 from Emerson Process Management - Fisher Controls International LLC.

If there are any technical questions or concerns, please contact:

Michael Wedemeyer
Manager, Quality
Fisher Controls International, LLC
205 South Center Street
Marshalltown, IA 50158
Phone: 641-754-2066
Fax: 641-754-2854
Michael.Wedemeyer@emerson.com



Fisher Controls International LLC
301 South First Ave.
P.O. Box 190
Marshalltown, Iowa 50158-0190
USA
T (641) 754-3011
F (641) 754-2830

Fisher Information Notice: FIN 2008-03

November 19, 2008

Subject: Fisher Order 033-B800163810 for Duke Energy - Oconee

From:

Bill Fitzgerald
Nuclear Business Unit Director
Fisher Controls International LLC
205 South Center Street
Marshalltown, IA 50158
Fax: (641) 754-2854

Equipment Affected By This Information Notice:

Items provided to Duke Energy - Oconee per Fisher Order Number 033-B800163810, Items 010A – 10L (Duke Energy Order DP16655). This equipment included 18" CL150 Fisher A31A valve assemblies (quantity 12). The equipment is identified by Fisher Serial Numbers 16986219 through 16986230 (Duke Energy Item Number DMV-1409).

Purpose:

The purpose of this Fisher Information Notice (FIN) is to alert Duke Energy that as of 28 October, 2008, Fisher Controls International LLC became aware of the possibility of a situation which may affect the performance of the applicable equipment.

We are informing you of this circumstance in accordance with Section 21.21 (b) of 10CFR21.

Applicability:

This notice applies only to the subject equipment supplied by Fisher Controls International LLC, identified above, that was provided to Duke Energy – Oconee Nuclear Station.



Fisher Information Notice: FIN 2008-03

Discussion:

Fisher Controls has determined that the subject items were provided with parts that were not properly processed per active valve requirements specified by the Duke Energy Order DP16655.

Specifically, Fisher provided commercial grade bearings and thrust bearings instead of commercial grade dedicated items per EPRI 5652.

We are reviewing the situation and will pursue a corrective action investigation to prevent problems like this in the future.

Arrangements have been made with Duke Energy to retrofit the correctly processed parts on the subject serial numbers.

This is a formal notification; Duke Energy was notified of this situation on October 28, 2008.

Action Required

No action is required.

10CFR21 Implications:

Fisher Controls requests that the recipient of this notice review it and take appropriate action in accordance with 10CFR21.

If there are any technical questions or concerns, please contact:

Michael Wedemeyer
Manager, Quality
Fisher Controls International LLC
205 South Center Street
Marshalltown, IA 50158
Fax: (641) 754-2854
Phone: (641) 745-2066
Michael.Wedemeyer@Emerson.com

