CCNPP3COLA PEmails

From: John Rycyna
Sent: Tuesday, November 25, 2008 3:33 PM
To: Wrobel, George
Cc: CCNPP3COL Resource; Joseph Colaccino; Michael Miernicki; David Terao; Eric Reichelt; James Biggins; Adam Gendelman
Subject: Draft RAI No 41 CIB1 1502.doc (P)
Attachments: Draft RAI No 41 CIB1 1502.doc

George,

Attached is DRAFT RAI No. 41. You have ten working days to review it and to decide whether you need a conference call to discuss it. After the call or after ten days the RAI will be finalized and sent to you. You then have 30 days to respond.

John Rycyna, PE
Project Manager
Division of New Reactor Licensing
Office of New Reactors
U.S. Nuclear Regulatory Commission
301-415-4122

Hearing Identifier: CalvertCliffs_Unit3Cola_Public_EX
Email Number: 431

Mail Envelope Properties (499C2FC6BB962446994CA8682D8ADF331179FC71B8)

Subject: Draft RAI No 41 CIB1 1502.doc (P)
Sent Date: 11/25/2008 3:32:56 PM
Received Date: 11/25/2008 3:32:59 PM
From: John Rycyna

Created By: John.Rycyna@nrc.gov

Recipients:
"CCNPP3COL Resource" <CCNPP3COL.Resource@nrc.gov>
Tracking Status: None
"Joseph Colaccino" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"Michael Miernicki" <Michael.Miernicki@nrc.gov>
Tracking Status: None
"David Terao" <David.Terao@nrc.gov>
Tracking Status: None
"Eric Reichelt" <Eric.Reichelt@nrc.gov>
Tracking Status: None
"James Biggins" <James.Biggins@nrc.gov>
Tracking Status: None
"Adam Gendelman" <Adam.Gendelman@nrc.gov>
Tracking Status: None
"Wrobel, George" <George.Wrobel@unistarnuclear.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	424	11/25/2008 3:32:59 PM
Draft RAI No 41 CIB1 1502.doc	24174	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 41 Revision 3
DRAFT
11/25/2008

Calvert Cliffs Unit 3
UniStar
Docket No. 52-016
SRP Section: 03.06.03 - Leak-Before-Break Evaluation Procedures
Application Section: 3.6.3

QUESTIONS for Component Integrity, Performance, and Testing Branch 1 (AP1000/EPR Projects) (CIB1)

03.06.03-1

Chapter 3.6.3 of the applicant's FSAR states that "Constellation Generation Group and UniStar Nuclear Operating Services shall confirm that the design Leak-Before-Break (LBB) analysis remains bounding for each piping system." Please provide as-designed LBB analyses for each LBB piping system prior to COL issuance or provide justification for concluding that the as-designed LBB analyses remain bounding for each piping system. Also correct the names of the applicants throughout the FSAR.