

PMSummerColpEM Resource

From: Tanya Simms
Sent: Monday, December 01, 2008 12:30 PM
To: 'Amy M. Monroe'; 'April R. Rice'; 'Jerry P. Harrison'; 'Julie M. Giles'
Cc: Ravindra Joshi; PMSummerColpEM Resource
Subject: RAI Letter No. 006 Related SRP Section 9.5.1 for Summer Units 2 and 3
Attachments: SUM-RAI-LTR-006.pdf

To All,

Attached is RAI Letter No. 006 related to SRP Sections 9.5.1 for Summer Units 2 and 3. The ADAMS accession number is ML083360348.

Tanya Simms
Project Manager
New Reactor Licensing
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, Maryland 20852-2738
301-415-1387
Tanya.Simms@nrc.gov

Hearing Identifier: VCSummer_COL_Public
Email Number: 57

Mail Envelope Properties (B4ECC0E252653F48B3F57C3B833465E8089DBC53AC)

Subject: RAI Letter No. 006 Related SRP Section 9.5.1 for Summer Units 2 and 3
Sent Date: 12/1/2008 12:30:25 PM
Received Date: 12/1/2008 12:34:49 PM
From: Tanya Simms

Created By: Tanya.Simms@nrc.gov

Recipients:

"Ravindra Joshi" <Ravindra.Joshi@nrc.gov>
Tracking Status: None
"PMSummerColpEM Resource" <PMSummerColpEM.Resource@nrc.gov>
Tracking Status: None
"Amy M. Monroe" <amonroe@scana.com>
Tracking Status: None
"April R. Rice" <arice@scana.com>
Tracking Status: None
"Jerry P. Harrison" <jharrison2@scana.com>
Tracking Status: None
"Julie M. Giles" <jmgiles@scana.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	401	12/1/2008 12:34:49 PM
SUM-RAI-LTR-006.pdf	127222	

Options

Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

SummerRAIsPEm Resource

From: Tanya Simms
Sent: Monday, December 01, 2008 12:09 PM
To: SummerRAIsPEm Resource
Subject: Request for Additional Information Letter No. 006 Related to SRP Section 09.05.01 for the Virgil C. Summer Nuclear Station Units 2 and 3 Combined License Application
Attachments: SUM-RAI-LTR-006.doc

Hearing Identifier: Summer_COL_eRAIs
Email Number: 7

Mail Envelope Properties (B4ECC0E252653F48B3F57C3B833465E8089DBC53A8)

Subject: Request for Additional Information Letter No. 006 Related to SRP Section 09.05.01 for the Virgil C. Summer Nuclear Station Units 2 and 3 Combined License Application
Sent Date: 12/1/2008 12:09:06 PM
Received Date: 12/1/2008 12:09:07 PM
From: Tanya Simms

Created By: Tanya.Simms@nrc.gov

Recipients:
"SummerRAIsPEm Resource" <SummerRAIsPEm.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	3	12/1/2008 12:09:07 PM
SUM-RAI-LTR-006.doc	51194	

Options
Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

December 1, 2008

Mr. Alfred M. Paglia
Manager, Nuclear Licensing
MC P40
South Carolina Electric & Gas Company
PO Box 88
Jenkinsville, SC 29065

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 006 RELATED TO
SRP SECTION 09.05.01 FOR THE VIRGIL C. SUMMER NUCLEAR STATION
UNITS 2 AND 3 COMBINED LICENSE APPLICATION

Dear Mr. Paglia:

By letter dated March 27, 2008, South Carolina Electric & Gas Company submitted its application to the U. S. Nuclear Regulatory Commission (NRC) for a combined license (COL) for two AP1000 advance passive pressurized water reactors pursuant to 10 CFR Part 52. The NRC staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within 30 days of the date of this letter. If changes are needed to the final safety analysis report, the staff requests that the RAI response include the proposed wording changes.

If you have any questions or comments concerning this matter, you may contact me at 301-415-1387 or you may contact Ravindra Joshi the lead project manager for the Virgil C. Summer Nuclear Station combined license at 301-415-6191.

Sincerely,

/RA/

Tanya Simms, Project Manager
AP1000 Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-027
52-028

Enclosure:
Request for Additional Information

CC: see next page

If you have any questions or comments concerning this matter, you may contact me at 301-415-1387 or you may contact Ravindra Joshi the lead project manager for the Virgil C. Summer Nuclear Station combined license at 301-415-6191.

Sincerely,

/RA/

Tanya Simms, Project Manager
AP1000 Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-027
52-028
eRAI Tracking No. 1651

Enclosure:
Request for Additional Information

Distribution:

Public	LGoldin	BHughes
RidsNroDnrlNwe1	MSpencer	MComar
RidsNroLAKGoldstein	TSimms	TDinh
RidsOgcMailCenter	BAnderson	RJoshi
SGoetz	CAraguas	RRadlinski
RidsRgn2MailCenter	RidsAcrsAcnwMailCenter	RidsNroDnrlNwe2

NRO-002

OFFICE	SFPT1/BC	NWE1/PM	OGC	NWE1/L-PM
NAME	RRadlinski*	TSimms*	MSpencer *	RJoshi*
DATE	11/17/08	11/17/08	11/18/08	12/01/08

*Approval captured electronically in the electronic RAI system.

OFFICIAL RECORD COPY

Request for Additional Information No. 1651 Revision 0
Virgil C. Summer Nuclear Station, Units 2 and 3
South Carolina Electric and Gas Company
Docket No. 52-027 and 52-028
SRP Section: 09.05.01 - Fire Protection Program
Application Section: 9.5.1.8.2.2

QUESTION for Fire Protection Team (SFPT)

09.05.01-2

FSAR subsection 13.1.1.2.10 stated that fire brigade training is the responsibility of the Manager, Nuclear Training. However, fire brigade training is not identified in FSAR subsection 13.1.1.3.2.2.1, Functional Manager in Charge of Training (Nuclear Training). The applicant should revise the COL application to include fire brigade training and the required qualification by knowledge, suitable training, and experience of the trainer in the above FSAR subsection. Coordination with the engineer in charge of fire protection should also be included.