

**FINAL ENVIRONMENTAL
IMPACT STATEMENT**

By the

**NEW YORK STATE
DEPARTMENT OF ENVIRONMENTAL CONSERVATION**

As Lead Agency

**Concerning the
Applications to Renew**

**NEW YORK
STATE POLLUTANT DISCHARGE ELIMINATION SYSTEM
(SPDES) PERMITS**

For the

**ROSETON 1 & 2, BOWLINE 1 & 2
AND INDIAN POINT 2 & 3
STEAM ELECTRIC GENERATING STATIONS,
ORANGE, ROCKLAND AND WESTCHESTER COUNTIES**

HUDSON RIVER POWER PLANTS FEIS

**Accepted:
June 25, 2003**

Prepared by NYS Department of Environmental Conservation

Contact:

**Betty Ann Hughes, NYS DEC, Division of Environmental Permits
625 Broadway, Albany, NY 12233-1750
(518) 402-9167; bahughes@gw.dec.state.ny.us**

**Final Environmental Impact Statement
for SPDES Permit Renewals at
Roseton 1 & 2, Bowline 1 & 2
And Indian Point 2 & 3
Steam Electric Generating Stations**

This Final Environmental Impact Statement (FEIS) consists of multiple sections:

- The fundamental underlying data and studies are contained in the 1999 DEIS, which is incorporated as part of this FEIS. The 1999 DEIS contains an extended description of the environmental setting, which is not duplicated in this FEIS.
- An Executive Summary immediately follows the Table of Contents.
- The first section following the Executive Summary of this FEIS is a discussion of the regulatory setting for and history of the proposed action which updates and augments the materials in the DEIS.
- The next section of this FEIS is a table in which all public comments received by the Department on the DEIS are excerpted and summarized. A list of all commentors is provided at the end of the table. The full texts of all comments received by the Department are included in Appendix F-I.
- The Department's responses to public comments complete the FEIS. In the interest of responding most effectively to the submitted comments, Department staff grouped the comments under related themes and responded to each theme.
- In addition to the public comments, other appendices provide background reports and reference materials that may not be readily available to readers.

FINAL ENVIRONMENTAL IMPACT STATEMENT

NEW YORK

STATE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMITS

For the ROSETON 1 & 2, BOWLINE 1 & 2, and INDIAN POINT 2 & 3

STEAM ELECTRIC GENERATING STATIONS

TABLE OF CONTENTS

EXECUTIVE SUMMARY	1
PROPOSED ACTION	5
Project History	7
Permitting Authority	7
The Hudson River Settlement Agreement	7
Department SPDES Permits	8
Consent Orders	9
The Draft Environmental Impact Statements	10
Public Hearings	11
Ownership Changes	11
Final Environmental Impact Statement	12
REGULATORY SETTING	13
Federal Clean Water Act	13
NPDES Permitting	13
CWA §316(b) and Cooling Water Intake Structures	15
New York State Laws	17
SPDES Permitting Program	17
Legislative Findings and Commissioner's Powers	22
New York State Coastal Management Program	24
Hudson River Estuary Management Program	24
Hudson River Valley Greenway Program	26
Endangered Species Act	27
The New York State Energy Plan	27
NYS Environmental Quality Review Act (SEQR)	28
MITIGATION AND ALTERNATIVES	29
Available Mitigation Technologies	29
Alternatives Assessment	30
PUBLIC COMMENT SUMMARY	39
List of Commentors	47
RESPONSES TO COMMENTS	49

Fish Populations - 1. "Cropping" (that, is, consumption of some portion of one or more populations) by power plants is not a legitimate use of NYS's fisheries and other aquatic resources.	49
The State's fish and wildlife	49
The State's waters	50
Ecosystem values	51
Impacts on the aquatic community	51
Fish Populations - 2. Many species in the Hudson River system are actually declining. While the striped bass (SB) population is up, that increase may be the result of other management decisions and activities. Historic baseline or trend data is not substantially discussed.	57
Fish Populations - 3. Several commentators questioned one or more of the assumptions used in one or more of the population models; in particular, density-dependence is unproven.	59
Atlantic Tomcod	62
Striped Bass	63
White Perch	63
American Shad	64
Bay Anchovy	64
Fish Populations - 4. Climate, disease, and the changing ecology of the Hudson River system are not considered in the population models.	64
Climate Change	65
Rainbow Smelt	66
Atlantic Tomcod	67
Comb Jellies	69
Zebra Mussels	70
Fish Population - 5. Thermal analyses need to be updated to reflect recent, more extreme conditions.	71
Fish Protection Points - 6. Fish protection points (FPP) would provide operational flexibility but even less protection than conditions in the Hudson River Settlement Agreement (HRSA).	76
Mitigation - 7. DEIS includes little information on barrier systems and acoustic deterrents.	82
Wedge-Wire Screens	82
Fish Barriers	83
Acoustic Deterrent System	84
Mitigation - 8. The DEIS significantly overstates costs and energy impacts of closed cycle cooling.	86
Mitigation - 9. DEIS alternatives and proposed action do not present a fair picture of available alternatives.	87
Other Topics - 10. The DEIS needs to consider effects of New York's recent conversion to a competitive energy market, take the State Energy Plan into account, or impose parity among facilities.	88

Other Topics - 11. Radiation discharges are not discussed in the DEIS, but should be.	90
Other Topics - 12. Several commentors expressed generalized opposition to renewal for one or more facilities.	92

Please note that appendices are not available on the website. However, you may request one or more of the appendices by contacting Betty Ann Hughes at bahughes@gw.dec.state.ny.us.

List of Appendices	93
F-I. Notices and Comments on 1999 DEIS	
F-II. Text of HRSA	
F-III. Fourth Amended Consent Order	
F-IV. ESSA reports	
F-V. Other cited references and letters not readily available . .	

EXECUTIVE SUMMARY

The action before the New York State Department of Environmental Conservation (Department) is the decision whether to renew State Pollutant Discharge Elimination System (SPDES) permits which would allow three steam electric generating stations to discharge waste heat, a pollutant, to the waters of the Hudson River; the permits would also allow the facilities to continue to withdraw water from the Hudson River for use as cooling water. The three facilities are:

- Bowline Point (Units 1 and 2), West Haverstraw, Rockland County;
- Indian Point (Units 2 and 3), Buchanan, Westchester County; and
- Roseton (Units 1 and 2), Newburgh, Orange County

(See Figure 1 in main text for general locations of all 3 facilities).

In December 1999, the owners and operators of the three facilities submitted a Draft Environmental Impact Statement (DEIS) to the Department which assessed the resources likely to be impacted by the facilities; evaluated alternative technologies and management strategies to mitigate impacts from each facility's operations; and proposed a preferred action intended to reduce the respective impacts. In March 2000, the Department accepted the DEIS for purposes of review and subsequently issued a Notice of Complete Application in the Environmental Notice Bulletin and in newspapers in the vicinity of each facility.

Department staff have further reviewed the DEIS and conclude that, while it was acceptable as an initial evaluation and assessment, it is not sufficient to stand as the final document, and additional information as to alternatives and evaluation of impacts must be considered. These considerations have been undertaken by Department staff to develop a final environmental impact assessment. This Final Environmental Impact Statement (FEIS) consists of the original DEIS submitted by the facilities' operators; comments received on the DEIS; the Department's responses to those comments, with similar comments grouped for response purposes; plus expanded discussions of the regulatory setting and alternatives for mitigation of impacts from the operation of the HRSA plants.

The Hudson River is rich with aquatic life, providing habitat for the early, sub-adult, and adult life stages of many aquatic species, including a number of game, commercial, and forage fish species. The Department's regulatory role includes limiting thermal discharges from each facility to ensure the survival of aquatic resources and also preventing aquatic organism mortality

resulting from impingement and entrainment at each facility's cooling water intake structure (CWIS).¹

To illustrate the magnitude of impacts of entrainment, Table 1 (below) uses data from the DEIS to calculate the average annual number of organisms of six of the fish species entrained by the three facilities.² If one assumes that all entrained fish die, as does the United States Environmental Protection Agency (USEPA) in its proposed rulemaking for cooling water intakes, then the total number of fish entrained is equal to total mortality from entrainment.³

Table 1. Estimated Average Numbers of Selected Fish Species Entrained Annually at Roseton, Indian Point, and Bowline Stations, Based on In-plant Abundance Sampling, 1981-1987.⁴

Plant Species	Roseton	Indian Point	Bowline	Total
American Shad	3,128,571	13,380,000	346,667	16,855,238
Bay Anchovy	1,892,500	326,666,667	81,000,000	409,559,167
River Herring⁵	345,714,286	466,666,667	13,814,286	826,195,238

¹ Entrainment occurs when small aquatic life forms are carried into and through the cooling system as water is withdrawn for use in a plant's cooling system; impingement occurs when larger aquatic life forms are caught against racks or screens at the intakes, where they may be trapped by the force of the water, suffocate or be otherwise injured.

² DEIS Appendix VI-1-D-2, "Estimated Total Number of Fish Entrained", and DEIS Appendix VI-1-D-1, "Estimated Number of Fish Killed Due to Entrainment", (both utilizing generator estimates of through-plant survival), and calculating the mean mortality over the years presented for each species at each facility.

³ National Pollutant Discharge Elimination System - Proposed Regulations to Establish Requirements for Cooling Water Intake Structures at Phase II Existing Facilities. USEPA Docket No. OW-2002-0049; see 67 FR 17122.

⁴ Figures are absolute numbers of entrainable life stages, including eggs, yolk-sac larvae, post-yolk-sac larvae, and some juveniles, of the species studied.

⁵ "River Herring" includes both Blueback Herring and Alewife, which are difficult to differentiate in their early life stages. It does not include other herring species like shad.

Striped Bass	129,857,143	158,000,000	15,571,429	303,428,571
White Perch	211,428,571	243,333,333	13,257,143	468,019,048
Atlantic Tomcod⁶	No Data This Study	No Data This Study	No Data This Study	No Data This Study
Total	692,021,071	1,208,046,667	123,989,524	2,024,057,262

The generators attempted to estimate through-plant survival, and using those adjustments, the calculations result in a slightly lower number of fish killed by entrainment mortality, as shown in Table 2 (below).

Table 2. Estimated Annual Entrainment Mortality of Six Fish Species at Roseton, Indian Point, and Bowline Stations, Using Generator Estimates of Through-plant Survival.

Plant Species	Roseton	Indian Point	Bowline	Total
American Shad	2,500,000	10,640,000	281,667	13,421,667
Bay Anchovy	1,892,500	326,666,667	78,285,714	406,844,881
River Herring	277,142,857	371,666,667	11,085,714	659,895,238
Striped Bass	40,428,571	46,500,000	4,671,429	91,600,000
White Perch	130,000,000	138,666,667	8,071,429	276,738,095
Atlantic Tomcod	No Data This Study	No Data This Study	No Data This Study	No Data This Study
Total	451,963,929	894,140,000	102,395,952	1,448,499,881

⁶ No numbers are available for Atlantic tomcod because, for the source study, no collections were made during the early part of the season when Atlantic tomcod entrainment and mortality would be a serious issue.

Based on data presented in the DEIS and analyses in that and in this FEIS, Department staff conclude that the generators' estimates represent the lower boundary of the actual mortality range, that is, the actual mortality lies somewhere between the generators' number (low end) and 100% (upper end, all entrained organisms die). Later sections of this FEIS discuss the significance of entrainment mortality; other impacts of continued operation of the HRSA generating stations, including thermal impacts; and potential control or mitigation measures.

As a result of the Department's further review of the DEIS plus the additional information and analysis provided by staff, a draft permit can be developed for each facility. Each draft permit will be based on this FEIS together with a detailed, site-specific application for that station and will contain a decision on the "best technology available" (BTA) to minimize entrainment and impingement mortality at that station. These BTA decisions are required by §316(b) of the federal Clean Water Act.⁷ Supplemental application materials relating to existing facilities and system designs are still necessary for each site. An individual draft permit will be issued for each site, but in general terms, each permit will require the covered facility to meet BTA by designating, as SPDES permit conditions, a compliance schedule to implement one or more of the technologies now available to substantially reduce entrainment and impingement mortalities from the cooling water intake at that station.

⁷ 33 U.S.C. §§ 1251 - 1376

PROPOSED ACTION

The action before the New York State (NYS) Department of Environmental Conservation (Department) is the decision whether to renew State Pollutant Discharge Elimination System (SPDES) permits which would allow three steam electric generating stations to discharge pollutants, including waste heat, to the waters of the Hudson River. The permits, if renewed, would also allow the continued withdrawal of water from the Hudson River to be used as cooling water. The three facilities are:

- Bowline Point (Units 1 and 2), West Haverstraw, Rockland County;
- Indian Point (Units 2 and 3), Buchanan, Westchester County; and
- Roseton (Units 1 and 2), Newburgh, Orange County.

Figure 1, on the following page, shows the location of the three generating stations

Project History

Permitting Authority

Bowline Point, Indian Point, and Roseton steam electric generating stations are all facilities which were in operation prior to enactment of the federal Clean Water Act in 1972. The Department regulates Bowline Point, Indian Point, and Roseton pursuant to its authority as the State agency approved by the United States Environmental Protection Agency (USEPA) to issue SPDES permits. On October 28, 1975, the USEPA gave its approval to the Department to administer the federal National Pollutant Discharge Elimination System (NPDES) program by virtue of a memorandum of agreement signed by the Department's Commissioner, Ogden R. Reed, and the Acting Region II Administrator for the USEPA, Eric B. Outwater. The Department's SPDES program is set forth in Article 17 of the Environmental Conservation Law (ECL), with underlying regulations promulgated at 6 NYCRR Parts 700 et seq and 750 et seq.

The Hudson River Settlement Agreement

Prior to authorizing the NYS SPDES program, earlier in 1975, the USEPA issued NPDES permits for the Indian Point nuclear power facility and the Roseton and Bowline Point fossil fuel power facilities. All three permits contained conditions to restrict thermal discharges, that is, water heated by the process of cooling the condenser coils at the fossil plants and by the secondary cooling phase of the nuclear power generation systems. At the time those permits were issued, the operators of these Hudson River power plants, Consolidated Edison (Con Ed) for Indian Point Unit 2, the New York Power Authority (NYPA) for Indian Point Unit 3, Central Hudson Gas and Electric (CHG&E) for Roseton, and Orange and Rockland Utilities (O&R) for Bowline Point used once-through cooling systems, withdrawing cooling water directly from and discharging the warmed effluent back to the Hudson River.

Among the issues considered by USEPA in issuing those 1975 NPDES permits were concerns regarding thermal discharges, cooling water intakes, and fish mortalities associated with the cooling water intakes. The USEPA's 1975 NPDES permits would have in effect required retrofitting of cooling towers at all three of these Hudson River power plants. In 1977, Con Ed, NYPA, CHG&E, and O&R (collectively, the "generators") sought an administrative adjudicatory hearing against the USEPA draft permits to overturn those cooling water intake conditions and other requirements of the 1975 NPDES permits. That and subsequent proceedings were joined by a number of other government agencies and non-governmental organizations (NGO's).

In 1981, after a number of years of adjudicatory proceedings, the generators signed the Hudson River Settlement Agreement (HRSA) to resolve the disputes relating to the USEPA's 1975 NPDES draft permits.⁹ The HRSA was a 10-year agreement designed to obtain necessary data, impose needed analytical assessments, and develop an impact assessment to determine how best to mitigate impacts to the Hudson River from the three generating facilities. The HRSA was also executed by the USEPA, the NYS Attorney General, the Department, and involved NGO stakeholders including the Scenic Hudson Preservation Conference (Scenic Hudson), Hudson River Fishermen's Association (Riverkeeper), and the Natural Resources Defense Council (NRDC). The HRSA was effective for the ten year period from May 10, 1981 to May 10, 1991.

The HRSA provided, among other things, for mitigative measures to reduce fish mortalities at each generation facility as a result of: (a) impingement of adult and juvenile fish on racks and screens at the plants' intake structures, and (b) entrainment of fish eggs and larvae through the respective units' cooling apparatus. Those measures included seasonal "outages", or discontinuing cooling water usage by ceasing plant operations. Those measures also included installation of variable speed pumps at Indian Point Units 2 and 3 within three and one-half years after the effective date of the agreement, to keep the volumes of Hudson River water used for cooling to the minimum required for efficient operation. In addition, the HRSA established a biological monitoring program for monitoring fish species and their life stages at different Hudson River locations during each season.

Department SPDES Permits

By statute, SPDES permits for surface water discharges have a maximum duration of five years.¹⁰ In 1982, the Department issued a SPDES permit to each of the facilities covered by the HRSA, including limitations governing the release of thermal discharges, and incorporating the terms of the HRSA agreement into the permit so that the environmentally protective mitigation measures set forth in the Agreement were included as conditions. These permits expired in 1987.

In 1987, the Department issued SPDES permit renewals to each of the three HRSA generation facilities (Indian Point Units 2 and 3 were issued a single permit even though the two units had different owners). These most recent SPDES permits for Indian Point Units 2 & 3, Bowline Point Units 1 & 2, and Roseton Units 1 & 2 Generating Stations became effective on October 1, 1987, with a common expiration date of October 1, 1992. Again, along with

⁹ The complete text of the HRSA is included as Appendix F-II to this FEIS.

¹⁰ ECL §17-0817(1)

appropriate thermal discharge conditions, the HRSA agreement was incorporated into these permits and the HRSA mitigation provisions were continued as conditions for operation.

Prior to the expiration of the 1987 permits, on April 3, 1992, the generators submitted timely applications to the Department for renewal of their respective SPDES permits. Pursuant to the New York State Administrative Procedure Act (SAPA) and the Department's implementing regulations, "[w]hen a licensee has made a timely and sufficient application for the renewal of a license or a new license with reference to any activity of a continuing nature, the existing license does not expire until the application has been finally determined by the agency..."¹¹

Also prior to the expiration of the 1987 SPDES permit, by correspondence dated May 15, 1991, the Department and the generators executed an agreement to continue the mitigative measures established in the 1981 agreement until SPDES renewal permits were issued. With respect to Indian Point Units 2 and 3, the letter agreement also memorialized Con Ed's and NYPA's commitment to install special fish protective screens to reduce fish impingement at the intake structures. In addition, the agreement provided that the parties would negotiate in good faith to develop a long-term resolution of: cooling water intake structures (CWIS), thermal discharges, fish mortality reductions due to mitigative measures, the costs of mitigative measures, and alternatives. Public notice was to be given of such negotiations and the parties expressed their understanding that interveners, including such groups as the Riverkeeper and Scenic Hudson, would be involved as participants in the negotiations.

On September 13, 1991, Riverkeeper, Scenic Hudson, and NRDC filed a law suit against the Department and the four generators seeking:

- annulment of the May 15, 1991 agreement between the Department and the generators;
- participation by those three NGO entities in the permitting process; as well as
- resolution of outstanding issues regarding mitigation measures.

Consent Orders

On March 23, 1992, the parties to that legal proceeding executed a judicially approved Consent Order resolving the matter which provided that the generators would continue the HRSA mitigative measures, such as the "outages" timed to reduce impacts to certain fish species, and to continue

¹¹ New York State Administrative Procedure Act (SAPA) §401(2); 6 NYCRR Part 621.

underwriting significant Hudson River fish species studies and data acquisition.¹²

The 1992 Consent Order was extended by the parties on four separate occasions, having expiration dates of September 1, 1994, September 1, 1995, September 1, 1997, and February 1, 1998. When the Fourth Amended Consent Order expired on February 1, 1998, the parties, who were by then actively engaged in negotiations regarding elements of draft SPDES permits, did not reach agreement to continue with a fifth extension of the Consent Order.¹³ However, the generators agreed to continue the mitigative measures included in the continuing SPDES permit and provisions of the Fourth Amended Consent Order until new SPDES permits were issued to them.¹⁴

The Draft Environmental Impact Statements

On May 20, 1992, pursuant to the State Environmental Quality Review Act (SEQR), the Department issued a positive declaration requiring the generators to prepare an environmental impact statement regarding the 1992 applications for permit renewals.¹⁵ That determination was based on the Department's assessment that the measures proposed in the generators' 1992 renewal applications were less protective of the Hudson River and its aquatic resources than the HRSA terms had been. In June 1993, the generators submitted a preliminary Draft Environmental Impact Statement (DEIS) to the Department in accordance with the regulatory requirement to submit a draft environmental impact statement for the renewal of their respective SPDES permits.

On September 3, 1993, the Department advised the four HRSA generators that it had reviewed the June 1993 preliminary DEIS and that their respective SPDES renewal applications remained incomplete pending receipt of additional information. The Department advised the generators of inadequacies of the preliminary DEIS, to which the generators later responded.

¹² Natural Resources Defense Council, Inc., Hudson River Fishermen's Association, et al., v. NYSDEC, Consolidated Edison Company of New York, Inc., New York Power Authority, Orange and Rockland Utilities, Inc., and Central Hudson Gas & Electric Corp., Albany County, Index No. 6570-91.

¹³ The Fourth Amended Consent Order is attached as Appendix F-III.

¹⁴ In the remainder of this FEIS, the general term "Consent Order" will apply to the entire series of extensions unless a particular date or extension is named.

¹⁵ ECL §8-0109.4; 6 NYCRR §617.7.

From 1993 to 1999, the Department, the generators, the New York State Department of Public Service (NYSDPS), the USEPA, the National Marine Fisheries Service (NMFS), the United States Fish and Wildlife Service (USFWS), Riverkeeper, NRDC, Scenic Hudson and New York Rivers United (NYRU) participated in an extensive effort to address numerous technical and procedural issues regarding the generators' plants, including conducting technical meetings or "workshops" of experts representing each participant or group, and conducting plenary meetings of all participants to draw together the technical and legal expertise devoted to resolving issues with the SPDES renewal applications for the HRSA plants.

On December 14, 1999, CHG&E, Southern Energy New York (successor to O&R), Con Ed, and NYPA presented the Department with a revised DEIS. Department Staff reviewed the DEIS and issued a Notice of Complete Application dated February 28, 2000, which was published in the Environmental Notice Bulletin (ENB) on March 8, 2000, and in newspapers in the vicinity of the plants during the week following March 8, 2000.¹⁶ The Notice sought public comments on the DEIS, which were to be submitted to the Department by April 24, 2000.

Public Hearings

Subsequently, on May 2, 2000, the Department's Office of Hearings and Mediation Services issued a Notice of Hearing and Notice of Extension of Comment Period.¹⁵ The Notice of Hearing announced a public legislative hearing to receive unsworn statements about the DEIS at the Croton Village Hall, Croton-on-Hudson, New York, at 2:00 PM and 7:30 PM on June 8, 2000. The Notice also extended the public comment deadline from April 24, 2000 to June 24, 2000. The May 2, 2000, Notice of Hearing was also published in the ENB and in newspapers in the vicinity of the plants. These notices included the times and location of the June 8, 2000, public hearing and also identified eight locations where the DEIS was available for review by the public. Sixteen written comments were received, and seventeen individuals spoke at the hearings, including representatives of the generators, NGO's, individuals, and the Department. The Department also provided the generators with several pages of comments.

Ownership Changes

As part of NYS's energy market restructuring, the HRSA plants have undergone ownership changes since the submission of the DEIS. Indian Point Units 2 and 3 are now owned and operated by Entergy Nuclear Indian Point 2, LLC, and Entergy Nuclear Indian Point 3, LLC. Bowline Point is now owned and operated by Mirant Bowline, LLC. Roseton is now owned and operated by Dynegy Northeast Generation.

¹⁶ Notices are included in Appendix F-I to this FEIS.

Final Environmental Impact Statement

This Final Environmental Impact Statement (FEIS) consists of multiple sections. The fundamental underlying data and studies are contained in the 1999 DEIS, which is incorporated as part of this FEIS. An augmented discussion of the regulatory setting for and history of the proposed action in this FEIS augments the materials in the DEIS. The full texts of all comments received by the Department are included in Appendix F-I, and public comments are excerpted and summarized in Table 3 (page –) of this FEIS; a list of all commentors is provided at the end of Table 3. The Department's responses to public comments complete the FEIS. In the interest of responding most effectively to the submitted comments, Department staff grouped the comments under related themes and responded to each theme.

REGULATORY SETTING

Federal Clean Water Act

NPDES Permitting

The basic federal law governing water pollution control in the United States is the federal Water Pollution Control Act (FWPCA), more commonly referred to as the Clean Water Act (CWA).¹⁶ Although the FWPCA itself dates to 1948, the CWA as we now know it was largely shaped by comprehensive amendments in 1972 which completely overhauled the existing system.¹⁷ The 1972 CWA is properly viewed as the starting point for modern water pollution control law.

While the CWA has been amended several times since 1972, the heart of the Act which has remained intact is its system of regulating both direct and indirect discharges of pollutants into U.S. waters: the National Pollutant Discharge Elimination System (NPDES).¹⁸ The fundamental premise of the CWA, expressed in §301, is not to regulate an otherwise lawful activity, but to make unlawful the discharge of *any* pollutant from a point source by any person.¹⁹ Thus, the discharge of pollutants is not a right and may only be allowed as specifically provided in the CWA. The bulk of the CWA may, therefore, be viewed as a detailed and highly regulated exception to the “no discharge” rule of §301.

Pollution control standards under the Act are of two general types:

- (1) effluent standards which limit the quality and quantity of pollutants discharged from the source, also called “technology-based” standards; and
- (2) ambient standards which limit the concentration of pollutants in a defined water segment, also called “water quality-based” standards.

By establishing limits tailored to the nature of a discharge rather than its location, a uniform nationwide playing field was established that removed incentives for dischargers to relocate to other states to avoid treatment requirements.

The focus of an ambient standard is on the capacity of the receiving water to absorb or dilute a given pollutant. Thus, water quality-based standards vary according to

¹⁶ 33 U.S.C. §§ 1251 - 1376.

¹⁷ FWPCA Amendments of 1972, Pub. L. No. 92-500, 86 Stat. 816.

¹⁸ See CWA § 402; 33 U.S.C. § 1342.

¹⁹ “Pollutant” is defined as including solid, industrial, agricultural and other wastes, sewage, sludge, heat, rock, sand, and biological and radioactive materials; CWA § 502(6), 33 U.S.C. § 1362(6). “Point source” is defined as any “discernable, confined, and discrete conveyance”; CWA § 502(14), 33 U.S.C. § 1362(14).

the use of the receiving water - for example, recreational, industrial, or public drinking water - and on local conditions, such as the size and flow of the receiving water, its turbidity, and other factors unique to the segment.

Technology-based effluent standards, on the other hand, do not focus on the qualities of the receiving water, but on the treatment a pollutant receives prior to its discharge. Technology-based standards define and mandate a level of effluent quality that is achievable using pollution control technology so that a pollutant's capacity to degrade the water segment into which it is discharged is lessened. Of the two, technology-based effluent standards dominate the CWA's regulatory system.

Both of these standards are implemented and enforced through the NPDES permit program, administered by the USEPA. Under §402 of the CWA, a discharger must obtain an NPDES permit from EPA or from a state that has an EPA-approved program.²⁰ The technology-based and water quality-based standards are written into the permits and are tailored to meet the particular permittee's situation, such as the pollutant-producing operation, the type and amount of pollutants to be discharged and the condition of the receiving water.

The CWA mandated development of water quality standards for water bodies and effluent limitations based on those standards, and it set forth the mechanism for incorporating water quality standards into NPDES permits. States were required to adopt classifications of water bodies according to their best uses. They were also required to develop standards for various pollutants that would establish maximum levels of pollutants in water bodies that would be allowable so that the water bodies could retain their best uses.²¹ These standards are then, in turn, incorporated into the NPDES permit as effluent limitations, along with any other relevant technology-based effluent limitations.

NPDES permits may also contain other conditions a permittee must meet, such as requirements for monitoring and reporting effluent discharges.²² Discharge without a permit or in violation of its conditions may subject the discharger to an enforcement action by the federal or state government, which in turn may result in civil and criminal penalties.²³ A noncomplying discharger may also be subject to enforcement by private individuals or groups under the Act's citizen suit provision.²⁴ In sum, the NPDES permit program is the focal point of the CWA's regulatory system, and compliance with an NPDES permit's conditions is deemed to be compliance with almost all of the Act's regulatory provisions.²⁵

²⁰ CWA § 402(a) and (b), 33 U.S.C. § 1342(a) and (b).

²¹ CWA § 303, 33 U.S.C. § 1313.

²² 40 C.F.R. §§ 122.41 to 122.50 (permit conditions).

²³ CWA § 309, 33 U.S.C. § 1319.

²⁴ CWA § 505, 33 U.S.C. § 1365.

²⁵ CWA § 402(k), 33 U.S.C. § 1342(k).

CWA §316(b) and Cooling Water Intake Structures

§ 316(b) of the CWA provides that any “point source” discharge standard established pursuant to §§301 or 306 of the CWA must require that the location, design, construction, and capacity of CWIS reflect the “best technology available” (BTA) for minimizing adverse environmental impacts.

EPA has defined a “cooling water intake structure” as the total physical structure and any associated constructed waterways used to withdraw water from waters of the U.S., extending from the point at which water is withdrawn from waters of the U.S. up to and including the intake pumps. EPA has defined “cooling water” as water used for contact or non-contact cooling, including water used for equipment cooling, evaporative cooling tower makeup, and dilution of effluent heat content.²⁶ The intended use of cooling water is to absorb waste heat from production processes or auxiliary operations.

CWA §316(b) addresses the adverse environmental impact caused by the intake of cooling water, not discharges into water. Despite this special focus, the requirements of §316(b) are closely linked to several of the core elements of the NPDES permit program established under §402 of the CWA to control discharges of pollutants into navigable waters. For example, §316(b) applies to point sources (facilities) that withdraw water from the waters of the U.S. for cooling through a CWIS and are subject to an NPDES permit. Conditions implementing §316(b) are included in NPDES permits on a case-by-case, site-specific basis.

The majority of impacts to aquatic organisms and habitat associated with intake structures is closely linked to water withdrawals from the various waters in which the intakes are located. Based upon preliminary estimates from an EPA questionnaire sent to more than 1,200 existing power plants and factories, industrial facilities in the U.S. withdraw more than 279 billion gallons of cooling water each day from waters of the U.S.²⁷

The withdrawal of such quantities of cooling water affects large numbers of aquatic organisms annually, including phytoplankton (tiny, free-floating photosynthetic organisms suspended in the water column), zooplankton (small aquatic animals, including fish eggs and larvae, that consume phytoplankton and other zooplankton), fish, crustaceans, shellfish, and many other forms of aquatic life.²⁸ Aquatic organisms drawn into CWIS are either impinged on components of the CWIS or entrained in the cooling water system itself.

Impingement takes place when organisms are trapped against intake screens by the force of the water passing through the cooling water intake structure. This can result in starvation and exhaustion (organisms are trapped against an intake screen

²⁶ See 66 Fed. Reg. 65259 (Dec. 18, 2001).

²⁷ See *generally*, 65 Fed. Reg. 49071 through 4 (Aug. 10, 2000) and 66 Fed. Reg. 65262 (Dec. 18, 2001).

²⁸ 66 Fed. Reg. 65262 (Dec. 18, 2001).

or other barrier at the entrance to the cooling water intake structure), asphyxiation (organisms are pressed against an intake screen or other barrier at the entrance to the cooling water intake structure by velocity forces which prevent proper gill movement, or organisms are removed from the water for prolonged periods of time), descaling (fish lose scales when removed from an intake screen by a wash system), and other physical harms.²⁹

Entrainment usually occurs when relatively small benthic, planktonic, and nektonic organisms, including early life stages of fish and shellfish, are drawn through the cooling water intake structure into the cooling system. In the normal water body ecosystem, many of these small organisms serve as prey for larger organisms that are found higher on the food chain. As entrained organisms pass through a plant's cooling system they are subject to mechanical, thermal, or toxic stress. Sources of such stress include physical impacts in the pumps and condenser tubing, pressure changes caused by diversion of the cooling water into the plant or by the hydraulic effects of the condensers, sheer stress, thermal shock, and chemical toxemia induced by antifouling agents such as chlorine.³⁰

In addition to impingement and entrainment losses associated with the operation of CWIS, another concern is the cumulative degradation of the aquatic environment as a result of:

- (1) multiple intake structures operating in the same watershed or in the same or nearby reaches; and
- (2) intakes located within or adjacent to an impaired waterbody.

Historically, impacts related to CWIS have been evaluated pursuant to CWA §316(b) on a facility-by-facility basis. While the potential cumulative effects of multiple intakes located within a specific waterbody or along a coastal segment are largely unknown, there is concern about the effects of multiple intakes on fishery stocks.³¹

²⁹ 66 Fed. Reg. 65263 (Dec. 18, 2001); *see also* Thurber, N.J. and D.J. Jude, *Impingement Losses at the D.C. Cook Nuclear Power Plant During 1975-1982 With a Discussion of Factors Responsible and Possible Impact on Local Populations*, Special Report No. 115 of the Great Lakes Research Division, Great Lakes and Marine Waters Center, Univ. of Mich. (1985).

³⁰ 66 Fed. Reg. 65263 (Dec. 18, 2001) *citing* Mayhew, D.A., L.D. Jensen, D.F. Hanson, and P.H. Muessig, *A Comparative Review of Entrainment Survival Studies at Power Plants in Estuarine Environments*, Environmental Science & Policy, 3:S295-S301 (2000).

³¹ 66 Fed. Reg. 65263 (Dec. 18, 2001) *referring to* Request by member States of Atlantic States Marine Fisheries Commission to investigate the cumulative impacts on commercial fishery stocks attributable to cooling water intakes located in coastal regions of the Atlantic in 2001.

New York State Laws

SPDES Permitting Program

Pursuant to authority granted by Congress in CWA § 402, USEPA has authority to allow states to carry out specified permitting functions, which would otherwise be performed by USEPA, for discharges into both interstate and intrastate waters. New York State received USEPA approval of such authority in the form of a Memorandum of Agreement between the state and USEPA in October 1975. The Memorandum established the basis for the SPDES permit program in New York State in lieu of a federally administered program.

Originally enacted in 1973, Article 17, Title 8 of the Environmental Conservation Law (ECL) authorizes The Department to administer the SPDES permitting program that governs the discharge of pollutants into the waters of the state at a given facility.¹ The purpose of ECL Article 17, Title 8 is:

To create a state pollutant discharge elimination system (SPDES) to insure that the State of New York shall possess adequate authority to issue permits regulating the discharge of pollutants from new or existing outlets or point sources into the waters of the state, upon condition that such discharges will conform to and meet all applicable requirements of the [FWPCA] ... and rules, regulations, guidelines, criteria, standards and limitations adopted pursuant thereto relating to effluent limitations, water quality related effluent limitations ...²

The discharge must also meet all applicable requirements of the ECL and the implementing regulations at 6 NYCRR Parts 700, et seq. and 750, et seq. The permitting objective is to prospectively control the discharge of point-source pollutants, including heat, by establishing chemical-specific limits and other requirements intended to assure that water quality standards in the receiving water body are achieved. Additional environmental objectives are to assure that aquatic communities are not unduly harmed by discharges, and to protect the public health and best usage of the water body.

Generally, thermal discharges to the waters of the State must meet water quality standards to assure the protection and propagation of a balanced, indigenous population of shellfish, fish, and wildlife in and on the body of water.³ In addition, thermal criteria apply to all waters of the State receiving thermal discharges.⁴ These criteria may be modified upon application of a permittee to the Department if the Department finds them to be unnecessarily restrictive and that modification

³² "Pollutant" is defined as any "dredged spoil, solid waste, incinerator residue, sewage, garbage, sewage sludge, munitions, chemical wastes, biological materials, radioactive materials, heat, wrecked or discarded equipment, rock, sand and industrial, municipal, and agricultural waste discharged into water." ECL § 17-0105(17).

³³ ECL § 17-0801.

³⁴ 6 NYCRR § 704.1(a).

³⁵ NYCRR § 704.2.

would still assure the protection and propagation of a balanced, indigenous population of shellfish, fish, and wildlife in and on the body of water into which the discharge is to be made.³⁶ The discharge of heat as a pollutant, a “thermal discharge”, is addressed in the Department’s regulations at 6 NYCRR Part 704.

In making a modification to thermal criteria, the Department typically imposes a “mixing zone” which limits the physical extent within which heated water can exceed specific applicable criteria.³⁷ Outside of the mixing zone, thermal criteria must be met to assure compliance with water quality standards. Temperature limitations are established and imposed on a case-by-case basis for each facility subject to Part 704 jurisdiction. NYS has adopted the federal CWA §316(b) BTA requirement for CWIS as part of the Department’s thermal discharge criteria at 6 NYCRR §704.5.

The HRSA facilities which are the subject of this FEIS, Indian Point, Bowline Point, and Roseton, must demonstrate their compliance with water quality standards.³⁸ Since 1981, these facilities’ operations, and their resulting thermal discharges, have been conditioned by their SPDES permits. Their current permits were due to expire in 1992 but were extended under SAPA.

According to the Consent Order, the HRSA facilities were required to use their “best reasonable efforts” to operate the respective plants to keep the volumes of water withdrawn for cooling at the minimum required for efficient operation.³⁹ The original 1981 HRSA contained similar general language, and also provided charts for each facility which identified average maximum river temperatures and specified approximate flows for each unit at Indian Point and for all units at Bowline and at Roseton for different periods throughout the year.

The thermal limitations associated with the HRSA facilities’ existing SPDES permits include the following:

Bowline Point:

As of the 1987 - 1992 SPDES permit term, Bowline did not exceed the thermal criteria and a mixing zone did not need to be specified to meet the water quality standard. The use of multiport high velocity diffusers provided sufficient mixing with ambient water sufficient to meet thermal criteria. As a consequence, additional specifications to meet thermal criteria have not been imposed. The SPDES permit provides a daily maximum discharge temperature (102°F).

³⁶ 6 NYCRR § 704.4.

³⁷ 6 NYCRR § 704.3.

³⁸ See App. F-II.

³⁹ See App. F-III.

Roseton:

As of the 1987 - 1992 SPDES permit term, Roseton did not exceed the thermal criteria and a mixing zone did not need to be specified to meet the water quality standard and additional specifications to meet thermal criteria were not imposed. The use of multiport high velocity diffusers provided sufficient mixing with ambient water to meet water quality criteria. The SPDES permit provides a daily maximum discharge temperature (99°F).

Indian Point:

As of the 1987 - 1992 SPDES permit term, thermal discharges from Indian Point did not meet applicable thermal criteria. To control thermal discharges, the SPDES permit for Indian Point Units 2 and 3 requires that the maximum discharge temperature for condenser cooling water not exceed 110°F. In addition, the daily average discharge temperature between April 15 and June 30 is not to exceed 93.2°F for an average of more than ten days per year during the term of the permit, beginning in 1981, provided that it not exceed 93.2°F on more than 15 days during that period in any year.

The Consent Order also provided that Indian Point give “due regard to ambient river water temperature, plant operating status, and the need to meet water quality standards or other permit conditions”.¹ Figures B-1 and B-2 to Attachment D of the Fourth Amended Consent Order provide graphic representations of “Predicted Condenser Cooling Water Flow Rate Schedules to Achieve Efficient Operations of Indian Point [Units 2 and 3]”. That Consent Order provides that there may be some deviation from these schedules because “the minimum flow rate for any given period is dependent upon ambient river water temperature”.

These provisions alone, however, are not sufficient for Indian Point to meet thermal criteria. Thermal modeling indicates that the thermal discharge from Indian Point causes water temperatures to rise more than allowed, which is four degrees (F.) over the temperature that existed before the addition of heat, or a maximum of 83°F, whichever is less, in the estuary cross sections specified in 6 NYCRR §704.2(b)(5).² A mixing zone was not specified in the previous SPDES permit for the Indian Point facility.

Even though thermal discharges from Bowline and Roseton meet water quality criteria, their thermal contribution to the Hudson River is additive with that of Indian Point and must be taken into account in determining whether the water quality standard is met. If the standard is not met, the circumstances can trigger the water quality standard requirement to assure the protection and propagation of a balanced, indigenous population. If analyses specified in the proposed SPDES permits are unable to make this assurance to the Department’s satisfaction, the next level of action would be for the Department to determine how thermal discharges would be limited to ensure that water quality standards are met.

⁴⁰ See App. F-III.

⁴¹ 1999 DEIS, Appendix VI-3-A, Thermal Modeling of Ebb and Flood Tide Thermal Plumes (CORMIX model).

New York has adopted the appropriate regulations for the operation of the SPDES permit program, including standards for the development and issuance of permits as well as for the types of effluent limitations to be imposed in these permits.⁴² In addition to the federally developed categorical effluent limitations, The Department has developed approximately 100 water quality standards for various pollutants in its regulations and less formal "guidance" values for many more pollutants.⁴³ The Department has also categorized through regulation all significant water bodies in the State, based upon the best use of each water body.⁴⁴

The Department's overall SPDES permitting activity is intended to implement the declared public policy of the State of New York that water resources not be wasted or degraded and "shall be adequate to meet the present and future needs for domestic, municipal, agricultural, commercial, industrial, power, recreational and other public, beneficial purposes."⁴⁵

Goals for water discharge permitting are also articulated in the ECL:

Reasonable standards of purity and quality of the waters of the state be maintained consistent with public health, safety and welfare and the public enjoyment thereof, the propagation and protection of fish and wildlife, including birds, mammals and other terrestrial and aquatic life, and the industrial development of the state, and to that end, to require the use of all known available and reasonable methods to prevent and control pollution, wastage and unreasonable disturbance and defilement of the waters of the state.⁴⁶

Any source proposing to discharge pollutants requiring a SPDES permit must file an application with The Department at least 180 days before the proposed commencement of the discharge⁴⁷ or, if renewing an existing SPDES permit, at least 180 days before the expiration of the existing permit.⁴⁸ Submission of a timely renewal application continues the terms of the existing SPDES permit until the renewal permit is issued by the Department.⁴⁹ If the Department determines to

⁴² See 6 NYCRR Part 750.1

⁴³ 6 NYCRR Part 703; Department Technical and Operational Guidance Series (TOGS) § 1.1.1.

⁴⁴ See 6 NYCRR Parts 701 and 800 to 941.

⁴⁵ ECL § 15-0105(3).

⁴⁶ ECL § 15-0105(7); *see also*, ECL § 17-0101.

⁴⁷ 6 NYCRR § 750-1.6

⁴⁸ 6 NYCRR § 750-1.16

⁴⁹ SAPA § 401(2).

issue the permit, it prepares a draft permit, including proposed effluent limitations and other conditions.⁵⁰

The Department is required to provide public notice of every draft SPDES permit which gives a description of the discharge and the terms of the draft permit, and sets forth a public comment period of no less than 30 days during which interested parties may submit written comments concerning the application.⁵¹ During the public comment period any person, including the applicant, may submit written comments or request a hearing. The Department is required to hold a legislative hearing to receive unsworn public comments if it determines that there is significant public interest and sufficient reason for such a hearing.⁵² If no hearing is held, only the written comment period occurs, and the Department will issue a final SPDES permit following the close of the public comment period.

In certain instances, an adjudicatory hearing may also be held, where evidence and sworn testimony is presented before an Administrative Law Judge (ALJ). Any interested party, as well as the applicant, may request an adjudicatory hearing with respect to any aspect of a draft SPDES permit so long as the request is made during the public comment period.⁵³ At such a hearing, parties have an opportunity to contest issues the ALJ has determined to be adjudicable.⁵⁴

The Department is required to determine the existence of the following facts in a SPDES permit renewal context:

1. That the permittee is in compliance with or has substantially complied with all the terms, condition, requirements, and schedules of compliance of the expiring SPDES permit;
2. That The Department has up-to-date information on the permittee's production levels, waste treatment practices, and the nature, contents, and frequency of the permittee's discharge, pursuant to new forms and applications or monitoring records and reports; and
3. That the discharge is consistent with currently applicable effluent and water quality standards and limitations, and other legally applicable requirements.⁵⁵

Upon a determination of the existence of these facts, the Department may issue a renewal permit.

The Department also has authority to modify SPDES permits for a number of reasons, including significant changes in a discharger's operations or new

⁵⁰ 6 NYCRR § 750-1.9

⁵¹ 6 NYCRR § 750-1.9

⁵² 6 NYCRR § 750-1.9

⁵³ 6 NYCRR § 750-1.1(d)

⁵⁴ 6 NYCRR § 624.4(b)(5), (c)

⁵⁵ 6 NYCRR §750-1.16

information, such as the promulgation of new standards by either the State or USEPA.⁵⁶ Permits can also be modified or revoked in response to violations of permit conditions, misrepresentations by the permittee, or changes in conditions.⁵⁷

Legislative Findings and Commissioner's Powers

In enacting legislation to preserve and protect the water resources and wildlife of the State of New York, the NYS Legislature made findings of fact and vested the Commissioner of the Department of Environmental Conservation with broad powers and authority germane to the regulation of electricity generating facility operations that use and impact such resources.

The Legislature has found:

The State of New York owns all fish, game, wildlife, shellfish, crustacea and protected insects in the state, except those legally acquired and held in private ownership. Any person who kills, takes or possesses such fish, game, wildlife, shellfish, crustacea or protected insects thereby consents that title thereto shall remain in the state for the purpose of regulating and controlling their use and disposition.⁵⁸

The general purpose of powers affecting fish and wildlife, granted to the department by the Fish and Wildlife Law, is to vest in the department, to the extent of the powers so granted, the efficient management of the fish and wildlife resources of the state. Such resources shall be deemed to include all animal and vegetable life and the soil, water and atmospheric environment thereof, owned by the state or of which it may obtain management, to the extent they constitute the habitat of fish and wildlife as defined in § 11-0103 ...⁵⁹

New York State has been generously endowed with water resources which have contributed and continued to contribute greatly to the position of preeminence attained by New York in population, agriculture, commerce, trade, industry and outdoor recreation.⁶⁰

All fish, game, wildlife, shellfish, crustacea and protected insects in the state, except those legally acquired and held in private ownership, are owned by the state and held for the use and enjoyment of the people of the state, and the state has a responsibility to preserve, protect and

⁵⁶ 6 NYCRR § 750-1.18

⁵⁷ 6 NYCRR § 750-1.20

⁵⁸ ECL § 11-0105.

⁵⁹ ECL § 11-0303(1); *see also*, ECL §§ 11-0303(2) and 11-0305.

⁶⁰ ECL § 15-0103(2).

conserve such terrestrial and aquatic resources from destruction and damage and to promote their natural propagation.⁶¹

It is in the best interests of this state that provision be made for the regulation and supervision of activities that deplete, defile, damage or otherwise adversely affect the waters of the state and land resources associated therewith.⁶²

The Department Commissioner has the power to:

Promote and coordinate management of water, land, fish, wildlife and air resources to assure their protection, enhancement, provision, allocation, and balanced utilization consistent with the environmental policy of the state and take into account the cumulative impact upon all such resources in making any determination in connection with any license, order, permit, certification or other similar action or promulgating any rule, regulation, standard or criterion.⁶³

Provide for the propagation, protection, and management of fish and other aquatic life and wildlife and the preservation of endangered species.⁶⁴

Provide for the protection and management of marine and coastal resources and of wetlands, estuaries and shorelines.⁶⁵

New York State Coastal Management Program

The NYS Coastal Management Program was developed under authority of New York State Executive Law 910-22 and 19 NYCRR Part 600. The operative sections of the Executive Law provide 11 points of policy that have been detailed in a single set of 44 decision-making criteria in the Coastal Management Program and final environmental impact statement. The Department, as a state agency, must find that all direct and funding actions, and any permitting actions that are the subject of an EIS under SEQR, are consistent with the Coastal Management Program.⁶⁶ In addition, SEQR regulations provide that, for any state agency action in a coastal area, a draft EIS must contain an identification of the applicable coastal resources/waterfront revitalization policies and a discussion of the effects of the

⁶¹ ECL § 15-0103(8).

⁶² ECL § 15-0103(13).

⁶³ ECL § 3-0301(1)(b).

⁶⁴ ECL § 3-0301(1)(c).

⁶⁵ ECL § 3-0301(1)(e).

⁶⁶ 6 NYCRR 617.9(e); 19 NYCRR 600.4(a)

proposed action on such policies.⁶⁷ The SPDES permit renewals that are the subject of this DEIS will not result in any new effects on coastal zone policies. Coastal zone consistency forms are contained in DEIS Appendix IV-5.

State law also requires that state agencies provide timely notice to local governments whenever an identified action will occur within an area covered by an approved local waterfront revitalization program (LWRP). The NYS Secretary of State is required to confer with state agencies and local governments when notified by a local government that a proposed state agency action may conflict with the policies and purposes of its approved LWRP, and may modify the proposed action to be consistent with the local plan.⁶⁸ None of these facilities is in an LWRP area.

The consistency provisions of the New York State Coastal Management Program enable the Department to consider the full range of coastal policies prior to undertaking and approving a specific action.

Hudson River Estuary Management Program

In 1987, ECL §11-0306 was amended in order to establish a Hudson River estuarine district including "the tidal waters of the Hudson River, including the tidal waters of its tributaries and wetlands from the federal lock and dam at Troy to the Verrazano-Narrows."⁶⁹ This section also directed the Department to establish a Hudson River estuary management program "in order to protect, preserve and, where possible, restore and enhance the Hudson River estuarine district."⁷⁰ The district was also to consider the remainder of the Hudson River, New York Bight, and the waters around Long Island, as they impact the Hudson River estuary.

A Hudson River estuary management advisory committee, consisting of representatives of commercial fishing, sportsmen, research, conservation, and recreation, as well as a Hudson River estuary coordinator, was created within the Department to manage the Hudson River estuary management program and assist in the development and implementation of the program.⁷¹

A Hudson River estuarine sanctuary was also established "for the purpose of protecting areas of special ecological significance within the Hudson River estuarine district and associated shorelands ...".⁷² The sanctuary also serves as a "long-term estuarine field laboratory for research and education concerning the Hudson River ecosystem."

⁶⁷ 6 NYCRR 617.14(d)(10)

⁶⁸ Executive Law 915-a.

⁶⁹ ECL §11-0306(1).

⁷⁰ ECL §11-0306(2).

⁷¹ ECL §11-0306(4).

⁷² ECL §11-0306(5)

The Department and the advisory committee were directed to develop a continuing estuary management program “for the preservation, protection, restoration and enhancement of the Hudson River estuarine district and associated shorelands including but not limited to its natural resources, its fish and wildlife and the habitats within it.”⁷³ The strategy was required to include, among other things, the following:

- ...
 - e. Evaluation of the impact of the uses of water on the Hudson River estuarine district including present and future demands for water and their impact on the balance of fresh and salt water in the estuary.
 - f. Identification of areas of potential ecological significance which may require rehabilitation.
 - g. A status report on the levels of toxicants in and their effects on important estuarine indicator species and for species that have potential or existing recreational or commercial value.
 - h. Identification of the anthropogenic activities and the conservation and management problems that pose an existing or potential threat to the resources and the functioning of the estuary.⁷⁴

In enacting ECL §11-0306, the Legislature made the following findings and declarations:

The legislature further finds that the Hudson River estuary is of statewide and national importance as a habitat for marine, anadromous, catadromous, riverine and freshwater fish species and that it is the only major estuary on the east coast to still retain strong populations of its historical spawning stocks. Such species are of vital importance to the ecology and the economy of the state and to the recreational and commercial needs of the people of the New York state and neighboring states. A lack of sufficient and reliable research and documentation has resulted in recurring disputes on the movements, life cycles and habitats of these species.

The legislature further finds that the Hudson River estuary possesses a fishery of outstanding commercial and recreational value, and the economic potential of the Hudson river estuary’s fishery is at present underdeveloped. Improper management and use of the Hudson River estuary will deprive present and future generations of the benefit and enjoyment of this valuable resource.

The legislature further finds that the protection of estuarine species throughout their life history; the protection of their spawning habitat, nursery habitat, wintering habitat and feeding and foraging habitat; and the protection, enhancement and restoration of the state’s natural resources upon which these species and their habitat depend requires a specific program for the proper management of the Hudson River estuary.

⁷³ ECL §11-0306(6).

⁷⁴ See ECL §11-0306(6)(e)-(h).

It is hereby declared to be the policy of the state to preserve, protect and, where possible, restore and enhance the natural resources, the species, the habitat and the commercial and recreational values of the Hudson River estuary.

Hudson River Valley Greenway Program

Article 44 of the ECL was amended in 1991 to establish a Hudson River Valley Greenway Communities Council (Greenway Council) to assist Hudson River Valley communities in the 10 counties of Westchester, Putnam, Dutchess, Columbia, Rennselaer, Albany, Green, Ulster, Orange, and Rockland in their plans for development. Article 44 was enacted as companion legislation to the Hudson River estuary management program discussed earlier.⁷⁵ The statute authorizes the Greenway Council to provide and support cooperative planning to establish a voluntary regional compact among Hudson Valley localities to protect the valley's natural and cultural resources and promote regional planning. The ECL also provides that, upon compact effectiveness, state agency actions for which an EIS is being prepared under SEQR, including Department actions, must be assessed in light of the Greenway compact and applicable rules and regulations, and that the Greenway Council should review and comment in writing on the DEIS.⁷⁶ As of early 2003, six counties and several localities were actively engaged in Greenway Compact planning and programs.⁷⁷

Endangered Species Act

Past operations at the Roseton Units 1 & 2, Bowline Units 1 & 2 and Indian Points Units 2 & 3 have occasionally resulted in the impingement of shortnose sturgeon on the facilities' traveling screens. Shortnose sturgeon are currently listed as endangered under the federal Endangered Species Act.⁷⁸ In previous permit proceedings, the generators supplied the NMFS with all data on shortnose sturgeon that were collected in biological sampling programs. In testimony to the EPA in 1979, NMFS concluded in a Biological Opinion made pursuant to Section 7 of the Endangered Species Act that the once-through cooling system of the power plants did not pose a threat to the shortnose sturgeon population in the Hudson River. The generators are currently in the process of obtaining updated Incidental Take Permits from NMFS.

⁷⁵ ECL §11-0306

⁷⁶ ECL §44-0115(3).

⁷⁷ Hudson River Valley Greenway Communities Council website, <http://www.hudsongreenway.state.ny.us/commcoun/commcoun.htm>

⁷⁸ Endangered Species Act of 1973, 16 U.S.C.A. §§ 1531 - 1544.

The New York State Energy Plan

The NY State Energy Plan (SEP) is published every four years pursuant to § 6-104 of the State Energy Law (effective until January 1, 2003). The SEP was last published in 2002.

§ 6-102 of the State Energy Law creates the State Energy Planning Board. Among other things, the State Energy Law requires that the State Energy Planning Board include in the SEP twenty-year forecasts of the demand for electricity and energy supply requirements needed to supply that energy demand; an assessment of the ability of existing energy supply sources and transmission systems to satisfy such energy requirements; and identification and analysis of costs, risks, benefits and uncertainties of energy supply source alternatives for satisfying energy supply requirements which are not reasonably certain to be met by existing energy supply sources.

The SEP is intended to be a reflection of the State's policies for promoting and adopting "flexible, yet stringent, environmental policies that balance the need for more energy with the need for improved public health and safety."¹ Among its major policy strategies and recommendations, it includes supporting "the continued safe operation of nuclear, coal, natural gas, oil, and hydroelectric generation as part of a diverse portfolio of electricity generation resources".²

The SEP does not take into account the specific need to renew the Roseton, Bowline or Indian Point SPDES permits or the need to complete this EIS. However, the SEP does observe that mortalities to aquatic organisms associated with impingement and entrainment from the operation of CWIS and thermal discharges from older electricity generation facilities are negative environmental impacts for which minimization should be provided.³ The SEP finds that, since the 1998 SEP was released, the State has made significant gains in reducing the environmental impacts associated with energy generation and consumption. It also finds that the impacts of energy generation on the State's aquatic resources are analyzed and addressed through existing regulatory programs.⁴ The SEP will inform the Department's assessment of the impacts to and general alternatives for mitigation of adverse environmental impacts from the Roseton, Bowline and Indian Point generation facilities.

NYS Environmental Quality Review Act (SEQR)

SEQR requires that NYS agencies and local governments consider the potential adverse environmental impacts of decisions they make, including approval of applications from regulated entities.⁵ SEQR provided the Department's authority for

⁷⁹ 2002 SEP, p. S-1.

⁸⁰ 2002 SEP, p. S-4.

⁸¹ 2002 SEP, p. 2-56.

⁸² 2002 SEP, p. 2-58.

⁸³ ECL Article 8

requiring an EIS on the proposed renewal of the facilities' SPDES permits. Before issuing a final decision on each of the applications, the Department will be required to make findings based on this FEIS concluding whether, among other tests, the selected alternative(s) will minimize or avoid adverse environmental impacts, "... to the maximum extent practicable ...".

MITIGATION AND ALTERNATIVES

Available Mitigation Technologies

Based on information in the 1999 DEIS, including DEIS Appendices VII and VIII, and on information obtained and analyses conducted since the DEIS was prepared, the Department believes that a range of available technologies exist to minimize aquatic resource mortality from the cooling water intake structures (CWIS) at the Indian Point, Roseton, and Bowline Point generating stations. This discussion will focus on conclusions relating to potential applicability to the HRSA facilities of a range of technology and management systems to reduce impacts on aquatic organisms from their CWIS operations. The "Response to Comments" section of this FEIS contains more detailed descriptions, background and updates on several of the technologies, and several supporting reports are attached in Appendix F- V.

At present, the existing cooling water system at each of the HRSA generating stations is a "once-through" system, that is, Hudson River water is taken into the cooling system, circulated past the condenser coils to absorb waste heat from operation of the generation equipment, and discharged back to the Hudson River at a higher temperature than at the intake. In the process, some larger aquatic organisms are impinged on intake screens and many more are entrained within the circulating cooling water. Under the HRSA and Consent Orders, and currently by concurrence of the generators, Indian Point has achieved some reductions in intake volumes through the use of variable flow pumps while Roseton cycles pumps on and off to reduce water volumes used. Additionally, Indian Point has installed Fletcher-modified Ristroph traveling screens to help reduce impingement mortality at those facilities, and Bowline Point uses a seasonally-deployed fine mesh barrier net to reduce both impingement and entrainment mortality.⁸⁴ While these represent some level of improvement compared to operations with no mitigation or protection, there are still significant unmitigated mortalities from entrainment and impingement at all three of the HRSA facilities.

In addition to proposing a "Fish Protection Point" (FPP) management system as the generators' preferred alternative,⁸⁵ the DEIS presented information on a wide range of other technologies to reduce water intake volumes, prevent impingement or entrainment, or reduce thermal discharges, and also discussed a range of management options which might achieve one or more of the same goals.⁸⁶ Those alternatives described by the generators included:

- outages, that is, reduction of water demand by ceasing generation at specified plants during specified time periods;

⁸⁴ DEIS § VIII; Radle, E. W. and M. J. Calaban, 2003. Implementation of CWA 316(b) in New York. Proceedings (in press), A Symposium on Cooling Water Intake Technologies to Protect Aquatic Organisms. Washington, D. C., May 2003.

⁸⁵ DEIS § VII.

⁸⁶ DEIS § VIII.

- technology to reduce water demand, including dry, wet, and wet/dry (a/k/a "hybrid") cooling towers;
- minimizing flow rates with variable speed pumps or modified pumping schedules;
- barrier systems to minimize numbers of aquatic organisms impinged or entrained, including Ristroph traveling screens, fine-mesh screens, cylindrical wedge-wire screens, barrier nets, and fine-mesh barrier systems;
- behavioral deterrent systems designed to "steer" one or more classes of aquatic organisms away from CWIS, including acoustic systems, electrical barriers, air bubble curtains, several light systems, water jet curtains, and hanging chains;
- district heating/cooling, that is, exporting waste steam to a nearby industrial or institutional user, which in effect makes the receiving steam circulation system function as a large heat diffuser and thereby reduces the need for cooling water intake from and discharge to a water body like the Hudson;
- replacement of power provided by the HRSA plants with power from other sources, which would essentially mean exporting impacts by importing power;
- a so-called "multiple choice" alternative which would have required a commitment to not extend the Nuclear Regulatory Commission (NRC) Indian Point licenses; to operate the existing Bowline Point and Roseton plants until 2015 and then repower those stations with closed-cycle cooling; and provide 32 weeks of outages annually, until the NRC licenses expire for Indian Point and until 2015 for the other two plants;
- enhancements provided elsewhere than the HRSA plants, such as fish stocking and habitat improvement; and
- dismissal of a "no action" alternative, as the Department must by law take one of only 3 actions on SPDES renewal applications - approve, approve with conditions, or deny.

Alternatives Assessment

Generally speaking, the most effective aquatic resource protection can be achieved by greatly reducing actual water usage, particularly during seasons of peak abundance of entrainable life stages.⁸⁷ Complete retrofit of the HRSA plants to closed-cycle ("dry") cooling systems would result in an approximately 95% water demand reduction and so must be given serious consideration for feasibility at each of the HRSA stations. Despite all of the benefits, however, closed-cycle systems do not come without impacts, and those potential impacts must also be weighed for each site. The success of closed-cycle cooling in other NYS deployments causes this technology to be given a relatively high level of consideration among available technologies, while not excluding other proposals.

⁸⁷ In the Matter of an Application for a State Pollutant Discharge Elimination System (SPDES) Permit by Athens Generating Company, LP, Commissioner's Interim Decision, June 2, 2000, pp. 11 - 17 (Athens Interim Decision). See also Wantuck, R. L., 2003. Resource Agency Views of Technology Employed to Prevent Fish Mortality at Cooling Water Intakes. Proceedings (in press), A Symposium on Cooling Water Intake Technologies to Protect Aquatic Organisms. Washington, D. C., May 2003.

Among the potential impacts of closed-cycle cooling are so-called “energy penalties” associated with operation of cooling towers, that is, losses of generation efficiency under certain operating and climatic conditions plus the energy required to run component systems like fans. In addition, there are certain expenses associated with installing closed-cycle cooling.⁸⁸ Actual costs tend to vary widely depending on individual site characteristics combined with plant and tower configurations, so potential costs to install cooling towers can only be estimated based on a specific design proposal for an individual site.⁸⁹

Several classes of cooling tower system designs exist, each of which can substantially reduce water demand but also have associated “energy penalties” and other potential impacts of specific systems which must be evaluated based on individual proposals for particular sites. Dry, or closed cycle cooling systems rely on fans and air cooling with recovery of condensate for recirculation. “Wet” cooling towers use evaporative cooling, and “hybrid” or “wet/dry” towers have cooling cells with both evaporative and dry components.⁹⁰ Evaporative systems tend to produce condensate “plumes” which can be visible for considerable distances in some climatic conditions. Frequency of plume visibility and relative water losses can vary substantially depending on the operating parameters of a given system. Furthermore, evaporated water is permanently lost to the source water body; in the Hudson River system, there is evidence indicating that such losses could be sufficiently significant to affect salt levels. Thus, were a wet or hybrid tower to be proposed for any of the HRSA facilities, the potential impacts of evaporative losses, plumes, and energy losses would require careful evaluation based on a specific design proposal for that site.⁹¹

Finally, modern cooling tower systems, whether dry, hybrid or wet, require a sufficient amount of land to support a series or array of cooling “cells”. Again, potential impacts would be site and design specific but include possible visibility from sensitive receptors as well as potential impacts on sensitive land resources. The mid-to-lower Hudson Valley has a number of sensitive visual receptors as identified in the Visual Impact Assessment Policy developed by the Department’s Division of Environmental Permits, but the ability to more precisely evaluate potential visual impacts would depend on knowing precise height, configuration and site placement of any proposed tower system.⁹² Similarly, prediction and evaluation of potential

⁸⁸ Grogan, D. B. & Assoc., Inc. 2000. Hudson River Power Plants, Cooling Water System Design Assessment. Technical Report prepared for ESSA Technologies, Ltd., Richmond Hill, Ontario, Canada; included in Appendix F-IV of this FEIS.

⁸⁹ Maulbetsch, J. and K. Zammit, 2003. Cooling System Retrofit Costs. Proceedings (in press), A Symposium on Cooling Water Intake Technologies to Protect Aquatic Organisms. Washington, D. C., May 2003.

⁹⁰ Grogan, 2000; Maulbetsch, 2003; see *also* DEIS Section VIII and appendices for basic descriptions and diagrams of cooling tower systems.

⁹¹ Grogan, 2000.

⁹² Department Program Policy DEP 00-2, Assessing and Mitigating Visual Impacts. July 31, 2000. www.dec.state.ny.us/website/dcs/policy/visual2000.pdf

land resource impacts would require that proposed site placement and size of the tower array, at least, be known.

A modification of generating station design that can be incorporated with new construction or when an existing electric generating plant is “repowered”, that is, has its core combustion and generating systems replaced, is combined-cycle generation. In the most basic terms, a combined-cycle plant is designed to use some of the waste heat from the initial combustion/generation process to power a secondary turbine. Use of combined-cycle technology greatly reduces the amount of waste heat which must be managed, thereby greatly reducing the total demand for cooling and, thus, the size of the necessary cooling system.

Other approaches can also reduce water demand, usage or flow rates, which can then result in reductions in entrainment, impingement, or both. Permanent, structural measures, such as modified intake structures to reduce intake velocities, are one example of this approach. In addition, management systems and seasonal adjustments like the outage schedule employed for the HRSA plants can reduce water withdrawn during critical seasons. Monitoring and verifying such systems can require substantial recordkeeping by generators and agencies. There are also potential conflicts resulting from outage requirements in a competitive market where actual generating schedules are determined by the New York Independent System Operator (NYISO). On the other hand, such systems may be more rapidly implemented as they do not typically require major new infrastructure construction.

Structural protection can be added at intakes to reduce entrainment, impingement, or both. Traveling screens, barrier nets, “aquatic filter barriers” (AFB) like the Gunderboom® Marine Life Exclusion System™ (MLES™), and wedgewire intake structures can all protect some or many life-stages from being trapped against or entering into cooling water intake systems.⁹³ Traveling screens are used at many intakes to reduce the load of small solids entering and potentially damaging the cooling system; in some cases, like at Indian Point, those screen systems have been modified to incorporate “fish return” components.⁹⁴ These screens are most effective at reducing impingement of larger aquatic organisms but do very little to reduce entrainment. Similarly, barrier nets are typically relatively coarse mesh (3 - 5 mm opening, or wider) and are more effective in reducing impingement than entrainment. Barrier nets have been used in a range of fresh- and saltwater systems in the United States.⁹⁵ A fine-mesh barrier net (3 mm opening) has been seasonally deployed at Bowline Point under the HRSA and subsequent Consent Orders.

⁹³ See *also* Responses to Comments, following, plus individual technology assessments in App. xx - yy of this FEIS.

⁹⁴ Radle and Calaban, 2003.

⁹⁵ Taft, E., T. Cook, J. Black, and N. Olken, 2003. Fish Protection Technologies for Existing Cooling Water Intake Structures and Their Costs. Proceedings (in press), A Symposium on Cooling Water Intake Technologies to Protect Aquatic Organisms. Washington, D. C., May 2003.

AFB's are a variant on barrier nets. Instead of relatively coarse openings, AFB's have micropores which allow water passage but block most floating or suspended organisms and objects. These micropores are sufficiently fine to act as a barrier to many fish eggs and larvae as well as other floating and suspended aquatic organisms. Depending on a facility's intake configuration, an AFB can be installed as an in-water, surface-to-bottom "curtain" surrounding an open-water intake, or as panels running along a shoreline, parallel to river flow, to screen a shoreline intake. The Department has monitored a series of deployments of a "curtain" installation of the Gunderboom® MLES™ at the Lovett generating station, also on the Hudson River, on the opposite shore and slightly downstream from Indian Point (Figure 2, following this text section). In those deployments, the MLES™ showed effectiveness approaching that of closed cycle cooling for reducing both entrainment and impingement.⁹⁶ Other researchers have identified "fouling" (clogging openings with debris or organisms) as a concern with both barrier nets and AFB's at other locations,⁹⁷ and shoreline or channel bottom modifications can be necessary for deployment. Thus, again, site- and design-specific evaluations and impact assessments must be made of any proposed installation of AFB or barrier net system, and effectiveness monitoring should be required for some time after installation.

Wedge-wire intake screens have also been shown to be very effective in reducing impingement but variably successful in reducing entrainment.⁹⁸ Wedge-wire screens essentially provide a filtering hood over an intake that both physically blocks many organisms from entering the intake and reduces intake flow rates, by essentially "spreading" the intake's draw over a relatively large surface area. How effective a specific wedge-wire screen installation will be in reducing entrainment depends on the "slot" size of the screen and on the size distribution of potentially entrainable aquatic organisms in that water body. Two millimeter (mm) slots, or openings between metal parts to provide water passage, will generally block organisms 15 mm and larger; smaller slot openings will protect smaller organisms but also reduce the flow rate through a given area of screen. Where water volume and flow rate requirements of a generating facility plus the local populations of entrainable organisms match the capabilities of the wedge-wire screen system, this can provide an effective intake protection system, however, determining that match will require detailed, site-specific analyses.

Behavioral and deterrent systems like acoustic deterrents have also shown promise for reducing mortality of some species or classes of aquatic organisms in specific

⁹⁶ See reports in Department application file for the 2003 Lovett SPDES renewal, Department # 3-3928-00010/00002 and 3-3928-00010/00045

⁹⁷ McLean, R. 2003. State of Maryland Perspectives on Cooling Water Intake Technologies to Protect Aquatic Organisms; and Henderson, P., R. Seaby and R. Somes. 2003. Filter Curtain Materials, Entrainment, Biofouling and Permeability. Both in Proceedings (in press), A Symposium on Cooling Water Intake Technologies to Protect Aquatic Organisms. Washington, D. C., May 2003.

⁹⁸ Taft, E., T. Cook, J. Black, and N. Olken. 2003. Fish Protection Technologies for Existing Cooling Water Intakes and Their Costs. Proceedings (in press), A Symposium on Cooling Water Intake Technologies to Protect Aquatic Organisms. Washington, D. C., May 2003.

situations. Most notably, sonic deterrent systems have been shown to be effective in protecting adults of some herring species from impingement at intakes in Lake Ontario, on the English Channel, and in Belgium.⁹⁹ Key design criteria of these deployed systems differ widely, including operating pitches, timing, and speaker placement. Because there are still wide differences in designs and an apparently narrow range of species susceptible to sonic deterrence, application at any of the HRSA plants would require site and resource assessments to determine likelihood of success as well as followup studies to monitor effectiveness. Other deterrent technologies do not have sufficient performance records to be considered available at this time.

The most promising BTA approach for the HRSA plants at this time appears to be combinations of technologies, or technologies plus management systems, deployed in such a manner as to provide increasingly effective aquatic resource protection. This conclusion is consistent with that of other researchers working with cooling water intakes at existing power stations.¹⁰⁰

Significantly for NYS, this approach of combined technologies would also be consistent with the BTA determinations recently reached for several new or repowered electric generating stations on the Hudson River and estuary system, which have generating capacities similar to units at the HRSA facilities:

- Athens Generating Station (Athens), between Albany and Kingston;¹⁰¹
- Bethlehem Energy Center (Bethlehem), slightly south of Albany;¹⁰²
- Bowline 3, adjoining Bowline Point 1 and 2, West Haverstraw;¹⁰³
- Lovett Electric Generating Station, Stony Point;¹⁰⁴
- Astoria Generating Company (Reliant/Astoria), Queens, New York City(NYC);¹⁰⁵

⁹⁹ Radle et al, 2003; Ross, Q. E., D. J. Dunning, J. K. Menezes, M. J. Kenna, Jr. and G. Tiller. 1996. Reducing Impingement of Alewives with High-Frequency Sound at a Power Plant Intake on Lake Ontario. *North American Journal of Fisheries Management*, 16:548-559; Maes, J., A. Turnpenny, D. Lambert, J. Nedwell, A. Parmentier and F. Ollevier. 2002. The Impact of Cooling Water Abstraction On Fish At The Electobel Power Plant Doel (Belgium) After Installation Of A Fish Guidance Sound System. *Journeew D'etude Du Cebedeau*, Nov/Dec 2002. Pp. 75-78.

¹⁰⁰ Taft et al, 2003; Maulbetsch et al, 2003.

¹⁰¹ Athens Interim Decision.

¹⁰² In the Matter of The Applications for Clean Air Act Title IV and SPDES permits by PSEG Power New York, Inc. (Bethlehem Energy Center), Interim Decision, January 31, 2002.

¹⁰³ In the Matter of the Application for a SPDES permit and Air Pollution Control permits by Mirant Bowline, LLC. (Bowline 3 Decision), Decision, March 19, 2002.

¹⁰⁴ Lovett Electric Generating Station, SPDES Permit (and supporting Fact Sheets), DEC # 3-3928-00010/0002; NY-0005711; February 6, 2003.

¹⁰⁵ In the Matter of the Application of Astoria Generating Company, L.P. for a Certificate to Construct and Operate a 1,816 MW Electric Generating Plant pursuant

- Astoria Energy (SCS/Astoria), Queens, NYC;¹⁰⁶ and
- New York Power Authority (NYPA/Astoria), also in Queens, NYC.¹⁰⁷

Locations of these facilities are shown on Figures 2 and 3, following this section.

For the Athens project, a new plant employing combined-cycle technology, potential impacts on aquatic resources were found to be a very compelling concern, and a dry cooling system was determined to be BTA. At Bethlehem, a repowering incorporating combined-cycle technology, third parties voiced strong concerns over potential visibility of the taller structures required for a full dry cooling system as opposed to wet or hybrid cooling tower systems, but significant numbers of species and life stages susceptible to both entrainment and impingement were present at the site. Thus, for that project, a plan was developed and approved to construct hybrid cooling towers, install a wedgewire structure over the intake, and seasonally deploy an MLES™ to further screen the intake during peak periods of potential entrainment. The MLES™ installation at Bethlehem will be flat panels generally paralleling the shoreline.

Bowline 3, a new combined-cycle plant, will use a combination of technologies similar to that at Bethlehem. In addition, Bowline 3's sponsors propose to use discharge water from Bowline 1 and 2, when available, instead of Hudson River water for its cooling water source. This management strategy could further reduce the amount of fresh river water required for the new generating plant. At the Reliant/Astoria facility, a repowering project on the Queens side of the East River, combined-cycle generation with hybrid towers plus intake protection will be provided; the towers will use a reverse osmosis treatment system to minimize salt drift impacts. The SCS/Astoria and NYPA/Astoria projects, both new plants employing combined-cycle generation, will use dry cooling.

In each of these recent decisions, consistent with established law, the aquatic and other natural resources present at and site-specific constraints of each project factored into the individual BTA determination. Each BTA decision must also be found to maximize fish protection while minimizing or avoiding other impacts "... to the maximum extent practicable ..." to satisfy SEQR as well as CWA §316(b). These decisions reiterate that each SPDES permit application involving a CWIS will present an opportunity to make an independent BTA decision.¹⁰⁸ By their very nature, BTA decisions are application-specific, based on site-specific characteristics rather than

to Article X of the Public Service Law (Reliant/Astoria Decision), Recommended Decision, April 3, 2003.

¹⁰⁶ In the Matter of an Application by Astoria Energy LLC for a Certificate to Construct and Operate a 1000 MW Electric Generating Plant pursuant to Article X of the Public Service Law (SCS/Astoria Decision), Order and Opinion Granting Certificate, November 21, 2001.

¹⁰⁷ In the Matter of an Application by the New York Power Authority for a Certificate to Construct and Operate a 500 MW Electric Generating Plant pursuant to Article X of the Public Service Law (NYPA/Astoria Decision), Recommended Decision, December 17, 2001.

¹⁰⁸ Athens Interim Decision, p.12.

pre-established quantitative goals applicable to applications generally. This appropriately addresses the unique physical and regulatory aspects of each site, including issues that are land-based and water body-specific, as well as its particular technological limitations or parameters.

Fig.3, facing page. Locations of Selected New and Existing Power Plants on the Lower Hudson Estuary, Hudson River, NY.¹⁰⁹

¹⁰⁹ Scale reduced from original by about 55%.

Fish Population - 5. Thermal analyses need to be updated to reflect recent, more extreme conditions.

The Department concurs with this comment. Thermal discharges were inadequately addressed in the DEIS. The DEIS asserts, with no supporting evidence, that "... [t]he surface water orientation of the plume allows a zone of passage in the lower portions of the water column, the preferred habitat of the indigenous species." Other data and analyses cast doubt on this assertion.

The sheer volumes of water necessary to meet the HRSA plants' cooling requirements are enormous. Together, Indian Point, Roseton, and Bowline are authorized to withdraw 1.69 trillion gallons per year for cooling water, and they discharge 220 trillion BTU of waste heat per year.¹⁷⁵ The volume of once-through cooling water is raised between 15° and 18° F, depending on the plant,¹⁷⁶ or an average of 16.2°F.¹⁷⁷

Some graphics and imagery effectively illustrate the basis for the Department's concerns. A study by HydroQual, Inc., examined passive particle movement and also investigated thermal and salinity profiles in several river reaches, including the portion of the Hudson River where the HRSA plants are located.¹⁷⁸ Figures 6 and 7 of this FEIS (following pages), excerpted from that study, show two vertical temperature profiles of the Hudson River from NYC to just above the northernmost of the HRSA plants, one during a spring and the other during a neap tide. Based on these representations, it appears that there may be times and conditions where effluent-warmed waters occupy nearly the entire vertical water column.

The surface extent of thermal discharges from the HRSA plants is also a concern. Figure 8 is an aerial thermal image of the plume from Indian Point, Unit 3 only, on the east side of the Hudson plus the smaller plume from Lovett on the west bank.¹⁷⁹ In this image, the two plumes came very close to meeting on the surface, even with Indian Point running at less than its full capacity.

Because the HRSA facilities and two other steam electric generating stations are essentially clustered in two relatively compact stretches of the Hudson River, there

¹⁷⁵ Power Plants with SIC code 4911, in Appendix F-V. Indian Point, Roseton, and Bowline are the first-, sixth, and seventh-largest users of water in the State, with a combined intake flow of 7,177 CFS (cubic feet per second).

¹⁷⁶ DEIS Chapter IV-B, Tables IV-6, IV-9, and IV-11. NOTE: ΔT (change in temperature) should read °F not °C.

¹⁷⁷ $\sum (\text{volume each plant} * \Delta T \text{ each plant}) / (\sum \text{volume of the 3 plants}) = \text{mean } \Delta T$

¹⁷⁸ HydroQual, 1999.

¹⁷⁹ Note that Unit 2 discharge canal is cold, so the plume shown resulted from generation and discharge at Unit 3, only, at Indian Point, plus Lovett.

is a strong potential for thermal effects on the river and its aquatic resources to be additive. Given the extent of warming shown in the HydroQual graphs, combined with the recent dramatic declines in tomcod and rainbow smelt as discussed previously, the Department believes it prudent to seek additional thermal discharge data for each facility, including a mixing zone analysis, and anticipates requiring tri-axial thermal studies as conditions to each of the SPDES renewals. Depending on the results of those analyses, additional controls may be required to minimize thermal discharges.

Fig. 6. Temperature Profile of the Hudson River, NYC to Newburgh, During a Spring Tide¹⁸⁰





Figure 12. (continued) Contours of the along-river temperature (upper panel) and salinity (lower panel) from the neap tide farfield survey, August 28, 1997. (Contour intervals 0.1 °C and 0.5 psu).


¹⁸⁰ HydroQual, 1999.

Fig. 7 Temperature Profile of the Hudson River, NYC to Newburgh, During a Neap Tide¹⁸¹



¹⁸¹ HydroQual, 1999.

**Fig.8. Thermal Plumes from Indian Point, Unit 3,
and Lovett Station, Tompkins Cove, Hudson River, New York State.**



(Original
Vista Corp, with permission)

photo ©Spectra

Fish Protection Points - 6. Fish protection points (FPP) would provide operational flexibility but even less protection than conditions in the Hudson River Settlement Agreement (HRSA).

The Fish Protection Point system proposed by the generators in the 1999 DEIS would allow a great deal of operational flexibility for the three HRSA plants. While some consideration of the need for generation capacity is warranted, particularly during periods of high electricity demand, the proposed system would sacrifice reductions in fish mortality in order to maximize freedom of plant operations. As proposed, the DEIS' preferred alternative would be less protective of aquatic resources than measures under the HRSA and subsequent Consent Orders.

Tables 4-A, B and C (following) compare several alternative operating scenarios and entrainment or impingement mitigation strategies for the HRSA plants. The tables display predictions of conditional mortality rates for 6 fish species, the volume of water used, and the volume of water lost to evaporation under a variety of mitigation strategies at each of the 3 plants. The tables use italicized text to indicate those values which would result from the implementation of the strategies agreed upon in the 1981 Settlement Agreement; they serve as the basis for comparison. Values which would reduce environmental impacts, by providing a higher level of fish protection or by using less water, are indicated by bold text. Values which cause greater environmental harm, by providing lower levels of fish protection or using more water, are indicated by both bold text and gray shading. It is instructive to note that, with respect to fish protection, only the proposed Fish Protection Points strategy would result in lower levels of protection than would be provided by the 1981 Settlement Agreement strategies. At Bowline Point, a single species would suffer greater losses, but at both Roseton and Indian Point, protection would be reduced for 3 of the 6 species.

Table 4. Comparisons of Selected Mitigation Alternative Strategies

Key:

x.xx Same as 1981 Settlement Agreement

y.yy Better than 1981 Settlement Agreement

z.zz Worse than 1981 Settlement Agreement

CEMR Conditional Entrainment Mortality Rate¹⁸²

MGD Million Gallons per Day

A. BOWLINE POINT								
	Striped Bass	American Shad	River Herring	Bay Anchovy	Atlantic Tomcod	White Perch	Water Volume	Water Evaporated
Alternative	CEMR	CEMR	CEMR	CEMR	CEMR	CEMR	MGD	MGD
1981 Settlement conditions	0.80	0.05	0.19	3.93	6.39	1.01	910.00	5.18
Hybrid Towers (full year)	0.10	0.00	0.00	0.14	0.53	0.02	43.20	12.96
Hybrid Towers (seasonal)	0.10	0.00	0.00	0.14	0.53	0.02	369.30	10.04
Fish Protection Points	0.77	0.02	0.12	3.93	7.13	0.27	910.00	5.18
Gunderboom (full year)	0.18	0.01	0.04	0.86	1.39	0.22	910.00	5.18
Gunderboom (seasonal)+ net	0.10	0.00	0.17	0.14	0.53	0.12	910.00	5.19
32-week Outage	0.00	0.00	0.00	0.00	0.00	0.00	349.80	1.99

Notes:

- GG. Values for the CEMR for 1981 Settlement Conditions, Hybrid Towers and the Fish Protection Points are from the 1999 DEIS.
- HH. Values for seasonal use of the Hybrid Towers (seasonal) are based on their use February 15 to September 15 (approximate dates) and were computed by Department staff.
- II. Values for Gunderboom assumed an 80 percent efficiency, with full flow to the facility and were computed by Department staff.
- JJ. Values for the 32-week outage are based on an outage from February 15 to September 15 (approximate dates) and were computed by Department staff.

¹⁸² See Footnote 134 of this FEIS.

**Table 4 (cont). Comparisons of
Selected Mitigation Alternative Strategies**

Key:

x.xx Same as 1981 Settlement Agreement

y.yy Better than 1981 Settlement Agreement

z.zz Worse than 1981 Settlement Agreement

CEMR Conditional Entrainment Mortality Rate¹⁷⁵

MGD Million Gallons per Day

B. ROSETON								
	Striped Bass	American Shad	River Herring	Bay Anchovy	Atlantic Tomcod	White Perch	Water Volume	Water Evaporated
Alternative	CEMR	CEMR	CEMR	CEMR	CEMR	CEMR	MGD	MGD
1981 Settlement conditions	2.40	0.78	3.28	0.51	1.67	4.92	923.00	5.18
Hybrid Towers (full year)	0.37	0.02	0.13	0.03	0.12	0.39	25.90	12.96
Hybrid Towers (seasonal)	0.37	0.02	0.13	0.03	0.12	0.39	370.00	10.04
Fish Protection Points	3.32	0.45	3.21	1.01	1.59	6.39	923.00	5.18
Gunderboom (full year)	0.50	0.16	0.68	0.11	0.35	1.03	923.00	5.18
32-week Outage	0.00	0.00	0.00	0.00	0.00	0.00	355.00	1.99

Notes:

- AA. Values for the CEMR for 1981 Settlement Conditions, Hybrid Towers and the Fish Protection Points are from the 1999 DEIS.
- BB. Values for seasonal use of the Hybrid Towers (seasonal) are based on their use February 15 to September 15 (approximate dates) and were computed by Department staff.
- CC. Values for Gunderboom assumed an 80 percent efficiency, with full flow to the facility and were computed by Department staff.
- DD. Values for the 32-week outage are based on an outage from February 15 to September 15 (approximate dates) and were computed by Department staff.

**Table 4(cont). Comparisons of
Selected Mitigation Alternative Strategies**

Key:

x.xx	Same as 1981 Settlement Agreement
y.yy	Better than 1981 Settlement Agreement
z.zz	Worse than 1981 Settlement Agreement
CEMR	Conditional Entrainment Mortality Rate ¹⁷⁵
MGD	Million Gallons per Day

C. INDIAN POINT								
	Striped Bass	American Shad	River Herring	Bay Anchovy	Atlantic Tomcod	White Perch	Water Volume	Water Evaporated
Alternative	CEMR	CEMR	CEMR	CEMR	CEMR	CEMR	MGD	MGD
1981 Settlement conditions	7.82	0.64	1.20	10.38	12.04	4.94	2505.0	12.82
Hybrid Towers (full year)	1.20	0.01	0.04	0.45	1.16	0.26	69.00	34.56
Hybrid Towers (seasonal)	1.20	0.01	0.04	0.45	1.16	0.26	982.00	26.40
Fish Protection Points	10.69	0.18	0.81	13.22	13.95	4.35	2419.0	12.82
32-week Outage	0.00	0.00	0.00	0.00	0.00	0.00	964.00	4.94

Notes:

- AA. Values for the CEMR for 1981 Settlement Conditions, Hybrid Towers and the Fish Protection Points are from the 1999 DEIS.
- BB. Values for seasonal use of the Hybrid Towers (seasonal) are based on their use February 15 to September 15 (approximate dates) and were computed by Department staff.
- CC. Values for Gunderboom assumed an 80 percent efficiency, with full flow to the facility and were computed by Department staff.
- DD. Values for the 32-week outage are based on an outage from February 15 to September 15 (approximate dates) and were computed by Department staff.

The proposed system would allow the trading of fish protection credits among the HRSA plants and their operators. Such trading would alter fish protection significantly in years in which one plant was off-line because credit for the inactive facility could be applied to one or both of the other two. The nature of the aquatic resource impacts would change because the different plant locations support different species and different life stages of fish. For this reason, trading among facilities and different operators could lead to unpredictable and probably less effective mitigation. As of the writing of this FEIS in mid-2003, Roseton and Bowline operate as peaking load facilities, as opposed to base load operation which was the case when the DEIS was published in 1999. If trading of credits among facilities and operators were to be incorporated into the permits of the HRSA facilities, credits from Bowline and Roseton could allow Indian Point to operate with little or no mitigation. This scenario would be contrary to the site-specific nature of BTA determinations required by 6 NYCRR Part 704 and CWA §316(b). Carrying credits accumulated in one year forward to subsequent years would *not* be a change from HRSA requirements. However, as proposed in the DEIS, credits could be carried forward and transferred to another facility. As discussed above, trading credits between the three facilities would add a new dimension of uncertainty to fish protection. Allowing credits accumulated at one facility in one year to be credited to another facility in a subsequent calendar year would be likely to compound this uncertainty.

Fish protection credit would also be added for the difference between SPDES flows (maximum pumping rate) and efficient flows at Indian Point, in contrast to the HRSA where credits were earned by operating Indian Point at mitigative flows (less than efficient). This change would lower the baseline from which credit for mitigation is measured. While not necessarily a reduction in fish protection from HRSA levels in and of itself, it would be coupled with a proposed level of protection less than HRSA levels. The lower starting point would mask some of the resultant reduction in fish protection.

The proposed measures specific to Indian Point would provide a significant reduction of fish protection by eliminating any requirement for outages (days off line). The preferred alternative proposes to achieve fish protection at that site solely through flow reductions without any outages. This would eliminate the previous HRSA requirement for 42 unit-days off line each calendar year.

The cumulative effect of the three changes described above would produce a scenario much less protective than current conditions. In addition, no new measures to reduce fish mortality at Roseton and Bowline are proposed. These relaxations in mitigation appear inconsistent with "anti-backsliding" prohibitions of the Clean Water Act.¹⁸³

The following excerpt from the review of the 1999 DEIS written by ESSA Technologies Inc., for the Department, summarizes differences between the generators' preferred alternative and HRSA conditions.

¹⁸³ CWA §303(d)(4)(B); 33 U.S.C. §1313(d)(4)(B); *see also* 40 CFR 131.12, 40 CFR 122.62, and 40 CFR 122.44.

"The proposed action put forward in the DEIS is a derivative of the Settlement Agreement scheme with some very critical differences. The proposed action:

1. translates the prior entrainment mitigation outage targets based on units of days to targets based on the aggregate Conditional Mortality Rate (CMR) due to entrainment for five target species: striped bass, American shad, bay anchovy, river herring and tomcod;
2. proposes that unlike the prior Credit Points, the new Fish Protection Points (FPPs) may be carried forward across years as well as traded between stations;
3. consistent with stipulated maximum flow requirements in the 1981 and 1987 SPDES permits for Indian Point, the proposal calculates and adds to the protection target the number of FPPs equivalent to the difference between "SPDES flows" and efficient flows for Indian Point Units 2 & 3;
4. proposes to continue the operation of current Modified Ristroph screen technology at the Indian Point Station for reduction of impingement mortality;
5. proposes to continue deployment of the barrier net at the Bowline Station for reduction of impingement mortality;
6. proposes to continue the management and mitigation regime for "thermal and chemical" discharge as carried out under the prior 1981 and 1987 permits, and
7. proposes to meet the requirements for entrainment mitigation exclusively through the management of station flows without necessarily invoking requirements for unit outages as previously required."¹⁸⁴

¹⁸⁴ ESSA, 2000; Section 2.2.

Mitigation - 7. DEIS includes little information on barrier systems and acoustic deterrents.

The Department concurs that additional information and updates to the data used in the DEIS are necessary. Additional information on several technologies follows.

Wedge-Wire Screens

Recent designs in water withdrawal technology have included development of wedge-wire screens to “filter” water prior to entrance into a system. Wedge-wire screens usually are designed with small openings, for example 2 mm slot width, but they can be designed with larger or smaller openings. Screening of water being withdrawn from a source water body is standard practice to eliminate fouling and clogging of pumps and cooling systems by detritus or large fishes, thus older power generation facilities typically employed traveling screens with approximately 3/8 inch mesh openings. This design excludes sticks, macrophytes (large aquatic plants) and large fishes from being entrained with the cooling water but does not exclude smaller organisms or particles. Bowline Point, Roseton and Indian Point facilities incorporate various types of large-mesh traveling screens, often with improved collection mechanisms and fish/detritus return mechanisms, in their intake designs.

The advantage of fine mesh wedge-wire screens is that the small openings prevent small aquatic organisms from being entrained into the circulating water system. Two millimeter slot width has been employed in new facility designs and it is expected that this opening will prevent ichthyoplankton larger than 15 mm from being entrained. In general, fishes greater than 15 mm length are greater than 2 mm in width, and are thus not susceptible to entrainment. The velocity of the water drawn into a system is directly associated with the size of the slot through which it is drawn. The Department imposes a low through-slot velocity to ensure that organisms are not impinged on the screen because they cannot swim away from the intake velocity. EPA recommends a through-slot velocity of 0.5 fps or less, but the Department has issued recent permits for intakes that generally have halved that velocity.¹⁸⁵ Additional protection is afforded by the current from tides or river flow on a wedge-wire screen because it assists in moving organisms away from the influence of the intake.

New power generation facilities recently approved in New York are all combined-cycle designs with closed-cycle cooling.¹⁸⁶ Combined-cycle facility produces two thirds of its power with a gas turbine (which does not require cooling), only one third of the facility requires cooling. This cooling requirement is further reduced by approximately 95 percent by employing closed-cycle cooling. Thus, typical cooling water requirements are 7 to 9 million gallons of water per day (MGD). This volume can be accommodated with two T-shaped sets of cylindrical screens six feet in diameter with 1 mm slot openings, with through-slot velocity of 0.2 feet per second.

¹⁸⁵ Athens Interim Decision.

¹⁸⁶ Athens Interim Decision.

In contrast, a single-cycle power generating facility using once-through cooling, such as Roseton Generating Station, requires a maximum of 926 MGD for cooling at full flow operation (less at efficient flow). For such a once-through cooling system, even with larger screens at higher intake velocities, a great number of wedge-wire screens would be required to supply the necessary cooling water; engineering challenges, higher costs and loss of generating capacity would likely result.

Fish Barriers

Since the preparation and filing of the DEIS in 1999, a new technology for eliminating aquatic organisms from a cooling water intake structure has emerged and been permitted by the Department. The technology is known generally as an "aquatic filter barrier" (AFB); the Gunderboom® Marine Life Exclusion System™ (MLES™) is the system which has been deployed, studied and permitted in NYS. Despite its name, use of the MLES™ is not restricted to marine systems.

The MLES™ is a semi-permeable fabric barrier which surrounds an intake structure and allows water to enter while excluding most very small particles, including aquatic organisms. Additional components of the MLES™ include: the structures necessary to maintain the barrier in place, such as anchors and floatation; a cleaning device; monitoring equipment; and other miscellaneous equipment as necessitated by the specific site conditions. Because the system is flexible, it may be shaped to follow desired water depth or to increase surface area. The barrier may be constructed in sections, allowing easier maintenance, installation and retrieval. At present, only one company, Gunderboom, has a patent to construct this type of barrier. Thus, an MLES™ is commonly referred to by the "Gunderboom®" trade name.

Gunderboom® MLES™, alone and in combination with other technologies, have been determined to be BTA at a number of facilities on the Hudson River, and requirements for installation have been written into the SPDES permits. Those with MLES™ requirements include the new electric generation facilities at Bowline Unit 3 (700 MW combined cycle) and Bethlehem Energy Center (750MW combined cycle). The Empire State Newsprint Project, a 500 MW combined-cycle facility in Rensselaer, New York, was issued a draft permit for an MLES™ in 2001. Lovett Generating Station Units 3-5, an existing facility with a 450 MW generating capacity, was issued a SPDES permit which included an MLES™ in February, 2003.

The Bowline Unit 3 MLES™ may generally be described as a straight line fabric screen, 137 feet in length and 27 feet deep, that allows 7.5 MGD of intake flow (maximum). ® Flow-through velocity is predicted to be approximately 0.004 fps with a flow rate of approximately 1.4 gallons per minute per square foot. An air-flow backwash system, strain gauges, water level monitors, and special bottom sealing fabric are required as part of the system. Seasonal deployment of the MLES™, from February 15 through September 30, will allow protection during the reproductive seasons of major Hudson River fish species.

The Bethlehem Energy Center facility will employ a different MLES™ design, yet still use Gunderboom fabric material as the principal screening device. A 16' by 145' rectangular H-pile and sheet pile structure will be constructed to support twelve

removable filter panels orientated to the river flow. The structure is sized for a maximum of 8.5 MGD flow with a fabric flow-through rate of 3.1 gallons per minute per square foot. (0.007 fps). Seasonal deployment of the MLES™ from April through August will be necessary for adequate protection to organisms. These filter panels will be removed mechanically for maintenance and at the end of each seasonal deployment; monitoring by the plant operator to ensure water passage, of strain on the panels, and related variables will be required.

The SPDES permit issued for the existing Lovett Generating Station requires the permittee to provide information, analyses and plans necessary to install, operate and maintain an MLES™. It is anticipated that this structure will be a Gunderboom curtain in the river that surrounds the intakes of Units 3,4 & 5. This means the curtain will be subject to tidal influence and will have some movement with river currents and wind. Close attention to operational parameters and maintenance will be required. The permit includes a protocol for operation, maintenance, monitoring, and responses.

The draft permit for the proposed Empire State Newsprint Project (ESNP) specifies an MLES™ that is somewhat different from those already permitted. The intake will be constructed a distance into the river along the bottom. The proposed Gunderboom® barrier of the MLES™ will necessarily be offshore, too, surrounding the wedge-wire intake screens in an oval shape 90' by 60' and be attached to 16 fender piles permanently installed in the river. This system is designed for a maximum of 9.7 MGD, with a through-screen flow of 0.01 feet per second and a flow rate of approximately 4.0 gallons per minute per square foot through the Gunderboom® fabric. The MLES™ would be deployed and operational during the primary fish spawning season in that section of the Hudson River, April 15 - June 30.

The Department is working with other facility owners toward investigating this method of aquatic mitigation at other existing generation facilities within New York State where an MLES™ could potentially reduce impingement and entrainment mortality.

Acoustic Deterrent System

A number of behavioral deterrent systems (e.g. fish hammers, hanging chains, bubble curtains, strobe lights, mercury lights etc.) have been studied by utilities in New York State for reducing impingement impacts at cooling water intakes. High frequency sound is the only behavioral deterrent technology shown to be effective and currently in use as an impingement mitigation technology in New York. The technology is in use at the J. A. Fitzpatrick Nuclear Generating Station (NGS), located on the south shore of Lake Ontario, and has effectively reduced the impingement of alewife at the station. The fish deterrent system, known by the trademark "Fish Startle System", emits a high frequency, broadband sound (122 - 128 KHz) at a source level of 190 decibels. The system has three major components: the integrated projector assemblies (IPAs), the power cable running from shore to intake, and the control panel. The IPAs contain the signal generators and transducers that emit the high frequency, broadband sound which has been shown to be strongly avoided by members of the clupeid family.

In 1989, the New York Power Authority, which owns and operates the Fitzpatrick NGS, started developing the mitigation system after learning that high frequency sound evoked a strong avoidance effect in some species of herring. Laboratory testing was successfully conducted on alewife, then a temporary sound system was developed and tested in Lake Ontario in 1991. Preliminary results showed that the number of fish in front of the intake was reduced by 81 to 87 percent when the system was operated. Between April and July 1993, a second full scale test was conducted. Paired impingement samples were collected with the system on and off and compared against impingement samples collected at the nearby Nile Mile Point Unit 1 NGS (control facility). The Nile Mile Point station is a similar sized NGS, with a similar offshore intake structure. The 1993 study reported the overall effectiveness of the system to be 84 percent (i.e., an 84 percent reduction in impingement as compared to the control facility).¹⁸⁷

In 1995, the Department determined the acoustic deterrent system to be BTA for minimizing adverse environmental impact at the Fitzpatrick NGS, and the system was therefore incorporated as a condition of its SPDES permit. Because sound at this frequency and decibel level has been shown to be effective for certain clupeid species only (alewife, blueback herring and American shad), the technology by itself has limited application. However, in combination with other mitigative technologies, its application may be more widespread.

British researchers have been testing an acoustic deterrent system on a number of species at a nuclear generating station in Belgium since 1997. The effectiveness of the system is stated to vary among species, due to species-specific hearing sensitivities and the levels at which a species will react to a sound stimulus. System efficiencies (deflection of fish) from 21 percent for flatfish, to up to 98 percent for herring are reported.¹⁸⁸ This work is promising if it proves to be effective over a wide range of species.

¹⁸⁷ Ross et al, 1996; Radle et al, 2003.

¹⁸⁸ Maes et al, 2003.

Mitigation - 8. The DEIS significantly overstates costs and energy impacts of closed cycle cooling.

A discussion of cooling tower design and operation was presented in Section VIII and Appendix VIII of the DEIS. The Department requested ESSA Technologies, Ltd., to review these analyses. This work was performed by D.B. Grogan Associates, Inc. and is included in Appendix V to this FEIS.

The information presented in the DEIS regarding cooling tower design and cost estimates is generally reasonable, based upon the assumptions used for this analysis. In order to determine BTA for individual sites, these assumptions should be modified or expanded to present further site-specific cooling tower alternatives which will result in different construction and operational costs, as well as different environmental impacts. Such additional analyses should include: tower designs based on a variety of wet/dry bulb scenarios; wet towers; a variety of tower fill and nozzle scenarios modified to increase operational efficiency; pre-treatment of cooling tower makeup water; and historical operation information from large, existing wet/dry (hybrid) systems.

The different closed-cycle cooling alternatives each result in different environmental impacts, including land use, aesthetics, fogging, evaporative losses, drift impacts, composition of the blowdown discharge, and thermal effects on the river. Energy efficiency, too, varies among the cooling technologies. For example, wet/dry cooling tower systems create a larger parasitic load when compared with wet systems. This results in a need for replacement power from other facilities whose air and water emissions may have an adverse environmental impact.

Costs of both construction and operation of closed systems are a concern when analyzing cooling system alternatives. The operational costs have been presented in the DEIS, but D.B. Grogan Associates, Inc. points out that the cost of lost electric generation may be significantly different in the present era of power deregulation and may be seriously underestimated in the DEIS.¹⁸⁹ Alternative designs that minimize this loss would significantly change the cost projections.

A recent EPA update, published on March 19, 2003, concerning 40 CFR Part 125, *Proposed Regulations To Establish Requirements for CWIS at Phase II Existing Facilities; Notice of Data Availability; Proposed Rule*, provides additional information on the cost of connecting a new facility to a closed-cycle system. It noted that the period of time for interconnections to be made for installations at existing facilities should be increased from EPA's earlier estimate and could require up to seven months at nuclear facilities. This could significantly increase the cost of closed-cycle systems unless very detailed planning and construction schedules are carried out to expeditiously complete this activity. Other revisions in EPA's analysis, however, show that compliance costs may actually be lower regarding energy penalties than originally forecast.

¹⁸⁹ Grogan, 2000.

Mitigation - 9. DEIS alternatives and proposed action do not present a fair picture of available alternatives.

The Department concurs strongly with this comment. As discussed in the "Mitigation and Alternatives" section earlier in this FEIS, based on the more specific descriptions of newer technologies and recent advances in established technologies discussed in preceding responses, and on discussions in the original DEIS, including DEIS Sections VII and VIII and Appendix VIII, the Department contends that a range of alternatives exist from which site-specific aquatic resource protection programs can be developed which will meet the requirements for BTA. Furthermore, the Department maintains that some of the most promising approaches for existing plants like these three Hudson River facilities will be in combinations of technologies, or technologies combined with improvements to management systems.

Other Topics - 10. The DEIS needs to consider effects of New York's recent conversion to a competitive energy market, take the State Energy Plan into account, or impose parity among facilities.

The concept of parity, or leveling the playing field between two or more separate holders of the same type of permit, is not a Department policy *per se*; nor is it required in law or regulation. For each SPDES permit application that includes a cooling water intake structure, the Department must determine whether the location, design, construction, and capacity of the cooling water intake structure reflects the "best technology available" (BTA) to minimize adverse environmental impact.¹⁹⁰ The Department makes each BTA decision on a case-by-case, site-specific basis, without necessarily applying the technology(s) or methodology(s) to minimize impacts between separate facilities in a rote manner that supports comparisons.¹⁹¹

To make a BTA decision, the Department must assess the proposed action (issuance or renewal of a SPDES permit) against the environmental impacts (direct, indirect and cumulative) and determine whether the applicant's proposed method of addressing impacts outweighs alternative methods. This is necessarily a site-specific endeavor that requires examination of technologies having the potential to "fit" the facility and minimize adverse impacts to the extent warranted by the environmental harm in the source water body. A particular mitigative technology may not produce comparable reductions of impacts between two otherwise comparable facilities. Furthermore, for any particular mitigative technology a success differential is likely to exist between facilities with different types of generation systems, CWIS, and/or cooling systems.

Mandating parity between existing facilities and new facilities subject to BTA determinations would require that an agency be able to resolve inherent difficulties and numerous issues, such as: (a) environmental impacts may not be the same, (b) construction, operation, and maintenance costs may not be the same (even using the same technology), (c) water bodies may be different, (d) public reaction to the project and/or perception of the need for minimization of impacts may be different, and (e) impacts to the State's energy capacity may be different. Such a mandate would also limit a decision maker's flexibility to prescribe BTA remedies within the boundaries of the statute, which does not require parity between facilities or BTA decisions.

In cases where the issues listed above are not present, in other words, where there is a strong basis for comparison between facilities, it is reasonable to expect that similar technologies and associated costs would be involved in prescribing a BTA remedy. However, this does not necessarily translate to "parity" because it is more likely to occur between the same types of facilities (i.e., between existing facilities or new facilities but not between an existing facility and a new facility). The

¹⁹⁰ 33 U.S.C. §1326(b); 6 NYCRR §704.5.

¹⁹¹ Athens Interim Decision

distinguishing issues listed above as examples are more likely to create discrepancies that interrupt attempts to level the playing field between or among separate BTA determinations.

Parity thus does not present itself as a clear component of mitigation remedies in making a BTA determination. That does not prevent a decision making agency from assessing whether the level of costs imposed on an existing facility can generally be measured in terms of costs of mitigative technology installed by other (new or existing) facilities. However, the apparent physical, engineering discrepancies between an existing and a new facility and the potential biological differences between source water bodies militate against direct comparisons of such facilities.

In conclusion, parity is not defined in the context of making a BTA determination. Absent a policy or administrative or judicial decision which identifies an acceptable equation for leveling out inherent discrepancies, the differences between existing and new facilities (and, potentially, the source water bodies) present significant obstacles to imposing parity to make newer, less polluting facilities cost competitive with older facilities.

Other Topics - 11. Radiation discharges are not discussed in the DEIS, but should be.

Under the Atomic Energy Act of 1954 (AEA/1954), authority to regulate nuclear discharges is reserved to the federal government.¹⁹² Discharges of cooling water from Indian Point Units 2 and 3 are regulated by NYS as SPDES discharges to the extent they contain effluent substances regulated pursuant to 6 NYCRR Part 703. Because Indian Point is a nuclear power generating facility, its construction, operation, and maintenance are regulated by the federal Nuclear Regulatory Commission(NRC), pursuant to the AEA/1954.

In 1962, the Atomic Energy Commission (AEC), the NRC's predecessor agency, and then-Governor Nelson A. Rockefeller, executed an "Agreement . . . for Discontinuance of Certain Commission Regulatory Authority" (Agreement). Pursuant to that Agreement the AEC discontinued its regulatory authority over certain radioactive materials ("byproduct materials, source materials, and special nuclear materials in quantities not sufficient to form a critical mass") so that NYS could apply its own licensing program to those substances. However, the AEC retained its licensing authority with respect to, among other things, the construction and operation of any production or utilization facility, including nuclear power generation facilities. Consequently, radioactive releases or discharges from nuclear power generation facilities are regulated, today, by the NRC, not NYS.

Under the authority of the AEA/1954 and 10 CFR Part 50, the NRC issues licenses and license extensions to nuclear power generating facilities and regulates any releases of radioactive material from licensed facilities. The current NRC licenses for Indian Point Unit 2 and Indian Point Unit 3 expire in 2013 and 2015, respectively.¹⁹³ The New York State SPDES permit for Indian Point Units 2 and 3 will control effluent discharges as to all substances controlled by the regulations set forth in 6 NYCRR Part 703 that are not otherwise controlled by the federal NRC authority in 10 CFR Part 50. Thus, the Department does not have the authority to require a SPDES permit renewal application to identify discharges that do not fall within its SPDES jurisdiction.

The 1962 Agreement fostered the creation of a licensing program at the state level for limited purposes where NYS had demonstrated to the AEC that sufficient technical expertise had been developed with regard to a short list of regulated substances. It bears repeating that in 1962, NYS did not undertake to acquire the AEC's authority to license nuclear power generation facilities or any radiation releases or discharges that could be associated with them, nor does NYS presently have or seek to develop the expertise necessary to administer such a licensing program.

¹⁹² Atomic Energy Act of 1954, 42 U.S.C. 2021; see §2021(c)(1).

¹⁹³ Entergy Nuclear Indian Point 2 and Entergy Nuclear Indian Point 3, operators of the respective nuclear generation plants, have stated in the media that they expect to begin the process of NRC license extension in 2006. Department staff understand from an independent inquiry to NRC staff that the 2006 date projected to start license extension is a reasonable one.

As noted above, New York State's SPDES permit renewal process is entirely separate from the federal NRC license extension process. However, the Department does have a role in the NRC license extension process. Because these facilities discharge cooling water into navigable waters of the United States, the Department's role in the NRC license extension proceeding will be to process and issue or deny the licensee's application for a state water quality certificate, pursuant to §401 of the Clean Water Act¹⁹⁴. Obtaining a state water quality certificate is a prerequisite to extending an NRC license. For the NRC to make a decision to grant or deny license extension, Entergy Nuclear Indian Point 2 and Entergy Nuclear Indian Point 3 will need to deliver a NYS water quality certificate to the NRC applicable to both Units 2 and 3. In considering whether to issue or deny a water quality certificate for Indian Point Units 2 and 3, the Department will apply the water quality standards set forth in 6 NYCRR Part 700, et seq.

In light of the foregoing, concerns for possible radioactive releases in the cooling water discharged from Indian Point, or concerns for possible health effects from radioactive emissions, should be addressed directly to the NRC, not the Department, either as a license compliance matter or in the course of license extension proceedings. Such concerns cannot be addressed in conditions to a SPDES permit.

¹⁹⁴ 33 U.S.C. §1341

Other Topics - 12. Several commentors expressed generalized opposition to renewal for one or more facilities.

These comments, while clearly deeply felt, did not raise substantive issues which can be addressed in the context of the issues and information included in this FEIS. Accordingly, no response or analysis is offered.

List of Appendices

Please note that appendices are not available on the website. However, you may request one or more of the appendices by contacting Betty Ann Hughes at bahughes@gw.dec.state.ny.us.

F-I. Notices and Comments on 1999 DEIS

- DEIS Notices
- Full texts of written public comments
- Public hearing transcripts
- Department comments (on CD; hard copy available on request)

F-II. Text of HRSA

F-III. Fourth Amended Consent Order

F-IV. ESSA reports

- On CD; hard copy available on request.

F-V. Other cited references and letters not readily available:

- 1991 letters by former Commissioner Jorling to HRSA utility executives
- Article by John Boreman
- Normandeau Associates, Inc. letter/reports
- Simpson letter
- List of Industrial Code 4911 Facilities in NYS
- On CD; hard copy available on request:
 - ASA 2002 (1999 year class report)
 - City of Poughkeepsie Hudson River Temperature Data (spreadsheet)