

ArevaEPRDCPEm Resource

From: Getachew Tesfaye
Sent: Friday, December 05, 2008 9:49 AM
To: 'usepr@areva.com'
Cc: Clinton Ashley; Christopher Jackson; Michael Miernicki; Joseph Colaccino; John Rycyna; ArevaEPRDCPEm Resource
Subject: U.S. EPR Design Certification Application RAI No. 139 (1566), FSAR Ch. 6
Attachments: RAI_139_SPCV_1566.doc

Attached please find the subject requests for additional information (RAI). A draft of the RAI was provided to you on November 7, 2008, and discussed with your staff on December 3, 2008. No change was made to the draft RAI as a result of that discussions. The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs, excluding the time period of **December 20, 2008 thru January 1, 2009, to account for the holiday season** as discussed with AREVA NP Inc. For any RAIs that cannot be answered **within 45 days**, it is expected that a date for receipt of this information will be provided to the staff within the 45-day period so that the staff can assess how this information will impact the published schedule.

Thanks,
Getachew Tesfaye
Sr. Project Manager
NRO/DNRL/NARP
(301) 415-3361

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 2

Mail Envelope Properties (C56E360E9D804F4B95BC673F886381E717F94BC3F6)

Subject: U.S. EPR Design Certification Application RAI No. 139 (1566), FSAR Ch. 6
Sent Date: 12/5/2008 9:49:07 AM
Received Date: 12/5/2008 9:49:40 AM
From: Getachew Tesfaye

Created By: Getachew.Tesfaye@nrc.gov

Recipients:

"Clinton Ashley" <Clinton.Ashley@nrc.gov>
Tracking Status: None
"Christopher Jackson" <Christopher.Jackson@nrc.gov>
Tracking Status: None
"Michael Miernicki" <Michael.Miernicki@nrc.gov>
Tracking Status: None
"Joseph Colaccino" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"John Rycyna" <John.Rycyna@nrc.gov>
Tracking Status: None
"ArevaEPRDCPEm Resource" <ArevaEPRDCPEm.Resource@nrc.gov>
Tracking Status: None
"usepr@areva.com" <usepr@areva.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	908	12/5/2008 9:49:40 AM
RAI_139_SPCV_1566.doc	28666	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 139 (1566), Revision 0

12/5/2008

U. S. EPR Standard Design Certification

AREVA NP Inc.

Docket No. 52-020

SRP Section: 06.02.02 - Containment Heat Removal Systems

Application Section: FSAR 6.2.2

QUESTIONS for Containment and Ventilation Branch 1 (AP1000/EPR Projects) (SPCV)

06.02.02-18

Consistent with guidance listed in RG 1.82 and GL 2004-02, provide a description of how permanent and temporary modifications to structures, systems, and components inside containment are programmatically controlled so changes to the analytical inputs and assumptions of the licensee analyses ensures ECCS remains in compliance with 10 CFR 50.46 and related regulatory requirements.

06.02.02-19

Regarding programmatic controls taken to limit debris sources in containment, provide a summary of the foreign material exclusion programmatic controls in place to control the introduction of foreign material into the containment.

06.02.02-20

Regarding programmatic controls taken to limit debris sources in containment, provide a description of how maintenance activities including associated temporary changes are assessed and managed in accordance with the Maintenance Rule, 10 CFR 50.65.

06.02.02-21

Regarding programmatic controls taken to limit debris sources in containment, provide a summary of the protective coating programmatic controls in place to control the introduction and use of coating material in containment and address coating deficiencies.