



NRC Workshop on Vendor Oversight for New Reactor Construction

Critical Characteristics: Selection and Verification

Milton Concepcion

Quality and Vendor Inspection Branch 1

Office of New Reactors

December 10, 2008



Agenda

- Commercial-Grade Item (CGI) Dedication Process
- NRC's Perspective on:
 - Technical Evaluations
 - Critical Characteristics
 - Like-For-Like CGI Replacements
 - Equivalency Evaluations
 - Seismic/Environmental Qualification

CGI Dedication Process

- Two principal QA criteria that the CGI dedication process should be designed to meet:
 - Criterion III, "Design Control"
 - Criterion VII, "Control of Purchased Material, Equipment and Services"

CGI Dedication Process (cont'd)

- An acceptable dedication program consists of:
 - Technical Evaluation - identifies
 - Technical requirements
 - Quality requirements
 - Acceptance Method - verifies
 - Technical and quality requirements have been met.

Technical Evaluations

- Identify item's safety function, performance requirements, part functional classification, service conditions.
- Identify **critical characteristics**, including acceptance criteria.
- Identify dedication methods for verification of acceptance criteria.

Technical Evaluations (cont'd)

- Information sources include, but not limited to:
 - Design output documents
 - Supplier technical information
 - Industry technical/operating experience
 - Failure modes and effects analyses (FMEAs)
- Complete documentation / auditable records of rationale, justifications, engineering analyses, etc.

Critical Characteristics (CCs)

- 10 CFR 21.3, “Definitions”
 - Important design, material, and performance characteristics of a CGI (or service) that, once verified, will provide reasonable assurance that the item (or service) will perform its intended safety function.

Critical Characteristics (CCs) (cont'd)

- Basis for Selection of CCs
 - Design, material, performance characteristics
 - Active/passive safety-related functions.
 - Safety/non-safety interfaces.
 - Changes in design, material, or manufacturing process.
 - Number and nature of CCs are based on safety function, application requirements, FMEA, and performance requirements.

Like-for-Like CGI Replacements

Like-for-like CGI replacement: the replacement of an item with an item that is identical.

Source: Generic Letter 91-05, "Licensee Commercial-Grade Procurement and Dedication Programs," April 9, 1991.
NQA-1, Quality Assurance Requirements for Nuclear Facility Applications."

Like-for-Like CGI Replacements

(cont'd)

- Like-for-like criteria:
 - Item is provided from the original equipment manufacturer and has not been subject to design, materials, manufacturing, or nomenclature changes,
or
 - Item was purchased at the same time and from the same supplier,
or
 - Evaluation of item confirms that no changes in the design, materials, or manufacturing process have occurred since procurement of original item.

Like-for-Like CGI Replacements

(cont'd)

- Like-for-like determination may not always be based solely on selection of commercial-grade vendors with items manufactured to meet the same industry standards of the original item.
- If dedicating entity can demonstrate that replacement item is identical, then the safety function, design requirements, and critical characteristics need not be re-determined. **However**, verification of the identified critical characteristics by appropriate dedication method(s) is required to verify acceptability of replacement item.

Equivalency Evaluations

Equivalency evaluation: A technical evaluation performed to confirm that a replacement item (not identical to the original) can satisfactorily perform its intended functions, including its safety functions.

Source: Generic Letter 91-05, "Licensee Commercial-Grade Procurement and Dedication Programs," April 9, 1991. NQA-1, Quality Assurance Requirements for Nuclear Facility Applications."

Equivalency Evaluations (cont'd)

- Equivalency evaluations shall be documented and include the following:
 - Identification of the change(s) in design, material, manufacturing process, configuration, form, fit, or function of the replacement item;
 - Evaluation of the change(s);
 - Confirmation that the change(s) do not adversely affect the current design or safety function of the item.

Equivalency Evaluations (cont'd)

- Equivalency evaluations are not to be used as the sole basis to accept a commercial-grade item. Selection and verification of the identified critical characteristics by an appropriate dedication method(s) is required to verify the acceptability of the replacement item.

Seismic/Environmental Qualification

- The commercial-grade item's functional performance requirements should include design and service conditions (harsh environment, seismic conditions).
- Identify critical characteristics that will provide assurance that seismic and environmental qualification is maintained

Questions/Comments

Contact:

Milton Concepcion

(301) 415-4054

Milton.Concepcion@nrc.gov