



State of New Jersey

DEPARTMENT OF ENVIRONMENTAL PROTECTION
Division of Environmental Safety and Health
Radiation Protection and Release Prevention Element
Bureau of Nuclear Engineering
PO Box 415
Trenton, New Jersey 08625-0415
Phone: (609) 984-7700
Fax: (609) 984-7513

JON S. CORZINE
Governor

LISA P. JACKSON
Commissioner

November 18, 2008

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001

Gentlemen:

Subject: Hope Creek Generating Station (HCGS)
Docket No. 50-354
License Amendment Request (LAR) H08-04

PSEG Nuclear LLC (PSEG) submitted the subject amendment request to the Nuclear Regulatory Commission (NRC) on July 30, 2008. The proposed amendment would revise the applicable Technical Specification Action statement by increasing the allowable outage time from 8 hours to 24 hours for one or two inoperable inverters in one AC power distribution channel.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering reviewed the request in accordance with the requirements of 10 CFR 50.91(b). We have no comments.

If you have any questions, please contact Jerry Humphreys at (609) 984-7469.

Sincerely,

Patrick Mulligan
Manager
Bureau of Nuclear Engineering

A001
NRR

c: P. Bauldauf, New Jersey DEP, Assistant Director
N. McNamara, NRC Region I State Liaison Officer
R. Ennis, NRC Hope Creek Project Manager
B. Welling, NRC Senior Resident Inspector, Hope Creek
M. Gaffney, PSEG Hope Creek Regulatory Assurance
C. Neely, PSEG Director - Regulatory Assurance