


U.S. EPR RLBLOCA Topical Report: Round 3 RAI

***AREVA NP and the NRC
September 10, 2008***

Introduction



***Sandra Sloan
Manager, Regulatory Affairs
New Plants Deployment***



Introduction

- > Background**
- > Meeting objectives**
 - ❖ Describe approach to address 3rd Round RAI**
 - ❖ Obtain NRC feedback on proposed approach**



AREVA RLBLOCA History

- | | |
|---|--------------------------|
| <i>> EMF-2103 Rev. 0 approved</i> | <i>April 2003</i> |
| <i>> U.S. EPR RLBLOCA topical report submitted (based on EMF-2103 Rev. 0)</i> | <i>March 2007</i> |
| <i>> U.S. EPR 1st round RAI issued</i> | <i>July 2007</i> |
| <i>> Transition program definition</i> | <i>Dec. 2007</i> |
| <i>> U.S. EPR 2nd round RAI issued</i> | <i>May 2008</i> |
| <i>> AREVA-NRC meeting to discuss unresolved items</i> | <i>July 2008</i> |
| <i>> U.S. EPR 3rd round RAI issued</i> | <i>Sept. 2008</i> |

Agenda

- > Introduction – Sandra Sloan
- > Discussion of RAI questions
 - ♦ 21 & 29 – Bert Dunn
 - ♦ 22 – Bert Dunn
 - ♦ 30 – Bert Dunn
 - ♦ 31 – Bert Dunn
 - ♦ 24 – Eugene Moore
 - ♦ 25 – Eugene Moore
 - ♦ 26 – Robert Martin
 - ♦ 27 & 28 – Robert Martin
 - ♦ 34 – Robert Martin
 - ♦ 23 – Liliane Schor
 - ♦ 32 – Liliane Schor
 - ♦ 33 – Liliane Schor
- > Summary and next steps – Sandra Sloan

Discussion of RAI Questions: RAI 21 & 29 – Required Case Set for U.S. EPR RLBLOCA Evaluation, LBLOCA Break Size Range



***Bert Dunn
Advisory Engineer, Reactor
Operations & Accident Analysis***

RAI 21 & 29 – Response

- > For the U.S. EPR, AREVA NP will modify the number of case sets run**
 - ♦ **Number of runs in the Case Set = 124**
 - ♦ **Break Spectrum = ANP-10278P = $2 \times A_{\text{pipe}}$ → SBLOCA (10% of A_{pipe})**
 - **Rev. 0 PIRT and modeling designed to cover this break range**
 - **Transition break range to increase break density near critical size**
 - **Spectrum change inappropriate for 124 case set**
- > Separate ordering for PCT, local oxidation, and core oxidation**
- > Tables of results and cumulative densities reported**
- > Statement of compliance will be that the cumulative densities demonstrate that these three criteria of 10CFR50.46 are met with a high degree of probability**

Discussion of RAI Questions: RAI 22 – GDC-35 Requirements

RAI 22 – Response

- > For the U.S. EPR, by design, there is no significant difference in results between the LOOP and non-LOOP case**
 - ◆ ECCS set to minimum either way**
 - ◆ Automatic pump trip on coincident SI signal and low RCP differential pressure (detecting void fraction)**
 - ◆ ECCS delays for non-LOOP condition < LOOP condition**

Discussion of RAI Questions: RAI 30 – Forslund-Rohsenow Heat Transfer Correlation

RAI 30 – Response

- > This issue has been addressed in the transition package as presented in ANP-2695, “Sequoyah Nuclear Plant Unit 1 Realistic Large Break LOCA Analysis,” February 2008**
- > An S-RELAP5 code modification limits the amount of Forslund-Rohsenow heat transfer correlation’s contribution to the film boiling heat transfer calculation to no more than 15% for void fractions above 90%**
- > This is the approach that will be taken for the U.S. EPR RLBLOCA analysis**

Discussion of RAI Questions: RAI 31 – Downcomer Boiling

RAI 31 – Response


- > Downcomer boiling issue**
 - ◆ **Transition package demonstrations**
 - Wall heat release
 - Axial noding sensitivity
 - Azimuthal noding sensitivity
 - Cold leg condensation rates

- > Cold leg condensation is important to the prediction of downcomer boiling phenomena and will be modeled in a new case set**


- > AREVA NP will document transition package sensitivity studies in revised ANP-10278P**

RAI 31 - Cold Leg Condensation Effect

Comparison Results for Low and High Post Accumulator Injection Cold Leg Condensation



Discussion of RAI Questions: RAI 24 – Range of Initial Conditions for Accumulators and IRWST



***Eugene Moore
Safety Analysis Group***

RAI 24 – Response

- > Provide detailed justification for the source of initial pressure, temperature, and volume of accumulators and IRWST**
- > Response will relate to technical specifications and explain relationship between building locations environment and the technical specification values**

RAI 24 – Example Building Ambient Conditions

Temperature, °F		
	Lower	Upper
Analysis Values (Acc., IRWST, Bldg.)	59	122
Technical Specification Values		
Building	59	131
IRWST	59	122
Accumulator Compartment	59	86
Maximum Expected Equipment Compartment Temperatures		
Below 2.3 m (see Note)		86
Between 2.3 - 10 m		104
Between 10 - 18 m		122
Above 18 m		131
Average		122

Note:

Top of IRWST equipment compartment at 0.0 m

Discussion of RAI Questions: RAI 25 – MSRT Partial Cooldown


RAI 25 – Response

> Document rationale for approach


- ❖ **Steam generator is instantaneously isolated at the time of the break**
- ❖ **The secondary side relief or safety valves not modelled because they are not actuated for limiting breaks**
- ❖ **Automatic steam generator partial cooldown to 870 psia (setpoint reached only for break sizes of 1.5 ft² or less, 15% DEGB)**
- ❖ **No depressurization for these smaller breaks is conservative**
- ❖ **Refill of loop seals will only occur at extended times and for pressures much below lowest steam generator pressures**

> Sensitivity studies


RAI 25 – Sensitivity Study Example Maximum PCT Case (65% DEGB)



RAI 25 – Sensitivity Study Example (10% DEGB)



Discussion of RAI Questions: RAI 26 – Reflood Flow Oscillations



***Robert Martin
Advisory Engineer,
Severe Accidents***

RAI 26 - Response


- > **Flow oscillations question to be resolved by building on the technical basis of EMF-2103(P)(A):**
 - ♦ Describe the particular oscillatory phenomena of interest, distinguish between cold-leg accumulator, manometer, and loop SI driven
 - ♦ Identify the analytical and experimental basis
 - ♦ Revisit earlier code-to-data comparisons drawn from existing code assessments (EMF-2102) to address code performance in general and at different scales

- > **Additional sensitivity analysis will examine the influence of various phenomenological contributors on the magnitude of oscillations and clad temperature, including**
 - ♦ Accumulator/SI temperature
 - ♦ Interfacial heat transfer (condensation) – increase in condensation applied for RAI 31 are expected to reduce any clad temperature sensitivity to oscillations
 - ♦ Others, as necessary; however, modification of core inlet resistances is not phenomenologically based; thus, not an appropriate study

- > **Assess sensitivity with appropriate measures (i.e., clad temperature, liquid level, and mass flux)**

RAI 26 – U.S. EPR RLBLOCA

Topical Report Figure A-13, Core Inlet Mass Flux



Discussion of RAI Questions: RAI 27 & 28 – System Pressure Spike on Accumulator Discharge

RAI 27 & 28 – Response

- > Both RAIs are related to post-cover-gas-release transport phenomena (i.e., pressure and clad temperature sensitivity).
A technical basis will be built from:**
 - ♦ Description of the phenomena, decomposed by important process and/or phenomenological contributors
 - ♦ Consolidating original technical basis presented in methodology document (EMF-2103) and developmental assessment document (EMF-2102)
 - ♦ Experiment insights from ISP-25, Achilles; investigate other programs for additional validation, where applicable
 - ♦ Analytical trends from previous RLBLOCA analyses
- > Sensitivity analysis will examine the influence of various phenomenological contributors on the magnitude of pressure increase as the accumulator cover gas escapes the RCS and on clad temperature**
 - ♦ Accumulator size (cover gas volume)
 - ♦ Interfacial heat transfer
 - ♦ Others (e.g., break modeling, steaming rates)

Discussion of RAI Questions: RAI 28 – Achilles Reflood Cooling Comparison

RAI 28 – Response


- > The question of accumulator cover-gas impact on LBLOCA analyses was addressed during the development EMF-2103 Rev. 0.**
- > Address this RAI by:**
 - ♦ Description of the phenomena, decomposed by important process and/or phenomenological contributors**
 - ♦ Consolidating original technical basis presented in methodology document (EMF-2103) and developmental assessment document (EMF-2102)**
 - ♦ Complement with other available test program results reported in EMF-2102, where applicable**

Discussion of RAI Questions: RAI 34 – Limiting Time in Life for LOCA Analyses

RAI 34 – Response

- > The questions on burn-up dependencies (stored energy, rupture) on LBLOCA analyses was addressed during the development of EMF-2103 Rev. 0.**
- > Address this RAI by:**
 - ❖ Description of the phenomena, decomposed by important process and/or phenomenological contributors**
 - ❖ Consolidating original technical basis presented in methodology document (EMF-2103)**
 - ❖ Compare system parameters from earlier analyses to U.S. EPR to disposition application to the U.S. EPR**

Discussion of RAI Questions: RAI 23 – Containment and Input Justification



***Liliane Schor
Supervisor, LOCA Group***

RAI 23 – Response

- > Basic approach will be similar to that of the transition program**
- > ICECON topical, EMF-CC-039, will be provided**
- > Inputs and modeling options for ICECON will be justified consistent with the transition program**

RAI 23 – Examples from Containment Analysis

- > Heat structures modeled conservatively
- > Heat sink surface area increased by 10%
- > Paint modeled as substrate
- > No air gap to liner
- > Free volume sampled from expected to large limit (lower transient pressure response)
- > Containment temperature sampled over technical specification range
- > Humidity set to 1.0
- > Condensing heat transfer coefficient (1.7 Uchida, transition program)
- > Spilled ECCS mixed with containment atmosphere

Discussion of RAI Questions: RAI 32 – Rod-to-Rod Radiation

RAI 32 – Response


- > The transition program addressed this issue by comparison of expected plant radiation heat transfer to radiation heat transfer in the FLECHT-SEASET benchmarks**
 - ♦ Rod-to-rod radiation increases above that subtended in the convective heat transfer modeling as cladding temperature approaches limiting values (>1700 F)**
 - ♦ Current treatment is conservative at limiting PCTs**
- > RAI response will provide justification consistent with the transition program**

Discussion of RAI Questions: RAI 33 – Decay Heat


RAI 33 – Response

- > Provide justification for EMF-2103 Rev. 0 method**
- > In accordance with Regulatory Guide 1.157, calculate the decay heat based on the 1979 ANSI/ANS standard**
- > The standard is applied conservatively**
 - ♦ Infinite operating time at full power**
 - ♦ All fissions assumed from U-235**
- > Uncertainty sampling base - 1979 ANSI/ANS standard**
 - ♦ Gaussian distribution**
 - Mean = 1.0**
 - Standard deviation = 3%**

RAI 33 – Comparison 1979 $\pm 2\sigma$ with ORIGIN-2




RAI 33 – PCT vs. Decay Heat Ratio (Equilibrium Cycle)



RAI 33 – Response Conclusion

- > For this equilibrium cycle calculation set, the limiting case is a blowdown peak, which minimizes the importance of decay heat (sampled multiplier ~ 0.96)**
- > The decay heat sampled values range from ~ -2.5 to +2.5 σ**
- > The 2nd, 3rd, and 4th cases sample above 1.0**
- > For other calculational sets the limiting PCT could occur for multiplier > 1.0**
 - ♦ The first core calculational set has a multiplier of ~ 1.05 for the limiting PCT case**
- > The current approach to decay heat is consistent with CSAU and Regulatory Guide 1.157**

Summary and Next Steps



Sandra Sloan

Summary and Next Steps

- > Resolution strategy identified for each RAI question**
- > AREVA to address 3rd round RAIs as described**
- > AREVA to keep NRC apprised of progress and identify appropriate opportunities for future meetings**
- > AREVA to provide:**
 - ◆ RAI responses**
 - ◆ Topical Report revision**
 - ◆ FSAR markups (as appropriate)**