PMHarrisCOL PEmails

From: Manny Comar
Sent: Thursday, October 23, 2008 8:27 AM
To: HarrisCOL Resource
Subject: FW: Geotechnical topic during upcoming audit

From: Manny Comar
Sent: Wednesday, October 22, 2008 5:07 PM
To: robert.kitchen@pgnmail.com
Cc: 'ron.knott@pgnmail.com'
Subject: Geotechnical topic during upcoming audit

Bob:

One of the question that came up during internal discussion at NRC may be added to the agenda for our upcoming audit starting on October 28, 2008. If your staff can answer this question, it would be helpful.

The approximately 20 degree dipping beds underlying HAR Unit 3 result in variable rock strata thickness, variable rock properties at equal elevations, and variable stress conditions within dipping layers across the footprint of the NI and to depths of significant stress increase. Please describe how you accounted for the dipping layered strata in computing the settlement and differential settlement under HAR Unit 3.

Manny Comar
Senior Project Manager
NRO/DNRL/NWE1
Nuclear Regulatory Commission
301-415-3863
mailto:manny.comar@nrc.gov

Hearing Identifier: ShearonHarris_COL_Public
Email Number: 268

Mail Envelope Properties (3AF7DEF82ADA8944AD8247B7ED7FD6517BFBFF73B3)

Subject: FW: Geotechnical topic during upcoming audit
Sent Date: 10/23/2008 8:26:44 AM
Received Date: 10/23/2008 8:26:46 AM
From: Manny Comar

Created By: Manny.Comar@nrc.gov

Recipients:
"HarrisCOL Resource" <HarrisCOL.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	1059	10/23/2008 8:26:46 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: