



LR-N08-0266
December 11, 2008

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Hope Creek Generating Station
Facility Operating License No. NPF-57
NRC Docket No. 50-354

Subject: Submittal of Relief Request Associated with the Second Inservice
Inspection (ISI) Interval


In accordance with 10 CFR 50.55a, "Codes and standards," paragraph (g)(5)(iii), PSEG Nuclear LLC (PSEG) hereby requests NRC approval of the attached request for the second 10-year inservice inspection (ISI) interval for the Hope Creek Generating Station which ended on December 12, 2007. The request addresses examination limitations for exams performed in accordance the requirements of the American Society of Mechanical Engineering (ASME) Boiler and Pressure Vessel Code, Section XI for Class 1 and 2 components.

PSEG requests approval of this request by December 12, 2009.

There are no commitments in this letter or attachment.

If you have any questions or require additional information, please contact Mr. Paul Duke at 856-339-1466.

Sincerely,



Jeffrey Keenan
Manager - Licensing
PSEG Nuclear LLC

Attachment: 10 CFR 50.55a Request HC-I2-RR-A25

A047
NRR

LR-N08-0266
December 11, 2008
Page 2

cc: S. Collins, Regional Administrator – NRC Region I
R. Ennis, Project Manager - USNRC
NRC Senior Resident Inspector - Hope Creek
P. Mulligan, Manager IV, NJBNE

10 CFR 50.55a Request Number: HC-I2-RR-A25

Relief Request In Accordance With 10 CFR 50.55a(g)(5)(iii)
Inservice Inspection Impracticality

NOTE:

Hope Creek Second Ten-Year Interval Inservice Inspection (ISI) examinations were conducted between December 13, 1997 (start) and December 12, 2007 (end).

NRC Approved (Yes or No): _____ Date _____

1. ASME Code Component(s) Affected

Code Class:	1, 2
Reference:	IWB-2200, IWB-2500, IWC-2500, Code Case N-578-1 paragraph -2500 Code Case N-460
Examination Categories:	B-A, B-D, B-G-1, B-J, C-G, R-A
Item Numbers:	See Table 1
Description:	Volumetric and surface examination coverage
Component ID:	See Table 1

2. Applicable Code Edition and Addenda

The code of record for the start of the Hope Creek Generating Station (HCGS) Second Ten-Year ISI Program interval is Section XI of the ASME Code, 1989 Edition, without Addenda. Beginning with the Third Period of the interval, PSEG elected to perform a mid-interval update to the 1998 Edition through 2000 Addenda. (Reference 2)

Also commencing with the Third Period of the interval, PSEG invoked a Risk-Informed Inservice Inspection (RISI) program based on EPRI Topical Report TR-112657, Rev. B-A methodology, which was supplemented by Code Case N-578-1. (Reference 3) The first outage of the Third Period was RF12.

3. Applicable Code Requirement

ASME Section XI, 1989 Edition, and 1998 Edition 2000 Addenda, requires examinations on components and welds as specified in Table IWB-2500-1 and IWC-2500-1. Code

10 CFR 50.55a Request Number: HC-I2-RR-A25

Case N-578-1 requires examinations on risk-informed piping as specified in Table 1 of the Code Case.

PSEG invoked ASME Section XI Code Case N-460, "Alternative Examination Coverage for Class 1 and Class 2 welds, Section XI Division 1." Code Case N-460 states in part, "... when the entire examination volume or area cannot be examined due to interference by another component or part geometry, a reduction in examination coverage on any Class 1 or Class 2 weld may be accepted provided the reduction in coverage for that weld is less than 10%." ASME Code Case N-460 is approved for use by the NRC in Regulatory Guide (RG) 1.147, Revision 15, "Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1."

The exam categories for this relief request are B-A, B-D, B-G-1, B-J, C-G, and R-A. The applicable code requirements for the relevant item numbers are as follows.

A. Exam Category B-A Pressure Retaining Welds in Reactor Vessels

Code Requirement: Item B1.12 requires essentially 100% volumetric examination, as defined by Figure IWB-2500-2, of all longitudinal reactor pressure vessel (RPV) shell welds. Item B1.40 requires essentially 100% of the head-to-flange weld as defined by Figure IWB-2500-5.

B. Exam Category B-D Full Penetration Welds of Nozzles in Vessels

Code Requirement: Item B3.90 requires essentially 100% volumetric examination, as defined by Figures IWB-2500-7 a through d, of the reactor vessel nozzle-to-vessel welds.

C. Exam Category B-G-1 Pressure Retaining Bolting Greater Than 2 Inches in Diameter

Code Requirement: Item B6.40 requires essentially 100% volumetric examination, as defined by Figure IWB-2500-12, of reactor vessel threads in flange.

D. Exam Category B-J Pressure Retaining Piping Welds

Code Requirement: Items B9.11 and B9.31 require essentially 100% volumetric and surface examinations, as defined by Figures IWB-2500-8, -9, -10, or -11, as applicable, for piping circumferential and branch connection welds.

E. Exam Category C-G Pressure Retaining Welds in Pumps and Valves

Code Requirement: Item C6.10 requires either inside or outside surface examination, as defined by Figure IWC-2500-8 for pump casing welds, including

10 CFR 50.55a Request Number: HC-I2-RR-A25

100% welds in all components in each piping run examined under Examination Category C-F.

F. Exam Category R-A Risk Informed Piping Examinations

Code Requirement: Item R1.20 requires essentially 100% volumetric exams as defined by Figure IWB-2500-8(c). Additionally, the exam volume is expanded to include the area ½ inch beyond each side of the base material thickness transition or counterbore.

4. Basis for Relief:

Pursuant to 10CFR50.55a(g)(5)(iii), relief is requested from ASME XI examination requirements for the performance of certain piping and vessel welds due to exam limitations. Table 1 herein identifies those inservice inspection nondestructive examinations contained within the Hope Creek ISI Program Long Term Plan for the Second Ten-Year Interval whose NDE exams were found to be inaccessible, physically limited or partially obstructed and therefore not capable of fully meeting code coverage requirements for examination extent. Attachment 1 provides additional descriptive details (sketches, illustrations, and/or drawings) for these components.

Subject components contained herein have received inservice inspection NDE examinations to the "extent practical" within the limitations of design, geometry and materials of construction of the components as allowed by Code. These components have also undergone necessary volumetric examination by radiography and/or surface examinations during fabrication, in accordance with approved construction/fabrication code requirements providing adequate assurance for the structural integrity of the components prior to plant operation. In addition, ASME Class 1 and Class 2 components, identified in Table 1, have been subjected to a visual leakage examination either after a completion of each refueling outage (Class 1 components) or during each inspection period (Class 2 component). This provides additional assurance that the structural integrity of the subject components was maintained.

PSEG has implemented Appendix VIII, "Performance Demonstration for Ultrasonic Examination Systems," of the ASME Code, Section XI, 1995 Edition with the 1996 Addenda in accordance with the November 22, 1999 revision of 10CFR50.55a. This provided new nondestructive examination requirements for reactor pressure vessel and Class 1 and 2 piping system welds. This resulted in revised coverage calculation methodologies that further reduced the credited examination coverage of those applicable components.

A. Exam Category B-A Pressure Retaining Welds in Reactor Vessels

Table 1 identifies the specific component information, description of the limitation, and a Figure for the configuration.

10 CFR 50.55a Request Number: HC-I2-RR-A25

Relief was previously granted in Hope Creek relief request RR-B1, Part A (TAC NO. MA2026) SER dated February 3, 2000 for the reactor vessel longitudinal weld seams examination coverage of at least 78%. This coverage was based on performing the examination from outside the reactor vessel as was the case for the first interval. The examination for the second interval was performed from inside the reactor vessel and less coverage was attained.

Impracticality Of Compliance: Code required coverage is impractical for the identified subject components due to the head flange configuration preventing ultrasonic examination from the flange side of the head flange weld, and proximity of core spray internal piping and feedwater spargers to the reactor vessel longitudinal weld seams limiting access to the weld seams.

Burden Caused By Compliance: The reactor vessel longitudinal weld seams were examined from inside the reactor vessel. Additional coverage could have been obtained if the inspection was performed from outside the reactor vessel but this would cause additional radiation dose to obtain access to the weld and to examine the weld.

To obtain full coverage of the flange, the Reactor Pressure Vessel (RPV) would require design modifications. This would impose a significant burden to PSEG.

Proposed Alternative And Basis For Use: No alternative provisions are practical for the subject welds. Examinations were performed to the maximum extent practical with no reportable indications.

Subject components have been subjected to a visual leakage examination after completion of each refueling outage. The head flange was also fully examined by MT with no reportable indications. These exams provide additional assurance that the structural integrity of the subject components was maintained.

B. Exam Category B-D Full Penetration Welds of Nozzles in Vessels – Inspection Program B

Table 1 identifies the specific component information, description of the limitation, and a Figure for the configuration.

Impracticality Of Compliance: Code required coverage is impractical for the subject components due to nozzle configuration and therefore portions of the Code required examination volume can not be completely examined with ultrasonic techniques. The curvature of the blend radius of nozzle forgings prevents ultrasonic scanning of the weld from the nozzle side.

Burden Caused By Compliance: Altering the reactor vessel or nozzle configuration would require design modifications that would impose a significant burden to PSEG.

10 CFR 50.55a Request Number: HC-I2-RR-A25

Proposed Alternative And Basis For Use: No alternative provisions are practical for the subject welds. Examinations were performed to the maximum extent practical with no reportable indications.

Subject components have been subjected to a visual leakage examination after completion of each refueling outage. This provides additional assurance that the structural integrity of the subject components was maintained.

C. Exam Category B-G-1 Pressure Retaining Bolting Greater Than 2 Inches in Diameter

Table 1 identifies the specific component information, description of the limitation, and a Figure for the configuration.

Impracticality Of Compliance: Code required coverage is impractical for the identified subject component due to head flange configuration. The ultrasonic examination of the threads in the flange is performed on the exposed carbon steel reactor vessel flange around the stud holes. The flange has stainless steel cladding from the inside surface of the vessel to approximately 3/8 inch from the stud hole. The ultrasonic transducer does not have access to this small area of the exposed carbon steel flange between the stud hole and the cladding.

Burden Caused By Compliance: Altering the head flange design or bolting configuration would require design modification that would impose a significant burden on PSEG.

Proposed Alternative And Basis For Use: No alternative provisions are practical for the subject component. Examinations were performed to the maximum extent practical with no reportable indications.

Subject component has been subjected to a visual leakage examination after completion of each refueling outage. This provides additional assurance that the structural integrity of the subject component was maintained.

D. Exam Category B-J Pressure Retaining Piping Welds

Table 1 identifies the specific component information, description of the limitation, and a Figure for the configuration.

Impracticality Of Compliance: Code required coverage is impractical for the identified subject components due to reducing tee configuration, branch piping configuration, valve and flange configuration, weld crown contours, weld-o-let configuration, sock-o-let configuration, and a pipe support. These issues limit or prevent full examination of the subject weld.

10 CFR 50.55a Request Number: HC-I2-RR-A25

Burden Caused By Compliance: Altering these components would require design modifications that would impose a burden on PSEG from a cost and radiation dose perspective.

Proposed Alternative And Basis For Use: No alternative provisions are practical for the subject welds. Examinations were performed to the maximum extent practical with no reportable indications.

Subject components have been subjected to a visual leakage examination after completion of each refueling outage. Also all components, except for one that was limited by a pipe support, were also fully examined by PT with no reportable indications. This provides additional assurance that the structural integrity of the subject components was maintained.

E. Exam Category C-G Pressure Retaining Welds in Pumps and Valves

Table 1 identifies the specific component information, description of the limitation, and a Figure for the configuration.

Relief was previously granted in Hope Creek relief request RR-C1, Part C (TAC NO. MA2026) SER dated February 3, 2000.

Impracticality Of Compliance: A major portion of the Core Spray Pump Casing Weld, CP 206-CSP-W2 is embedded in the concrete pump pedestal. Relief Request RR-C1, Part C, for the second inspection interval requested relief for 73% coverage for this weld. This coverage was based on the first interval data sheets reporting 73% coverage. Subsequent review of the first interval data sheets showed that the exam was 73% limited due to inaccessibility because of the pump pedestal. The second interval examination of this weld achieved 23.4% coverage due to the concrete pump pedestal obstruction.

Burden Caused By Compliance: Altering this component would require a design modification that would impose a burden on PSEG from a cost and radiation dose perspective.

Proposed Alternative And Basis For Use: No alternative provisions are practical for the subject weld. Examinations were performed to the maximum extent practical with no reportable indications.

The subject component has been subjected to a visual leakage examination during each period of the interval. This provides additional assurance that the structural integrity of the subject component was maintained.

10 CFR 50.55a Request Number: HC-I2-RR-A25

F. Exam Category R-A Risk Informed Piping Examinations

Table 1 identifies the specific component information, description of the limitation, and a Figure for the configuration.

Impracticality Of Compliance: Code required coverage is impractical for the identified subject components due to weld-o-let configuration, pipe to flange configuration, valve taper configuration, and a weld crown condition. These issues limit the examination of the subject weld.

Burden Caused By Compliance: The required ASME Code coverage is impractical for the subject welds since the components would require design modifications that would impose a significant burden to PSEG.

Proposed Alternative And Basis For Use: No alternative provisions are practical for the subject welds. Examinations were performed to the maximum extent practical with no reportable indications.

Subject components have been subjected to a visual leakage examination after completion of each refueling outage. This provides additional assurance that the structural integrity of the subject components was maintained.

5. Duration of Proposed Alternative

The End of Interval Relief is requested for the Second Ten-Year Inspection Interval for Hope Creek Generating Station, which ended on December 12, 2007.

6. Precedents:

As part of the submission of the Hope Creek second 10-year interval ISI program plan and associated relief requests, limitations relief requests RR-B1 and RR-C1 were submitted. In the Safety Evaluation of that submission, relief was granted for relief requests RR-B1, parts A, B, C, D, and F, and RR-C1, parts A, B, and C, for the Hope Creek second 10-year interval (Reference 1).

7. References:

- 1) Safety Evaluation Of Relief Requests For Second 10-Year Interval For Inservice Inspection Program – Hope Creek Generating Station (TAC No. MA2026), February 3, 2000
- 2) Letter, LR-N04-0420, from Christina L. Perino (PSEG Nuclear LLC) to USNRC, Update ASME XI Code of Record, dated October 29, 2004
- 3) Hope Creek Generating Station – Implementation Of a Risk-Informed Inservice Inspection Program (TAC No. MC2221), December 8, 2004

Table 1
Hope Creek Generating Station
RR#: HC-I2-RR-A25
2nd ISI Interval Exam Limitations

Sum#	Component ID	Description	ASME Cat	ASME Item #	ASME Class	Limited NDE Exam	Code Coverage Achieved	Exam Outage	Figure	Required Examination Volume	Limitation Description
100055	RPV1-W12-1	LONGITUDINAL SEAM AT 110 DEG	B-A	B1.12	1	UT	71.40%	RF14	1	>90%	Examined from the inside surface. Examination limited due to proximity of core spray internal piping & feedwater spargers.
100060	RPV1-W12-2	LONGITUDINAL SEAM AT 230 DEG	B-A	B1.12	1	UT	70.00%	RF14	2	>78% RR-B1	Examined from the inside surface. Examination limited due to proximity of core spray internal piping & feedwater spargers. Required volume from approved relief request RR-B1
100065	RPV1-W12-3	LONGITUDINAL SEAM AT 350 DEG	B-A	B1.12	1	UT	71.50%	RF14	3	>78% RR-B1	Examined from the inside surface. Examination limited due to proximity of core spray internal piping & feedwater spargers. Required volume from approved relief request RR-B1
100145	RPV1-W20	HEAD TO FLANGE	B-A	B1.40	1	UT	70.23%	RF09 RF11 RF13	4	>90%	UT exams limited due to head flange configuration. No UT scan from flange side. Full coverage was attained during MT exam.
100200	RPV1-N2B	NOZZLE TO SHELL WELD 12" RECIRC INLET AT 60 DEG	B-D	B3.90	1	UT	77.45%	RF09	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100205	RPV1-N2C	NOZZLE TO SHELL WELD 12" RECIRC INLET AT 90 DEG	B-D	B3.90	1	UT	77.45%	RF09	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100235	RPV1-N2J	NOZZLE TO SHELL WELD 12" RECIRC INLET AT 300 DEG	B-D	B3.90	1	UT	77.45%	RF09	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100240	RPV1-N2K	NOZZLE TO SHELL WELD 12" RECIRC INLET AT 330 DEG	B-D	B3.90	1	UT	77.45%	RF09	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100265	RPV1-N4A	NOZZLE TO SHELL WELD	B-D	B3.90	1	UT	75.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100270	RPV1-N4B	NOZZLE TO SHELL WELD	B-D	B3.90	1	UT	75.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100275	RPV1-N4C	NOZZLE TO SHELL WELD	B-D	B3.90	1	UT	71.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100280	RPV1-N4D	NOZZLE TO SHELL WELD	B-D	B3.90	1	UT	75.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100285	RPV1-N4E	NOZZLE TO SHELL WELD	B-D	B3.90	1	UT	75.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100290	RPV1-N4F	NOZZLE TO SHELL WELD	B-D	B3.90	1	UT	71.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100295	RPV1-N5A	NOZZLE TO SHELL WELD 10" CORE SPRAY INLET AT 120 DEG	B-D	B3.90	1	UT	77.45%	RF09	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100300	RPV1-N5B	NOZZLE TO SHELL WELD 10" CORE SPRAY INLET AT 240 DEG	B-D	B3.90	1	UT	77.45%	RF09	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100320	RPV1-N8A	NOZZLE TO SHELL JET INSTRUMENTATION	B-D	B3.90	1	UT	75.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100325	RPV1-N8B	NOZZLE TO SHELL 4" JET INSTRUMENTATION	B-D	B3.90	1	UT	75.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100330	RPV1-N9A	NOZZLE TO SHELL WELD 4" CRD HYDRAULIC RETURN	B-D	B3.90	1	UT	77.45%	RF09	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100400	RPV1-N17A	NOZZLE TO SHELL AT 45 DEG	B-D	B3.90	1	UT	75.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100401	RPV1-N17B	NOZZLE TO SHELL AT 135 DEG	B-D	B3.90	1	UT	75.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100403	RPV1-N17D	NOZZLE TO SHELL AT 315 DEG	B-D	B3.90	1	UT	75.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100404	RPV1-N6A	NOZZLE TO HEAD HEAD SPRAY NOZZLE	B-D	B3.90	1	UT	75.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100405	RPV1-N6B	NOZZLE TO HEAD SPARE HEAD NOZZLE	B-D	B3.90	1	UT	75.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.

Table 1
Hope Creek Generating Station
RR#: HC-I2-RR-A25
2nd ISI Interval Exam Limitations

Sum#	Component ID	Description	ASME Cat	ASME Item #	ASME Class	Limited NDE Exam	Code Coverage Achieved	Exam Outage	Figure	Required Examination Volume	Limitation Description
100406	RPV1-N7	NOZZLE TO HEAD VENT NOZZLE	B-D	B3.90	1	UT	75.00%	RF12	5	>90%	UT limited due to nozzle configuration. Examined from the shell side only due to blend radii limiting nozzle side scan.
100880	RPV1-THDF	THREADS IN FLANGE	B-G-1	B6.40	1	UT	75.00%	RF14	6	>90%	UT limited due to flange configuration.
105890	1-BB-28VCA-013-6-R2	PIPE TO REDUCING TEE	B-J	B9.11	1	UT	50.00%	RF10	7	>90%	UT limited due to reducing tee configuration. Single sided access. 100% PT coverage.
108105	1-BC-6DBA-003-21	VALVE TO FLANGE	B-J	B9.11	1	UT	33.33%	RF10	8	>90%	UT limited due to configuration of valve and flange. 100% PT coverage.
109170	1-BC-12CCA-116-5	PIPE TO REDUCING TEE	B-J	B9.11	1	UT	80.20%	RF09	9	>90%	UT limited due to tee configuration and weld contour. 100% PT coverage.
110200	1-BG-4CCA-012-1	WELDOLET TO PIPE	B-J	B9.11	1	UT	50.00%	RF10	10	>90%	UT limited due to weld-o-let configuration. No exam upstream. Single sided access. 100% PT coverage.
110230	1-BG-4CCA-011-1	WELDOLET TO PIPE	B-J	B9.11	1	UT	50.00%	RF10	11	>90%	UT limited due to weld-o-let configuration. No exam upstream. Single sided access. 100% PT coverage.
110432	1-FC-4DBA-003-7A	PIPE TO FLOW ELEMENT	B-J	B9.11	1	UT	67.90%	RF09	12	>90%	UT limited due to sock-o-let configuration and weld contour. 100% PT coverage.
110433	1-FC-4DBA-003-7B	FLOW ELEMENT TO PIPE	B-J	B9.11	1	UT	76.20%	RF09	12	>90%	UT limited due to weld crown configuration. 100% PT coverage.
110475	1-FC-4DBA-003-16	ELBOW TO PIPE	B-J	B9.11	1	MT UT	51.846% 26.05%	RF10	13	>90%	MT exam and UT limited due to pipe support.
106080	1-BB-22VCA-013-3BC1	12-IN BRANCH CONNECTION	B-J	B9.31	1	UT	75.00%	RF10	14	>90%	UT limited due branch piping configuration resulting in single sided access. 100% PT coverage.
106125	1-BB-22VCA-013-3BC2	12-IN BRANCH CONNECTION	B-J	B9.31	1	UT	75.00%	RF10	15	>90%	UT limited due branch piping configuration resulting in single sided access. 100% PT coverage.
106910	1-BB-22VCA-014-1BC1	12-IN BRANCH CONNECTION	B-J	B9.31	1	UT	75.00%	RF10	16	>90%	UT limited due branch piping configuration resulting in single sided access. 100% PT coverage.
106955	1-BB-22VCA-014-1BC2	12-IN BRANCH CONNECTION	B-J	B9.31	1	UT	75.00%	RF10	17	>90%	UT limited due branch piping configuration resulting in single sided access. 100% PT coverage.
107025	1-BB-22VCA-014-3BC2	12-IN BRANCH CONNECTION	B-J	B9.31	1	UT	75.00%	RF10	18	>90%	UT limited due branch piping configuration resulting in single sided access. 100% PT coverage.
250130	CP 206-CSP-W2	CORE SPRAY PUMP - PUMP CASING WELD	C-G	C6.10	2	PT	23.40%	RF09	19	>73.0% RR-C1	PT limited due to a concrete pump pedestal obstruction. Required volume from approved relief request RR-C1
105585	1-BB-4VCA-011-1-R1	BRANCH CONNECTION TO PIPE	R-A	R1.20	1	UT	50.00%	3/30/05	20	>90%	UT limited due to weld-o-let configuration. Pre-service exam followed a repair during a forced outage. Supplemented by construction RT.
105790	1-BB-4VCA-012-1-R1	BRANCH CONNECTION TO PIPE	R-A	R1.20	1	UT	50.00%	4/3/05	21	>90%	UT limited due to weld-o-let configuration. Pre-service exam followed a repair during a forced outage. Supplemented by construction RT.
109810	1-BG-6DBA-001-29	PIPE TO VALVE	R-A	R1.20	1	UT	58.07%	RF12	22	>90%	UT limited due to valve taper configuration and weld crown.


Request Number HC-I2-RR-A25

Figure 1




IHI SOUTHWEST TECHNOLOGIES
RPV EXAMINATION - OCTOBER 2007
HOPE CREEK GENERATING STATION - RF14

Examination Location & Coverage Map for Weld No. RPV1-W12-1



Transverse Exams



Parallel Exams


Request Number HC-I2-RR-A25

Figure 2




IHI SOUTHWEST TECHNOLOGIES
RPV EXAMINATION - OCTOBER 2007
HOPE CREEK GENERATING STATION - RF14

Examination Location & Coverage Map for Weld No. RPV1-W12-2



Transverse Exams



Parallel Exams


Request Number HC-I2-RR-A25

Figure 3




IHI SOUTHWEST TECHNOLOGIES
RPV EXAMINATION - OCTOBER 2007
HOPE CREEK GENERATING STATION - RF14

Examination Location & Coverage Map for Weld No. RPV1-W12-3




Transverse Exams



Parallel Exams

Figure 4

Limitation Due to Reactor Vessel Closure Head to Flange Configuration



Request Number HC-I2-RR-A25
Figure 5

Limitation Due to Nozzle Configuration (Typical)







Figure 6

Threads in RPV Flange Limitation Due to Cladding



/// SCAN AREA LIMITATION

REF. DWG.: KU-1-159-414 DETAIL "B"

Limitation Due to Reducing Tee Configuration


FRAMATOME ANP		PROFILE AND THICKNESS				
Exam Date: 10/13/01		Summary No.: 105890				
Site: Hope Creek, RFO 10		Examination Method: UT				
System: Nuclear Boiler and Recirculation		Identification: 1-BB-28VCA-013-6-R2				
POSITION	0	90	180	270		
1	1.38"	N/A	N/A	N/A	CROWN HEIGHT: 0.02"	
2	1.38"	N/A	N/A	N/A	CROWN WIDTH: 1.30"	
3	1.34"	N/A	N/A	N/A	NOM DIAMETER: 28.0"	
4	1.38"	N/A	N/A	N/A	WELD LENGTH: 92.0"	
5	N/A	N/A	N/A	N/A		

Limited EXAM Due to Reducing tee Configuration
 50% Code Required Volume
 = Limitation
 = AREA


FACTORY MUTUAL
INSURANCE COMPANY
Contract No. 1036/01

Prepared By: <i>Bob Keller</i> Date: 10.14.01	Reviewed By: <i>Bob Keller</i> Date: 10/19/01	Utility Review By: <i>Walter Darling</i> Date: 10/23/01
--	--	--

Limitation Due to Valve and Flange Configuration



FRAMATOME ANP		PROFILE AND THICKNESS				
Exam Date: 10/18/01		Summary No.: 108105				
Site: Hope Creek, RFO 10		Examination Method: UT				
System: Residual Heat Removal System Piping		Identification: 1-BC-6DBA-003-21				
POSITION	0	90	180	270		
1	N/A	N/A	N/A	N/A	CROWN HEIGHT:	0.10"
2	N/A	N/A	N/A	N/A	CROWN WIDTH:	1.00"
3	0.53"	N/A	N/A	N/A	NOM DIAMETER:	6.00"
4	N/A	N/A	N/A	N/A	WELD LENGTH:	21.50"
5	N/A	N/A	N/A	N/A		
<p>Scanned Clockwise AND Counter clockwise on weld only 33% Coverage of Total weld Volume attained</p> 						
Prepared By: <i>David T. Haddock</i> 10-19-01		Reviewed By: <i>Bill Kropf</i> 10-19-01		Utility Review By: <i>William D. Haddock</i> 10-24-01 5/5		
Date		Date		Date		

Limitation Due to Tee Configuration and Weld Contour



**Request Number HC-I2-RR-A25
Figure 10**

Limitation Due to Weld-O-Let Configuration

PROFILE AND THICKNESS	
FRAMATOME ANP Exam Date: 10/17/01	Summary No.: 110200 Examination Method: UT
Site: Hope Creek, RFO 10	
System: Reactor Water Cleanup System Piping	
POSITION 0	90 N/A
1	N/A N/A
2	N/A N/A
3	0.24" N/A
4	0.23" N/A
5	0.23" N/A
CROWN HEIGHT: Flush CROWN WIDTH: 0.50" NOM DIAMETER: 4.0" WELD LENGTH: 14.25"	
Identification: 1-BG-4CCA-012-1	
	
<p><i>No Examination Upstream Weld-O-Let Configuration</i></p>	
	
FACTORY MUTUAL INSURANCE COMPANY <i>10/24/01</i>	
Prepared By <i>[Signature]</i> Date 10-18-01	Reviewed By <i>[Signature]</i> Date 10/24/01
Utility Review By <i>[Signature]</i> Date 10/24/01	

**Request Number HC-I2-RR-A25
Figure 11**

Limitation Due to Weld-O-Let Configuration


		PROFILE AND THICKNESS										
		<div style="display: flex; justify-content: space-between;"> <div>Exam Date: 10/17/01</div> <div>Summary No.: 110230</div> </div>										
Site: Hope Creek, RFO 10		Examination Method: UT										
		Identification: 1-BG-4CCA-011-1										
System: Reactor Water Cleanup System Piping												
POSITION	0							90	180	270		
1	N/A							N/A	N/A	N/A	CROWN HEIGHT: 0.03"	
2	N/A							N/A	N/A	N/A	CROWN WIDTH: 0.55"	
3	0.23"							N/A	N/A	N/A	NOM DIAMETER: 4.0"	
4	0.23"							N/A	N/A	N/A	WELD LENGTH: 14.3"	
5	0.24"	N/A	N/A	N/A								
		No SCANN UPSTREAM DUE TO WELDOLET 50% Coverage of Code-REQUIRED EXAMINATION										
		FACTORY MUTUAL INSURANCE COMPANY <i>Cable Days 10/28/01</i>										
Prepared By		10.18.01		Date		Reviewed By						
10.18.01		Date		Utility Review By		Date						
10.18.01		Date		10.26.01		Date						

Request Number HC-I2-RR-A25
Figure 12

Limitation Due to Sock-O-Let Configuration and Weld Contour

% of Code Required Volume Calculated
from the 70% For the axial Direction


1-FC-4DBA-003-7A
1-FC-4DBA-003-7B




TDC
70%

AREA COVERED WITH 70%
VOLUME NOT COVERED WITH 70%

1-FC-4DBA-003-7A
1-FC-4DBA-003-7B



TDC
45%



CIRC SCANN Performed with 45°


1-FC-4DBA-003-7A

REVIEWED & ACCEPTED
FACTORY-MUTUAL
ENGINEERING ASSOCIATION
DATE 5-16-00

Page 6 of 6
Baker-Hughes

Request Number HC-I2-RR-A25
Figure 13




Limitation Due to Pipe Support



Sw. R.I. STRAIGHT BEAM LAMINATION EXAMINATION RECORD

ILLUMINATION AREA LIMITATIONS: (IF NONE, SO STATE): NONE
no exam on branch convection due to configuration.


Limitation Due to Branch Piping Configuration

		PROFILE AND THICKNESS				
		Summary No.: 106125				
Site: Hope Creek, RFO 10		Examination Method: UT				
System: Nuclear Boiler and Recirculation		Identification: 1-BB-22VCA-013-3BC2				
POSITION	0	90	180	270		
1	1.10"	1.20"	1.10"	1.10"	CROWN HEIGHT: Flush	
2	1.10"	1.20"	1.10"	1.10"	CROWN WIDTH: 1.90"	
3	1.25"	1.30"	1.20"	1.30"	NOM DIAMETER: 22.0"	
4	N/A	N/A	N/A	N/A	WELD LENGTH: 80.0"	
5	N/A	N/A	N/A	N/A		
						
						
Prepared By: <i>David Thelander</i>		Reviewed By: <i>David Thelander</i>		Utility Review By: <i>Wayne Darling</i>		
Date: 11-13-01		Date: 11-13-01		Date: 10-24-01		


Request Number HC-I2-RR-A25
Figure 16

Limitation Due to Branch Piping Configuration

FRAMATOME ANP		PROFILE AND THICKNESS		
Exam Date: 10/14/01		Summary No.: 106910		
Site: Hope Creek, RFO 10		Examination Method: UT		
System: Nuclear Boiler and Recirculation		Identification: 1-BB-22VCA-014-1BC1		
POSITION	0	90	180	270
1	1.10"	N/A	N/A	N/A
2	1.10"	N/A	N/A	N/A
3	1.20"	N/A	N/A	N/A
4	N/A	N/A	N/A	N/A
5	N/A	N/A	N/A	N/A
CROWN HEIGHT: Flush				
CROWN WIDTH: 1.25"				
NOM DIAMETER: 22.0"				
WELD LENGTH: 80.0"				



AREA Not Scanned
= from Branch Connection



FACTORY MUTUAL
INSURANCE COMPANY

Prepared By: *David T. ...* Date: 10-14-01

Reviewed By: *[Signature]* Date: 10-14-01

Utility Review By: *Wayne ...* Date: 10-19-01

**Request Number HC-I2-RR-A25
Figure 17**

Limitation Due to Branch Piping Configuration




FRAMATOME ANP		PROFILE AND THICKNESS				
		Exam Date: 10/14/01				
Site: Hope Creek, RFO 10		Summary No.: 106955				
		Examination Method: UT				
		Identification: 1-BB-22VCA-014-1BC2				
System: Nuclear Boiler and Recirculation						
POSITION	0	90	180	270		
1	1.10"	N/A	N/A	N/A	CROWN HEIGHT: Flush	
2	1.15"	N/A	N/A	N/A	CROWN WIDTH: 1.25"	
3	1.15"	N/A	N/A	N/A	NOM DIAMETER: 22.0"	
4	N/A	N/A	N/A	N/A	WELD LENGTH: 80.0"	
5	N/A	N/A	N/A	N/A		
Factory Mutual Insurance Company						
Prepared By: <i>John Thibault</i> 10-14-01		Reviewed By: <i>DK</i> 10-14-01		Utility Review By: <i>Wagner/Darby</i> 10-14-01		
Date		Date		Date		

Limited Exam
 = from Branch Side of weld
 Axial Scan from UP STREAM
 or PIPE Side only

Branch Connection


Request Number HC-I2-RR-A25
Figure 18

Limitation Due to Branch Piping Configuration

		PROFILE AND THICKNESS		
		Exam Date: 10/13/01	Summary No.: 107025	
Site: Hope Creek, RFO 10		Examination Method: UT		
System: Nuclear Boiler and Recirculation		Identification: 1-BB-22VCA-014-3BC2		
POSITION	0	90	180	270
1	1.10"	N/A	N/A	N/A
2	1.10"	N/A	N/A	N/A
3	1.15"	N/A	N/A	N/A
4	N/A	N/A	N/A	N/A
5	N/A	N/A	N/A	N/A
CROWN HEIGHT: Flush				
CROWN WIDTH: 1.25"				
NOM DIAMETER: 22.0"				
WELD LENGTH: 80.0"				
				
				
<p>Branch Connection</p> <p>Factory Mutual Insurance Company</p> <p><i>Completed 10/24/01</i></p>				
Prepared By: <i>David Zuber</i> Date: 10-24-01		Reviewed By: <i>W. J. [Signature]</i> Date: 10-14-01		
Utility Review By: <i>W. J. [Signature]</i> Date: 10-19-01		Date: 5/18/06		



Request Number HC-I2-RR-A25
Figure 19

Limitation Due to Pump Concrete Pedestal Obstruction





**Request Number HC-I2-RR-A25
Figure 20**

Limitation Due to Weld-O-Let Configuration

		ULTRASONIC EXAMINATION SCAN LIMITATION REPORT													
Customer: PSEG / HC1		System: BB Recirculation Loop "B"													
		Summary No.: 105585													
Component ID: 1-BB-4VCA-011-1-R1		Applicable Report No: UT-04-317, UT-04-318, UT-04-319													
Reference Point: 0°		No examination performed upstream due to the configuration of the branch connection. <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td></td> <td>Upstream Exam %</td> <td>Downstream Exam %</td> </tr> <tr> <td>Axial</td> <td align="center">0%</td> <td align="center">100%</td> </tr> <tr> <td>Circ CW</td> <td align="center">0%</td> <td align="center">100%</td> </tr> <tr> <td>Circ CCW</td> <td align="center">0%</td> <td align="center">100%</td> </tr> </table> (Calculations and/or Comments above) Total Exam Coverage: 50%			Upstream Exam %	Downstream Exam %	Axial	0%	100%	Circ CW	0%	100%	Circ CCW	0%	100%
	Upstream Exam %			Downstream Exam %											
Axial	0%			100%											
Circ CW	0%			100%											
Circ CCW	0%			100%											
1) Interfering Condition Branch Connection															
Distance From Centerline 0.0" To US Side															
Distance From Ref. Point 0.0" CW To 14.50" CW															
2) Interfering Condition NA															
Distance From Centerline NA To NA															
Distance From Ref. Point NA To NA															
3) Interfering Condition NA															
Distance From Centerline NA To NA															
Distance From Ref. Point NA To NA															
(For All Measurements Indicate: US, DS, CW, CCW)															
Sketch Of Limitation(s):															
															
(INCLUDED THE EXTENT OF % COMPLETED OF EXAM AND REASON FOR LIMITED REPORT, AND SKETCH SHOWING AREA OF LIMITATION.)															
Examiner: A A Conti Level: III Date: 03-30-05		Examiner: W J Persinger Level: II Date: 03-30-05													
Reviewer: Bob Kellerhall <i>Bob Kellerhall III</i>		Date: <i>4/7/05</i>													
Customer: John O'Neil <i>John O'Neil</i>		Date: <i>4/7/05</i>													

**Request Number HC-I2-RR-A25
Figure 21**

Limitation Due to Weld-O-Let Configuration

 PSEG Nuclear LLC		ULTRASONIC EXAMINATION SCAN LIMITATION REPORT													
Customer: PSEG / HC1		System: BB Recirculation Loop A													
Summary No.: 105790															
Component ID: 1-BB-4VCA-012-1-R1		Applicable Report No: UT-04-314, UT-04-315, UT-04-316													
Reference Point: 0°		No examination performed upstream due to the configuration of the branch connection.													
1) Interfering Condition Branch Connection															
Distance From Centerline	0.0" To US Side														
Distance From Ref. Point	0.0" CW To 14.50" CW														
2) Interfering Condition NA															
Distance From Centerline	NA To NA														
Distance From Ref. Point	NA To NA														
3) Interfering Condition NA															
Distance From Centerline	NA To NA														
Distance From Ref. Point	NA To NA														
(For All Measurements Indicate: US, DS, CW, CCW)															
		<table border="1"> <thead> <tr> <th></th> <th>Upstream Exam %</th> <th>Downstream Exam %</th> </tr> </thead> <tbody> <tr> <td>Axial</td> <td>0%</td> <td>100%</td> </tr> <tr> <td>Circ CW</td> <td>0%</td> <td>100%</td> </tr> <tr> <td>Circ CCW</td> <td>0%</td> <td>100%</td> </tr> </tbody> </table>			Upstream Exam %	Downstream Exam %	Axial	0%	100%	Circ CW	0%	100%	Circ CCW	0%	100%
	Upstream Exam %	Downstream Exam %													
Axial	0%	100%													
Circ CW	0%	100%													
Circ CCW	0%	100%													
		(Calculations and/or Comments above) Total Exam Coverage: 50%													
Sketch Of Limitation(s):															
															
(INCLUDED THE EXTENT OF % COMPLETED OF EXAM AND REASON FOR LIMITED REPORT, AND SKETCH SHOWING AREA OF LIMITATION.)															
Examiner: Persinger, Walter	Level: II	Date: 04-03-05	Examiner: Crull, Peter												
Reviewer: Kellerhall, Bob	Level: I/HC	Date: 4/2/05	Date: 4/9/05												
Customer: O'Neil, John															

Request Number HC-I2-RR-A25
Figure 22

Limitation due to Valve Taper and Weld Crown

PSEG Nuclear LLC		Weld Thickness & Contour (UT-04-248 Page 3 of 3)	
Summary	109810	Component ID	1-BG-6DBA-001-29
		Description	PIPE TO VALVE
Unit	<input type="checkbox"/> Salem 1 <input type="checkbox"/> Salem 2 <input checked="" type="checkbox"/> Hope Creek	Location	<input checked="" type="checkbox"/> 0° <input type="checkbox"/> 90° <input type="checkbox"/> 180° <input type="checkbox"/> 270°

Photograph

Reviewed & Approved

Date: 11/17/04

NDE Principle Level III

PSEG

Nuclear LLC

CC + CCW ~~71.70~~ 71.53% EXAM Valve Contour 71.53

89.22

89.22% from UPSTREAM

0% from Valve Side

$$\frac{232.28}{4} = 58.07\%$$

CL OF WELD

Flow →

Dimensions			
#	Description	Dim	Comments
T1	<input checked="" type="checkbox"/> Pipe <input type="checkbox"/> Elbow <input type="checkbox"/> Valve <input type="checkbox"/> Tee Upstream	.471"	
T2	Toe of weld upstream	.487"	
T3	Weld Thickness	.558"	
T4	Toe of weld downstream	N/A	
T5	<input type="checkbox"/> Pipe <input type="checkbox"/> Elbow <input checked="" type="checkbox"/> Valve <input type="checkbox"/> Tee Downstream	N/A	
	Limitations (if yes attach photo)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	Is Weld Identification Marked	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	Is Lo Marked	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
	Can weld be visually defined	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

Examined By: Persinger, Walter Date: 11/17/04

NDE Specialist Review: Bob Killehall Date: 11/22/04