TRAINING MATERIAL TITLE:	Plot and Evaluate 1/M Data
TRAINING MATERIAL NUMBER:	2AD-016
PROGRAM TITLE:	Licensed Operator Training
COMPUTER CODE:	2AD-016
REVISION NUMBER:	0

#### **TECHNICAL REFERENCES:**

20M-50.4.F, Perform An ECP Calculation Rev. 7

**INSTRUCTIONAL SETTING**:

Classroom

30 Minutes

APPROXIMATE DURATION:

PREPARED BY:	R. J. Brooks	
<u></u> ,		Date
PEER REVIEW BY:		Date
APPROVED FOR USE:	Training Supervisor or Designee	Date

### TRAINING MATERIAL CHANGE FORM

Affected Training Materials: 2AD-016						
Type of Change:	Type of Change:					
Changes Requiring Revision	Learning Objective Re	lated Change?	New Rev. # 0			
Changes Not Requiring Revision	The Change Does Not Objectives or Material	Impact Learning Quality.	Existing Rev. #			
List/Description of Change(s):						
Reason for Change (s):						
APPROVALS:						
R. J. Brooks Prepared by Training Superintendent/S	upervisor/Peer	Date	<b>NOTE</b> : Additions, deletions or changes to training materials must be reviewed for their possible impact to the Training Qualification Matrix. See			
("Changes Not Requiring	Revision" only)	Duiv	Incumbent Impact Review, NOBP-TR-1104.			

RTL#A5.640U			1/2-ADM-1301.FC Page 3 of 7 Revision t
JPM NUMBER: 2AD-016 JPM REVISION: 0	JPM TITLE: Plot and	Evaluate 1/M Data	
K/A REFERENCE: 2.1.43 4.1/4.3 TASK ID: 0011-003-01-013 JPM APPLICATION: REQUALIFICATION INITIAL EXAM TRAINING FAULTED JPM ADMINISTRATIVE JPM			013
EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED BY:
<ul> <li>Perform</li> <li>Simulate</li> </ul>	<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	BVT NRC Other:

ĩ.

	EVALUATION RESULTS				
Performer Name: Performer SSN:					
Time 🗌 Yes Critical: 🔀 No	Allotted 30 Min	utes	Actual Time:	minutes	
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:					
	OBSERVE	RS			
Name/SSN: Name/SSN:					
Name/SSN: Name/SSN:					
EVALUATOR					
Evaluator (Print): Date:					
Evaluator Signature:					

•

#### **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	Determine that 1/M data predicts >500 pcm below ECP value for critical rod height. Notify SM/US that appropriate actions of 2OM-50.4.D must be taken. (No further rod withdrawal)
RECOMMENDED STARTING LOCATION:	Classroom
<b>DIRECTIONS:</b>	You are to perform the task Evaluate 1/M data
INITIAL CONDITIONS:	The unit is in Mode 2. A reactor startup is in progress. Control Bank C is at 129 steps. Control Bank D is at 1 step. RCS Boron concentration is 1875 ppm.
INITIATING CUE:	The Unit Supervisor directs you to complete the 1/M plot per 2OM- 50.4.F data sheet 3 using the SR count rate data provided. Compare the 1/M data with the predicted ECP data and make a recommendation for further rod withdrawal. Document your recommendation in the box below. (Located on candidate direction sheet )
REFERENCES:	20M-50.4.F, Performing An Estimated Critical Position Calculation, Rev. 7
TOOLS:	Calculator; Ruler/straight edge.
HANDOUT:	20M-50.4.F, Performing An Estimated Critical Position Calculation, Rev. 7 partially completed Data Sheet 3 & Figure 1



When determining Control Rod Position, a straight vertical line should be drawn from the nonzontar axis to the 2. control bank steps.

20M-50.4.I Rev sion

 $\sim$ 'n

Unit 2

**BVPS-IFR** 

FIGURE 

ł

#### **CANDIDATE DIRECTION SHEET**

#### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

Read:	
TASK:	You are to perform the task Evaluate 1/M data
INITIAL CONDITIONS:	The unit is in Mode 2. A reactor startup is in progress. Control Bank C is at 129 steps. Control Bank D is at 1 step. RCS Boron concentration is 1875 ppm.
INITIATING CUE:	The Unit Supervisor directs you to complete the 1/M plot per 2OM- 50.4.F data sheet 3 using the SR count rate data provided. Compare the 1/M data with the predicted ECP data and make a recommendation for further rod withdrawal. Document your recommendation in the box below.
RECOMMENDATION:	
At this time, ask the e	valuator any questions you have on this JPM.
When satisfied that ye	ou understand the assigned task, announce "I am now beginning the JPM"
Simulate performance	e or perform as directed the required task.

Point to any indicator or component you verify or check and announce your observations.

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.

•

JPM NUMBER: 2AD-016 JPM REVISION: 0 JPM TITLE: Plot and Evaluate 1/M Data			
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ \√U		
	START TIME:		
1. Refer to data sheet 3	1.1 Applicant refers to data sheet 3 for count rate data.		
	COMMENTS:		
2.C Refer to 1/M plot	2.1C Candidate evaluates count rate data from data sheet 3 and plots on the 1/M for 300, 325, 375, AND 385 total steps. EVALUATOR NOTE: See attached Answer Key for 1/M plot values. COMMENTS:		
3.C Evaluate 1/M plot data	<ul> <li>3.1C Applicant determines that the 1/M plot predicts criticality</li> <li>&gt;500 pcm below ECP. Maximum rod height is Bank D at 40 steps versus ECP of Bank D 101 steps.</li> </ul>		
	COMMENTS:		
1			

.

JPM NUMBER: 2AD-016       JPM TITLE: Plot and Evaluate 1/M Data         JPM REVISION: 0				
STEP ("C" Denotes CRITICAL STEP)	) STA	NDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	\$/U	
4.C Inform SM/US	4.1 <b>0</b> COI	C Applicant informs SM/US that 1/M data indicates that criticality will occur >500 pcm below the ECP. Recommend NO FURTHER ROD WITHDRAWALS.		
		<b>TERMINATING CUE:</b> When the applicant makes a recommendation on continued startup, the evaluation for this JPM is complete.		
		STOP TIME:		

ъ

TRAINING MATERIAL TITLE:	Perform the Daily Heat Balance	
TRAINING MATERIAL NUMBER:	2CR-558	
PROGRAM TITLE:	Licensed Operator Training (Retraining)	
<u>COMPUTER CODE</u> :	2CR-558	
REVISION NUMBER:	1	
<u>TECHNICAL REFERENCES:</u> 2OM-54.4.C1, Rev 19 Steam Tables		
INSTRUCTIONAL SETTING:	Classroom	
APPROXIMATE DURATION:	30 minutes	
PDEDADED DV. D. I. Droo	Jen	
<u>rkeraked bi</u> , <u>k. j. bioo</u>		Date
PEER REVIEW BY:		Date
APPROVED FOR USE:	Training Supervisor in Designee	Date

#### TRAINING MATERIAL CHANGE FORM

Affected Training Material	Affected Training Materials: 2CR-558					
Type of Change:						
Changes Requiring Revision	Learning Objective Re	elated Change?	New Rev. # 1			
Changes Not Requiring Revision	The Change Does Not Objectives or Materia	Impact Learning Quality.	Existing Rev. #0 New Change #			
List/Description of Change Updated JPM to current JP Added data sheet C which	List/Description of Change(s): Updated JPM to current JPM format. Added data sheet C which forces a gain adjustment for N41, N42, and N43.					
Reason for Change (s): Increase "Faulted" JPM bank						
APPROVALS:						
R. J. Brooks Prepared by		Date	NOTE: Additions, deletions or changes to training materials must be reviewed for their possible impact to the Training			
Training Superintendent/S ("Changes Not Requiring	upervisor/Peer Revision" only)	Date	Qualification Matrix. See Incumbent Impact Review, NOBP-TR-1104.			

24

JPM NUMBER: 2CR-558 JPM REVISION: 1	JPM TITLE: Perform the Daily Heat Balance		
K/A REFERENCE: 015 A 19300 2.1.7	1.01 3.5/3.8 7K1.08 3.1/3.4 4.4/4.7	TASK ID: 0021-009-06-	013
JPM APPLICATION:	REQUALIFICATION	N 🛛 INITIAL EXAM	TRAINING
EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED EY:
Perform     Simulate	Plant Site     Simulator     Classroom	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	BVT NRC Other:

EVALUATION RESULTS					
Performer Name:			Performer SSN:		
Time  Yes Critical:  No	Allotted Time:	30 min	utes	Actual Time:	minutes
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:					
	OE	SERVER	.S		······································
Name/SSN:		Nam	e/SSN:		
Name/SSN:		Nam	ie/SSN:		
EVALUATOR					
Evaluator (Print):			]	Date:	<u>_</u>
Evaluator Signature:					

RTL#A5.640U

#### **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	The daily heat balance calculation is calculated and the required Pow $\pi$ Range instrument gain adjustments are identified as specified in the Answer Key.
RECOMMENDED STARTING LOCATION:	Control Room
<b>DIRECTIONS:</b>	You are to perform the task Calculating the Daily Heat Balance.
INITIAL CONDITIONS:	The Unit is in Mode 1. Tavg matches Tref and power has been stable for at least 30 minutes. The plant computers are unavailable.
INITIATING CUE:	The Unit Supervisor directs you to perform a daily heat balance in accordance with 2OM-54.4.C1, Daily Heat Balance, Part D, to comply with the Tech Spec Surveillance Logs. Perform steps D1 thru D6 and report the results. The LEFM Channel Check has been performed satisfactorily.
REFERENCES:	20M-54.4.C1, Daily Heat Balance, Rev. 19
TOOLS:	Calculator Steam Tables
HANDOUT:	20M-54.4.C1, Daily Heat Balance, Rev. 19 Plant Parameters Data Sheet

### **CANDIDATE DIRECTION SHEET**

#### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

	Read:				
TASK:		You are to perform the task of Calculating a Daily Heat Balance.			
INITIA	AL CONDITIONS:	The Unit is in Mode 1. Tavg matches Tref and power has been stable for at least 30 minutes. The plant computers are unavailable.			
INITIA	ATING CUE:	The Unit Supervisor directs you to perform a daily heat balance in accordance with 2OM-54.4.C1, Daily Heat Balance, Part D, to comply with the Tech Spec Surveillance Logs. Perform steps D1 thru D6 and report the results. The LEFM Channel Check has been performed satisfactorily.			
	At this time, ask the eval	uator any questions you have on this JPM.			
	When satisfied that you u	understand the assigned task, announce "I am now beginning the JPM".			
	Simulate performance or Point to any indicator or	perform as directed the required task. component you verify or check and announce your observations.			
	After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.				

JPM NUMBER: 2CR-558 JPM REVISION: 1	PM TII	LE: P	erform the Daily Heat Balance	
STEP ( "C" Denotes CRITICAL STEP )		STANI	DARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	
			START TIME:	
			<b>Simulator Setup:</b> Simulator is not required for this JPM performance, a Plant Parameter Data sheet is to be provided to each candidate.	
			<ul> <li>EVALUATOR NOTE: Plant Parameter Data Sheet to contain the following;</li> <li>S/G Blowdown flow ΔP in Inches H<sub>2</sub>O</li> <li>Power Range NI indications</li> <li>Feedwater Temperature from LEFM</li> <li>10 min avg Feedwater Mass Flow rate from LEFM</li> <li>S/G Steam Pressures</li> </ul>	
1. Candidate locates appropriate procedure.		1.1	Provide candidate with a copy of 2OM-54.4.C1 and a plant parameter data sheet. <b>EVALUATOR NOTE:</b> Procedure can be provided to	
		Сомі	MENTS:	
2. Gathers the necessary dat	ta.	2.1. 2.2.	Candidate records $\Delta P$ 's from plant parameter data sheet. Candidate records NIS Indicated power levels from the plant parameter data sheet.	
			<b>EVALUATOR NOTE:</b> Part "A" of procedure can be completed prior to providing to candidate, if previously completed, N/A this JPM step.	
		СОМ	MENTS:	

IPM N JPM R	IPM NUMBER: 2CR-558       JPM TITLE: Perform the Daily Heat Balance         JPM REVISION: 1       JPM TITLE: Perform the Daily Heat Balance				
STEP ("C" E	Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ №U			
3.	Candidate notes that a LEFM Channel check is required.	<ul> <li>3.1 Candidate notes that per the initial conditions, a Channel Check has been performed.</li> <li>EVALUATOR CUE: If candidate asks question, restate that a Channel Check has been previously performed per the initial conditions.</li> <li>COMMENTS:</li> </ul>			
4.	Converts S/G blowdown flow from ΔP in Inches H <sub>2</sub> O to "lbm/hr"	<ul> <li>4.1 Candidate converts each S/G blowdown flow from ΔP in Inches H<sub>2</sub>O to "lbm/hr"</li> <li>COMMENTS:</li> </ul>			
5.	Obtain and record appropriate plant data. All required data is provided on the plant parameter data sheet.	<ul> <li>5.1 Candidate records data from the plant parameter data sheet</li> <li>5.2 Records the LEFM Feedwater temperature.</li> <li>5.3 Records the LEFM Feedwater Mass Flow Rate.</li> <li>5.4 Records the S/G Steam pressures and converts to PSIA.</li> <li>5.5 Records the S/G Blowdown flowrates previously calculated.</li> <li>COMMENTS:</li> </ul>			

JPM NUMBER: 2CR-558 JPM REVISION: 1	JPM TITLE: Perform the Daily Heat Balance
STEP ("C" Denotes CRITICAL STEP ) 6.C Perform calculations.	STANDARD       (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒       >/U         6.1C       Candidate calculates the average steam pressure for all 3 S/G's by adding all 3 indications and dividing by 3.       5.2C         6.2C       Candidate calculates the total S/G Blowdown mass flowrate by adding all 3 S/G blowdown flowrates together.       6.3C         6.3C       Candidate calculates the total Steam Mass flowrate by subtracting the total blowdown mass flowrate from the feedwater mass flowrate.         COMMENTS:
7.C Obtain Enthalpy's	<ul> <li>7.1C Candidate obtains the steam enthalpy (h<sub>ST</sub>) from the saturated steam table using "h<sub>g</sub>" at the calculated average steam pressure.</li> <li>7.2C Candidate obtains blowdown enthalpy (h<sub>BD</sub>) of the blowdown from each steam generator by determining "h<sub>f</sub>" for saturated fluid, based on the respective steam generator steam pressure.</li> <li>7.3C Candidate obtains feedwater enthalpy (h<sub>FW</sub>) by determining the "h<sub>f</sub>" for saturated fluid, based on the LEFM feedwater temperature</li> <li>COMMENTS:</li> </ul>

IPM NUMBER: 2CR-558 JPM REVISION: 1	JPM TITL	TLE: Perform the Daily Heat Balance		
STEP ("C" Denotes CRITICAL STEP)	S	TAND	ARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	<u>\$</u> /U
8.C Determine the Heat Trai	nsfer 8 8 8 8 0 0	.1C .2C .3C .4 C	Candidate multiplies the total steam mass flow rate times the steam enthalpy. Candidate multiplies the blowdown mass flow rate from each steam generator times the respective blowdown enthalpy for each steam generator. Candidate adds the blowdown mass flow rates for each steam generator Candidate multiplies the total feedwater mass flow rate times the feedwater enthalpy. ENTS:	
9.C Determine the NET read power.	ctor 9 9 9 9	9.1C 9.2C 9.3C 9.4C	Candidate calculates the RCS Output by adding the Steam and blowdown heat transfers <b>AND THEN</b> subtracting the Feedwater heat transfer. Candidate calculates the Net Reactor Power by subtracting "33.105" from the RCS Output. Candidate calculates the Megawatt Thermal by multiplying the Net Reactor Power times "10 <sup>-6</sup> " <b>AND</b> then dividing the resultant by "3.413". Candidate calculates the "% Reactor Power" by dividing the Megawatt Thermal by "2900" <b>AND</b> then Multiplying the resultant by "100%". IENTS:	

IPM NUMBER: 2CR-558JPM TIJPM REVISION: 1JPM TI	TLE: Perform the Daily Heat Balance
STEP ("C" Denotes CRITICAL STEP)	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ 5/U
10. Review the results	<ul> <li>10.1 Candidate compares the calculated power level to 2900 MWt and determines that 2OM-52.2.A does not need to be referred to for limitations on power.</li> <li>EVALUATOR CUE: Power is less than 2900 MWt.</li> <li>COMMENTS:</li> </ul>
<ul> <li>11.C Determine if Power Range Channels gain adjustment s necessary.</li> <li>EVALUATOR NOTE: Alternate Path, Gain adjustment will be required to successfully complete JPM.</li> </ul>	<ul> <li>11.1C Candidate reviews criteria and determines that a gain adjustment will be required.</li> <li>EVALUATOR NOTE: The Criteria and required NI(s) needing gain adjustment is dependant upon the data given in the particular plant parameter data sheet.</li> <li>COMMENTS:</li> </ul>
12. Determine if calculated power is less than 70%	<ul> <li>12.1 Candidate determines that calculated power level is greater than 70% therefore I&amp;C does NOT need to reduce the Setpoints to 85%.</li> <li>EVALUATOR NOTE: Candidate should N/A the step.</li> <li>COMMENTS:</li> </ul>

JPM NUMBER: 2CR-558 JPM REVISION: 1	TLE: Perform the Daily Heat Balance
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ 5/U
13.C Complete table check marks for NI's needing adjustment.	<ul> <li>13.1C Candidate completes procedure table with check marks in the appropriate locations for each NI.</li> <li>EVALUATOR NOTE: The required NI(s) needing gain adjustment is dependant upon the data given in the particular plant parameter data sheet.</li> <li>COMMENTS:</li> </ul>
14. Candidate requests review and approval of Heat Balance results.	<ul> <li>14.1 Candidate reports to the SM/US the results of the Heat Balance and which specific NI's need gain adjustment.</li> <li>14.2 Candidate requests that the results be reviewed and approved prior to NI Gain adjustment.</li> <li>EVALUATOR CUE: Report to candidate that another operator will review the heat balance results prior to performing NI Gain adjustment.</li> <li>EVALUATOR NOTE: Grader discretion is required when evaluating calculations.</li> <li>COMMENTS:</li> </ul>
	STOP TIME:

.

JPM TITLE: Perform the Daily Heat Balance

#### Plant Parameter Data Sheet - C

······	"A"	"B"	"C"	· · ·
Feedwater Temperature (LEFM)			in the second second	432°f
Feedwater mass flowrate (10 <sup>6</sup> PPH)				12.58
S/G Blowdown Flow, (in H <sub>2</sub> 0)	4.50	4.50	4.50	
Steam Pressure (psig)	826.20	826.20	826.20	
Power Range N41 indication (%)	99.00	All States and the set		
Power Range N42 indication (%)	99.10			
Power Range N43 indication (%)	99.10	1.1.1.1.1.5.5.6.1.1		
Power Range N44 indication (%)	99.40	ale and start and start and start at		

.

#### **OPERATIONS JOB PERFORMANCE MEASURE (JPM)**

TRAINING MATERIAL TITLE:	Prepare a Clearance Tagout (2SWE*P21B)
TRAINING MATERIAL NUMBER:	2AD-017
PROGRAM TITLE:	Licensed Operator Training
COMPUTER CODE:	2AD-017
REVISION NUMBER:	0
<u>TECHNICAL REFERENCES:</u> NOBP-OP-1001, Clearance Program, NOP-OP-1001, Clearance/Tagging Pr	Rev. 0 rogram, Rev. 9

INSTRUCTIONAL SETTING:

Classroom

APPROXIMATE DURATION: 25 Minutes

PREPARED BY:	R. J. Brooks		
			Date
PEER REVIEW BY:		12,55	Date
APPROVED FOR USE:			
	Training Suj	perv 3. of Designee	Date

¥2

## TRAINING MATERIAL CHANGE FORM

Affected Training Materia	ls: 2AD-017		
Type of Change:			
Changes Requiring Revision	Learning Objective Re	lated Change?	New Rev. # 0
Changes Not Requiring Revision	The Change Does Not Objectives or Material	Impact Learning Quality.	Existing Rev. #
List/Description of Change	e(s):		
Reason for Change (s):			
APPROVALS:			
R. J. Brooks Prepared by		Date	<b>NOTE</b> : Additions, deletions or changes to training materials must be reviewed for their possible impact to the Training
Training Superintendent/S ("Changes Not Requiring	upervisor/Peer Revision" only)	Date	Qualification Matrix. See Incumbent Impact Review, NOBP-TR-1104.

RTL#A5.640U			1/2-ADM-1301.FC Page 3 of 5 Revision
JPM NUMBER: 2AD-017 JPM REVISION: 0	JPM TITLE: Prepare	a Clearance Tagout (2SWE*	P21B)
K/A REFERENCE: 2.2.13 JPM APPLICATION:	(3.6) REQUALIFICATION FAULTED JPM	TASK ID: 0481-020-03- N 🛛 INITIAL EXAM 🛛 ADMINISTRAT	013 TRAINING TIVE JPM
EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED BY:
Perform Simulate	<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	BVT NRC Other:

EVALUATION RESULTS				
Performer Name:	Performer SSN:			
Time Yes Critical: No	Allotted Time: 25 Min	utes	Actual Time:	minutes
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:				
	OBSERVER	S		
Name/SSN:	Nan	ne/SSN:		
Name/SSN:	Nan	ne/SSN:		
	EVALUATO	DR		
Evaluator (Print): Date:				
Evaluator Signature:				

# **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	Identify the tags and sequence of placement for a tagout of 2SWE*P21B Standby Service Water Pump.
RECOMMENDED STARTING LOCATION:	Classroom
<b>DIRECTIONS:</b>	You are to perform the task Prepare a Clearance Tagout
INITIAL CONDITIONS:	The plant is in Refueling Mode, no fuel is in the reactor. 2SWE*P21B Standby Service Water Pump is to be placed on clearance. Service Water Pumps 2SWS*P21A <b>AND</b> B are Operable and running. 2SWE*P21A Standby Service Water Pump is operable.
INITIATING CUE:	You are to identify the required clearance points (equipment), position (placement configuration), and sequence for clearing 2SWE*P21B Standby Service Water Pump, for pump inspection. NO seal cooler work <b>OR</b> motor work will be performed. SOMS is out of service. Document your results on the table provided.
REFERENCES:	NOBP-OP-1001, Clearance Program, Rev. 0 NOP-OP-1001, Clearance/Tagging Program, Rev. 9
TOOLS:	None
HANDOUT:	NOBP-OP-1001, Clearance Program, Rev. 0 NOP-OP-1001, Clearance/Tagging Program, Rev. 9 OP Manual Fig. No. 30-1A, 10080-RM-430-1A, Rev. 4 OM Chapter 2OM-30.3.C, Power Supply and Control Switch Checklist.

Read:

.

 $\mathbf{p}$ 

### **CANDIDATE DIRECTION SHEET**

#### THIS SHEET TO BE GIVEN TO CANDIDATE \* \*

TASK:		You are to perform the task Prepare a Clearance Tagout	
INITIA	L CONDITIONS:	The plant is in Refueling Mode, no fuel is in the reactor. 2SWE*P21B Standby Service Water Pump is to be placed on clearance. Service Water Pumps 2SWS*P21A AND B are Operable and running. 2SWE*P21A Standby Service Water Pump is operable.	
INITIA	TING CUE:	You are to identify the required clearance points (equipment), position (placement configuration), and sequence for clearing 2SWE*P21B Standby Service Water Pump, for pump inspection. NO seal cooler work <b>OR</b> motor work will be performed. SOMS is out of service. Document your results on the table provided.	
	At this time, ask the eval	uator any questions you have on this JPM.	
	When satisfied that you understand the assigned task, announce "I am now beginning the JPM".		
	Simulate performance or Point to any indicator or	perform as directed the required task. component you verify or check and announce your observations.	
	After determining the Task has been met announce "I have completed the JPM". Then hand this sheet to the evaluator		

Then hand this sheet to the evaluator.

-

JPM NUMBER: 2AD-017 JPM REVISION: 0	JPM TITLE: Prepare a Clearance Tagout (2SWE*P21B)			
STEP ("C" Denotes CRITICAL STEP)	)	STANDARD	(Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	5∕U
and a second			START TIME:	
			EVALUATOR NOTE: This task is normally performed using the SOMS clearance computer and signed electronically. For this JPM, the SOMS computer is NOT available.	
			EVALUATOR NOTE: Provide JPM handout and student copy of table.	
1.C Candidate completes the table.		1.1C Candi	dates table matches the ANSWER KEY.	
		COMMENT	rs:	
			<b>TERMINATING CUE:</b> When the candidate identifies and reports that all tags are identified, the evaluation for this JPM is complete.	
			STOP TIME:	

# ANSWER KEY (DO NOT GIVE TO STUDENTS)

Component ID	Component Description	Position	Sequence
2SWE*P21B-CS	Control Switch for Standby Service	Pull-To-Lock	1
(AE)	Water Pump 2SWS*P21C (AE)	(PTL)	
4KVS-2DF-2F19	Supply to Standby Service Water Pump 2SWE*P21B	Racked Out	2
SWE-224	Disch Isol Valve	Shut	3
SWE-260	Seal WTR Supply to STBY SW PP (2SWE-P21B) Isol	Shut	3
SWE-228	Disch Isol Valve To Screen Wash	Shut	3
SWE-308	Drain Isol On Discharge At 2SWE-P21B	Open	4

Evaluator NOTE: Student may identify additional points. The points listed above are the minimum required for this JPM. All additional points must be evaluated to ensure the clearance is correct.

# **STUDENT COPY**

Component ID	<b>Component Description</b>	Position	Sequence
		er-se Mai 8 - 1.47	
			· · · · · · · · · · · · · · · · · · ·
			*



Ĝ<u>G carco</u>

18

🔶 🔶 👌

#### **OPERATIONS JOB PERFORMANCE MEASURE (JPM)**

TRAINING MATERIAL TITLE:	Respond to a Radiation Monitor Alarm
TRAINING MATERIAL NUMBER:	2AD-018
PROGRAM TITLE:	Licensed Operator Training
COMPUTER CODE:	2AD-018
<b>REVISION NUMBER</b> :	0

**TECHNICAL REFERENCES:** 

20M-43.4.AEE Rev. 5 20M-43.4.AAC Rev. 1 20M-43.4.ACC Rev. 4 20M-25.4.L, Discharging Steam Generator Blowdown Evaporator Test Tank [2SGC-TK23A(B)] Contents To Cooling Tower Blowdown. Rev. 24

INSTRUCTIONAL SETTING: Simulator

APPROXIMATE DURATION: 10 Minutes

PREPARED BY:	R. J. Brooks	
PEER REVIEW BY:	\ <b>१</b> \	Date
APPROVED FOR LISE		Date
<u></u>	Training Supervisor of Designee	Date

-

ь

## TRAINING MATERIAL CHANGE FORM

Affected Training Materia	ls: 2AD-018		
Type of Change:			
Changes Requiring Revision	Learning Objectiv	e Related Change?	New Rev. # 0
Changes Not Requiring Revision	The Change Does Objectives or Mat	Not Impact Learning erial Quality.	Existing Rev. # New Change #
List/Description of Change	e(s):		<u> </u>
Original issue			
Reason for Change (s):			
APPROVALS:			
R. J. Brooks			NOTE: Additions, deletions or
Prepared by		Date	changes to training materials must be reviewed for their possible impact to the Training
Training Superintendent/S ("Changes Not Requiring	upervisor/Peer Revision" only)	Date	Qualification Matrix. See Incumbent Impact Review, NOBP-TR-1104.

ń

JPM NUMBER: 2AD-018 JPM REVISION: 0	JPM TITLE: Respond to a Radiation Monitor Alarm		
K/A REFERENCE: 2.3.11 JPM APPLICATION:	3.8 REQUALIFICATIO FAULTED JPM	TASK ID: 0171-016-01- N 🛛 INITIAL EXAM 🛛 ADMINISTRAT	013 TRAINING TIVE JPM
EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED BY:
<ul> <li>Perform</li> <li>Simulate</li> </ul>	Plant Site     Simulator     Classroom	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	BVT NRC Other:

EVALUATION RESULTS				
Performer Name:		Performer SSN:		
Time  Yes Critical:  No	Allotted Time: 10 Min	utes	Actual Time:	minutes
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:				
	OBSERVER	S		
Name/SSN: Name/SSN:				
Name/SSN: Name		ne/SSN:		
EVALUATOR				
Evaluator (Print): Date:				
Evaluator Signature:				

.

## **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	Liquid Waste Eff Isol Vlv 2SGC-HCV100 is CLOSED and SG Blowdown Test Tank Pump 2SGC-P26B is stopped. RWDA-L Discharge Stop Data is documented.
RECOMMENDED STARTING LOCATION:	Simulator
DIRECTIONS:	You are to perform the task Respond to a Radiation Monitor Alarm.
INITIAL CONDITIONS:	Unit 2 is Mode 3 with the Shutdown banks withdrawn. A liquid waste discharge of Steam Generator Blowdown Test Tank 2SGC-TK23B is in progress to Unit 1 blowdown. A Discharge permit (RWDA-L – 99999T) has been issued for this discharge. A4-5C, Radiation Monitoring Level High alarm has been received in the control room.
INITIATING CUE:	The Unit Supervisor directs you to respond to the Radiation Monitoring Level High alarm in accordance with plant procedures.
REFERENCES:	20M-43.4.AEE Rev. 5 20M-43.4.AAC Rev. 1 20M-43.4.ACC Rev. 4
TOOLS:	None
HANDOUT:	RWDA-L-99999T filled out up to the discharge in progress point. 2OM-25.4.L, Discharging Steam Generator Blowdown Evaporator Test Tank [2SGC-TK23A(B)] Contents To Cooling Tower Blowdown filled out up to the discharge in progress point.

1 |

#### **CANDIDATE DIRECTION SHEET**

#### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

Read:	
TASK:	You are to perform the task Respond to a Radiation Monitor Alarm.
INITIAL CONDITIONS:	Unit 2 is Mode 3 with the Shutdown banks withdrawn. A liquid waste discharge of Steam Generator Blowdown Test Tank 2SGC-TK23B is in progress to Unit 1 blowdown. A Discharge permit (RWDA-L – 99999T) has been issued for this discharge. A4-5C, Radiation Monitoring Level High alarm has been received in the control room.
INITIATING CUE:	The Unit Supervisor directs you to respond to the Radiation Monitoring Level High alarm in accordance with plant procedures.

At this time, ask the evaluator any	y questions you have on this JPM.
-------------------------------------	-----------------------------------

When satisfied that you understand the assigned task, announce "I am now beginning the JPM".

	Simulate performance or perform as directed the required task. Point to any indicator or component you verify or check and announce your observations.
--	---

After determining the Task has been met announce " I have completed the JPM'	<b>'</b> .
Then hand this sheet to the evaluator.	

t

JPM NUMBER: 2AD-018 JPM REVISION: 0 JPM TITLE: Respond to a Radiation Monitor Alarm		
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	
	START TIME:	eur -sue rest
n versamen birdana iyos neyt — newenni sidalana orazon dinazologi (rasketira	Simulator Setup:	
	POST GREEN MAGNETIC PLACARD FOR SITE LIQUID WASTE DISCHARGE IN PROGRESS	
	Mode 3 Snap (IC-240 for 2LOT6 NRC exam)	
	1. Setup a LW discharge of 2SGC-TK23B using 2SGC-P26B, SG Blowdown Test Tank Pump.	
	2. Set ALERT setpoint of 2SGC-RQ100 to 1.22E-3 µCi/ml	
	(1065 sel; channel items; 122-3 enter)	
	3. Set HIGH setpoint of 2SGC-RQ100 to 1.74E-3 μCi/ml.	
1	(174-3 enter)	
	4. Start sample pump.	
	5. Insert a failure to prevent 2SGC-HCV100 Liquid Waste Eff Isol Vlv. from AUTO closing on HIGH alarm from 2SGC- RQ100.	
	6. Insert malfunction to raise 2SGC-RQ100 above the high alarm setpoint.	
	7. Verify A4-5C, Radiation Monitoring Level High alarms	
	Items 2, 3, and 4 will need to be done each time the simulator is reset. (they do not carryover in the IC)	
<ol> <li>Applicant refers to ARP for A 5C, Radiation Monitoring Lev High 2OM-43.4.AAC.</li> </ol>	4- el COMMENTS:	

JPM NUMBER: 2AD-018 JPM REVISION: 0 JPM TI	TLE: Respond to a Radiation Monitor Alarm
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ \\/U
<ol> <li>Perform the following at the RM- 11 operators console:</li> <li>Press the grid 6 pushbutton AND Determine which radiation monitor in alarm (blinking and has turned red).</li> </ol>	<ul> <li>2.1 At DRMS panel depresses Grid 6</li> <li>2.2 Verifies 1LX065 is blinking and RED</li> <li>COMMENTS:</li> </ul>
· · ·	<b>EVALUTOR NOTE:</b> The four digit number is the radiation monitor number less the letters (i.e. 1PA234 will be 1234).
<ol> <li>Type in the 4-digit numerical code number of the alarming monitor AND Press the SEL pushbutton.</li> </ol>	<ul><li>3.1 Types 1065 on DRMS keyboard AND depresses the SEL pushbutton</li><li>COMMENTS:</li></ul>
4. Press the STATUS pushbutton.	<ul><li>4.1 Depresses the STATUS pushbutton on the DRMS keyboard.</li><li>COMMENTS:</li></ul>
,

JPM JPM	JPM NUMBER: 2AD-018 JPM REVISION: 0 JPM TITLE: Respond to a Radiation Monitor Alarm					
STE. ( "C 5.	P "Denotes CRITICAL STEP ) Press SYSTEM ACK to siler the console alarm.	STANDARD       (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒       Standard         nce       5.1       Depresses the SYSTEM ACK pushbutton on the DRMS keyboard.         COMMENTS:       Standard	//U			
6.	If any radiation monitor is at approaching, 1000 times nor- background, Immediately no the SM/US <b>AND</b> Refer to 1/2OM-57, "Emergency Preparedness Plan" for furthe actions.	OR mal tify       6.1 N/A         EVALUTOR CUE:         Role-play SM/US and inform the candidate that 2SGC-RQ100 is NOT 1000 times normal background.         er         COMMENTS:				
7.	Refer to local alarm response procedures 20M-43.4.ACN through 20M-43.4.AEJ and 20M-43.4.AEL for correctiv actions.	EVALUTOR NOTE:         Candidate may also refer to 2OM-43.4.ACC in the next step. This would be acceptable. (This procedure also contains the "Critical" steps necessary to isolate the LW discharge).         e       7.1 Refers to 2OM-43.4.AEE.         COMMENTS:				

6

JPM NUMBER: 2AD-018 JPM REVISION: 0 JPM TITLE: Respond to a Radiation Monitor Alarm					
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ 5/U				
<ul> <li>8.C If a high radiation condition is suspected in [2SGC-TK23B]:</li> <li>Verify Closed [2SGC-HCV100], Liquid Waste Eff Isol Vlv. (BB-A).</li> </ul>	<ul> <li>8.1 Verifies 2SGC-HCV100 Liquid Waste Eff High Rad Isol Vlv Green light NOT LIT and RED light LIT</li> <li>8.2C Rotates 2SGC-HIC100 Liquid Waste Eff High Rad Isol Vlv Controller counterclockwise until demand output is ZERO.</li> <li>8.3 Verifies 2SGC-HCV100 Liquid Waste Eff High Rad Isol Vlv Green light - LIT and RED light - NOT LIT</li> <li>COMMENTS:</li> </ul>				
9.C Stop [2SGC-P26A(B)], SG Blowdown Test Tank Pumps (BB-A).	9.1C Places CS for SG Blowdown Test Tank Pump 2SGC- P26B to STOP COMMENTS:				
10. Notify Health Physics.	10.1       Contacts Health Physics to inform them that the discharge was secured due to High Alarm on 2SGC-RQ100.         EVALUTOR CUE:         Role-play Health Physic and acknowledge the report.         COMMENTS:				

JPM NUMBER: 2AD-018 JPM REVISION: 0	JPM TITLE: Respond to a Radiation Monitor Alarm
STEP ("C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ 5/U
11. Have chemistry sample the contents of the in service Blowdown Test Tank to w high radiation condition.	SG erify 11.1 Contacts Chemistry to inform them that the discharge was secured due to High Alarm on 2SGC-RQ100 AND request SG Blowdown Test Tank to verify high radiation condition. EVALUTOR CUE: Role-play Chemistry and acknowledge the report. COMMENTS:
	EVALUTOR CUE:         Role-play SM/US and direct the candidate to complete         the required documentation on the RWDA-L for stopping         the discharge.         EVALUTOR NOTE:         The guidance for completing the RWDA-L         documentation is contained in 20M-25.4.L         D.
<ul> <li>12.C Record the following or RWDA-L at the "Disclessop"</li> <li>Date</li> <li>Time</li> <li>Tank Level</li> </ul>	n the harge 12.1C Records the following information on space provided on the RWDA-L • Date • Time • Tank Level equal to ~95 inches • Initials COMMENTS:

.

JPM NUMBER: 2AD-018 JPM REVISION: 0 JPM TI	TLE: Respond to a Radiation Monitor Alarm
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ 5/U
13.C Calculates the volume discharged and records on the RWDA-L at the "Discharge Stop"	<ul> <li>13.1 Determines volume discharged by subtracting current volume for 95 inches from original volume of 17, 705</li> <li>13.2 IAW Table 1 on page 29 of 2OM-25.4.L 95 inches is 13,341 gals.</li> <li>13.3 17705 - 13341 = 4, 364 gals</li> <li>13.4C Records 4, 364 gals on RWDA-L</li> <li>COMMENTS:</li> </ul>
	<b>EVALUTOR CUE:</b> That completes this JPM.
	STOP TIME:

Form 1/2-ENV-05.04.F01, Rev 0 (Page 1 of 5)RTL#A9.520ARWDA-L: Part 1, Summary of Discharge DataRWDA-L: Part 1, Summary of Discharge DataBf 3r Valley Power Station-2RWDA L 99999T

This permit authorizes the discharge of a maximum of 17705.3 gallons from tank 2SGC-TK23B at a maximum discharge rate of 85.0 gpm to the environment via U1 blowdown with a minimum total cooling tower blowdown of 4000.0 gpm at Unit 1 and Unit 2 with a monitor ALERT alarm setpoint of 1.22E-03 uCi/ml and a monitor HIGH alarm setpoint of 1.74E-03 uCi/ml on 2SGC-RQ100 (See Below for Alternate Alarm Setpoints) This tank was recirculated \_YESTERDAY 0001 hours to YESTERDAY 2001 hours (at which time it was sampled) for a total of 1200 minutes. Prepared By Reviewed By Remarks: O. H. Gamma **J. H. Beta** Peer Review Sig ToDAY Date IOCAV Signature Date Cooling Tower Flow Set Unit 1 MCA U1&U2 N/A Monitor Source Unit 1 MCO U1&U2\_ Check Init Monitor Alarms Adjusted Approvęd TODAY ALERT MIL HIGH Init U1 Shift Sig Date U2 Shift Mar Sia Date Alternate Alarm Setpoints Refer to 1/2-ENV-05.04 (Alarm CT B/D) gpm) X 4.00E-06=HIGH = ( N/HuCi/ml) (Max Exp Disch) (map HIGH Х 0.70 = ALERT =NuCi/ml) Lischarge Record Discharge Start Discharge Stop Vol. CT Flow, gpm mo dy yr hr mn levl ini mo dy yr hr mn|levl|ini qal. TOTAL 1 HOUR JYX 130 TODAY AGO Discharged Volume, gal = Discharge Time, min = Monitor Alarms Reset Reviewed By Reviewed By NA ALERT NA HIGH Init Init Ul Shift Mgr Sig Date U2 Shift Mgr Sig Date Post Release Review gpm) X ( min) = ( gal) C.T. Flow Discharge Time Dilution Volume ( gal) / ( Discharge Vol gpm) = C.T. Flow min) / 4.43E+00 = Post Time Dose Cor: Composite Size File Update Post Review ml -----/-----Init date ----/----Init date Signature Date

EXERCISE MODE ONLY

Porm 1/2-ENV-05.04.P01, Rev 0 (page 2 of 5) RMDA-L: Part 2, Tank Analysis Beaver Valley Power Station-2

#### RWDA-L-999997

. · ·

TANK: 2SGC-TK23B TANK VOLUME: 17705.3 gal, 6.70E+07 ml LEVEL: 130.0 in SAMPLE IDENTIFICATION: 20080422005 TOTAL C.T. FLOW: 4000.0 gpm

NUCLIDE CR-51 CO-58 CO-60 FB-59 AG-110M SB-124 SB-125	Concentration uCi/ml 5.32B-06 3.96E-05 1.47E-06 1.45E-06 5.20E-07 8.82B-06 1.11E-05	OBC Fraction* 1.06E-03 1.98E-01 4.90E-02 1.45E-02 8.66E-03 1.26E-01 3.70E-02	Count Rate 1.07E+02 7.21E+03 3.50E+02 1.83E+02 2.22E+02 2.37E+03 1.68E+03	EPA-RQ Fraction 3.56E-07 2.65E-04 9.65E-04 9.72E-06 3.42E-06 5.91E-05 7.44E-05
<b>H</b> -3	1.40B-02	1.40B+D0		9.38E-03
 TOTALS	1.41B-02	1.83B+00	1.21B+04	9.81E-D3

\* undiluted

Total Activity = 9.43B+05 uCi

MAXIMUM DISCHARGE FLOW RATE = 8.50E+01 gpm \*\*\*\*SET TO MAXIMUM\*\*\*

•

Dilution Factor = 4.71E+01

#### NOBLE GAS CONCENTRATION IN RIVER = 0.00E+00 uCi/ml

EXERCISE MODE ONLY

Porm 1/2-ENV-05.04.F01, Rev 0 (page 3 of 5) RWDA-L: Part 3, Pre-Release Dose Projections Beaver Valley Power Station-2 (All Dose Values in mRem)

RTL#A9.520A

RWDA-L-99997

NUCLIDE CR-51 CO-58 CO-60 FR-59 AG-110M SB-124 SB-125	CONCENTRATION 5.328-06 3.968-05 1.478-06 1.458-06 5.208-07 8.828-06 1.118-05	BONE 0.00E+00 0.00E+00 3.71E-05 1.21E-08 1.71E-06 1.37E-06	LIVER 0.00E+00 8.71E-05 9.31E-06 8.73E-05 1.12E-08 3.23E-08 1.53E-08	TOTAL BODY 1.67E-07 1.95E-04 2.05E-05 3.34E-05 6.65E-09 6.75E-07 3.28E-07	THYROID 9.968-08 0.008+00 0.008+00 0.008+00 0.008+00 4.148-09 1.408-09	KIDNEY 3.67E-D8 0.00E+00 0.00E+00 0.00E+00 2.20E-08 0.00E+00 0.00E+00	LUNG 2.21E-07 0.00E+00 0.00E+00 1.98E-05 0.00E+00 1.33E-06 1.06E-06	GI-LL 4.19E+95 1.77E-3 1.74E-4 2.91E-64 4.58E-66 4.84E-15 1.51E-5
FE-55 SR-89 SR-90 H-3 G.Alpha	0.008+00 0.008+00 0.008+00 1.408-02 0.008+00	0.008+00 0.008+00 0.008+00 0.008+00 0.008+00 0.008+00	0.008+00 0.008+00 0.008+00 9.308-05 0.008+00	0.008+00 0.008+00 0.008+00 9.308-05 0.008+00	0.008+00 0.008+00 0.008+00 9.308-05 0.008+00	0.008+00 0.008+00 9.308-05 0.008+00	0.008+00 0.008+00 0.008+00 9.308-05 0.008+00	0.00E+(0 0.00E+(0 0.00E+(0 9.30E-0 0.00E+0
PROJECTED UNIT 1/2 PROJECTED	RELEASE DOSE = RELEASE DOSE =	4.028-05 2.018-05	2.77 <b>5-04</b> 1.38 <b>8-04</b>	3.43E-04 1.71E-04	9.31B-05 4.65E-05	9.308-05 4.658-05	1.158-04 5.778-05	2.44B-0 1.22B-0
Unit 1 Curren UNIT 1 PROJECTE Unit 2 Curren UNIT 2 PROJECTE	t Month Dose = D MONTH DOSE = t Month Dose = D MONTH DOSE =	6.318-04 6.518-04 6.318-04 6.518-04	4.738-03 4.868-03 4.738-03 4.868-03	3.82E-03 3.99E-03 3.82E-03 3.99E-03	2.778-03 2.818-03 2.778-03 2.818-03	3.948-03 3.998-03 3.948-03 3.998-03	2.808-03 2.868-03 2.808-03 2.808-03 2.868-03	6.28E-0 7.50E-0 6.28E-0 7.50E-0
Unit 1 Current UNIT 1 PROJECTED Unit 2 Current UNIT 2 PROJECTED	Quarter Dose = QUARTER DOSE = Quarter Dose = QUARTER DOSE =	6.31 <b>B-04</b> 6.51 <b>B-04</b> 6.31 <b>B-04</b> 6.51 <b>B-04</b>	4.738-03 4.868-03 4.738-03 4.868-03	3.828-03 3.998-03 3.828-03 3.998-03	2.77E-03 2.81E-03 2.77E-03 2.81E-03	3.94E-03 3.99E-03 3.94E-03 3.99E-03	2-80E-03 2-86E-03 2-80E-03 2-86E-03	6.28E-03 7.50E-03 6.28E-03 7.50E-03
Unit 1 Currey UNIT 1 PROJECTI Unit 2 Currey UNIT 2 PROJECTI	nt Year Dose = RD YEAR DOSE = nt Year Dose = RD YEAR DOSE =	2.82E-02 2.83E-02 2.82E-02 2.83E-02 2.83E-02	5.958-02 5.968-02 5.958-02 5.968-02 5.968-02	3.828-02 3.848-02 3.828-02 3.848-02 3.848-02	8.84E-03 8.89E-03 8.84E-03 8.84E-03 8.89E-03	3.238-02 3.238-02 3.236-02 3.236-02	1.268-02 1.268-02 1.268-02 1.268-02	2.92E-02 3.05E-02 2.92E-02 3.05E-02

rhe sum of the RQ's is < 1; this is not considered a Reportable Quantity.

EXERCISE MODE ONLY

#### Form 1/2-ENV-05.04,F01, Rev 0 (Page 4 of 5)

RWDA-L: Part 4, Checklist, Pre-Release Data and Alternate Alarm Setpoint Determination Beaver Valley Power Station - 1 / 2

Initials AGB Pre-Release Data obtained from Operations [Ref: procedure 1/2-ENV-05.04] Samples obtained & Valve Verifications performed [Ref: procedure 1/2-ENV-05.01] Initials ACC Initials P48 Initials P48 Samples analyzed [Ref: procedure 1/2-ENV-05.25] Sample bottles marked with the RWDA-L number [Ref: procedure 1/2-ENV-05.01] Initials PG 2 RWDA-L prepared via the LIQDIS computer Code [Ref: procedure 1/2-ENV-05.04] Alarm Setpoints adjusted [Form 1-HPP-4.02.001.F01 & 1-HPP-4.02.040.F01 or 2-HPP-4.02.022.F01 & 2-HPP-4.02.037.F01] Initials A. 3 Initials PAB RWDA-L turned-over to Control Room Shift Manager or Unit Supervisor [Ref: procedure 1/2-ENV-05.04] Effluent Monitor Readings obtained during discharge [Ref: Form 1/2-ENV-05.04.F01 (page 5 of 5)] Initials RWDA-L Pre-Release Data: Complete this portion of the form PRIOR to entrance into the LIQDIS Computer Code [ ] <U1> Unit 1 [√] <U2> Unit 2 Source of Discharge: [] <1> for 1LW-TK-6A, or [] <2> for 6B [] <1> for 2LWS-TK21A, or [] <2> for 21B Tank Identification<sup>2</sup> [ ] <3> for 1LW-TK-3A, or [ ] <4> for 3B [] <3> for 2SGC-TK21A, or [] <4> for 21B [] <5> for 1LW-TK-5A, or [] <6> for 5B [ ] <5> for 2SGC-TK23A, or [~] <6> for 23B [ ] <7> for 1LW-TK-7A, or [ ] <8> for 7B [] <7> for Not Applicable, or [] <8> for N/A Note: Use [ ] <7> for Other Releases (e.g.: Chemical Waste Sump) Note: Use [ ] <1> for Other Releases (e.g.: Fire Sump) Tank Volume: 17705.3 gallons Tank Level: 130,0 [] feet, or [Vinches Recirculation Start: Sample Time: YESTERDAY 2001 hours YESTERDAY 0001 to YESTERDAY 2001 hours or / Unit 2 Sample ID No. 20080422005 Sample ID: [ ] Unit 1 Sample ID No. Minimum CT Flow from Unit 1 and Unit 2: イクロウ gpm\_(As a Guide, Operations will provide this value based on the "Low Alarm Setpoint" minus - 500 gpm) Discharge Path: [+/<U1> Send Liquid Waste to Unit 1 CT Blowdown, or [ ] <U2> Send Liquid Waste to Unit 2 CT Blowdown Sample NOTE: For independent sampling, record the Concentrations highest nuclide concentration from each sample Independent / Replicate Sample Comparison uCi/ml Particulates uCi/ml Noble Gas No radiation monitor available for the discharge path Na-24 Ar-41 (See ODCM procedure 1/2-ODC-3.03, Table 3.3-12, Action 2(1) 5.319E-6 [] Replicate sample was requested by promisiny supervision: Cr-51 Kr-85 Mn-54 Xe-131m (See NRC Regulatory Guide 4.1 ector or a concentration from 1st Sample Co-57 Xe-133 3.961 E-5 Co-58 Xe-133m damma concentration from 2rid Sample 1.471 5-6 Co-60 Xe-135 % Diff = 1081 ) minus (2nd (2nd 450 E-6 Fe-59 Xe-135m 56-122 3.343E-6 Zn-65 The total gamma concentration of the 1st & 2nd samples shall Sn-117m 2,455E-7 gree within a factor of 2 (i.e.; % Diff is between -50% to +100%). Zr-97 / Nb-97 These radionulides are Mo-99 / Tc-99m not in LEQDES dete 5.198 E-7 Ag-110m ADMINISTRATIVE GUIDE RELIEF bere. Value were 8.821E-6 Sb-124 Reprocessing is not practical per Shift Manager entered into rome 1.110 E-5 1/2- ENV-01.05. FOR 4 Sb-125 IFAdministrative Guide Relief is obtained from Shift-Manager, THEN 2300 eleve artist determination I-131 as generated Zr-95 / Nb-95 If 21E-4, reprocess, or obtain Administrative Guide Relief, as shown >>>> ed to reduce If >3E-6, reprocess, or obtain Administrative Guide Relief, as shown >>>> Cs-134 ninistrative Guide Cs-137 If ≥4E-6, reprocess, or obtain Administrative Guide Relief, as shown >>>> lues for future discharges Totai uring the applicable calendar 7.19E-5 Particulate If >1E-4, reprocess, or obtain Administrative Guide Relief, as shown >>>> month, quarter(s), and year. Date : TODAY 12345 SAP ID No .: Prepared By: Peer Review Signature: Shoull anobell SAP ID No.: 45678 Date TODAY Alternate Alarm Setpoint Determination: Complete this portion of the form AFTER exit from the LIQDIS Computer Code ] RM-1LW-104: Is Total Particulate >3.14E-3 uCi/ml ? [ ] IF YES, THEN Alternate Alarm Setpoints SHALL NOT be used [ ]YES [ ]NO ] RM-1LW-116: Is Total Particulate >7.33E-3 uCi/ml ? K IF NO, THEN Alternate Alarm Setpoints MAY be used [ ] YES [ ] NO 2SGC-RQ100: Is Total Particulate >1.14E-3 uCi/mi ? See procedure 1/2-ENV-05.04 for additional guidance I IYES NO SAP ID No. 12345 Prepared By: D TODAY Date : Peer Review Signature: Saude Con Sull Date : TODAY SAP ID No 45678

F TL A9.520A

#### Form 1/2-ENV-05.04.F01, Rev 0 (page 5 of 5) RWDA-L: Part 5, Effluent Radiation Monitor Tracking Beaver Valley Power Station - 1 / 2

Beaver Valley Power Station - 1 / 2	Tank Identification: 25GC - TK 23B						
Discharge Period See RWDA Cover Sheet for Actual Times							
Initial Start Date/Time: TODAY INOUR AGO Fina	al Stop Date/Time:						
Effluent Radiation Monitor & Determination of Acceptable Range of R	Readings During Discharge:						
[] Unit 1 Liquid Waste Tank Discharge via [RM-1LW-104]:	RM-1LW-104 bkgd ≈ cpm						
RWDA-L Count Rate: Form 1/2-ENV-05.04.F01 (page 2 of 5) = net com	n RM-1LW-104 Gross HSP = cpm						
NOTE: MDCR = Minimum Detectable Count Rate	RM-1LW-104 Gross HHSP = cpm						
[ ] ]E the RWDA-L Count Rate is ≤1,141 net cpm (MDCR), THEN the discharge is control	olled by the alarm setpoints (No further calculations required						
[] IF the RWDA-L Count Rate is >1,141 net cpm, THEN determine the Acceptable Rang	ge of Readings for control of the discharge, as follows:						
Maximum = (RWDA-L Count Rate cpm) x (2) + (bkgd	cpm) =cpm						
Minimum = (RWDA-L Count Rate cpm) / (2) + (bkgd	cpm) =cpm						
[] Unit 1 Laundry & Shower Drain Tank Discharge via [RM-1LW-116]:	RM-1LW-116 bkgd = cpm						
RWDA-L Count Rate: Form 1/2-ENV-05.04.F01 (page 2 of 5) = net cpr	m RM-1LW-116 Gross HSP = cpm						
NOTE: MDCR = Minimum Detectable Count Rate	RM-1LW-116 Gross HHSP = cpm						
[ ] IF the RWDA-L Count Rate is <236 net cpm (MDCR), THEN the discharge is controlle	ed by the alarm setpoints (No further calculations required).						
[ ] IF the RWDA-L Count Rate is >236 net cpm, THEN determine the Acceptable Range	e of Readings for control of the discharge, as follows:						
Maximum = (RWDA-L Count Rate cpm) x (2) + (bkgd	cpm) = cpm						
Minimum = (RWDA-L Count Rate cpm) / (2) + (bkgd	cpm) =cpm						
[ ] Unit 2 Liquid Waste Tank Discharge via [2SGC-RQ100]:	2SGC-RQ100 bkgd = ∪Ci/ml						
RWDA-L Count Rate: Form 1/2-ENV-05.04.F01 (page 2 of 5) = net cpr	n 2SGC-RQ100 Gross ASP = uDi/ml						
NOTE: MDCR = Minimum Detectable Count Rate	2SGC-RQ100 Gross HSP = uCi/ml						
[] IF the RWDA-L Count Rate is <247 net cpm (MDCR), THEN the discharge is controlle	ed by the alarm setpoints (No further calculations required).						
[ ] IF the RWDA-L Count Rate is >247 net cpm, THEN determine the Acceptable Range	e of Readings for control of the discharge, as follows:						
Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml/cpm) x (2)	) + (bkgd uCi/ml) = uCi/ml						
Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml/cpm) / (2)	:) + (bkgduCi/ml) =uCi/ml						
Gross Effluent Radiation Monitor Readings:	NOTE: Record actual reading (ie; Do Not Round Down						
Obtain At Least 2: Effluent Monitor Readings Per Discharge, AND At Least 1: Per 8 h	ir Shift For the Applicable Monitor:						
Date / Time /; Reading, is reading within range	er Yest J. Not j: KT Initials: SAP No						
Date / Time /: Reading Is reading within range							
Date / Time /: Reading: Is reading within range	27 Yes[] No[ J: RT Initials; SAP No						
Date / Time /: Reading is reading within range							
Date / Time /; Reading; Is reading within range							
Date / Time /: Reading is reading within range	s? Yes[] No[]: RT Initials: SAP No						
[ ] <u>IF</u> Effluent Monitor Readings are not within the Acceptable Range of Readings, <u>THE</u>	N contact Chemistry Supervision						
[ ] Chemistry Supervision has determined that the discharge should be terminated; and C	Operations has been notified to terminate the discharge.						
[] Chemistry Supervision has determined that the discharge may continue. Reasoning:							
Final Review of all Monitor Readings by Chemistry Supervision:							
Gross Calculated Monitor Reading = [ ] cpm, [ ] uCi	i/ml						
% Difference = (Max Obs Reading - Calc Reading) / Calc Reading =	%[]Sat[]Unsat						
NOTES: Sat = SATISFACTORY: % Difference is Within a Factor of Unsat = UNSATISFACTORY: % Difference is Outside the Generate a Condition Report	f 2 ( -50% to +100%) "Sat" Range.						
Reviewed By: SAP No:	Date:						

RTL# AB.520A

RWDA-L-99999T



í

ï

ţ

.

4.4

TRAINING MATERIAL TITLE:	Plot and Evaluate 1/M Data and Determine Required Only)	Actions (SRO
TRAINING MATERIAL NUMBE	<u>R:</u> 2AD-019	
PROGRAM TITLE:	Licensed Operator Training	
<u>COMPUTER CODE</u> :	2AD-019	
REVISION NUMBER:	0	
TECHNICAL REFERENCES:		
20M-50.4.D 20M-50.4.F		
INSTRUCTIONAL SETTING:	Classroom	
APPROXIMATE DURATION:	20 Minutes	
	`	
PREPARED BY: R. J. Br	rooks	Data
PEER REVIEW BY:		
		Date
APPROVED FOR USE:	Training Supervisor or Designee	Date

,

\*\*

#### TRAINING MATERIAL CHANGE FORM

Affected Training Materia	ls: 2AD-019						
Type of Change:							
Changes Requiring Revision	Learning Objective Ro	elated Change?	New Rev. # 0				
Changes Not Requiring Revision	The Change Does Not Objectives or Materia	Impact Learning Quality.	Existing Rev. #				
List/Description of Change	e(s):						
Reason for Change (s):							
APPROVALS:							
R. J. Brooks Prepared by Training Superintendent/Supervisor/Peer		Date	<b>NOTE</b> : Additions, deletions or changes to training materials must be reviewed for their possible impact to the Training Qualification Matrix. See Incumbent Impact Review,				
("Changes Not Requiring	Revision'' only)		NOBP-TR-1104.				

KTL#A2.040U	RTL	#A	5.	64	01	J
-------------	-----	----	----	----	----	---

,

JPM NUMBER: 2AD-019 JPM REVISION: 0	JPM TITLE: Plot and Actions (SRO Only)	Evaluate 1/M Data and Dete	ermine Required			
K/A REFERENCE: 2.1.43 JPM APPLICATION:	4.3 REQUALIFICATION FAULTED JPM	TASK ID: 1340-007-03- N 🛛 INITIAL EXAM 🛛 ADMINISTRAT	023 TRAINING TIVE JPM			
EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED FY:			
Perform Simulate	<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	BVT NRC Other:			
EVALUATION RESULTS						

EVALUATION RESULTS					
Performer Name:	Per	Performer SSN:			
TimeYesAllottedCritical:NoTime:	20 Minutes	Actual Time:	minutes		
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:					
OBSERVERS					
Name/SSN: Name/SSN:					
Name/SSN:	Name/SS	Name/SSN:			
EVALUATOR					
Evaluator (Print):	Date:				
Evaluator Signature:					

.

# **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	<ul> <li>Determine that 1/M data predicts &gt;500 pcm below ECP value for critical rod height. Determines No further rod withdrawal will be allowed, and the following actions must be taken:</li> <li>Insert all control rods to 0 Steps.</li> <li>Verify RCS Boron Concentration.</li> <li>Verify SDM</li> <li>DO NOT recommence S/LL without Plant Manager energyal</li> </ul>
RECOMMENDED STARTING LOCATION:	Classroom
<b>DIRECTIONS:</b>	You are to perform the task Evaluate 1/M data.
INITIAL CONDITIONS:	The Unit is in Mode 2. A reactor startup is in progress. Control Bank C is at 129 steps. Control Bank D is at 1 step. RCS Boron concentration is 1875 ppm.
INITIATING CUE:	The Unit Supervisor directs you to complete the 1/M plot per 2OM- 50.4.F data sheet 3 using the SR count rate data provided. Compare the 1/M data with the predicted ECP data and determine actions related to further rod withdrawal. Document any recommended actions in the box below. (Located on the candidate direction sheet)
REFERENCES:	20M-50.4.D, Reactor Startup From Mode 3 To Mode 2, Rev. 49 20M-50.4.F, Performing An Estimated Critical Position Calculation Rev. 7
TOOLS:	None
HANDOUT:	2OM-50.4.F, Performing An Estimated Critical Position Calculation. Rev. 7 partially completed Data Sheet 3 & Figure 1 2OM-50.4.D, Reactor Startup From Mode 3 To Mode 2, Rev. 49



2 When determining Control Rod Position, a straight vertical line should be drawn from the horizontal axis to the control bank steps.

FIGURE 1

#### **CANDIDATE DIRECTION SHEET**

#### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

Read:	
TASK:	You are to perform the task Evaluate 1/M data.
INITIAL CONDITIONS:	The Unit is in Mode 2. A reactor startup is in progress. Control Bank C is at 129 steps. Control Bank D is at 1 step. RCS Boron concentration is 1875 ppm.
INITIATING CUE:	The Unit Supervisor directs you to complete the 1/M plot per 2OM- 50.4.F data sheet 3 using the SR count rate data provided. Compare the 1/M data with the predicted ECP data and determine actions related to further rod withdrawal. Document any recommended actions in the box below.

# **RECOMMENDED ACTIONS:**

At this time, ask the evaluator any questions you have on this JPM.

When satisfied that you understand the assigned task, announce "I am now beginning the JPM".

Simulate performance or perform as directed the required task.	
Point to any indicator or component you verify or check and announce your obser	vations.

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.

•

.

4

JPM NUMBER: 2AD-019 JPM TITLE Plot and Evaluate 1/M Data and Determine Required IPM REVISION: 0 Actions (SRO Only)		
STEP	STANDARD	<b>ו</b> ריך
( "C" Denotes CRITICAL STEP )	(Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	,/U
	START TIME:	
1. Refer to Data sheet 3.	1.1 Applicant refers to data sheet 3 for count rate data.	
	COMMENTS:	
2.C Refer to 1/M plot.	2.1C Candidate evaluates count rate data from data sheet 3 and plots on the 1/M for 300, 325, 375, AND 385 total steps.	
	<b>EVALUATOR NOTE:</b> See Attached Answer Key for 1/M plot values.	
	COMMENTS:	
3.C Evaluate 1/M plot data	<ul> <li>3.1C Applicant determines that the 1/M plot predicts criticality</li> <li>&gt;500 pcm below ECP. Maximum rod height is Bank D at 40 steps versus ECP of Bank D 101 steps.</li> </ul>	
	COMMENTS:	
1		

JPM NUMBER: 2AD-019 JPM TI JPM REVISION: 0 Action	ITLE Plot and Evaluate 1/M Data and Determine Required         s (SRO Only)	
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	<u>\/U</u>
	<b>EVALUATOR CUE:</b> If necessary ask candidate to provide specific actions required.	
4.C Determines action for continued startup IAW 2OM-50.4.D Attachment 3 Action #4.	<ul> <li>4.1C Applicant determines that 1/M data indicates that criticality will occur &gt;500 pcm below the ECP.</li> <li>Insert all control rods to 0 steps.</li> <li>Verify RCS boron concentration.</li> <li>Verify SDM</li> <li>Do not continue without Plant Manager approval.</li> </ul> TERMINATING CUE: When the applicant makes a recommendation on continued startup, the evaluation for this JPM is complete.	
	COMMENTS:	
	STOP TIME:	

.

#### **OPERATIONS JOB PERFORMANCE MEASURE (JPM)**

TRAINING MATERIAL TITLE:	Prepare Partial OST [2OST-6.6] for Performance (SRO ONLY)
TRAINING MATERIAL NUMBER:	2AD-025
PROGRAM TITLE:	Licensed Operator Training
COMPUTER CODE:	2AD-025
REVISION NUMBER:	0

#### **TECHNICAL REFERENCES:**

NOP-LP-2601, Procedure Use And Adherence (Rev. 1) 2OST-6.6, PORV Isolation Valve Test and Position Check (Rev. 18)

**INSTRUCTIONAL SETTING:** 

Classroom

15 Minutes

APPROXIMATE DURATION:

PREPARED BY:	R. J. Brooks		
			Date
PEER REVIEW BY:			Date
APPROVED FOR USE:			
	Training	Supervi of or Designee	Date

### TRAINING MATERIAL CHANGE FORM

Affected Training Material	s: 2AD-025			
Type of Change:				
Changes Requiring Revision	Learning Objective Re	lated Change?	New Rev. # 0	
Changes Not Requiring Revision	The Change Does Not Objectives or Material	Impact Learning Quality.	Existing Rev. #	
List/Description of Change	e(s):			
Reason for Change (s):				
APPROVALS:				
Prepared by		Date	changes to training materials must be reviewed for their possible impact to the Training	
Training Superintendent/Security ("Changes Not Requiring D	upervisor/Peer Revision " only)	Date	Qualification Matrix. See Incumbent Impact Review, NOBP-TR-1104.	

.

JPM NUMBER: 2AD-025 JPM REVISION: 0	JPM TITLE: Prepare Partial OST [2OST-6.6] for Performance (SRO ONLY)		Performance (SRO
K/A REFERENCE: 2.1.20 JPM APPLICATION:	4.6 REQUALIFICATION FAULTED JPM	TASK ID: 1320-006-03- N 🛛 INITIAL EXAM 🛛 ADMINISTRAT	023 TRAINING TVE JPM
<b>EVALUATION METHOD:</b>	LOCATION:	TYPE:	ADMINISTERED BY:
<ul> <li>Perform</li> <li>Simulate</li> </ul>	<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	<ul> <li>BVT</li> <li>NRC</li> <li>Other:</li> </ul>

EVALUATION RESULTS				
Performer Name:		Performer SSN:		
Time Ves Critical: No	Allotted Time: 15 Min	utes	Actual Time:	minutes
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:				
	OBSERVER	S		
Name/SSN:	Nam	e/SSN:		
Name/SSN: Name/SSN:				
	EVALUATO	R		
Evaluator (Print):		I	Date:	
Evaluator Signature:		<mark>.</mark>		

RTL#A5.640U

.

# **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	All steps of 2OST-6.6 that relate specifically to 2RCS*MOV537 are omitted or marked N/A. (Answer Key provided to assist in this evaluation)
RECOMMENDED STARTING LOCATION:	Classroom
<b>DIRECTIONS:</b>	You are to perform the task Prepare a Partial OST for Performance.
INITIAL CONDITIONS:	Unit 2 is at 100% power. 2OST-6.6, PORV Isolation Valve Test and Position Check is on the Work Implementation Schedule (WIS) and is scheduled to be performed on your shift. PRZR PORV 2RCS*PCV455D is INOPERABLE but CAPABLE of being manually cycled. Technical Specification 3.4.11 required action A.1 has been completed and PORV 455D Motor Operated Isol Vlv 2MOV*MOV537 is CLOSED. All PORV Motor Operated Isol Vlvs were last stroked 70 days ago. The last ASME Valve remote position indication verification was performed 90 days ago on ALL PORV Motor Operated Isol Vlv.
INITIATING CUE:	As the Shift manager, IAW the guidance provided in NOP-LP-2601, Procedure Use And Adherence, Prepare 2OST-6.6, PORV Isolation Valve Test and Position Check for a Partial OST Performance. PORV 455D Motor Operated Isol Vlv 2MOV*MOV537 will NOT be tested. Return the marked-up OST to the evaluator. (Assume the evaluator will perform the second licensed SRO concurrence of your mark-ups).
REFERENCES:	NOP-LP-2601, Procedure Use And Adherence (Rev. 1) 2OST-6.6, PORV Isolation Valve Test and Position Check (Rev. 18)
TOOLS:	None
HANDOUT:	NOP-LP-2601, Procedure Use And Adherence (Rev. 1) 20ST-6.6, PORV Isolation Valve Test and Position Check (Rev. 18)

Read:

.

#### **CANDIDATE DIRECTION SHEET**

# \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

TASK:		You are to perform the task Prepare a Partial OST for Performance.	
INITIA	L CONDITIONS:	Unit 2 is at 100% power. 2OST-6.6, PORV Isolation Valve Test and Position Check is on the Work Implementation Schedule (WIS) and is scheduled to be performed on your shift. PRZR PORV 2RCS*PCV455D is INOPERABLE but CAPABLE of being manually cycled. Technical Specification 3.4.11 required action A.1 has been completed and PORV 455D Motor Operated Isol Vlv 2MOV*MOV537 is CLOSED. All PORV Motor Operated Isol Vlvs were last stroked 70 days ago. The last ASME Valve remote position indication verification was performed 90 days ago on ALL PORV Motor Operated Isol Vlv.	
INITIA	TING CUE:	As the Shift manager, IAW the guidance provided in NOP-LP-2601, Procedure Use And Adherence, Prepare 2OST-6.6, PORV Isolation Valve Test and Position Check for a Partial OST Performance. PORV 455D Motor Operated Isol Vlv 2MOV*MOV537 will NOT be tested. Return the marked-up OST to the evaluator. (Assume the evaluator will perform the second licensed SRO concurrence of your mark-ups).	
	At this time, ask the evaluator any questions you have on this JPM.		
	When satisfied that you understand the assigned task, announce "I am now beginning the JPM".		
	Simulate performance or perform as directed the required task. Point to any indicator or component you verify or check and announce your observations.		
	After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.		

.

JPM NUMBER: 2AD-025	JPM TI	LE: Prepare Partial OST [2OST-6.6] for Performance (SRO		
JPM REVISION: 0	ONLY)			
JPM NUMBER: 2AD-025       JPM TI         JPM REVISION: 0       ONLY)         STEP       ("C" Denotes CRITICAL STEP )         1. The Shift Manager or designated         SRO shall determine if the section or step will be designated as N/A or whether the section or step shall be performed.         The Shift Manager or designated		STANDARD       (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒       \$/U         START TIME:		
The Shift Manager or desi SRO shall document the d in the official record copy procedure.	gnated ecision of the	<ul> <li>Circles Partial OST</li> <li>Writes an explanation documenting why PORV 455D Motor Operated Isol VIv 2MOV*MOV537 will NOT be performed.</li> <li>EVALUTOR NOTE: Completing Test Results section may be deferred until test completion; therefore candidate may NOT perform this step as part of the JPM. This is acceptable.</li> <li>COMMENTS:</li> </ul>		

5

•

JPM NUMBER: 2AD-025	JPM TITLE	E: Prepare Partial OST [2OST-6.6] for Performance (SRO
STEP ("C" Denotes CRITICAL STEP)	S1	(Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ ▷/U
2.C If the Shift Manager or designated SRO has granted approval, the performer or responsible supervisor shall ensure that the procedure section or step is designated as N/A, initialed and dated.		<ol> <li>Candidate performs the following:         <ul> <li>On Page 9 item VII.A.1- places 70 days ago and initials in the space provided.</li> <li>On Page 9 item VII.A.2- places 90 days ago and initials in the space provided.</li> <li>On Page 9 item VII.A.3.a- places N/A.</li> </ul> </li> </ol>
	2. 2. 2. 2. 2. 2. 2. 2. 2. 2. 2. 2. 2. 2	<ul> <li>On Page 10 item VII.A.3.c- places N/A.</li> <li>On Page 13 item VII.C.1.b.1 places N/A.</li> <li>On Page 14 places N/A on ALL items.</li> <li>On Page 15 items g and h places N/A.</li> <li>On Page 16 items 2, 3, 4, 5, and 2.b.1 places N/A.</li> <li>On Page 17 places N/A on ALL items.</li> <li>On Page 18 items g and h places N/A.</li> <li>On Page 19 items 2, 3, 4, and 5, places N/A.</li> </ul>

JPM NUMBER: 2AD-025 JPM T JPM REVISION: 0 ONLY	ITLE: Prepare Partial OST [2OST-6.6] for Performance (SRO
	J
STEP ("C" Denotes CRITICAL STEP)	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ 5/U
3.C Marks all of step 3 N/A and initials and dates	3.1C On pages 19 through 22 places N/A for all of step 3, initials and dates.
	COMMENTS:
	<b>EVALUTOR NOTE:</b> Grader discretion may be required. The "critical" portions of this JPM are to clearly document the steps that are to be performed and the steps that are NOT to be performed. An answer key is provided to assist in evaluating this JPM.
	EVALUTOR CUE: That completes this JPM.

-

### OPERATIONS JOB PERFORMANCE MEASURE (JPM)

TRAINING MATERIAL TITLE:	Review/Approve Completed Surveillance of RHS Pump (SRO ONL Y)		
TRAINING MATERIAL NUMBER:	2AD-026		
PROGRAM TITLE:	Licensed Operator Training		
COMPUTER CODE:	2AD-026		
REVISION NUMBER:	0		

#### **TECHNICAL REFERENCES:**

-

OST-10.2 Residual Heat Removal Pump [2RHS\*P21B] Performance Test Rev. 10

INSTRUCTIONAL SETT	<u>ING</u> :	Classroom		
APPROXIMATE DURAT	<u>'ION</u> :	10 Minutes		<b>A T</b>
PREPARED BY:	R. J. Brooks			Date
PEER REVIEW BY:			<u> </u>	Date
APPROVED FOR USE:	· · · · · · · · · · · · · · · · · · ·	Training Super-	visor o Designee	Date

.

### TRAINING MATERIAL CHANGE FORM

Affected Training Material	s: 2AD-026	
Type of Change:		
Changes Requiring Revision	Learning Objective Related Change?	New Rev. # 0
Changes Not Requiring Revision	The Change Does Not Impact Learning Objectives or Material Quality.	Existing Rev. # New Change #
List/Description of Change	e(s):	
New JPM		
Reason for Change (s):		
APPROVALS:		
R. J. Brooks Prepared by	Date	<b>NOTE</b> : Additions, deletions or changes to training materials must be reviewed for their
Training Superintendent/S ("Changes Not Requiring	upervisor/Peer Date Revision'' only)	Qualification Matrix. See Incumbent Impact Review, NOBP-TR-1104.

•

JPM NUMBER: 2AD-026 JPM REVISION: 0	JPM TITLE: Review/Approve Completed Surveillance of RHS Pump				
K/A REFERENCE: 2.2.37	4.6	TASK ID: 132	20-011-03-	023	
JPM APPLICATION:	REQUALIFICATION		L EXAM	TRAINING	
$\boxtimes$	FAULTED JPM	ADMI	NISTRAT	IVE JPM	
EVALUATION METHOD: Perform Simulate	LOCATION: Plant Site Simulator Classroom	TYPE: Annual Requ Initial Exam JJT/TPE Training Other:	aal Exam	ADMINISTERED BY: BVT NRC Other:	
	EVALUATIO	ON RESULTS			
Performer Name:		Performer	SSN:		
Time 🗌 Yes Critical: 🔀 No	0 Minutes	Minutes Actual minutes Time:			
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:					
OBSERVERS					
Name/SSN:	Name/SSN:				
Name/SSN:	Name/SSN:				
EVALUATOR					
Evaluator (Print):	I	Date:	· · · · · · · · · · · · · · · · ·		
Evaluator Signature:					

#### **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	2RHS*P21B is declared inoperable based on unacceptable $\Delta$ P and vibrations.
RECOMMENDED STARTING LOCATION:	Classroom
<b>DIRECTIONS:</b>	You are to perform the task Review/Approve completed Surveillance of RHR Pump 2RHS*P21B to determine operability as defined by the acceptance criteria.
INITIAL CONDITIONS:	Unit 2 is in Mode 5 with RCS core exit thermocouple temperatures at 110°F. Surveillance 2OST-10.2 Residual Heat Removal Pump [2RHS*P21B] Performance Test has been completed by the RO and reviewed by the STA.
'NITIATING CUE:	Review/Approve completed Surveillance of RHR Pump 2RHS*P21B to determine operability as defined by the acceptance criteria. Document the results of your review in the comments section of the cover page.
REFERENCES:	2OST-10.2 Residual Heat Removal Pump [2RHS*P21B] Performance Test. Rev. 10
TOOLS:	None
HANDOUT:	2OST-10.2 Residual Heat Removal Pump [2RHS*P21B] Performance Test (Rev. 10) completed With unacceptable $\Delta$ P and vibrations.

1

#### OPERATIONS JOB PERFORMANCE MEASURE

#### **CANDIDATE DIRECTION SHEET**

#### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

Read:	
TASK:	You are to perform the task Review/Approve completed Surveillance of RHR Pump 2RHS*P21B to determine operability as defined by the acceptance criteria.
INITIAL CONDITIONS:	Unit 2 is in Mode 5 with RCS core exit thermocouple temperatures at 110°F. Surveillance 20ST-10.2 Residual Heat Removal Pump [2RHS*P21B] Performance Test has been completed by the RO and reviewed by the STA.
INITIATING CUE:	Review/Approve completed Surveillance of RHR Pump 2RHS*P21B to determine operability as defined by the acceptance criteria. Document the results of your review in the comments section of the cover page.

At this time, ask the evaluator any questions you have on this JPM.

When satisfied that you understand the assigned task, announce "I am now beginning the JPM".

Simulate performance or perform as directed the required task. Point to any indicator or component you verify or check and announce your observations.

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.

JPM NUMBER: 2AD-026 JPM REVISION: 0	TLE: Review/Approve Completed Surveillance of RHS Pump
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT) $\Rightarrow$ 3/U
	START TIME:
<ol> <li>Refers to appropriate procedure step.</li> </ol>	<ul> <li>1.1 Consult the Acceptance Criteria for acceptable performance.</li> <li>COMMENTS:</li> </ul>
2.C [2RHS*P21B], Residual Heat Removal Pump: Operates within the limits of ASME XI IST Program ( <b>[ITS]</b> T.S.5.5.4) as follows: Motor Vibration (Data Sheet 1)	<ul> <li>2.1 Compares Actual Motor Vibrations on Data Sheet 1 to Acceptable and Alert range.</li> <li>2.2C Determines Motor Inboard (2) Axial is GREATER THAN Acceptable and Alert Range</li> <li>COMMENTS:</li> </ul>
<ul> <li>3.C [2RHS*P21B], Residual Heat Removal Pump: Operates within the limits of ASME XI IST Program ([ITS] T.S.5.5.4) as follows: Pump Vibration (Data Sheet 1)</li> </ul>	<ul> <li>3.1. Compares Actual Pump Vibrations on Data Sheet 1 to Acceptable and Alert range.</li> <li>3.2C Determines Pump Inboard (3) Horizontal and Vertical are BOTH greater than Acceptable and Alert Range.</li> <li>COMMENTS:</li> </ul>

,

JPM NUMBER: 2AD-026 JPM REVISION: 0 JPM T	ITLE: Review/Approve Completed Surveillance of RHS Pump	
STEP ("C" Denotes CRITICAL STEP)	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ 3/	U
<ul> <li>4.C [2RHS*P21B], Residual Heat Removal Pump: Operates within the limits of ASME XI IST Program ([ITS]T.S. 5.5.4) as follows: Delta-P (Data Sheet 2)</li> </ul>	<ul> <li>4.1 Compares calculated Delta P on Data Sheet 2 to Acceptable Range.</li> <li>4.2C Determines calculated Delta P is LESS THAN Acceptable Range.</li> <li>COMMENTS:</li> </ul>	
<ul> <li>5. [2RHS*4], Residual Heat Removal Pump 21B Disch Check Vlv, operates within the requirements of ASME XI IST Program ([ITS] T.S. 5.5.4) for forward flow (full-stroke) at a flowrate of 4000 gpm (Step VII.B.9).</li> </ul>	<ul> <li>5.1 Reviews step VII.B.9 of OST to determine if 4000 gpm was achieved.</li> <li>5.2 Determines step was completed satisfactorily.</li> <li>COMMENTS:</li> </ul>	
<ul> <li>6.C [2SIS*141], SI Accum Tank 21C Check to Loop C Cold Leg, partia stroke forward flow test. (Check valve operation is acceptable IF III.A.1 above is met.) ([ITS] T.S. 5.5.4)</li> </ul>	<ul> <li>6.1C Determines DOES NOT MEET Acceptance criteria based on unacceptable Δ P and vibrations.</li> <li>COMMENTS:</li> </ul>	

JPM NUMBER: 2AD-026 JPM REVISION: 0	JPM TIT	LE: R	eview/Approve Completed Surveillance of RHS Pump		
STEP ( "C" Denotes CRITICAL STEP )		STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ √U			
<ul> <li>RHR heat exchanger outlet temperature indication conforms with the expected temperature based on current plant conditions. (Data Sheet 3)</li> </ul>		7.1	Compares the Data from Data sheet 3 to initial conditions of core exit thermocouples of 110°F. Determines that these are as expected.		
		COMN	MENTS:		
<ol> <li>RHR heat exchanger outlet temperatures and RCS cold temperature are within 25° each other. (Data Sheet 3)</li> </ol>	t 1 leg F of	8.1	Compares Data from Data sheet 3; and, determines that RHR heat exchanger outlet temperatures and RCS cold leg temperature are within 25°F of each other.		
		COM	MENTS:		

JPM NUMBER: 2AD-026 JPM REVISION: 0	JPM TITLE: Review/Approve Completed Surveillance of RHS Pump
STEP ("C" Denotes CRITICAL STEP)	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ 5/U
9.C Complete the front cover sheet.	<ul> <li>9.1 Places a checkmark in the Problems encountered block of cover page.</li> <li>9.2C Lists the following problems on OST problem sheet: <ul> <li>Motor Inboard (2) Axial vibration is GREATER THAN Acceptable and Alert Range</li> <li>Pump Inboard (3) Horizontal and Vertical vibrations are BOTH greater than Acceptable and Alert Range.</li> <li>Calculated Delta P is LESS THAN Acceptable Range.</li> <li>[2SIS*141], SI Accum Tank 21C Check to Loop C Cold Leg, partial stroke forward flow test. (Check valve operation is unacceptable (Due to problems listed above).</li> </ul> </li> <li>COMMENTS:</li> </ul>
	EXAMINER CUE: That completes this JPM
	STOP TIME:

TRAINING MATERIAL TITLE:	Review/Approve LW Discharge (SRO ONLY)		
TRAINING MATERIAL NUMBER:	2AD-023		
PROGRAM TITLE:	Licensed Operator Training		
COMPUTER CODE:	2AD-023		
<b>REVISION NUMBER</b> :	0		

#### **TECHNICAL REFERENCES:**

2OM-25.4.L, Discharging Steam Generator Blowdown Evaporator Test Tank [2SGC-TK23A(B)] Contents To Cooling Tower Blowdown. Rev. 24

INSTRUCTIONAL SETTING:

Classroom

APPROXIMATE DURATION: 15 Minutes

PREPARED BY	R I Brooks	
		Date
PEER REVIEW BY:		Date
APPROVED FOR USE:	Training Supervisor Training Supervisor	Date

.

# TRAINING MATERIAL CHANGE FORM

Affected Training Materials: 2AD-023							
Type of Change:							
Changes Requiring Revision	Learning Objective	Related Change?	New Rev. # 0				
Changes Not Requiring Revision	The Change Does N Objectives or Mater	Not Impact Learning rial Quality.	Existing Rev. #				
List/Description of Chang Reason for Change (s):	e(s):						
APPROVALS:							
Prepared by		Date	<b>NOTE:</b> Additions, deletions or changes to training materials must be reviewed for their possible impact to the Training				
Training Superintendent/S ("Changes Not Requiring	upervisor/Peer Revision" only)	Date	Qualification Matrix. See Incumbent Impact Review, NOBP-TR-1104.				
RTL#A5.640	ΟU						
------------	----						
------------	----						

~

JPM NUMBER: 2AD-023 JPM REVISION: 0	JPM TITLE: Review/	Approve LW Discharge (SR	O ONLY)
K/A REFERENCE: 2.3.11 JPM APPLICATION: 🔀	4.3 REQUALIFICATION FAULTED JPM	TASK ID: 1300-009-03- N 🛛 INITIAL EXAM	023 TRAINING TVE JPM
EVALUATION METHOD: Perform Simulate	LOCATION: Plant Site Simulator Classroom	TYPE: Annual Requal Exam Initial Exam OJT/TPE Training Other:	ADMINISTERED BY: BVT NRC Other:

EVA:	JUATION RESULTS	,		
Performer Name:	Perform	Performer SSN:		
TimeYesAllottedCritical:NoTime:	15 Minutes	Actual Time: minutes		
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:				
	OBSERVERS			
Name/SSN:	Name/SSN:			
Name/SSN:	Name/SSN:			
	EVALUATOR			
Evaluator (Print):		Date:		
Evaluator Signature:		-		

.

# **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	RWDA-L-99999T is <b>NOT</b> approved for the following reasons: Wrong tank volume and Wrong alternate radiation monitor alarm setpoint calculation.
RECOMMENDED STARTING LOCATION:	Classroom
<b>DIRECTIONS:</b>	You are to perform the task Review/Approve LW Discharge.
INITIAL CONDITIONS:	Unit 2 is at 100% power. RWDA-L-99999T has been prepared for discharging Steam Generator Blowdown Evaporator Test Tank 2SGC- TK23B. Steam Generator Blowdown Evaporator Test Tank 2SGC- TK23B level is 130 inches. Procedure 2OM-25.4.L, Discharging Steam Generator Blowdown Evaporator Test Tank [2SGC-TK23A(B)] Contents To Cooling Tower Blowdown has been completed through step IV.A.11.
INITIATING CUE:	Approve RWDA-L-99999T IAW procedure 2OM-25.4.L, Discharging Steam Generator Blowdown Evaporator Test Tank [2SGC-TK23A(B)] Contents To Cooling Tower Blowdown step IV.A.12. Document the results of your approval in appropriate steps of 2OM- 25.4.L AND in the block below. (Located on candidate direction sheet)
REFERENCES:	2OM-25.4.L, Discharging Steam Generator Blowdown Evaporator Test Tank [2SGC-TK23A(B)] Contents To Cooling Tower Blowdown Rev. 24 Curve Book for 2SGC-TK23B
TOOLS:	Calculator
HANDOUT:	<ul> <li>RWDA-L-99999T filled out with the following errors:</li> <li>18,000 gal volume for the tank instead of 17,705 gals.</li> <li>Wrong alternate radiation monitor alarm setpoint calculation. (1.88E.<sup>3</sup> instead of 1.88E<sup>4</sup></li> <li>2OM-25.4.L, Discharging Steam Generator Blowdown Evaporator Test Tank [2SGC-TK23A(B)] Contents To Cooling Tower Blowdown filled out up to step IV.A.12</li> </ul>

1

## **CANDIDATE DIRECTION SHEET**

	* THIS	SHEET TO BE GIVEN TO CANDIDATE *
	Read:	
TASK:		You are to perform the task Review/Approve LW Discharge.
INITIAI	L CONDITIONS:	Unit 2 is at 100% power. RWDA-L-999997 has been prepared for discharging Steam Generator Blowdown Evaporator Test Tank 2SGC- TK23B. Steam Generator Blowdown Evaporator Test Tank 2SGC- TK23B level is 130 inches. Procedure 20M-25.4.L, Discharging
INITIAT	FING CUE:	Steam Generator Blowdown Evaporator Test Tank [2SGC-TK23A(B)] Contents To Cooling Tower Blowdown has been completed through step IV.A.11. Approve RWDA-L-99999T IAW procedure 2OM-25.4.L, Discharging Steam Generator Blowdown Evaporator Test Tank [2SGC-TK23A(B)] Contents To Cooling Tower Blowdown step IV.A.12. Document the results of your approval in appropriate steps of 2OM- 25.4.L AND in the block below.
RESUL	TS:	
	At this time, ask the eval	uator any questions you have on this JPM.
	When satisfied that you u	inderstand the assigned task, announce "I am now beginning the JPM".
	Simulate performance or Point to any indicator or	perform as directed the required task. component you verify or check and announce your observations.

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator. ٠

IPM NUMBER: 2AD-023 JPM REVISION: 0	JPM TIT	TLE: Review/Approve LW Discharge (SRO ONLY)	
STEP ( "C" Denotes CRITICAL STEP )		STANDARD (Indicate "S" FOR SAT_or "U" FOR UNSAT)⇒ S	5 U
		START TIME:	
<ol> <li>After the RWDA-L is app by Radiation Protection A Chemistry, have the SM of review the RWDA-L to ce the following: Verify that the Unit 1 SM has signed the RWDA-L "Approved By".</li> </ol>	oroved ND or US onfirm <b>OR</b> US at	<ul> <li>1.1 Verifies Unit 1 Shift Manager has signed the appropriate block on the RWDA-L</li> <li>COMMENTS:</li> </ul>	
2.C The tank data is correct.		<ul> <li>2.1C Refers to Tank Curve book and determines that the tank data is INCORRECT. The correct volume for 130 inches should be 17,705 gals. NOT 18,000 gals.</li> <li>EVALUTOR NOTE: Candidate may also refer to recirculation time of the tank. The recirculation time is more than the minimum required.</li> <li>COMMENTS:</li> </ul>	
3. Verify Chemistry has au the RWDA-L.	thorized	<ul> <li>3.1 Verifies Chemistry has signed the appropriate block on the RWDA-L</li> <li>COMMENTS:</li> </ul>	

JPM ]	NUMBER: 2AD-023 REVISION: 0	JPM TI	LE: R	eview/Approve LW Discharge (SRO ONLY)	
STEP ("C"	Denotes CRITICAL STEP )		STANI	DARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	 s/U
4. Verify Radiation Protection has authorized the RWDA-L.		<ul> <li>4.1 Verifies Rad Pro has signed the appropriate block on the RWDA-L</li> <li>COMMENTS:</li> </ul>			
5.C	All hand calculations ar correct.	re	5.1C	Determines that the alternate radiation Alarm setpoint calculation is <b>INCORRECT</b> . <b>EVALUTOR NOTE:</b> 4000/85 X 4.0E <sup>-6</sup> should equal 1.88E <sup>-4</sup> NOT 1.88E <sup>-</sup> 3 AND this also makes 1.88E <sup>-4</sup> X .7 INCORRECT.	
6.	Verify the effective per the RWDA-L has <b>NOT</b>	iod for 'expired.	6.1 COMN	Determines RWDA-L is still effective. <b>EVALUTOR NOTE:</b> IAW P&L I on page 3 the RWDA-L is effective for 72 hours from the time the sample was drawn MENTS:	

٠

JPM NUMBER: 2AD-023 JPM REVISION: 0	JPM TIT	LE: Review/Approve LW Discharge (SRO ONLY)
<ul> <li>STEP ("C" Denotes CRITICAL STEP)</li> <li>7.C If the tank is NOT accepta discharge, an approval sig is NOT required.</li> </ul>	ible for nature	STANDARD       (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒       S       U         7.1C       In the remarks section places the following information:       •       Mark the RWDA-L VOID       •         •       Tank volume is incorrect.       •       •       •       •
reason, initial, AND Retu RWDA-L to Radiation Pro (Otherwise N/A this step).	n the otection.	<ul> <li>Fradition moments and a serpoint calculations are incorrect</li> <li>Candidate initials</li> <li>EVALUTOR NOTE: Some discretion is required when grading this step of the JPM. It is NOT required to place the exact words listed here for the tank volume and radiation monitor alarm setpoint. However, it is critical the candidate documents all the errors on the form</li> </ul>
		COMMENTS:
		EVALUTOR CUE: That completes this JPM.
		STOP TIME:

Form 1/2-ENV-05.04.F01, Rev 0 (Page 1 of 5) RWDA-L: Part 1, Summary of Discharge Data Beaver Valley Power Station-2

RTL#A9.5202

RWD'A-] ~999997

This permit authorizes the discharge of a maximum of 18,000 gallons from tank 2SGC-TK23B at a maximum discharge rate of 85.0 gpm to the environment via U1 blowdown with a minimum total cooling tower blowdown of 4000.0 gpm at Unit 1 and Unit 2 with a monitor ALERT alarm setsoin of 1.22E-03 uCi/ml and a monitor HICH alarm setpoint of 1.74E-03 (3) uCi/ml on 2SGC-RQ100 (See Below for Alternate Alarm Setpoints) TODAY Yesterday 0001 hours to Yesterday 2001 hours This tank was recirculated from Yesterday 0001 hours to Yesterday 20 (at which time it was sampled) for a total of 1200 minutes. Prepared By Reviewed By Remarks: D. B. Gamma TODAY TODAY J. B. Heta Signature Date Peer Review Sig Datė Cooling Tower Flow Set Monitor Source 1Y1CO **U1&U** Check Unit Monitor Alarms Adjusted Approved By Approved By m Shilty (UI) TODAY ALERT Ul Shift Mgr Sig Date U2 Shift Mqr Siq Date Alternate Alarm Setpoints Refer to 1/2-ENV-05.04 (Alarm CT B/D) gpm) ---- X 4.00E-06=HIGH = (  $1.88 E^{-3}$  uCi/ml) A000 85 (Max Exp Disch) gpm)  $0.70 = ALBRT = (1.32 E^{-3} uCi/ml)$ HIGH Х ischarge Record Discharge Start Discharge Stop Vol. CT Flow, gpm dy. yr hr mn levl ini dy yr hr mn|levl|ini TOTAL mo mo gal. Discharge Time, min = Discharged Volume, gal = Monitor Alarms Reset Reviewed By Reviewed By ALRAT NA HIGH NA Init Ul Shift Mgr Sig Date Init U2 Shift Mgr Sig Date Post Release Review gpm) X C.T. Flow ( min) = ( gal) Discharge Time Dilution Volume gpm) = (C.T. Flow min) / 4.43E+00 =(gal) Discharge Vol Post Time Dose Corr Composite Size File Update Post Review ml -----/-----Init date Init date Signature Date

EXERCISE MODE ONLY

Porm 1/2-BWV-05.04.P01, Rev 0 (page 2 of 5) RWDA-L: Part 2, Tank Analysis Beaver Valley Power Station-2

TANK: 2SGC-TK23B TANK VOLUME: 17705.3 gal, 6.70K+07 ml LEVEL: 130.0 in AMPLE IDENTIFICATION: 20080422005 TOTAL C.T. PLOW: 4000.0 gpm

NUCLIDE CR-51 CO-58 CO-60 FE-59 AG-110N SB-124 SB-125	Concentration uCi/ml 5.328-06 3.962-05 1.478-06 1.458-06 5.208-07 8.828-06 1.118-05	OEC Fraction* 1.06E-03 1.98E-01 4.90E-02 1.45E-02 8.66E-03 1.26E-01 3.70E-02	Count Rate 1.078+02 7.218+03 3.508+02 1.838+02 2.228+02 2.378+03 1.688+03	BPA-RQ Fraction 3.56B-07 2.65B-04 9.86E-06 3.48B-06 3.48B-06 5.91B-05 5.91B-05 7.44E-05
SB-112	1.115-05	3.708-02	1.688+03	7.448-05

H-3	1.408-02	1.408+00		9.38B-03
 TOTALS	1.41B-02	1.838+00	1.21 <b>B+04</b>	9.81B-03

\* undiluted

Total Activity = 9.43B+05 uCi

MAXIMUM DISCHARGE FLOW RATE = 8.508+01 gpm \*\*\*SET TO MAXIMUM\*\*\*

Dilution Factor = 4.71E+01

#### NOBLE GAS CONCENTRATION IN RIVER = 0.00E+00 uCi/ml

EXERCISE MODE ONLY

Form 1/2-ENV-05.04.F01, Rev 0 (page 3 of 5) RWDA-L: Part 3, Pre-Release Dose Projections Beaver Valley Power Station-2 (All Dose Values in mRem)

RTL#A9.520A

RWDA-L-99999	I
--------------	---

NUCLIDE CR-51 CO-58 CO-60 FE-59 AG-110M SB-124 SB-125	CONCENTRATION 5.32E-06 3.96E-05 1.47E-06 1.45E-06 5.20E-07 8.82E-06 1.11E-05	BONE 0.00E+00 0.00E+00 3.71E-05 1.21E-08 1.71E-06 1.37E-06	LIVER 0.00E+00 8.71E-05 9.31E-06 8.73E-05 1.12E-08 3.23E-08 1.53E-08	TOTAL BODY 1.67E-07 1.95E-04 2.05E-05 3.34E-05 6.65E-09 6.75E-07 3.28E-07	THYROID 9.96E-08 0.00E+00 0.00E+00 0.00E+00 0.00E+00 4.14E-09 1.40E-09	XIDNEY 3.678-08 0.008+00 0.008+00 0.008+00 2.208-08 0.008+00 0.008+00	LUNG 2.218-07 0.008+00 1.988-05 0.008+00 1.338-06 1.338-06 1.068-06	GI-LLI 4.198-05 1.77E-03 1.74E-04 2.91E-04 4.58E-06 4.84E-05 1.51E-05
FB-55 SR-89 SR-90 H-3 G.Alpha	0.008+00 0.008+00 0.008+00 1.408-02 0.008+00	0.008+00 D.008+00 O.008+00 O.008+00 O.008+00 O.008+00	0.008+00 0.008+00 0.008+00 9.308-05 0.008+00	0.008+00 0.008+00 0.008+00 9.308-05 0.008+00	0.008+00 0.008+00 0.008+00 9.308-05 0.008+00	0.00E+00 0.00E+00 0.00E+00 9.30E-05 0.00E+00	0.008+00 0.008+00 0.008+00 9.308-05 0.008+00	0.008+00 0.008+00 0.008+00 9.308-05 0.008+00
PROJECTED UNIT 1/2 PROJECTED	RELEASE DOSE = RELEASE DOSE =	4.028-05 2.018-05	2.77B-04 1.38B-04	3.43B-04 1.71B-04	9.318-05 4.658-05	9.30B-05 4.65E-05	1.15E-04 5.77E-05	2.44E-03 1.22E-03
Unit 1 Curren UNIT 1 PROJECTE Unit 2 Curren UNIT 2 PROJECTE	t Month Dose = D MONTH DOSE = t Month Dose = D MONTH DOSE =	6.31E-04 6.51E-04 6.31E-04 6.51E-04	4.738-03 4.868-03 4.738-03 4.868-03	3.828-03 3.998-03 3.828-03 3.998-03	2.778-03 2.818-03 2.778-03 2.818-03	3.94E-03 3.99E-03 3.94E-03 3.99E-03	2.808-03 2.868-03 2.808-03 2.868-03 2.868-03	6.28E-03 7.50E-03 6.28E-03 7.50E-03
Unit 1 Current UNIT 1 PROJECTED Unit 2 Current UNIT 2 PROJECTED	Quarter Dose = QUARTER DOSE = Quarter Dose = QUARTER DOSE =	6.318-04 6.518-04 6.318-04 6.518-04	4.738-03 4.868-03 4.738-03 4.868-03	3.82E-03 3.998-03 3.82E-03 3.99E-03	2.77E-03 2.81E-03 2.77E-03 2.81E-03	3.948-03 3.998-03 3.948-03 3.998-03	2.80E-03 2.86E-03 2.80E-03 2.86E-03	6.288-03 7.508-03 6.288-03 7.508-03
Unit 1 Currey UNIT 1 PROJECTI Unit 2 Currey UNIT 2 PROJECTI	nt Year Dose = ED YEAR DOSE = It Year Dose = ED YEAR DOSE =	2.82E-02 2.83E-02 2.82E-02 2.83E-02 2.83E-02	5.958-02 5.968-02 5.958-02 5.968-02 5.968-02	3.82B-02 3.84B-02 3.82B-02 3.84E-02 3.84E-02	8.84E-03 8.89E-03 8.84E-03 8.84E-03 8.89E-03	3.23E-02 3.23E-02 3.23E-02 3.23E-02 3.23E-02	1.26E-02 1.26E-02 1.26E-02 1.26E-02	2.928-02 3.058-02 2.928-02 3.058-02

sum of the RQ's is < 1; this is not considered a Reportable Quantity.

EXERCISE MODE ONLY

#### Form 1/2-ENV-05.04.F01, Rev 0 (Page 4 of 5)

ĥ

-----

RWDA-L: Part 4, Checklist, Pre-Release Data and Alternate Alarm Setpoint Determination Beaver Valley Power Station - 1/2 RWDA-L-999991

Initials AB : Pre-I	Release Data obtained	from Operations [Ref. procedure	1/2-ENV-05.04)	
Initials Hag : Sam	ples obtained & Valve	Verifications performed [Ref: proc	edure 1/2-ENV-05.01]	
Initials P48 : Sam	ples analyzed [Ref: pr	ocedure 1/2-ENV-05.25]		
Initials PGG Sam	ple bottles marked wit	h the RWDA-L number (Ref: proce	edure 1/2-ENV-05.01]	
Initials PG - RWL	JA-L prepared via the	LIQDIS computer Code [Ref. proc	edure 1/2-ENV-05.04]	
Initials PLAS RMF	A-L turned-over to Co	Citral Room Shift Manager of Linit	P-4.02.040.FUT of 2-HPP-4.02.022.FUT & 2	-HPP-4.02.037.F01
Initials : Efflu	ent Monitor Readings	obtained during discharge IRef. Fr	Supervisor [Ker. procedure (12-ENV-05.04]	
RWDA-L Pre-Release	se Data: Complete	this portion of the form PRIO	R to entrance into the LIQDIS Comput	er Code
Source of Discharge:	[] <u1> Unit 1</u1>		M <u2> Unit 2</u2>	
Tank	[ ] <1> for 1LW-TH	<-6A, or { } <2> for 6B	[ ] <1> for 2LWS-TK21A, or [ ] <2> for	21B
Identification:	[]<3> for 1LW-TH	<-3A, of { } <4> for 3B	] <3> for 2SGC-TK21A, or [ ] <4> for	218
	1 1<5> for 1LW-TH	<-5A, or   ] <6> for 5B	L 1<5> for 2SGC-TX23A or bitse> for	238
	1 3 <7> for 11 W-TH	(-74 or [] c8> for 7P		- N/A
	1 c7b (ex Others Balance			
Note: 050		es (e.g., Chemical Waste Sump)	Note: Use   ] <1> for Other Releases (	.g.: Fire Sump)
Tank Volume: 7770	S-S_gallons		Tank Level: 1 DO. 0     feet	or (Vinches
Recirculation Start: YE	STERDAY 0001 to	o YESTERDAY 2001 hours	Sample Time: YESTERDAY 2001	hours
Sample ID: []Unit 1 S	ample ID No.	or (4 Unit 2 Sample ID N	20080422005	
Minimum CT Flow from I	Unit 1 and Unit 2: 4	000 gpm (As a Guide, O	perations will provide this value based on the "L	w Alarm Setpoint" minus - 500 gp
Discharge Path: [-/ <u1< td=""><td>&gt; Send Liquid Waste</td><td>to Unit 1 CT Blowdown, or [ ] <u:< td=""><td>2&gt; Send Liquid Waste to Unit 2 CT Blowdov</td><td>/n</td></u:<></td></u1<>	> Send Liquid Waste	to Unit 1 CT Blowdown, or [ ] <u:< td=""><td>2&gt; Send Liquid Waste to Unit 2 CT Blowdov</td><td>/n</td></u:<>	2> Send Liquid Waste to Unit 2 CT Blowdov	/n
Sample	OTE: For Independer	nt sampling, record the		
Concentrations I m	gaest hucilde conce	Atration from each sample	Independent/Replicate	Sample Comparison;
Particulates	ucimi N	oble Gas uCi/mi	[] No radiation monitor available for the	discharge path.
Na-24	A	<u>s-41</u>	See ODCM procedure 1/2-ODC-3.0	3, Table 3.3-12, Action 23)
Cr-51 3.314 E	-6 K	ir-85	[] Replicate sample was requested by	anamistry supervision:
Mn-54	×	e-131m	(See NRC Regulatory Guide 9.15, S	chon (C.5)
Co-57	X	e-133	UCUMI = Total	stopa concentration from 1st Sam
Co-58 3.961	E-5   x	e-133m	Ling in Oly Shin	mma concentration from 2nd Sam
Co.50 1.471	E-6	0.135		
1400	F-C	e-135	% Diff = 1051 (1st	) minus (2nd
Fe-59 11-100		e-135m		·
Zn-65	(5	6-122 3.343E-6	The total gamma concentration of	I the 1st & 2nd samples shall
Zr-97 / Nb-97	1)5	n-117m 2,455 E-7	Agree within a factor of 2/Le . % C	liff is between -50% to +188%)
Mo-99 / Tc-99m		these soulicound day and	$\mathcal{V}$	
no-our riak		net in LEODER LE /		
Ag-110m 5.1 78	<u>}</u>	real . Va Prace	ADMINISTRATIVE	
Sb-124 8.82	15-6 / 7	entered into rime	Reprocessing is not practical per Shil	t Manager
So-125 1.110	E-5 11	12- ENV-01.05. FOR 10-	/ IF Administrative Guide Reliet is obta	ined from Shift-Manager, THEN
1-131		release artent detamintenting	1.23-00	In In
7- 05 / NH- 05				A A A A A A A A A A A A A A A A A A A
T1-22 1 IND-22	<u></u>	IE-4, reprocess, or obtain Adm	inistrative Guide Relief, as shown >>>>	to address the heed to reduc
Cs-134	<u>If≥</u>	3E-6, reprocess, or obtain Adm	iinistrative Guide Relief, as shown >>>>	existing Siministrative Guid
Cs-137	<u> </u> [ >	4E-6, reprocess, or obtain Adm	inistrative Guide Relief, as shown >>>>	values for future discharge
otal	_			during the pertinetian land
Particulate 7,19E	-5 1	1E-4, reprocess or obtain Ad-	inistrative Guide Delief as about the	yumny the applicable calend
The second secon	" <u>_</u>	Toprocess, or bolain Adm	Announte Guide Kener, 45 Shown >>>>	month, quarter(s), and year
Prepared By: 7-65	700		SAP 10 No.: 12345	Date : TODAY
Peer Review Signature	Sparell- Can	bell	SAR ID No. 45679	D-1-
				TODAY
Alternate Alarm Setp	oint Determination	: Complete this portion of the	e form AFTER exit from the LIQDIS C	omputer Code
] RM-1LW-104: Is Total	Particulate >3.14E-3	UCI/ml? []YES []NO	[ ] IF YES, THEN Alternate Alarm Setp	oints SHALL NOT be used
) RM-1LW-116: Is Total	Particulate >7.33E-3	UCIMI? LIVES LINO	KI IF NO, THEN Alternate Alarm Seton	nts MAY be used
1 25GC-R0100 In Tota	Particulate >1 1AE 2			
		UCUTITY LYES ANNO	See procedure 1/2-ENV-05.04 for a	dditional guidance
repared By: P. 15.		٤	SAP ID No. 12345	Date : TODAY
eer Review Signature	SQ. Mara 1	.100	45678	
	- unall up?	nee		Date: IODAT

Reaver Valley Power Station - 1 / 2	, L	Tank Identification:	2560-	TK738
			2300	
Discharge Period		Se	RWDA Cover S	heet for Actual Times
Initial Start Date/Time:	Final Stop	Date/Time:		
Efficient Radiation Monitor & Determination of Acceptable Ra	nge of Readin	gs During Disch	irge:	
[] Unit 1 Liquid Waste Tank Discharge via [RM-1LW-104]:		RM-1LV	/-104 bkgd =	;pm
RWDA-L Count Rate: Form 1/2-ENV-05.04.F01 (page 2 of 5) =	net cpm	RM-1LW-104	Gross HSP =	:pm
NOTE: MDCR = Minimum Detectable Count Rate	Į	RM-1LW-104 G	oss HHSP =	pm_
[]] <u>F</u> the RWDA-L Count Rate is ≤1,141 net cpm (MDCR), <u>THEN</u> the discharg	e is controlled by t	he alarm setpoints (N	o further calcula	ations required).
[] IF the RWDA-L Count Rate is >1,141 net cpm, THEN determine the Accept	table Range of Re	eadings for control of	the discharge, a	as follows:
Maximum = (RWDA-L Count Ratecpm) x (2) + (bkgd	cpm	a) =	cpm	
Minimum ≈ (RWDA-L Count Rate cpm) / (2) + (bkgd	срп	n) =	cpm	
[ ] Unit 1 Laundry & Shower Drain Tank Discharge via [RM-1LW-1*	16]:	RM-1LV	/-116 bkgd =	com
RWDA-L Count Rate: Form 1/2-ENV-05.04.F01 (page 2 of 5) =	net cpm	RM-1LW-116	Grøss HSP =	epm.
NOTE: MDCR = Minimum Detectable Count Rate		RM-1LW-116 G	oss HHSP =	com
[ ] IF the RWDA-L Count Rate is ≤236 net cpm (MDCR), THEN the discharge	is controlled by the	alarm setpoints (No	further calculati	ons required).
[ ] IF the RWDA-L Count Rate is >236 net cpm, THEN determine the Accepta	ble Range of Rea	dings for control of th	ne discharge, as	follows:
Maximum ≈ (RWDA-L Count Rate cpm) x (2) + (bkgd	cpm	n) =	cpm	
Minimum = (RWDA-L Count Rate cpm) / (2) + (bkgd	cpm	n) =	cpm	
[ ] Unit 2 Liquid Waste Tank Discharge via [2SGC-RQ100]:		2SGC-RQ	100 bkgd =	uCaml
RWDA-L Count Rate: Form 1/2-ENV-05.04.F01 (page 2 of 5) =	net.cpm	25GC-RQ100 G	oss ASP =	uCi/ml
NOTE: MDCR = Minimum Detectable Count Rate		2SGC-RQ100 Gr	oss HSP =	uCi/ml
I 1 IF the RWDA-L Count Rate is <247 net com (MDCR), THEN the discharge i	is controlled by the	alarm setpoints (No	further calculati	ons required).
		, , ,		. ,
[] IF the RWDA-L Count Rate is >247 net cpm, THEN determine the Acceptal	ble Range of Rea	dings for control of t	ie discharge, as	follows:
[] IF the RWDA-L Count Rate is >247 net cpm, <u>THEN</u> determine the Acceptal Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/mL	ble Range of Rea /cpm) x (2) + (bkgd	dings for control of t	ne discharge, as ml) =	follows: uCi/ml
[] <u>IF</u> the RWDA-L Count Rate is >247 net cpm, <u>THEN</u> determine the Acceptal Maximum ≈ (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/m	ble Range of Rea /cpm) x (2) + (bkgo l/cpm) / (2) + (bkgo	d <b>ings f</b> ar cantral of tł duCi/ duCi/	e discharge, as ml) = ml) =	follows: uCi/ml uCi/ml
[ ] IF the RWDA-L Count Rate is >247 net cpm, <u>THEN</u> determine the Accepta Maximum ≈ (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/m Gross Effluent Radiation Monitor Readings: Obtain At Least 2 Effluent Monitor Readings Per Discharge, <u>AND</u> At Least	ble Range of Rea /cpm) x (2) + (bkg l/cpm) / (2) + (bkg l/cpm) / R N N N	dings for control of t d uCi/ d uCi/ IOTE: Record actua For the Applicable N	e discharge, as ml) = ml) = reading (ie; D ionitor;	follows: uCi/mi <u>uCi/mi</u> c.Not Round Down)
I IF the RWDA-L Count Rate is >247 net cpm, <u>THEN</u> determine the Accepta Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/m Gross Effluent Radiation Monitor Readings: Obtain At Least 2 Effluent Monitor Readings Per Discharge, <u>AND</u> At Least Date / Time /: Reading; Is reading w	ble Range of Rea /cpm) x (2) + (bkgd //cpm) / (2) + (bkgd) / (bkgd	dings for control of the duCi/ duCi/ COTE: Record actual For the Applicable N   No[]: RT Initials	e discharge, as ml) = ml) = reading (ie; D conitor;; SAP N	follows: uCi/mi uCi/mi o Not Round Down3
I IF the RWDA-L Count Rate is >247 net cpm, <u>THEN</u> determine the Accepta     Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml     Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml     Gross Effluent Radiation Monitor Readings:     Obtain At Least 2 Effluent Monitor Readings Per Discharge, <u>AND</u> At Least     Date / Time /: Reading: Is reading w     Date / Time /: Reading: Is reading w	ble Range of Rea /cpm) x (2) + (bkg //cpm) / (2) + (2) /cpm) / (2) + (2) /cpm) / (2) + (2) /cpm) / (2) + (2) /cpm) / (2) + (bkg /cpm) / (2) +	dings for control of the duCi/ duCi/ COTE: Record actual For the Applicable N   No[]: RT Initials ] No[]: RT Initials	e discharge, as ml) = ml) = reading (ie; D lonitor: : SAP N : SAP N	follows: uCi/ml UCi/ml o Not Round Down\$ o
I IF the RWDA-L Count Rate is >247 net cpm, THEN determine the Accepta Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Gross Effluent Radiation Monitor Readings:         Gross Effluent Radiation Monitor Readings:         Obtain At Least 2 Effluent Monitor Readings Per Discharge, AND At Least Date / Time /: Reading: Is reading w Date / Time /: Reading: Is reading w Date / Time /: Reading: Is reading w	ble Range of Rea /cpm) x (2) + (bkg/ l/cpm) / (2) + (bkg/ l/cpm) / (2) + (bkg/ k/cpm) / (2) + (bkg/ k/cpm) / (2) + (bkg/ k/cpm) / (2) + (bkg/ k/cpm) / (2) + (2) + (2) k/cpm) / (2) + (2)	dings for control of the duCi/ duCi/ (OTE: Record actual for the Applicable M ] No[]: RT Initials ] No[]: RT Initials ] No[]: RT Initials	e discharge, as ml) = reading (fe; D onitor: : SAP N : SAP N : SAP N	follows: uCi/ml uCi/ml o: Not Round Down) lo lo
I IE the RWDA-L Count Rate is >247 net cpm, THEN determine the Accepta Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Cross Effluent Radiation Monitor Readings:         Gross Effluent Radiation Monitor Readings:         Obtain At Least 2 Effluent Monitor Readings Per Discharge, AND At Least Date / Time /: Reading: Is reading w Date / Time	ble Range of Rea /cpm) x (2) + (bkg //cpm) / (2) + (bkg //thin range? Yes[ /ithin range? Yes[ /ithin range? Yes[ /ithin range? Yes[	dings for control of the duCi/ duCi/ for the Applicable M No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials	e discharge, as ml) = reading (ie: D onitor: : SAP N : SAP N : SAP N : SAP N	follows: uCi/mi UCi/mi o Not Round Dow ny lo lo lo
I IF the RWDA-L Count Rate is >247 net cpm, THEN determine the Accepta Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/m Gross Effluent Radiation Monitor Readings Obtain At Least 2 Effluent Monitor Readings Per Discharge, AND At Least Date / Time /: Reading: Is reading w Date / Time	ble Range of Rea /cpm) x (2) + (bkg //cpm) / (	dings for control of the duCi/ duCi/ COTE: Record actual For the Applicable N No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials	e discharge, as ml) = reading (ie; D lonitor: : SAP N : SAP N : SAP N : SAP N : SAP N	follows: uCi/ml Ci/ml o Not Round Downs lo lo lo lo
I IF the RWDA-L Count Rate is >247 net cpm, THEN determine the Accepta Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Cross: Effluent Radiation Monitor: Readings:         Gross: Effluent Radiation Monitor: Readings:         Obtain At Least 2: Effluent Monitor: Readings:         Date / Time /: Reading: Is reading w         Date / Time /: Rea	ble Range of Rea /cpm) x (2) + (bkg/ l/cpm) / (2) + (bkg/ l/cpm) / (2) + (bkg/ kithin range? Yes[ jithin range? Yes[ jithin range? Yes[ jithin range? Yes[ jithin range? Yes[ jithin range? Yes[	dings for control of the dimensional of the dimensional control of the dime	e discharge, as ml) = reading (fe; D onitor: SAP N : SAP N : SAP N : SAP N : SAP N : SAP N	follows: uCi/ml uCi/ml o: Not Round Dow m lo lo lo lo lo lo
[] IF the RWDA-L Count Rate is >247 net cpm, THEN determine the Accepta Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Gross Effluent Radiation Monitor Readings         Gross Effluent Radiation Monitor Readings         Obtain At Least 2 Effluent Monitor Readings         Date / Time /: Reading: Is reading w Date / Time	ble Range of Rea /cpm) x (2) + (bkg/ //cpm) / (2) + (bkg/ //thin range? Yes[ /ithin range? Yes[	dings for control of the duCi/ duCi/ duCi/ for the Applicable N No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials to Chemistry Supervisions has been notified	e discharge, as ml) = reading (e: D onitor: : SAP N : SAP N : SAP N : SAP N : SAP N 	follows: uCi/mi UCi/mi o Not Round Dow ny lo lo lo lo lo lo lo discharge.
I IE the RWDA-L Count Rate is >247 net cpm, <u>THEN</u> determine the Accepta Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Gross Effluent Radiation Monitor Readings: Obtain At Least 2 Effluent Monitor Readings Per Discharge, AND At Least Date / Time /: Reading: Is reading w Date / Time: Reading: Is reading w Date / Time	ble Range of Rea /cpm) x (2) + (bkg/ //cpm) / (2) + (bkg/ //cpm) / (2) + (bkg/ //cpm) / (2) + (bkg/ //cm/ /cm/ //cm/ //cm/ //cm/ //cm/ //cm/ //cm/ /cm/ //cm/ //cm/ /cm/cm/ /cm/	dings for control of the duCi/ duCi/ for the Applicable M No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials to Chemistry Supervisions has been notified	e discharge, as ml) = reading (e: D onitor: : SAP N : SAP N	follows: uCi/mi UCi/mi o Not Round Dow ny lo lo lo lo lo lo discharge.
[] IF the RWDA-L Count Rate is >247 net cpm, THEN determine the Accepta Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Gross Effluent Radiation Monitor Readings: Obtain At Least 2 Effluent Monitor Readings Per Discharge, AND At Least Date / Time /: Reading is reading w Date / Time	ble Range of Rea /cpm) x (2) + (bkg/ //cpm) / (2) + (bkg/ //cpm) / (2) + (bkg/ //cpm) / (2) + (bkg/ //cm/ /cm/ //cm/ //cm/ //cm/ //cm/ //cm/ //cm/ /cm/ //cm/ //cm/ /cm/cm/ /cm/	dings for control of the duCi/ duCi/ duCi/ for the Applicable M   No[]: RT Initials   No[]: RT Initials ct Chemistry Supervitions has been notified	e discharge, as ml) = reading (ie; D onitor; SAP N : SAP N	follows: uCi/ml UCi/ml o Not Round Down) lo lo lo lo lo discharge.
I IF the RWDA-L Count Rate is >247 net cpm, THEN determine the Accepta Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Gross: Effluent Radiation Monitor Readings: Obtain At Least 2 Effluent Monitor Readings Per Discharge, AND At Least Date / Time /: Reading: Is reading w Date / Time: Reading: Is reading w Date / Time	ble Range of Rea /cpm) x (2) + (bkg/ //cpm) / (2) + (bkg/ //cpm) / (2) + (bkg/ //chin range? Yes[ ] //thin range? Yes[ ] //thi	dings for control of the duCi/ duCi/ duCi/ for the Applicable M No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials there is the second field	e discharge, as ml) = reading (ie: D conitor: : SAP N : SAP N : SAP N : SAP N : SAP N : SAP N 	follows: uCi/mi UCi/mi o Not Round Down lo lo lo lo lo discharge.
[] IE the RWDA-L Count Rate is >247 net cpm, THEN determine the Accepta Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Gross Effluent Radiation Monitor Readings: Obtain At Least 2 Effluent Monitor Readings Per Discharge, AND At Least Date / Time /: Reading Per Discharge, AND At Least Date / Time /: Reading: Is reading w Date / Time /: Reading: Is reading w Commistry Supervision has determined that the discharge may continue. Reading         [] Chemistry Supervision has determined that the discharge may continue. Reading Supervision has determined that the discharge may continue. Reading Supervision has determined that the discharge may continue. Reading Supervision has determined that the discharge may continue. Reading Supervision has determined that the discharge may continue. Reading Supervision has determined that the discharge may continue. Reading Supervision has determined that the discharge may continue. Reading Supervision has determined that the discharge may continue. Reading Supervision has determined that the discharge may continue. Reading Supervision has determined that the discharge may continue. Reading Supervision has determined that the discharge may continue. Reading Supervision has determined tha	ble Range of Rea /cpm) x (2) + (bkg //cpm) / (2) + (bkg //cpm) / (2) + (bkg //cpm) / (2) + (bkg //children kan kan kan kan //children kan kan kan //children kan kan kan kan kan //children kan kan kan kan kan //children kan kan kan kan kan kan //children kan kan kan kan kan kan kan kan kan ka	dings for control of the d uCi/ d uCi/ for the Applicable M l No[]: RT Initials ] No[]: RT Initials ] No[]: RT Initials ] No[]: RT Initials ] No[]: RT Initials [ No[]: RT Initials there is the provided of the second of	e discharge, as ml) = reading (ie: D onitor: : SAP N : SAP N	follows: uCi/mi io. io. io
[] IE the RWDA-L Count Rate is >247 net cpm, THEN determine the Accepta Maximum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Minimum = (RWDA-L Count Rate cpm) x (5.61E-9 uCi/ml Gross Effluent Radiation Monitor Readings: Obtain At Least 2 Effluent Monitor Readings Per Discharge, AND At Least Date / Time /: Reading is reading w Date / Time /: Reading is reading w Commistry Supervision has determined that the discharge should be termined [] Chemistry Supervision has determined that the discharge may continue. Re Final Review of all Monitor Readings by Chemistry Supervision Gross Calculated Monitor Reading = [] cpm % Difference = (Max Obs Reading - Calc Reading) / Calc Read NOTES: Sat = SATISFACTORY: % Difference is Within a F Unsat = UNSATISFACTORY: % Difference is Out: Generate a Condition Report	ble Range of Rea /cpm) x (2) + (bkg/ //cpm) / (2) + (bkg/ //cpm) / (2) + (bkg/ //cpm) / (2) + (bkg/ //chin range? Yes[] //ithin range? Yes[] //ithi	dings for control of the d uCi/ d uCi/ fOTE: Record actual for the Applicable N No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials No[]: RT Initials Ct Chemistry Supervisions has been notified % [] Sat [] 0% to +100%) Range:	e discharge, as ml) = reading (ie: D ionitor: : SAP N : SAP N	follows: uCi/mi io. 

#### **OPERATIONS JOB PERFORMANCE MEASURE (JPM)**

TRAINING MATERIAL TITLE:	Classify an Emergency Event (Scenario Specific)
TRAINING MATERIAL NUMBER:	2AD-021
PROGRAM TITLE:	Licensed Operator Training
COMPUTER CODE:	2AD-021
<u>REVISION NUMBER</u> :	0

## **TECHNICAL REFERENCES:**

EPP/I-1a, Recognition and Classification of Emergency Conditions, Rev. 10

**INSTRUCTIONAL SETTING**:

Simulator

APPROXIMATE DURATION:

15 Minutes

PREPARED BY:	R. J. Brooks	
PEER REVIEW BY:		Date Date
APPROVED FOR USE:	Training Supervise or Designee	Date

# TRAINING MATERIAL CHANGE FORM

Affected Training Materia	ls: 2AD-021		
Type of Change:			
Changes Requiring Revision	Learning Objective Related Cl	hange?	New Rev. # 0
Changes Not Requiring Revision	The Change Does Not Impact Objectives or Material Quality	Learning	Existing Rev. #
List/Description of Change	e(s):	<i>.</i>	
Reason for Change (s):			
APPROVALS:			
<u>K. J. Brooks</u> Prepared by	Date		<b>NOTE</b> : Additions, deletions or changes to training materials must be reviewed for their possible impact to the Training
Training Superintendent/S ("Changes Not Requiring	upervisor/Peer Date Revision" only)		Qualification Matrix. See Incumbent Impact Review, NOBP-TR-1104.

RTL#A5.640U			1/2-ADM-1301.F0 Page 3 of Revision
JPM NUMBER: 2AD-021 IPM REVISION: 0	JPM TITLE: Classify	an Emergency Event (Scena	rio Specific)
K/A REFERENCE: 2.4.41 JPM APPLICATION:	(4.1) REQUALIFICATION FAULTED JPM	TASK ID: 1350-004-03- N 🛛 INITIAL EXAM 🛛 ADMINISTRAT	023 TRAINING TIVE JPM
EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED BY:
Perform Simulate	<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	BVT NRC Other:

	EVALUATION H	ESULTS		
Performer Name:		Performer	SSN:	
Time 🗌 Yes Critical: 🔀 No	Allotted Time: 10 M	nutes	Actual Time:	minutes
JPM RESULTS: SAT UNSA Comments:	T (Comments requ	ired for UNS	AT evaluation)	)
	OBSERVE	RS		
Name/SSN:	Na	me/SSN:		
Name/SSN:	Na	me/SSN:		
	EVALUAT	OR		
Evaluator (Print):		<u></u>	Date:	·
Evaluator Signature:		- <u></u>		

RTL#A5.640U

.

# **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	The correct EPP classification is made for the associated scenario <b>AND</b> all "critical" steps of the initial notification form are correctly completed.
RECOMMENDED STARTING LOCATION:	Simulator
<b>DIRECTIONS:</b>	You are to perform the task Classify An Emergency Event and complete the initial notification form.
INITIAL CONDITIONS:	The simulator scenario just completed.(2LOT6 NRC Exam)
INITIATING CUE:	<ul> <li>As the Unit Supervisor, you are to classify the events in the scenario just completed in accordance with EPP/I-1a, Recognition and Classification of Emergency Conditions AND complete the initial notification form.</li> <li>For the purpose of filling out the initial notification form the following conditions exist: <ul> <li>The code word is "TANGO"</li> <li>Unit 1 is at 100% steady state power</li> <li>Wind direction at 150' is 65°</li> <li>Wind speed at 35' is 7 mph</li> </ul> </li> </ul>
REFERENCES:	EPP/I-1a, Recognition and Classification of Emergency Conditions, Rev. 10
TOOLS:	None
HANDOUT:	EPP/I-1a, Recognition and Classification of Emergency Conditions, Rev. 10

D 1

### **CANDIDATE DIRECTION SHEET**

## \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

	Kead:	
TASK:		You are to perform the task Classify An Emergency Event and complete the initial notification form.
INITIA	L CONDITIONS:	The simulator scenario just completed.(2LOT6 NRC Exam)
INITIA	TING CUE:	As the Unit Supervisor, you are to classify the events in the scenario just completed in accordance with EPP/I-1a, Recognition and Classification of Emergency Conditions <b>AND</b> complete the initial notification form. For the purpose of filling out the initial notification form the following conditions exist: • The code word is "TANGO" • Unit 1 is at 100% steady state power • Wind direction at 150' is 65° • Wind speed at 35' is 7 mph
	At this time, ask the eval	uator any questions you have on this JPM.
	When satisfied that you u	inderstand the assigned task, announce "I am now beginning the JPM".
	Simulate performance or Point to any indicator or	perform as directed the required task. component you verify or check and announce your observations.

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.

. This							<b>ENI</b>
	is:		At:	Beaver	Valley	Power Star	tion
My T Num	Felephone 7 ber is:	24-643-8000	The Code Wor	d is: TANG	Not	ification Time is:	
. En	nergency Class	sification:					
X	Unusual Ev	ent	Site Area Err	lergency			
	Alert		General Eme	rgency	🔲 Thi	s event has been te	rminated
Unit(s):	2	D	eclaration Time	Time	Date:	DATE	
A 11 T Init	to Power Leve	1 at time of Notif	ication	126.15	<b>T</b> ] ]	00%. UN	1720
Br	ief non-techni	cal description of	f the event belo	 Nizatio	N of 1	the main s	team sy
U) re	<u>NYIAN</u> Sultin	<u>ea rapia</u> 1 inta. re	Aid RC	5 coolde	WIN A	NÙ SAFe	łY
LU 10 11	NYIAM Sultin Ulectio	<u>ina ri</u> NACtua	apid RC tion	S coolde	wn A	NÙ SAFe	łÀ
UJ re JC . The	NYIAM Sulting Ulection ere is:	No Radiologic Release in Prop to the event	al X gress due	An Airborne Radiological R in Progress due event	telease e to the	A Liquid Radio Release in Prog event	logical ress due to the
UJ re JA . The	NYIAM Sulting Ulection	No Radiologica Release in Prop to the event	al gress due deg	An Airborne Radiological R in Progress due event rees at 150' Wit	telease e to the nd Speed is:	A Liquid Radio Release in Prog event 7.	logical ress due to the mph at 3
UJ re JC . The . The . W	NYIAM Sulting ere is:	No Radiologic Release in Pro- to the event is from:	al gress due $5^{\circ}$ deg on (PAR):	An Airborne Radiological F in Progress due event rees at 150' With	telease e to the nd Speed is:	A Liquid Radio Release in Prog event 7.	logical ress due to the mph at 3

2. Thi				THIS IS	AN ACTUA	AL EVE
	s is:		At:	Beaver V	alley Powe	r Statio
My Nu	<sup>7</sup> Telephone 7	24-643-8000	The Code Word	is: TANG	Notification	Time is:
3. E	Emergency Clas	sification:			<u> </u>	
[	] Unusual Ev	rent 🚺	Site Area Em	ergency		
[	Alert		General Emer	gency	This event h	as been termin
Unit(s	):2	D	eclaration Time:	TIME	Date: <b>DA</b>	TE
All Ui	nits Power Leve	l at time of Notif	ication	UNITI	100% · V	NIT Z
4. 1 1	The Emergency Brief non-techni	Action Level (EA	AL) number is:		2.3	
<u>r</u> t	eactor Pactor rip from	ower >s the Ch	% And Are	Attempt INSucce	s to cau: ssful.	e a m
5. T	here is:	No Radiologica Release in Prog to the event	al X gress due	An Airborne Radiological Re in Progress due t	A Liquease Release Release event	uid Radiologic se in Progress
				O' OIIC		
6.	Wind Direction	is from:	5° degr	ees at 150' Wind	Speed is:	7

1.	NUCLEAR	POWER PLA	ANT INITIA	AL NOTIFICA	TION FORM
	Call Status 🔀 T	HIS IS A DRILL		S IS AN ACTU	AL EVENT
2.	This is:		At: Beav	ver Valley Pow	er Station
а. н	My Telephone 72 Number is:	4-643-8000 The Co	ode Word is: TA	NGO Notification	n Time is:
<b>C</b> "3.	Emergency Class:	fication:			
		nt 🔀 Site	Area Emergency		
TT		Declarat			
A	11 Units Power Level	at time of Notification		T 1 100%. U	A:+7 0%
` <b>C″</b> 4.	The Emergency A Brief non-technic	L Escalat No Cha Action Level (EAL) nur al description of the ev	Ion In Inge mber is: vent below:	TAB 2.2 Ach:eve or	MAintain
	hot Shut	down			
<b>``C</b> "5.	hat Shut	No Radiological Release in Progress de to the event	ue An Airbo Radiologi in Progres event	rne A Li cal Release Release Release ss due to the even	quid Radiological ase in Progress due to the
` <b>C</b> " 5.	hat Shut There is:	No Radiological Release in Progress di to the event	ue An Airbo Radiologi in Progres event degrees at 150'	rne [] A Lic cal Release Release Release so due to the even Wind Speed is:	quid Radiological ase in Progress due to the 7 mph at 35
ст. Ст. 7.	hot Shut There is:	No Radiological Release in Progress d to the event from:	ue An Airbo Radiologi in Progres event degrees at 150' JR): <b>NON</b>	rne  A Lic cal Release Relea ss due to the even Wind Speed is:	quid Radiological ase in Progress due to the <b>7</b> mph at 35
" <b>C</b> "5. <b>C</b> <sup>°</sup> 6. 7. 8.	hat Shut   There is:   □   Wind Direction is Protective Action   □   Conclusion:	No Radiological Release in Progress d to the event from: Recommendation (PA	ue An Airbo Radiologi in Progres event degrees at 150' JR): <b>NON</b>	rne	quid Radiological ase in Progress due to the 7 mph at 35 ALEVENT

1/2-]	EPP-1P-1.1.I	TO1 AN	ISW	ER	( K	(ey	PTI #	* 457151)D
Rev.			NA er plan					FORM
1.	NUCLEAR POWER PLANT INITIAL NOTIFICATION FORM         1. Call Status       THIS IS A DRILL       THIS IS AN ACTUAL EVENT         2. This is:							
2.	This is: —			At: Be	eaver Va	alley Po	wer Stat	tion
	My Telephone Number is:	e 724-643-80	00 The Code	e Word is:	TANG	SO Notifica	tion Time is:	~
м <sub>с</sub> , з.	Emergency	Classification:						
	Unusu	al Event	Site Ar	ea Emergenc	У			
	🔀 Alert	~	Genera	l Emergency	Ľ	This eve	ent has been te	rminated
Ur	nit(s):	2	Declaratior	n Time: 👖	ime	Date:	ATE	
Al	ll Units Power	Level at time of	f Notification	Ŭ	NIT 1	100%;	UNIT	20%
T	his represents a	a/an: <b>`C''</b>	Initial Dec	claration	In Classific	cation Status		
1,11			No Chang	je	TAR 7	3 16	2174	4
<b>L</b> 4.	Brief non-t	echnical descrip	otion of the even	it below:	nt oc	Cur A	FTER VA	
	Signal Loss a	And M t RCS B	Anual t Arrier du	nip fre Le to l	m CR Priman	was g y to se	contary	UI. OR Leak
<b>°C</b> 5.	There is:	No Radi Release to the ev	iological in Progress due vent	An A Radie in Pro	irborne blogical Rele bgress due to t	ase R the e	Liquid Radio celease in Prog vent	logical ress due to the
<b>`</b> /" 6.	Wind Dire	ction is from:	65°	degrees at	150' Wind §	Speed is:	7_	mph at 35'
7.	Protective	Action Recomm	nendation (PAR	): _NC	nc			
8.	Conclusion:	X THIS I	IS A DRILL		HIS IS .	AN AC'	TUAL E	VENT
AP]	PROVED: _	NAME	)		_ DAT	E:	ATE	

,

IPM NUMBER: 2AD-021 JPM REVISION: 0	JPM TII	LE: Classify an Emergency Event (Scenario Specific)
STEP ("C" Denotes CRITICAL STEP)		STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U
		START TIME:
		<b>EVALUATOR NOTE:</b> The Candidate is being evaluated on classifying the events in the scenario just completed. (2LOT6 NRC Exam) It may be necessary to review the events before beginning the JPM.
1.C Classify the event in acco with the Emergency Plan	rdance	1.1C Candidate correctly classifies the event.
		• Scenario #1: Unusual Event, Tab 2.10 Steam/Feed Line Break
		• Scenario #2: Site Area Emergency, Tab 2.3, Failure of Reactor Protection
[	ļ	• Scenario #3: Site Area Emergency, Tab 2.2, CSF Red Path on Heat Sink
		• Scenario #4: Alert, Tab 2.3, Failure of Reactor Protection
		OR
		Alert, Tab 1.2.4 Loss of RCS Barrier
		COMMENTS:

'PM NUMBER: 2AD-021 JPM REVISION: 0	JPM TITLE: Classify an Emergency Event (Scenario Specific)	
STEP ( "C" Denotes CRITICAL STEP	) STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	<b>S</b> <i>i</i> U
2.C Completes the initial notification form.	2.1 Places the following information on the space provided on the initial notification form.	
	• Item 1 places a checkmark in the this is a drill box	
	• Item 2 leaves name and notification time blank (this is for the communicator) places the word TANGO in the code space.	}
	• C Item 3 places a checkmark in the appropriate classification box (as identified in step 1 of the JPM above) and places a checkmark in the initial declaration box	
	• Item 3 places a 2 in the Unit space, places current time in the declaration time space, places the date in the date space, places Unit 1 at 1005 and Unit 2 at 0% in the all units power level space.	
	• C Item 4 places the appropriate EAL tab number in the EAL number space (as identified in step 1 of the JPM above).	
	• Item 4 places the appropriate EAL description in the space provided (as identified in step 1 of the JPM above)	
}	• C Item 5 places a checkmark in the an airborne radiological release in progress due to this event box.	
	• C Item 6 places 65° and 7 mph in the wind speed and direction spaces	
	• Item 7 is left blank or NONE	
	• Item 8 places a checkmark in the this is a drill box	

.

.

VPM NUMBER: 2AD-021 JPM REVISION: 0	JPM TITLE:	Classify an Emergency Event (Scenario Specific)	
STEP ( "C" Denotes CRITICAL STEP	) STAN	IDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	<u>S, U</u>
	2.2 F a	laces candidate name and current date in the approved space nd date.	
		EVALUATOR NOTE: Refer to Answer Key for initial notification form critical steps.	
		TERMINATING CUE: That completes this JPM	
	COM	IMENTS:	
		STOP TIME:	

#### **OPERATIONS JOB PERFORMANCE MEASURE (JPM)**

TRAINING MATERIAL TITLE:	Perform Partial Movement Test (CB-D)
TRAINING MATERIAL NUMBER:	2CR-647
PROGRAM TITLE:	Licensed Operator Training (Retraining)
COMPUTER CODE:	<u>2CR-647</u>
<b>REVISION NUMBER</b> :	0

#### **TECHNICAL REFERENCES:**

2OST-1.1, Control Rod Assembly Partial Movement Test Rev 10

 INSTRUCTIONAL SETTING:
 Simulator

 APPROXIMATE DURATION:
 10 Minutes

 PREPARED BY:
 R. J. Brooks

 Date
 Date

 PEER REVIEW BY:
 Date

 APPROVED FOR USE:
 Training Supervisor in Designee

## TRAINING MATERIAL CHANGE FORM

Affected Training Materia	ls: 2CR-647		
Type of Change:			
Changes Requiring Revision	Learning Objective Re	lated Change?	New Rev. # 0
Changes Not Requiring Revision	The Change Does Not Objectives or Material	Impact Learning Quality.	Existing Rev. # New Change #
List/Description of Change	e(s):		
Original issue			
Reason for Change (s):			
APPROVALS:			
R. J. Brooks Prepared by		Date	<b>NOTE</b> : Additions, deletions or changes to training materials must be reviewed for their possible impact to the Training Oualification Matrix. See
Training Superintendent/S ("Changes Not Requiring	upervisor/Peer Revision" only)	Date	Incumbent Impact Review, NOBP-TR-1104.

JPM NUMBER: 2CR-647 JPM REVISION: 0	JPM TITLE: Perform	Partial Movement Test (CB-I	D)
K/A REFERENCE: 001 A3	3.05 3.5/3.5 REQUALIFICATION	TASK ID: 0010010201 0011-002-06- N 🛛 INITIAL EXAM	013
	FAULTED JPM		
EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED BY:
<ul> <li>Perform</li> <li>Simulate</li> </ul>	<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	BVT NRC Other:

	EVALUATION R	ESULTS		
Performer Name:		Performer	SSN:	
Time 🗌 Yes Critical: 🔀 No	Allotted Time: 10 mir	utes	Actual Time:	minutes
JPM RESULTS: D SAT D UNSA Comments:	T (Comments requi	red for UNS	AT evaluation)	
	OBSERVE	RS		
Name/SSN:	Nar	ne/SSN:		
Name/SSN:	Nar	me/SSN:	· · · · · · · · · · · · · · · · · · ·	
	EVALUAT	OR		
Evaluator (Print):			Date:	
Evaluator Signature:				

.

## **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	Control Bank 'D' is verified operable (moved 10 steps) AND Rod H2 is identified as NOT aligned by $\pm$ 12 steps.
RECOMMENDED STARTING LOCATION:	CONTROL ROOM
DIRECTIONS:	You are to perform the task of Control Rod Assembly Partial Movement Test.
INITIAL CONDITIONS:	The reactor is in Mode 1, 100% power. All procedural Initial Conditions are satisfied.
INITIATING CUE:	Your supervisor directs you to verify Control Bank 'D' is operable by performing Section VII.B of 20ST-1.1, Control Rod Assembly Partial Movement Test, and report your results to your supervisor.
REFERENCES:	20ST-1.1, Control Rod Assembly Partial Movement Test Rev. 10
TOOLS:	NONE
HANDOUT:	2OST-1.1 filled out up to step VII.B

# **CANDIDATE DIRECTION SHEET**

# \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

	Read:	
TASK:		You are to perform the task of Control Rod Assembly Partial Movement Test.
INITIA	L CONDITIONS:	The reactor is in Mode 1, 100% power. All procedural Initial Conditions are satisfied.
INITIA	TING CUE:	Your supervisor directs you to verify Control Bank 'D' is operable by performing Section VII.B of 2OST-1.1, Control Rod Assembly Partial Movement Test, and report your results to your supervisor.
	At this time, ask the eval	uator any questions you have on this JPM.
	When satisfied that you u	inderstand the assigned task, announce "I am now beginning the JPM"
	Simulate performance or Point to any indicator or	perform as directed the required task. component you verify or check and announce your observations.

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.

# 2LOIT-08-NRC JPMs S1 & S2

Initial	conditions	s/simulat	or setup
with the prime of the second	and the second second second second		

 - <u></u>		and a summer of the statement of the		
10.00 A	- March angle 20, the state of the state	A second seco	and the second	2 200 Aug 1 Aug 1 Aug 1 Aug 1 Aug 1 Aug
an de dist		a in the ar		
	ميد الشاهير الم			
 man allo an	Se ges generations and		and the second	an a
		- A.G.) -	4. / / / / / / / / / / / / / / / / / / /	
			اند. الاستشار بيونيد والمسار في ول	ی در ۱۹۰۰ دمی در ۲۰۰۰ ۱۹۰۰ دمی در ۲۰۰۰
				مەب <del>- نىسىپ</del>
			and the second s	· - a and interest

NO ACTION REQUIRED FOR S-2

Run LRTIC file commands

Horns, Printers, Sounds ready

Trg 1 to actuate dropped rod

Dropped rod

Initialize

Trg 2 to clear dropped rod

Dropped rod cleared

JPM NUMBER: 2CR-647 JPM REVISION: 0	FLE: Perform Partial Movement Test (CB-D)		
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	<u>S./U</u>	
	START TIME:		
	SIMULATOR SET-UP: Initialize IC-10. Turn on all PRZR heaters Stick rod H2 such that it ratchets down when outward rod motion is attempted. Rods in Auto		
1. Record the Rod Step Counter Control Bank 'D' Group 1 and 2 readings.	<ul><li>1.1 Logs Control Bank 'D' Group 1 and 2 Readings.</li><li>COMMENTS:</li></ul>		
2. Using the DRPI, Record the rod height of the Control Bank D rods listed below: Rod H2Rod F6 Rod B8Rod F10 Rod H14Rod K10 Rod P8Rod K6	2.1 Records the rod height of the Control Bank D rods           EVALUATOR NOTE:           Although the Rods are at 229 steps, DRPI will only           indicate 228 steps           COMMENTS:		
3.C Place the Control Rod Bank Sel SW to MAN position.	3.1C Places the Control Rod Bank Sel SW to MAN position COMMENTS:		

•

٠

JPM JPM	PM NUMBER: 2CR-647 PM REVISION: 0 JPM TITLE: Perform Partial Movement Test (CB-D)				
STEH ("C' 4.C	Using the IN-HOLD-OUT lever, drive CB 'D' 10 steps into the cord until verification of individual rod movement is obtained by observat of the DRPIs.	STANDARD       (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒       \$/U         4.1C       Places the IN-HOLD-OUT lever to IN and Inserts rods 10 steps in 5 step increments as indicated by the Group Step Demand counters, and verifies individual rod motion on DRPI.         On       EVALUATOR NOTE: Annuciator A4-9G, Computer Monitored Alarm is expected each time rod motion is demanded.         COMMENTS:			
5.	Record the Control Bank 'D' step counter position.	<ul> <li>5.1 Records the Control Bank 'D' step counter position for Group 1 and 2.</li> <li>COMMENTS:</li> </ul>			
6.	Record the Control Bank 'D' rod position as indicated by DRPI.	<ul> <li>6.1 Candidate locates each individual rod DRPI indication and records the rod height.</li> <li>COMMENTS:</li> </ul>			
7.	Compare the step counter indicati for each rod group (from Step VII.B.5) with the DRPI indication each RCCA (from Step VII.B.6). Verify the step counter and DRPI indications are within ± 12 steps a stated in T.S. 3.1.4.	n 7.1 Candidate compares the Group Step Demand counters against the DRPIs for Control Bank 'D'. Determines all rods are within ± 12 steps. COMMENTS:			

.

JPM NUMBER: 2CR-647 JPM REVISION: 0 JPM TITLE: Perform Partial Movement Test (CB-D)				
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ 5 U			
	<b>FAULT STATEMENT:</b> The next step of the JPM is Faulted. When the candidate begins to withdraw the control rods, Rod H2 will ratchet inward such that it will be misaligned by more than 12 steps from the rest of the bank.			
	<b>EVALUATOR NOTE:</b> Candidate may immediately STOP rod motion before achieving 229 steps.			
8.C Return Control Bank D rods (in 5 step increments) to the group positions recorded in Step VII.B.1.	<ul> <li>8.1 Candidate locates the IN-HOLD-OUT lever.</li> <li>8.2C Candidate places it to the OUT direction AND attempts to withdraw the Group Step Demand counters to 229 steps.</li> <li>8.3C Candidate recognizes Rod H2 is ratcheting inward and stops rod motion.</li> <li>EVALUATOR NOTE: Candidate may refer to Annuciator A4-8G, Rod Position Deviation</li> <li>COMMENTS:</li> </ul>			
	<b>EVALUATOR CUE:</b> If necessary Role-play the Unit Supervisor and instruct the candidate to <b>STOP</b> rod withdrawal <b>AND</b> remain here until further instructions. It may also be necessary to ask the candidate to re-perform step 7 of the JPM to verify rod alignment.			

JPM NUN JPM REV	ABER: 2CR-647 TISION: 0	JPM TI	TLE: Perform Partial Movement Test (CB-D)	
STEP ( "C" Deno	otes CRITICAL STEP	)	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	s U
9.C Com for ea VII.F each Verif indic stated	pare the step counter in ach rod group (from St B.5) with the DRPI ind RCCA (from Step VII y the step counter and ations are within $\pm 12$ l in T.S. 3.1.4.	ndication ep ication for .B.6). DRPI steps as	<ul> <li>9.1C Candidate compares the Group Step Demand counters against the DRPIs for Control Bank 'D'. Determines rod H2 is NOT within ± 12 steps of the other rods in the bank.</li> <li>COMMENTS:</li> </ul>	
			<b>EVALUATOR CUE:</b> Terminate JPM at this point.	
1 <b>P</b> N - <b>3</b> - <b>9</b> -			STOP TIME:	

# **OPERATINS JOB PERFORMANCE MEASURE (JPM)**

TRAINING MATERIAL TITLE:	Perform a Hot Bus Transfer
TRAINING MATERIAL NUMBER:	2CR-023
PROGRAM TITLE:	Licensed Operator Retraining
COMPUTER CODE:	<u>2CR-023</u>
REVISION NUMBER:	9

## **TECHNICAL REFERENCES:**

JM-36.4.C, Transferring 4KV System from US SERV TFMR to SS SERV TFMR, Rev 9

INSTRUCTIONAL SETT	<u>`ING</u> :	Simulator				
APPROXIMATE DURA	<u>ΓΙΟΝ</u> :	15 Minutes				
					(72	Ç.
PREPARED BY:	R. J. Brooks			ا میں اور	Date	
PEER REVIEW BY:					Data	
PROVED FOR USE					Date	
		Training Supe	rviso of Designee	<u></u>	Date	

.

٠

# TRAINING MATERIAL CHANGE FORM

Affected Training Materials: 2CR-023						
Type of Change:						
Changes Requiring Revision Learning Objective Related Change?		New Rev. #9				
Changes Not Requiring Revision The Change Does Not Impact Learning Objectives or Material Quality.		Existing Rev. # 8 New Change #				
List/Description of Change	e(s):					
<ol> <li>Updated to reflect a</li> <li>Update to current p</li> </ol>	<ol> <li>Updated to reflect actual control room mark numbers and nomenclature.</li> <li>Update to current procedure revision, Rev 9</li> </ol>					
Reason for Change (s):						
1. Improve JPM accur	acy.					
APPROVALS:						
R. J. Brooks		NOTE: Additions, deletions or hanges to training materials				
Prepared by	Date P C	nust be reviewed for their possible impact to the Training Qualification Matrix. See ncumbent Impact Review,				
Training Superintendent/Society ("Changes Not Requiring")	upervisor/Peer Date Revision" only)	NOBP-TR-1104.				

JPM NUMBER: 2CR-023 JPM REVISION: 9	JPM TITLE: Perform a Hot Bus Transfer				
K/A REFERENCE: 062K1.04 3.7/4.2 TASK ID: 0361-013-01-013 062A4.01 3.3/3.1					
JPM APPLICATION:	REQUALIFICATION		L EXAM	TRAINING	
	FAULTED JPM	ADMI	NISTRAT	IVE JPM	
EVALUATION METHOD: Perform Simulate	LOCATION: Plant Site Simulator Classroom	TYPE: Annual Request Initial Exam OJT/TPE Training Other:	ial Exam	ADMINISTERED BY: BVT NRC Other:	
	EVALUATIO	N RESULTS		·····	
Performer Name:		Performer	SSN:		
Time 🗌 Yes Critical: 🔀 No	Allotted Time: 15	5 minutes Actual minutes Time:		minutes	
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:					
OBSERVERS					
Name/SSN:		Name/SSN:			
Name/SSN:		Name/SSN:			
EVALUATOR					
Evaluator (Print):	Evaluator (Print): Date:				
Evaluator Signature:					
•

### OPERATIONS JOB PERFORMANCE MEASURE

### **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	The 4kv Bus 2B is being supplied by the System Station Service Transformer.
RECOMMENDED STARTING LOCATION:	Control Room
DIRECTIONS:	You are to perform the task Perform a Hot Bus Transfer
INITIAL CONDITIONS:	The plant is at 100% power with all systems in NSA. It is desired to place the 2B 4KV bus on offsite power to allow for a relay check on ACB-142C.
INITIATING CUE:	Your supervisor directs you to transfer the 2B 4KV bus to the 2A SSST, but do not set it up for auto transfer back to the 2C USST.
REFERENCES:	20M-36.4.C, Transferring 4KV system from USST to SSST, Rev 9
TOOLS:	None
HANDOUT:	20M-36.4.C

#### OPERATIONS JOB PERFORMANCE MEASURE

#### **CANDIDATE DIRECTION SHEET**

#### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

Read:	
TASK:	Perform a Hot Bus Transfer
INITIAL CONDITIONS:	The plant is at 100% power with all systems in NSA. It is desired to place the 2B 4KV bus on offsite power to allow for a relay check on ACB-142C.
INITIATING CUE:	Your supervisor directs you to transfer the 2B 4KV bus to the 2A SSST, but do not set it up for auto transfer back to the 2C USST.
At this time, ask the eval	luator any questions you have on this JPM.
When satisfied that you	understand the assigned task, announce "I am now beginning the JPM"
Simulate performance of	perform as directed the required task.

Point to any indicator or component you verify or check and announce your observations.

After determining the Task has been met announce "I have completed the JPM". Then hand this sheet to the evaluator.

# 2LOIT-08-NRC JPMs S1 & S2

Initial conditions/simulator setup



NO ACTION REQUIRED FOR S-2

Initialize

Run

LRTIC file commands

Horns, Printers, Sounds ready

Trg 1 to actuate dropped rod

Dropped rod

Trg 2 to clear dropped rod

Dropped rod cleared

4

٠

JPM NUMBER: 2CR JPM REVISION: 9	-023 JPM TI	TLE: Perform a Hot Bus Transfer	
STEP ( "C" Denotes CRITICAI	L STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	SU
		START TIME:	
		SIMULATOR SETUP: Init in LRT 100% power IC set.	
<ol> <li>Obtain procedure Transferring 4kv USST to SSST.</li> </ol>	e 2OM-36.4.C, system from	<ul><li>1.1 Candidate locates procedure.</li><li>COMMENTS:</li></ul>	
2. Verify voltages of bus are approxim on all phases as of	on the 2B 4kv nately the same on SSST 2A.	<ul> <li>2.1 Candidate locates the 4KV Common volts meter, 4KV Bus 2B Volts meter, and 2A SS Serv Tmr Voltmeter Phase selector switch.</li> <li>2.2 Checks all phases and verifies 2B bus and 2A SSST are within 2.0 volts.</li> <li>COMMENTS:</li> </ul>	
3.C Place Live Bus 7 to ON.	fransfer Switch	<ul> <li>3.1 Candidate locates Live bus Transfer Switch.</li> <li>3.2C Turns switch to the ON position.</li> <li>COMMENTS:</li> </ul>	

- 1

JPM NUMBER	: 2CR-023 N: 9	JPM TI	TLE: Perf	form a Hot Bus Transfer	
STEP		STANDA	RD		
( "C" Denotes CRITICAL STEP )			(Indicate "S" FOR SAT or "U" FOR UNSAT) $\Rightarrow$	5/U	
4.C Close ACB-142A.		4.1	Candidate locates control switch for 2A SS SERV TFMR TO 4KV BUS 2B ACB-142A.		
			4.2C	Turns switch to the CLOSE position.	
			4.3	Verifies BOTH Red lights are – LIT and the white light is – NOT LIT	
			СОММІ	ENTS:	
5. Verify that amps increase on Bus 2B Tfmr 2A ammeter.		5.1 5.2	Candidate locates 4KV BUS 2B TFMR 2A ammeter. Verifies it indicates greater than ZERO amps.		
			COMMI	ENTS:	
6.C Open ACI	B-142C.		6.1 6.2C 6.3 COMMI	Candidate locates control switch for 2C US SERV TFMR TO 4KV BUS 2B ACB-142C. Places it in the OPEN/TRIP position. Verifies BOTH Red lights are – NOT LIT and the white light is – LIT ENTS:	
1					

### RTL#A5.640U

ï

٠

JPM NUMBER: 2CR-023 JPM REVISION: 9	JPM TITLE: Perform a Hot Bus Transfer				
STEP ( "C" Denotes CRITICAL STEP )		STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT) $\Rightarrow$ S U			
7. Place the Live Bus Trans Switch to OFF.	sfer	<ul> <li>7.1 Candidate locates Live Bus Transfer Switch.</li> <li>7.2 Places it in the OFF position.</li> <li>COMMENTS:</li> </ul>			
<ol> <li>Place Load Tap Changer in AUTO (only necessary if voltage adjusted earlier).</li> </ol>		<ul> <li>8.1 N/A</li> <li>8.2 Places it in the AUTO position.</li> <li>COMMENTS:</li> </ul>			
		EVALUATOR CUE: That completes this JPM			
		STOP TIME:			

2

### **OPERATIONS JOB PERFORMANCE MEASURE (JPM)**

<u>TRAINING MATERIAL TITLE</u> :	Transfer to Cold Leg Recirculation (ES-1.3)	
TRAINING MATERIAL NUMBER:	2CR-529	
PROGRAM TITLE:	Licensed Operator Retraining	
COMPUTER CODE:	2CR-529	
<b>REVISION NUMBER</b> :	3	
TECHNICAL REFERENCES: 20M-53A.1.ES-1.3 (Issue 1C), Revis	sion 5	
INSTRUCTIONAL SETTING:	Control Room	
APPROXIMATE DURATION:	10 Minutes	
<u>PREPARED BY</u> : K. J. Broc	<u> </u>	Date
PEER REVIEW BY:	ce	Date
APPROVED FOR USE:	Training Supervisor + Designee	Date

.

### TRAINING MATERIAL CHANGE FORM

Affected Training Material	s: 2CR-529	
Type of Change:		
Changes Requiring Revision	Learning Objective Related Change?	New Rev. # 3
Changes Not Requiring Revision	The Change Does Not Impact Learning Objectives or Material Quality.	Existing Rev. # 2 New Change #
List/Description of Change	e(s):	
Updated procedure to curre Updated JPM to reflect act Added Evaluator Cue to ste Modified setup force a diff	ent revision. ual control room mark numbers and nome ep 5 of JPM (2LOT6 NRC exam validation ferent procedural flowpath	enclature. on comment)
Reason for Change (s):		
Improve JPM clarity and to	o reflect current procedure revision.	
APPROVALS:		
		·····
<u>R. J. Brooks</u> Prepared by	Date	NOTE: Additions, deletions or changes to training materials must be reviewed for their possible impact to the Training
Training Superintendent/S ("Changes Not Requiring	upervisor/Peer Date Revision" only)	Incumbent Impact Review, NOBP-TR-1104.

JPM NUMBER: 2CR-529 JPM REVISION: 3	JPM TITLE: Transfer	to Cold Leg Recirculation (E	S-1.3)
K/A REFERENCE: 006K- 006A- 006 A	4.083.4/3.64.024.0/3.84.053.9/3.8	TASK ID: 0111-019-01-	013
JPM APPLICATION:	REQUALIFICATION	N 🛛 INITIAL EXAM	TRAINING
EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED BY:
<ul> <li>Perform</li> <li>Simulate</li> </ul>	<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	<ul> <li>BVT</li> <li>NRC</li> <li>Other:</li> </ul>

	EVALUATION RI	ESULTS		
Performer Name:		Performer S	SSN:	
Time  Yes Critical:  No	Allotted Time: 10 min	utes	Actual Time:	minutes
JPM RESULTS: D SAT UNSA Comments:	T (Comments requir	ed for UNSA	AT evaluation	n)
	OBSERVER	S		
Name/SSN:	Nan	ne/SSN:		
Name/SSN:	Nan	ne/SSN:		
	EVALUATO	)R		
Evaluator (Print):		I	Date:	
Evaluator Signature:				

### **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	Parallel redundant Cold Leg Recirculation flowpaths are established according to Step 5 of 2OM-53A, Procedure ES-1.3.
RECOMMENDED STARTING LOCATION:	CONTROL ROOM
<b>DIRECTIONS:</b>	You are to simulate (perform) the task Transfer to Cold Leg Recirculation (ES-1.3).
INITIAL CONDITIONS:	The plant is recovering from a Loss of Coolant Accident. The Control Room Operators are now at step 5 of ES-1.3, Transfer to Cold Leg Recirc.
INITIATING CUE:	Your supervisor directs you to perform Step 5 of ES-1.3 'Transfer to Cold Leg Recirc'.
REFERENCES:	20M-53A.1.ES-1.3 (Issue 1C), Revision 5
TOOLS:	4 Shorting Bars
HANDOUT:	20M-53A.1.ES-1.3

#### **CANDIDATE DIRECTION SHEET**

#### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

Read:	
TASK:	Transfer to Cold Leg Recirculation (ES-1.3)
INITIAL CONDITIONS:	The plant is recovering from a Loss of Coolant Accident. The Control Room Operators are now at step 5 of ES-1.3, Transfer to Cold Leg Recirc.
INITIATING CUE:	Your supervisor directs you to perform Step 5 of ES-1.3 'Transfer to Cold Leg Recirc'.

At this time, ask the evaluator any questions you have on this JPM.

When satisfied that you understand the assigned task, announce "I am now beginning the JPM".

Simulate performance or perform as directed the required task. Point to any indicator or component you verify or check and announce your observations.

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.

# 2LOIT-08-NRC JPM S3

# Initial conditions/simulator setup

Transfer to Cold Leg Recirc

Initialize

Run

LRTIC file commands

Horns, Printers, Sounds ready

DBA LOCA on "C" loop

[2RSS\*P21D] Tripped

1/2-ADM-1301.F04 Page 6 of () Revision

JPM NUMBER: 2CR-529 JPM REVISION: 3	TITLE: Transfer to Cold Leg Recirculation (ES-1.3)			
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	5 ′U		
	START TIME:			
	SIMULATOR SETUP:			
	Mair RCS03C, Open 2CCS*AOV118 Start an Air compressor. Reset SI both trains. Stop both EDG's. Wait until RWST level <400 inches. Reset CIA & CIB. Ensure 2CHS*P21A/C running. Place both LHSI pumps in PTL. Energize charging pump suction and discharge valves via LOA-LOV093 thru 096, and LOV102 thru 105, Insert following to trip [2RSS*P21D] PMP-CSS010			
	<b>EVALUATOR NOTE:</b> Have 4 shorting bars available for candidate to perform this JPM			
1. Obtain a copy of procedure ES-1.3 of	1.1 Candidate locates ES-1.3 of 20M-53A			
20M-33A.	<b>EVALUATOR NOTE:</b> Procedure can be provided to Candidate, if provided, N/A this JPM step.			
	COMMENTS:			

JPM NUMBER: 2CR-529 JPM REVISION: 3	CR-529       JPM TITLE: Transfer to Cold Leg Recirculation (ES-1.3)		
STEP ( "C" Denotes CRITICAL STEP )		STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	s U
2. Verify TWO charging/HHSI pu running.	umps	<ul> <li>2.1 Verifies Charging Pump High Head Safety Inj 2CHS*P21A and C Red lights are – LIT and the white lights are – NOT LIT.</li> <li>COMMENTS:</li> </ul>	
3.C Insert shorting bar into (2SIS*MOV836) High Head SI Leg Isol. Valve Jack.	Cold	<ul> <li>3.1C Candidate locates jack for High Head SI Cold Leg Isol Vlv 2SIS*MOV836 and inserts shorting bar.</li> <li>COMMENTS:</li> </ul>	
4.C Open 2SIS*MOV836 HHSI Co Isol. Valve.	old Leg	<ul> <li>4.1 Candidate locates control switch for High Head SI Cold Leg Isol Vlv 2SIS*MOV836.</li> <li>4.2C Candidate places CS to OPEN</li> <li>4.3 Candidate verifies Red light is – LIT and green light is - NOT LIT</li> <li>COMMENTS:</li> </ul>	

JPM NUMBER: 2CR-529 JPM REVISION: 3	JPM TITLE: Transfer to Cold Leg Recirculation (ES-1.3)		
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ 57	σ	
<ol> <li>Verify Recirc Spray pumps 210 21D – Both Running.</li> </ol>	<ul> <li>S and</li> <li>S.1 Candidate verifies Recirc Spray Pump 2RSS*P21C red light is – LIT and white light is – NOT LIT</li> <li>S.2 Candidate verifies Recirc Spray Pump 2RSS*P21D red light is – NOT LIT and white light is – LIT</li> <li>EVALUATOR CUE: If necessary inform the candidate that Recirc Spray Pump 2RSS*P21D will NOT START.</li> <li>S.3 Candidate verifies HHSI pumps 2CHS*P21 A and C red lights are – LIT and white lights are – NOT LIT</li> <li>COMMENTS:</li> </ul>		
6.C Insert shorting bar into appropriate jacks and then close appropriate pump discharge isolation valves 2CHS*MOV8132A & B.	<ul> <li>ate</li> <li>6.1C Candidate locates jacks for Charging Pump Disch Isol Vlv 2CHS*MOV8132A &amp; B and inserts shorting bars.</li> <li>6.2 Candidate locates control switches for Charging Pump Disch Isol Vlv 2CHS*MOV8132A &amp; B.</li> <li>6.3C Candidate places Control switches to CLOSE</li> <li>6.4 Candidate verifies green lights are – LIT and red lights are – NOT LIT</li> <li>COMMENTS:</li> </ul>		

JPM NUMBER: 2CR-529 JPM REVISION: 3	JPM TI	TLE: Transfer to Cold Leg Recirculation (ES-1.3)	
STEP ("C" Denotes CRITICAL STEP)	)	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	s U
7. Verify 2SIS*F1945, (946) LH A & B flow is indicated.	SI Train	<ul> <li>7.1 Verifies 21A LHSI Pump Disch Flow 2SIS-F945 indicates greater than ZERO flow</li> <li>COMMENTS:</li> </ul>	
8. Verify [2SIS*FI940, 943] Tra flow – indicated.	in A, B	<ul> <li>8.1 Candidate locates HHSI TRN A 2SIS*FI940 indicates greater than ZERO flow</li> <li>COMMENTS:</li> </ul>	
		STOP TIME:	

TRAINING MATERIAL TITLE:	Establish RCS Bleed and Feed per FR-H.1
TRAINING MATERIAL NUMBER:	2CR-624
PROGRAM TITLE:	Licensed Operator Training (Retraining)
COMPUTER CODE:	2CR-624
REVISION NUMBER:	5

#### TECHNICAL REFERENCES:

?OM-53A.1.FR-H.1, Issue 1C, Response To Loss Of Secondary Heat Sink, Rev. 7

INSTRUCTIONAL SETT	<u>ING</u> :	Simulator			
APPROXIMATE DURA	<u> </u>	10 minutes			
PREPARED BY:	R. J. Brooks			نې ۱/ (۲ نه په	
PEER REVIEW BY:					Date     Date
APPROVED FOR USE:		Training Sup	erviso & Designee	<u></u>	Date

## TRAINING MATERIAL CHANGE FORM

······································					
Affected Training Material	ls: JPM 2CR-624				
Type of Change:					
Changes Requiring Revision	Learning Objective Re	lated Change?	New Rev. # 5		
Changes Not Requiring Revision	The Change Does Not Objectives or Material	Impact Learning Quality.	Existing Rev. # 4 New Change #		
List/Description of Change	e(s):				
Updated JPM to current JP Modified failure. (PCV455	PM format. 5C and D will not open)				
Reason for Change (s):					
Reason for Change (s).					
JPM Enhancement					
APPROVALS:					
R I Brooks			NOTE: Additions deletions or		
Prepared by		Date	changes to training materials must be reviewed for their possible impact to the Training		
Training Superintendent/S ("Changes Not Requiring	upervisor/Peer Revision'' only)	Date	Qualification Matrix. See Incumbent Impact Review, NOBP-TR-1104.		

PM NUMBER: 2CR-624 JPM REVISION: 5	JPM TITLE: Establish	RCS Bleed and Feed per FR	-H.1
K/A REFERENCE: E05 E	A1.1 4.1/4.0	TASK ID: 0533-006-05-	013
JPM APPLICATION:	REQUALIFICATION	N 🛛 INITIAL EXAM	TRAINING
EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED B'/:
<ul> <li>Perform</li> <li>Simulate</li> </ul>	<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	BVT NRC Other:

EVALUATION RESULTS				
Performer Name: Performer SSN:				
Time 🗌 Yes Critical: 🔀 No	Allotted Time: 10 min	utes	Actual Time:	minutes
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:				
	OBSERVER	RS		
Name/SSN:	Nan	ne/SSN:		
Name/SSN:	Nan	ne/SSN:		
EVALUATOR				
Evaluator (Print): Date:				
Evaluator Signature:				

### **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	RCS Bleed and Feed are initiated (SI flow, one PRZR PORV open, all RX vessel head vents open). At least one SG isolated and depressurizing for low pressure water injection.
RECOMMENDED STARTING LOCATION:	Simulator
DIRECTIONS:	You are to perform the task of Establishing RCS Bleed and Feed per FR-H.1, Response To Loss of Secondary Heat Sink.
INITIAL CONDITIONS:	The plant has tripped from 100% power. FR-H.1, Response To Loss of Secondary Heat Sink has been entered. Steps 1 through 5 are complete. While performing step 6, the RCS bleed and feed criteria of continuous action Step 2 are met due to S/G WR levels dropping to less than 14%.
NITIATING CUE:	Your supervisor directs you to establish RCS bleed and feed by performing steps 13 through 16 of FR-H.1, Response To Loss of Secondary Heat Sink.
REFERENCES:	20M-53A.1.FR-H.1, Issue 1C, Response To Loss of Secondary Heat Sink, Rev. 7
TOOLS:	None
HANDOUT:	20M-53A.1.FR-H.1, Issue 1C, Response To Loss of Secondary Heat Sink, Rev. 7

.

### **CANDIDATE DIRECTION SHEET**

### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

	Read:		
TASK:		You are to perform the task of Establishing RCS Bleed and Feed per FR-H.1, Response To Loss of Secondary Heat Sink.	
<b>INITIAL CONDITIONS:</b> The plant has tripped from 100% power. FR-1 of Secondary Heat Sink has been entered. Ste complete. While performing step 6, the RCS 1 continuous action Step 2 are met due to S/G W less than 14%.		The plant has tripped from 100% power. FR-H.1, Response To Loss of Secondary Heat Sink has been entered. Steps 1 through 5 are complete. While performing step 6, the RCS bleed and feed criteria of continuous action Step 2 are met due to S/G WR levels dropping to less than 14%.	
INITIA	ATING CUE:	Your supervisor directs you to establish RCS bleed and feed by performing steps 13 through 16 of FR-H.1, Response To Loss of Secondary Heat Sink.	
	At this time, ask the eval	uator any questions you have on this JPM.	
	When satisfied that you understand the assigned task, announce "I am now beginning the JPM".		
	Simulate performance or perform as directed the required task. Point to any indicator or component you verify or check and announce your observations.		
	After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.		

# 2LOIT-08-NRC JPM S4

	Initial conditions	/simulator_setup
and a second particular second se		Initialize
and a second		Run
		LRTIC file co
		Horns, Printer

Initiate Bleed/Feed per FR-H.1

		the second s
		an an an Annair an Annaich a
1		22 C
	and a second	ليوري ويحد مسترية متعادية معام المراجد. ويوري المراجع
**************************************	and a state to be a state to be a state of the state of t	
\$	والمتحاف والرابية المراجع المرجع المرجعين والمتكافحات والمحافظ والمحاف والمراجع المراجع	and have the track that a second development of the
	· · · · · · · · · · · · · · · · · · ·	
Large mark		·····
r		
		7
<b>-</b>	د و سهری در اینان ایند دست این دانسته بیان در میشوه همان است. دستهای از اینان دانسته این اینان دانسته و س	<mark>لوفريد</mark> ر د ردست مدريها يا د د د. مربعات منظم د مدين ا د
(	and the second	······································
	ਿੱਤ ਹੈ ਕਿ ਤੱਤ ਹੁੰਦੀ ਤੱਥੋਂ ਕਿ ਇੱਕ ਸਭ ਕਿੰਦ ਹੁੰਦੇ 🔅	
CONTRACT AND	international second	to a manual and the man with the second seco
Ē	an a	
Γ		
		4.

LRTIC file commands

Horns, Printers, Sounds ready

[2FWS-P21B Trip]

[2FWS-P21A Trip]

[2FWE\*P23A Trip]

[2FWE\*P23A Trip]

Failure of AUTO reactor trip train A, manual successful

Failure of AUTO reactor trip train B, manual successful

[2RCS\*PCV455C] failed shut

[2RCS\*PCV455D] failed shut

[2FWE\*P22] Trip

JPM NUMBER: 2CR-624 JPM REVISION: 4 JPM TI	TLE: Establish RCS Bleed and Feed per FR-H.1
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U
an a	START TIME:
	SIMULATOR SETUP: Init IC-237 for 2LOT6 NRC Exam Defeat 2FWE-P22, 23A, & 23B. Fail 2FWS-HYV157A, B, & C closed. To establish conditions for JPM, trip 2FWS-P21A & B, place steam dumps in STM PRESS Mode at ~1005 psig. Stop 2RCS-P21A, B, & C. Allow SG levels to drop to < 13% and SNAP IC. Fail PRZR PORVs PCV455C and D from opening.
1. Obtain procedure.	1.1 Candidate locates procedure FR-H.1
2.C Actuate SI.	2.1C Candidate locates and actuates control switches for Train A and Train B Safety Injection.
	2.2 Verifies alarm A12-1D "Safety Injection Signal" is - LIT
	COMMENTS:

STEP ( "C"	Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S
3.	Verify RCS Feed Path <ul> <li>HHSI Flow Indicated.</li> </ul>	<ul> <li>3.1 Candidate locates HHSI Train "B" flow indicator – [2SIS-FI943] and verifies HHSI flow is greater than ZERO.</li> <li>COMMENTS:</li> </ul>
4.	Establish RCS Bleed Path • Power to PRZR PORV block valves AVAILABLE.	FAULT STATEMENT:         The next step begins the alternate path for this JPM.         There will only be ONE PRZR PORV available as a bleed path. The candidate will be required to OPEN all RX Vessel head vents to obtain adequate bleed flow.         4.1 Candidate verifies the following indicating lights:          2RCS-MOV535, 536 and 537 red lights – LIT green lights – NOT LIT         COMMENTS:
5.	Establish RCS Bleed Path • Verify block valves – ALL OPEN.	5.1 N/A Previously verified COMMENTS:

•

STEP ("C" Denotes CRITICAL STEP)	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S
<ul> <li>6.C Establish RCS Bleed Path</li> <li>Open all PORVs.</li> </ul>	<ul> <li>FAULT STATEMENT: ONLY PRZR PORV, 2RCS-PCV456 will open in the next step. This will require the candidate to Open RCS vent paths.</li> <li>6.1 Candidate locates PRZR PORV Control Switches.</li> <li>6.2 Places CS for PRZR PORV, 2RCS-PCV455C, 455D and 456 to OPEN.</li> <li>6.3 Verifies PRZR PORV, 2RCS-PCV456 red light – LIT green light – NOT LIT</li> <li>6.4 Recognizes/verifies PRZR PORV, 2RCS-PCV455C and 455D red lights – NOT LIT green lights – LIT</li> <li>COMMENTS:</li> </ul>
<ul> <li>7.C Verify Adequate RCS Bleed Path.</li> <li>PRZR PORV's and associated block valves – AT LEAST TWO OPEN</li> </ul>	<ul> <li>7.1C Determines that ONLY ONE PRZR PORV and associated block valve is open and Places all reactor vessel head vent control switches to OPEN. [2RCS-SOV200A, B] [2RCS-SOV201A, B]</li> <li>7.2 Verifies red lights – LIT green lights – NOT LIT</li> <li>7.3C Depresses Δ PB for 2RCS-HCVC250A and B</li> <li>7.4 Verifies 2RCS-HCVC250A and B at 100% demand.</li> <li>COMMENTS:</li> </ul>

JEIM REVISION: 4				
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U			
<ol> <li>Align any available low pressure water source.</li> </ol>	<ul> <li>8.1 Attempts to align a low press. water source to an intact SG. No action needed.</li> <li>EVALUATOR CUE: Another operator will work on a low pressure water source using Attachment A-1.10.</li> <li>COMMENTS:</li> </ul>			
	<b>EVALUATOR CUE:</b> In the next step, Role-play the Unit Supervisor and direct the candidate to use SG 21A for depressurization.			
9.C Isolate steam supply to Turbine driven Aux feed pump from S/G selected for depressurization.	<ul> <li>9.1C Places CS for 2MSS*SOV105A and D to CLOSE.</li> <li>9.2 Verifies red lights – NOT LIT green lights – LIT.</li> </ul>			
10.C Close MSIV on selected S/G.	10.1C Places CS for 21A SG MSIV 2MSS-AOV101A to CLOSE.			
	10.2 Verifies red lights – NOT LIT green lights – LIT.			
	COMMENTS:			

JPM NUMBER: 2CR-624 JPM REVISION: 4 JPM TITLE: Establish RCS Bleed and Feed per FR-H.1					
STEP ("C")	Denotes CRITICAL STEP )		STAND	ARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	\$/U
11. <b>C</b>	Open Atm Steam dump on selected SG to depre	valve ssurize.	11.1 <b>C</b>	Places 21A S/G Atm Stm Dump Control 2SVS*PCV101A to MAN and depresses the output $\Delta$ PB	
			11.2	Verifies red light – LIT green light – NOT LIT and 100% demand on controller	
			COMM	IENTS:	
			E T	CVALUATOR CUE:         That completes this JPM	
				STOP TIME:	

TRAINING MATERIAL TITLE:	Respond to PRT Trouble	······································
TRAINING MATERIAL NUMBER	<u>2CR-155</u>	
PROGRAM TITLE:	Licensed Operator Training	
COMPUTER CODE:	2CR-155	
<u>REVISION NUMBER</u> :	0	
TECHNICAL REFERENCES:		
20M-6.4.AAY, Rev. 8		
INSTRUCTIONAL SETTING:	Simulator	
APPROXIMATE DURATION:	15 Minutes	
PREPARED BY: R. J. Bro	ooks	- Data
PEER REVIEW BY:		Date
APPROVED FOR LISE.		Date
	Training Supervisor y Designee	Date

L

### TRAINING MATERIAL CHANGE FORM

Affected Training Materials: 2CR-155				
Type of Change:				
Changes Requiring Revision	Learning Objective	Related Change?	New Rev. # 0	
Changes Not Requiring Revision	The Change Does N Objectives or Materi	ot Impact Learning al Quality.	Existing Rev. # New Change #	
List/Description of Change	e(s):			
Original issue				
Reason for Change (s):				
APPROVALS				
R. J. Brooks Prepared by		Date	<b>NOTE</b> : Additions, deletions or changes to training materials must be reviewed for their possible impact to the Training	
Training Superintendent/Security Changes Not Requiring	upervisor/Peer Revision'' only)	Date	Qualification Matrix. See Incumbent Impact Review, NOBP-TR-1104.	

\_\_\_\_

JPM NUMBER: 2CR-155 JPM REVISION: 0	JPM TITLE: Respond to PRT Trouble			
K/A REFERENCE: 007 A 007 A	2.02 2.6 / 3.2 2.05 3.2 / 3/6	TASK ID: 007-003-0101		
JPM APPLICATION:	REQUALIFICATION	N 🛛 INITIAL EXAM	TRAINING	
EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED B 7:	
<ul> <li>Perform</li> <li>Simulate</li> </ul>	Plant Site     Simulator     Classroom	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	BVT NRC Other:	

EVALUATION RESULTS				
Performer Name:		Performer	SSN:	
fime Yes Critical: No	Allotted Time: 15 Mir	utes	Actual Time:	minutes
JPM RESULTS: SAT UNSA Comments:	T (Comments requir	ed for UNS	AT evaluatior	n)
	OBSERVER	RS	···	
Name/SSN:	Nan	ne/SSN:		
Name/SSN:	Nan	ne/SSN:		
	<u> </u>	)R		
Evaluator (Print):		]	Date:	
Evaluator Signature:				

# **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	PRT High Temperature alarm is cleared and PRT level is dropping.
RECOMMENDED STARTING LOCATION:	Control Room
DIRECTIONS:	You are to perform the task respond to Pressurizer Relief Tank Trouble.
INITIAL CONDITIONS:	<ul> <li>The plant is operating at 25% power.</li> <li>A PRZR PORV was leaking BUT is NOW NO LONGER LEAKING.</li> <li>The Pressurizer Relief Tank Trouble annunciator [A4-3H] has just actuated as a result of this leakage.</li> </ul>
INITIATING CUE:	Your supervisor directs you to respond to Annunciator A4-3H "Pressurizer Relief Tank Trouble" and take action to clear the annunciator.
REFERENCES:	20M-6.4.AAY, Revision 8
TOOLS:	NONE
HANDOUT:	20M-6.4.AAY, Revision 8

\*

\*

### **CANDIDATE DIRECTION SHEET**

THIS SHEET TO BE GIVEN TO CANDIDATE

	Read:		
TASK:		You are to perform the task respond to Pressurizer Relief Tank Trouble.	
INITIA	L CONDITIONS:		
		<ul> <li>The plant is operating at 25% power.</li> <li>A PRZR PORV was leaking BUT is NOW NO LONGER LEAKING.</li> <li>The Pressurizer Relief Tank Trouble annunciator [A4-3H] has just actuated as a result of this leakage.</li> </ul>	
INITIA	TING CUE:	Your supervisor directs you to respond to Annunciator A4-3H "Pressurizer Relief Tank Trouble" and take action to clear the annunciator.	
	At this time, ask the evaluation	uator any questions you have on this JPM.	
	When satisfied that you understand the assigned task, announce "I am now beginning the JPM".		
	Simulate performance or Point to any indicator or	perform as directed the required task. component you verify or check and announce your observations.	

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.

# 2LOIT-08-NRC JPMs S5 & S6

### Initial conditions/simulator setup

 n ya panaka na manaka na manak Manaka na manaka na ma	ar an	an a	in the number of the	- of a dimition of the
، مۇرىيەت، سى باي ي				المحققين والمساوين
 	itž v			
			· · · · · · · · · · · · · · · · · · ·	

S5 - Respond to PRT Problems

S6 Transfer from MFRVs to BPFRVs

Initialize

Run

LRTIC file commands

Horns, Printers, Sounds ready

Trg 2 when [2RCS\*AOV519] placed to open

Reduce PRT temperature indication

Trg 1 when "A" BPFRV placed in AUTO Open [2FWS\*FCV479]

JPM NUMBER: 2CR-155 JPM REVISION: 0	PM TITLE: Respond to PRT Trouble
STEP ("C" Denotes CRITICAL STEP)	STANDARD       (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U         Simulator Setup: Initialize Simulator IC 238 for 2LOT6         NRC exam. Mode 1 ~ 25% power.         TRGSET 2 XA11097P ==1'         IMFXMT RCS078A (2 0) 110 120         Trg2 When 2RCSAOV519 is opened reduce PRT         temperature indication         START TIME:
1. Obtain copy of 2OM-6.4.AAY.	<ul> <li>1.1 Candidate locates 2OM-6.4.AAY, reviews and determines proper procedure section is PRT temperature is &gt; 125°F and level is &gt; 78%</li> <li>1.2 Determines 2OM-6.4.AAY Part A for High temp and Part D for High level are both applicable.</li> <li>COMMENTS:</li> </ul>
<ul> <li>2.C Reduce PRZR Relief Tank Temp &lt; 125F as follows:</li> <li>Open [2RCS-MOV516], PRZ Relief Tank Spray Vlv.</li> </ul>	EVALUATOR NOTE: Candidate may address the actions in either order. The JPM is formatted to address High temperature first. Step 6 of the JPM begins to address the high level.         perature       2.1C       Places CS for PRZR Relief Tank Spray Vlv 2RCS-MOV516 to OPEN         ZR       2.2       Verifies red light – LIT and green light – NOT LIT         COMMENTS:       COMMENTS:

JPM NUMBER: 2CR-155 JPM REVISION: 0 JPM TITLE: Respond to PRT Trouble				
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U			
3.C Open [2RCS-AOV519], PRZR R Tank Pri Grade M/U Wtr Inlet.	<ul> <li>elief 3.1C Places CS for PRZR Relief Tank Pri Grade M/U Wtr Inlet2RCS-AOV519 to OPEN</li> <li>3.2 Verifies red light – LIT and green light – NOT LIT</li> <li>COMMENTS:</li> </ul>			
<ul> <li>4.C When the desired PRT temperaturachieved,</li> <li>Close [2RCS-AOV519], PR Relief Tank Pri Grade M/U Inlet.</li> <li>Close [2RCS-MOV516], PF Relief Tank Spray Vlv.</li> </ul>	re is       4.1C       Monitors PRT temperature to verify it has decreased below 125°F         ZR       EVALUATOR CUE: If necessary, inform candidate that it is desired to reduce temperature below 120°F         RZR       4.2C       Places CS for PRZR Relief Tank Pri Grade M/U Wtr Inlet2RCS-AOV519 to CLOSE         4.3       Verifies red light – NOT LIT and green light – LIT         4.4C       Places CS for PRZR Relief Tank Spray Vlv 2RCS-MOV516 to CLOSE         4.5       Verifies red light – NOT LIT and green light – LIT         COMMENTS:       COMMENTS:			
5. Independently verify [2RCS-AOV closed and log in the Narrative Log	519] 5.1 N/A EVALUATOR CUE: Inform the candidate that another operator will perform the independent verification. COMMENTS:			

÷

JPM NUMBER: 2CR-155 JPM REVISION: 0	PM TITLE: Respond to PRT Trouble
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S/U
	<b>EVALUATOR NOTE:</b> Candidate should proceed to 20M-6.4.AAY Part D to address the PRT High level.
<ul> <li>6.C Lower PRZR Relief Tank level to 72%, ([2RCS-LI470], VB-B):</li> <li>Open [2RCS-MOV523], PR Relief Tank Drain Vlv, (BB-</li> </ul>	<ul> <li>&lt; 6.1C Places CS for PRZR Relief Tank Drain Vlv 2RCS-MOV523 to OPEN</li> <li>ZR</li> <li>6.2 Verifies red light – LIT and green light – NOT LIT</li> <li>COMMENTS:</li> </ul>
7.C Start [2DGS-P21A(B)], Primary I Tfr Pump.	Drains       7.1C       Places CS for Primary Drains Tfr Pump. 2DGS-P21A(B) to START         7.2       Verifies red light – LIT and green light – NOT LIT         COMMENTS:
8.C When PRZR Relief Tank level to 72%, Stop [2DGS-P21A(B)], Prin Drains Tfr Pump AND Return con switch to AUTO.	<ul> <li>8.1 Monitors PRT level to verify level is dropping and has dropped below 72%.</li> <li>8.2C Places CS for Primary Drains Tfr Pump. 2DGS-P21A(B) to AUTO</li> <li>8.3 Verifies red light – NOT LIT and green light – LIT</li> <li>COMMENTS:</li> </ul>
.

JPM NUMBER: 2CR-155 JPM REVISION: 0	JPM TITLE: Respond to PRT Trouble
STEP ("C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ 57
9.C Close [2RCS-MOV523], PR Relief Tank Drain Vlv.	ZR       9.1C       Places CS for PRZR Relief Tank Drain Vlv 2RCS-MOV523 to CLOSE         9.2       Verifies red light – NOT LIT and green light – LIT         COMMENTS:
	EVALUATOR CUE:         That completes this JPM         STOP TIME:

TRAINING MATERIAL TITLE:	Shift From Main Feedwater Reg Valves to Bypasses
TRAINING MATERIAL NUMBER:	2CR-572
PROGRAM TITLE:	Licensed Operator Retraining
COMPUTER CODE:	2CR-572
REVISION NUMBER:	1

**TECHNICAL REFERENCES:** 

2OM-52.4.R.1.F, Station Shutdown From 100% Power To Mode 5, Revision 9

**INSTRUCTIONAL SETTING**:

Control Room

APPROXIMATE DURATION:

15 Minutes

PREPARED BY:	R. J. Brooks		
<u>ran nan pr</u> .			Date
PEER REVIEW BY:		<u> </u>	
			Date
<u>APPROVED FOR USE:</u>		Training Superviso or Designee	Date

#### TRAINING MATERIAL CHANGE FORM

Affected Training Materia	ls: 2CR-572	
Type of Change:		
Changes Requiring Revision	Learning Objective Related Change?	New Rev. # 1
Changes Not Requiring Revision	The Change Does Not Impact Learning Objectives or Material Quality.	Existing Rev. # 0 New Change #
List/Description of Change	e(s):	
Updated to reflect current	procedure	
Υ.		
Reason for Change (s):		
Updated to reflect current	procedure	
APPROVALS:		
R. J. Brooks Prepared by	Date	NOTE: Additions, deletions or changes to training materials must be reviewed for their possible impact to the Training
Training Superintendent/S ("Changes Not Requiring	upervisor/Peer Date Revision" only)	Qualification Matrix. See Incumbent Impact Review, NOBP-TR-1104.

.

JPM NUMBER: 2CR-572 JPM REVISION: 1		JPM TITLE: Shift From Main Feedwater Reg Valves to Bypasses			
	K/A REFERENCE:	035A4.	01 3.7/3.6	TASK ID: 0241-004-01-0	13
	JPM APPLICATION:	$\boxtimes$	REQUALIFICATION	🛛 INITIAL EXAM	TRAINING
		$\boxtimes$	FAULTED JPM		VE JPM
	EVALUATION MET	HOD:	LOCATION:	TYPE:	ADMINISTERED BY:
	<ul> <li>Perform</li> <li>Simulate</li> </ul>		<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	BVT NRC Other:

EVALUATION RESULTS				
Performer Name:		Performer S	SN:	
Time  Yes Critical:  No	Allotted Time: 15 minu	ites	Actual Time:	minutes
JPM RESULTS: UNSAT Comments:	(Comments required	d for UNSAT	evaluation)	
	OBSERVER	S		
Name/SSN:	Nam	e/SSN:		
Name/SSN:	Nam	e/SSN:		
	EVALUATO	R		
Evaluator (Print):			Date:	
Evaluator Signature:				

JPM NUMBER: 2CR-072 JPM REVISION: 1	JPM TITLE: Shift From Main Feedwater Reg Valves to Bypasses
TASK STANDARD:	<b>EVALUATOR DIRECTION SHEET</b> The "A" Bypass Feed Regulating Valve has been placed in service in automatic mode and then, after candidate recognizes failure of automatic control, returned to Manual mode with candidate controlling steam generater level.
RECOMMENDED STARTING LOCATION:	CONTROL ROOM
DIRECTIONS:	You are to perform the task Transfer from Main Feed Regulating Valve to Bypass.
INITIAL CONDITIONS:	<ul> <li>A plant shutdown is in progress</li> <li>The plant is at approximately 25% power.</li> <li>2OM-52.4.R.1.F, Station Shutdown From 100% Power To Mode 5 has been completed up to Step IV.D.5.</li> <li>The 21B and C S/G main Feed Reg Valves have been removed from service.</li> <li>The 21A main Feed Reg Valve [2FWS-FCV478] operated erratically during the shutdown and is currently in "AUTO" for observation.</li> </ul>
INITIATING CUE:	<ul> <li>Your supervisor directs you to place 21A S/G Bypass Feed Reg Valve [2FWS-FCV479] in service in accordance with 2OM-52.4.R.1.F, Station Shutdown From 100% Power To Mode 5 Attachment 10 step A.</li> <li>[2FWS-FCV479] is to be placed in automatic to control steam generator level.</li> <li>You are to maintain 21A S/G NR level between 39% and 49%.</li> </ul>
REFERENCES:	20M-52.4.R.1.F, Station Shutdown From 100% Power To Mode 5, Revision 9
TOOLS:	None
HANDOUT:	2OM-52.4.R.1.F, Station Shutdown From 100% Power To Mode 5, Attachment 10 Revision 9

#### **CANDIDATE DIRECTION SHEET**

#### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

	Read:	
TASK:		You are to perform the task Transfer from Main Feed Regulating Valve to Bypass.
INITIAL	CONDITIONS: ING CUE:	<ul> <li>A plant shutdown is in progress</li> <li>The plant is at approximately 25% power.</li> <li>2OM-52.4.R.1.F, Station Shutdown From 100% Power To Mode 5 has been completed up to Step IV.D.5.</li> <li>The 21B and C S/G main Feed Reg Valves have been removed from service.</li> <li>The 21A main Feed Reg Valve [2FWS-FCV478] operated erratically during the shutdown and is currently in "AUTO" for observation.</li> <li>Your supervisor directs you to place 21A S/G Bypass Feed Reg Valve [2FWS-FCV479] in service in accordance with 20M-52.4.R.1.F, Station Shutdown From 100% Power To Mode 5 Attachment 10 step A.</li> <li>[2FWS-FCV479] is to be placed in automatic to control steam generator level.</li> <li>You are to maintain 21A S/G NR level between 39% and 49%.</li> </ul>
	At this time, ask the evaluat	tor any questions you have on this JPM.
	When satisfied that you understand the assigned task, announce "I am now beginning the JPM".	
	Simulate performance or perform as directed the required task. Point to any indicator or component you verify or check and announce your observations.	

After determining the Task has been met announce " I have completed the JPM".

Then hand this sheet to the evaluator.

# 2LOIT-08-NRC JPMs S5 & S6

### Initial conditions/simulator setup



### S5 - Respond to PRT Problems

#### S6 Transfer from MFRVs to BPFRVs

 Initialize

Run

LRTIC file commands

Horns, Printers, Sounds ready

Trg 2 when [2RCS\*AOV519] placed to open

Reduce PRT temperature indication

Trg 1 when "A" BPFRV placed in AUTO Open [2FWS\*FCV479]

JPM NUMBER: 2CR-572 JPM REVISION: 1	TLE: Transfer from Main Feedwater Reg Valves to Bypasses	
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S	s U
	START TIME:	
	<b>EVALUATOR NOTE:</b> <b>Initialize IC-238 for 2LOT6 NRC Exam,</b> Set Bank D Control Rods to 126 steps. Put "SGWIDE" trend up on BOP's PCS screen. Open MFRV isolation valve 2FWS-MOV154A. Place 2FWS-FCV478 in AUTO, place 2FWS- FCV479 in MANUAL and close valve. To set up alternate path, set Trigger 1 to actuate when the Bypass controller AUTO pushbutton is depressed <b>TRGSET 1 'XC11064E'</b> Insert command to fail Bypass to full open over 60 seconds from Trigger 1, (PB in AUTO) <b>IMF CNH-CFW11B (1 0) 100 60 ASIS</b>	
<ol> <li>Obtain a copy of 2OM-52.4.R.1.F, Station Shutdown From 100% Power To Mode 5, Attachment 10</li> </ol>	<ul> <li>1.1 Candidate locates a copy of 2OM-52.4.R.1.F, Station Shutdown From 100% Power To Mode 5, Attachment 10</li> <li>EVALUATOR NOTE: Procedure can be provided to candidate, if provided, N/A this JPM Step.</li> <li>COMMENTS:</li> </ul>	
2.C Place controller in MANUAL AND Slowly Open the 21A Bypass FCV.	<ul> <li>2.1C Intermittently depresses the Bypass Control Valve [2FWS-FCV479] up pushbutton.</li> <li>2.2 Verifies feed flow increases</li> <li>COMMENTS:</li> </ul>	

PM NUMBER: 2CR-572JPM TITLE: Transfer from Main Feedwater Reg Valves to BypassesJPM REVISION: 1		
STEP ( "C" Denotes CRITICAL STEP )         3. As the 21A Bypass FCV is being opened, close [2FWS-FCV 478], 21A Main Feedwater Reg Valve, MANUAL OR AUTO to mainta 21A SG level WITHIN 39% to 49%.	STANDARD       (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒       S U         3.1       Verifies 21A Main Feedwater Reg Valve 2FWS-FCV 478 demand signal is decreasing and feed flow is reducing.       Image: Commentation of the second signal is decreasing and feed flow is reducing.         in       COMMENTS:       Image: Commentation of the second signal second se	
4.C Continue to Open the 21A Bypas FCV UNTIL the 21A Main Feed Reg Valve is closed.	<ul> <li>4.1C Intermittently depresses the Bypass Control Valve [2FWS-FCV479] up pushbutton.</li> <li>4.2 Verifies 21A Main Feed Reg Valve green light – LIT and red light NOT LIT</li> <li>COMMENTS:</li> </ul>	
<ul> <li>5.C WHEN the 21A Main Feed Re Valve is fully closed, perform the following: <ul> <li>Verify the 21A Main Feed Reg Valve controller in MAN.</li> </ul> </li> </ul>	5.1C Places 21A Main Feed Reg Valve controller to MAN 5.2 Verifies MAN light – LIT and AUTO light is – NOT LIT comments:	

.

JPM NUMBER: 2CR-572 JPM REVISION: 1 JPM TI	TLE: Transfer from Main Feedwater Reg Valves to Bypasses
STEP ("C" Denotes CRITICAL STEP)	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U
<ol> <li>Observe Feedwater flow, steam flow and SG level for evidence of leakage past the 21A Main Feed Reg Valve.</li> </ol>	6.1 Verifies feed flow, steam flow, and NR level are stable COMMENTS:
7.C Close [2FWS-MOV154A], 21A SG Main Feedwater Isol Vlv.	<ul> <li>7.1C Places CS for 21A SG Main Feedwater Isol Vlv 2FWS-MOV154A to CLOSE</li> <li>7.2 Verifies green light – LIT and red light – NOT LIT</li> <li>COMMENTS:</li> </ul>
	FAULT STATEMENT:         This is where the alternate path will begin; valve will trend         open to 100% over 60 seconds as soon as the controller PB is         placed in AUTO.
8.C Place controller for the 21A Bypass FCV in AUTO AND Monitor SG level AND flow.	<ul> <li>8.1C Places controller for the 21A Bypass FCV in AUTO</li> <li>8.2 Verifies MAN light – NOT LIT and AUTO light is – LIT</li> <li>8.3 Determines valve is failing OPEN in Automatic.</li> <li>COMMENTS:</li> </ul>

٠

JPM NUMBER: 2CR-572 JPM REVISION: 1	JPM TI	FLE: T	ransfer from Main Feedwater Reg Valves to Bypasses	
STEP ("C" Denotes CRITICAL STEP)		STANI	DARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	<u>s</u> U
9.C If level control is NOT stat restore the valve controller MANULAL AND Maintain	ole, to SG NR	9.1C	Places controller for the 21A Bypass FCV in MAN	
level between 39% and 49%	%.	9.3C	Intermittently depresses the Bypass Control Valve [2FWS-FCV479] up/down pushbutton to regain manual control of SG level with NR level between 39% and 49%.	
		COMN	MENTS:	
			EVALUATOR CUE: That completes this JPM	
n An the second			STOP TIME:	



TRAINING MATERIAL TITLE:	Perform Nuclear Intermediate Range Channel Functional Test
TRAINING MATERIAL NUMBER:	2CR-646
PROGRAM TITLE:	License Operator Training (Retraining)
COMPUTER CODE:	<u>2CR-646</u>
<b>REVISION NUMBER</b> :	0

#### **TECHNICAL REFERENCES:**

2OST-2.2, Nuclear Intermediate Range Channel Functional Test

**INSTRUCTIONAL SETTING**:

APPROXIMATE DURATION:

PREPARED BY:	R. J. Brooks	
		Date
PEER REVIEW BY:	· · · · · · · · · · · · · · · ·	
APPROVED FOR USE:		Date
	Training Supervise - Designee	Date

Simulator

10 Minutes

### TRAINING MATERIAL CHANGE FORM

Affected Training Material	ls: 2CR-646		
Type of Change:			
Changes Requiring Revision	Learning Objective Re	lated Change?	New Rev. # 0
Changes Not Requiring Revision	The Change Does Not Objectives or Material	Impact Learning Quality.	Existing Rev. # N/A New Change #
List/Description of Change	e(s):		
• Initial issue of JPM			
Reason for Change (s):			
APPROVALS:		r	
R. J. Brooks		Dete	<b>NOTE</b> : Additions, deletions or changes to training materials
		LJate	must be reviewed for their possible impact to the Training Qualification Matrix, See
Training Superintendent/Superintende	upervisor/Peer Revision" only)	Date	Incumbent Impact Review, NOBP-TR-1104.

RTL#A5.640U			1/2-ADM-1301.F0 Page 3 of 1 Revision
JPM NUMBER: 2CR-646 JPM REVISION: 0	JPM TITLE: Perform Nuc Test	elear Intermediate Range Ch	annel Functional
K/A REFERENCE: 015 A	3.03 3.9/3.9 T.	ASK ID: 0021-011-06-01	3
JPM APPLICATION:	REQUALIFICATION	🛛 INITIAL EXAM	TRAINING
·	FAULTED JPM	ADMINISTRATIV	'E JPM

EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED B (:
Perform Simulate	<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	BVT NRC Other:

EVALUATION RESULTS								
Performer Name:		Performer SSN:						
Time 🗌 Yes Critical: 🔀 No	Allotted Time: 10 min	utes	Actual Time:	minutes				
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:								
	OBSERVER	RS						
Name/SSN:	Nan	ne/SSN:						
Name/SSN:	Nan	Name/SSN:						
	EVALUATO	DR						
Evaluator (Print):	·····	]	Date:					
Evaluator Signature:								

κ.

### **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	Hi level Rod stop is tested satisfactorily and the surveillance is <b>STOPPED</b> when the high level trip will not reset.
RECOMMENDED STARTING LOCATION:	Simulator
DIRECTIONS:	You are to perform the task of Nuclear Intermediate Range Channel Functional Test.
INITIAL CONDITIONS:	The plant is in Mode 2 with reactor power ~ 3%. 2OST-2.2, Nuclear Intermediate Range Channel Functional Test has been completed through step VII.B.9.
INITIATING CUE:	Your supervisor directs you to complete 2OST-2.2, Nuclear Intermediate Range Channel Functional Test Beginning at step VII.B.10.
REFERENCES:	2OST-2.2, Nuclear Intermediate Range Channel Functional Test Revision 7
TOOLS:	None
HANDOUT:	20ST-2.2, Nuclear Intermediate Range Channel Functional Test completed through step VII.B.9.

١

### CANDIDATE DIRECTION SHEET

### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

	Read:	
TASK:		You are to perform the task of Nuclear Intermediate Range Channel Functional Test.
INITIA	L CONDITIONS:	The plant is in Mode 2 with reactor power $\sim 3\%$ . 2OST-2.2, Nuclear Intermediate Range Channel Functional Test has been completed through step VII.B.9.
INITIA	TING CUE:	Your supervisor directs you to complete 2OST-2.2, Nuclear Intermediate Range Channel Functional Test Beginning at step VII.B.10.
	At this time, ask the eval	uator any questions you have on this JPM.
	When satisfied that you	understand the assigned task, announce "I am now beginning the JPM"
	Simulate performance or Point to any indicator or	perform as directed the required task. component you verify or check and announce your observations.
	After determining the Ta Then hand this sheet to t	ask has been met announce " I have completed the JPM". he evaluator.

# 2LOIT-08-NRC JPMs S7 & S8

### Initial conditions/simulator setup



#### S7 Perform IRNI Functional Test

د در است سامرین	 ىز	تى 1. 1.11 ئۇرىغى ئەرىكى ئەرىپى 1.11 ئۇرىغ ئەرىكى ئەرىپى		 Same Second	
9 1 1 8 - F			96. <u>-</u> 4.	2	

#### ADMIN JPM

6	· · · ·	· · · · · ·						·		 A	·····			مەنىيەر » مەنىيەر	- 40 N N	
				1				1				-				
•					/ 		۰								2	
	 		, ,		 N 4	<u>.</u>	- <u>.</u>		<u>у</u> ос.	 		 				
							1				<u> </u>				20	- 1
11.10																-naha
о. ч а	 <u>.</u>					÷	- -	- <u></u>		-		 	~			
										\$ <u>?</u> ~			*			÷

#### Makeup to the RWST

	an a T		क्षित्र विश्वेष स्थितः स्वतंत्र स्थितः स्वतंत्र स्थानम्बर्गस्य	and a second	
		and the second second second second	<u>in an an</u>		
				Ar Si	

#### Initialize

Run

LRTIC file commands

Horns, Printers, Sounds ready

Trg 1 to fail N35 Bistable (Rx trip) 'as is' when actuated

Fails N35 (Rx trip) bistable 'as is'

Fail [2GS-HCV100] open

Trg 5 to remove failure of [2GS-HCV100]

Clear malfunction of [2GS-HCV100]

High failure of liquid waste discharge rad monitor

Close [2CHS\*79]

Open [2chs\*87]

JPM NUMBER: 2CR-646 JPM TITLE: Perform Nuclear Intermediate Range Channel Functional Test					
STEP	STANDARD				
( "C" Denotes CRITICAL STEP )	$(Indicate "S" FOR SAT or "U" FOR UNSAT) \Rightarrow S U$				
	START TIME:				
	SIMULATOR SETUP: Initialize IC-Mode 2 ~ 3% power FAULT by making Hi flux trip NOT reset				
<ul> <li>1.C Perform the test of the IRN-35 High Level Rod Stop as follows:</li> <li>Place the Test Mode Switch in VARIABLE.</li> <li>Verify that the "HIGH LEVEL ROD STOP" Drawer Status Light is OFF.</li> </ul>	<ul> <li>1.1C Rotates the Test Mode Variable control switch clockwise to the VARIABLE position.</li> <li>1.2 Verifies N35 Drawer Status Light "HIGH LEVEL ROD STOP" is NOT LIT.</li> <li>COMMENTS:</li> </ul>				
2.C Turn the Variable control knob clockwise until the "HIGH LEVEL ROD STOP" Drawer Status Light turns ON.	<ul> <li>2.1C SLOWLY rotates the Test Mode Variable control knob clockwise UNTIL the "HIGH LEVEL ROD STOP" Drawer Status Light is LIT.</li> <li>COMMENTS:</li> </ul>				

.

JPM NUMBER: 2CR-646 JPM TITL JPM REVISION: 0 Test	E: Perfo	rm Nuclear Intermediate Range Channel Functional	
STEP		DARD	
("C" Denotes CRITICAL STEP )		(Indicate "S" FOR SAT or "U" FOR UNSAT) $\Rightarrow$	<u>s U</u>
3.C Record the neutron level indication on the NIS Drawer meter when the Drawer Status Light turns ON: Verify the NIS Drawer indication satisfies the Acceptance criteria.	3.1 3.2C	Records, in the space provided the neutron level indication on the N35 Drawer meter when the Drawer Status Light turns ON. Verifies the value recorded is between the Low and High limits listed in the surveillance and initials the space provided.	
		MENTS	
<ul> <li>4.C Record the neutron level indication on [2NMI-NI35B], Intermediate Range Current, when the Drawer Status Light turns ON:</li> <li>Verify the indication on [2NMI-NI35B] is within the high and low</li> </ul>	4.1 4.2C	Records, in the space provided the neutron level indication on [2NMI-NI35B], Intermediate Range Current when the Drawer Status Light turns ON. Verifies the value recorded is between the Acceptance Criteria Low and High limits listed in the surveillance and initials the space provided.	
umus.	СОМ	EVALUATOR CUE: If necessary to avoid contact with other candidates, CUE candidate that Benchboard [2NMI-NI35B], Intermediate Range Current is the SAME AS the drawer meter.	

JPM NUMBER: 2CR-646 JPM TITLE: Perform Nuclear Intermediate Range Channel Functional					
JPM REVISION: 0 Test					
STEP	STA	ANDARD			
( "C" Denotes CRITICAL STEP )		$(\text{Indicate "S" FOR SAT or "U" FOR UNSAT}) \Rightarrow S U$			
5.C Turn the Variable control knob counterclockwise until the "HIGH LEVEL ROD STOP" Drawer Status Light turns OFF.		C SLOWLY Rotates Variable control knob counterclockwise until the "HIGH LEVEL ROD STOP" Drawer Status Light is NOT LIT. MMENTS:			
6.C Record the neutron level ind	ication on 6.1	Records, in the space provided the neutron level indication on the N35 Drawer meter when the Drawer			
Drawer Status Light turns O Verify the NIS Drawer indicat satisfies the Acceptance criter	FF: ion is 6.2 a.	<ul> <li>Status Light is NOT LIT.</li> <li>C Verifies the value recorded is between the Low and High limits listed in the surveillance and initials the space provided.</li> </ul>			
	СО	OMMENTS:			

JPM REVISION: 0	Test	
STEP ( "C" Denotes CRITICAL STEP )	)	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S
<ul> <li>7. Perform the test of the Inter Range Neutron Flux High I Setpoint as follows: Verify the following: <ul> <li>Status Light C-9, "INTRX TRIP", is OFF.</li> <li>PCS Point N0020D, "CHAN 1 HIGH FLUXNORMAL.</li> </ul> </li> </ul>	rmediate Reactor Trip F RNG N35 INT RNG (", indicates	<ul> <li>7.1 Verifies the following:</li> <li>Status Light C-9, "INT RNG N35 RX TRIP", is NOT LIT.</li> <li>PCS Point N0020D, "INT RNG CHAN 1 HIGH FLUX", indicates NORMAL.</li> </ul> EVALUATOR CUE: If necessary to avoid contact with other candidates, CUE candidate that Benchboard Status Light C-9, "INT RNG N35 RX TRIP", is NOT LIT. AND PCS Point N0020D, "INT RNG CHAN 1 HIGH FLUX", indicates NORMAL. COMMENTS:
8.C Turn the Variable control clockwise until the "HIG TRIP" Drawer Status Lig	knob H LEVEL ht turns ON.	<ul> <li>8.1C SLOWLY Rotates Variable control knob clockwise until the "HIGH LEVEL TRIP" Drawer Status Light is LIT.</li> <li>COMMENTS:</li> </ul>

JPM TITLE: Perform Nuclear Intermediate Range Channel Functional

JPM NUMBER: 2CR-646

U

JPM JPM	JPM NUMBER: 2CR-646JPM TITLE: Perform Nuclear Intermediate Range Channel FunctionalJPM REVISION: 0Test				
<u>K</u>				·	
STEP ( "C" Denotes CRITICAL STEP )		STAN	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S/U		
9.C	Record the neutron level ind on the NIS Drawer meter wi Drawer Status Light turns O Verify the NIS Drawer indic satisfies the Acceptance crit	lication hen the PN: cation eria.	9.1 9.2C COM	EVALUATOR NOTE: In the next step, the IRN-35 Trip Setpoint (recorded in Instruction A.4) High Limit has already been recorded in the space provided as part of a previously performed step in the initial conditions. Records, in the space provided the neutron level indication on the N35 Drawer meter when the Drawer Status Light is LIT. Verifies the value recorded below the High limit listed in the surveillance and initials the space provided. MENTS:	
10.	If the NIS Drawer indication setpoint is NOT within the Acceptance Criteria, Refer t Attachment A, "Measureme [2NMI NM35A(36A)], Log Amplifier Output". (Otherw	n for the ont of the Current vise N/A)	10.1 COM	Determines reference to Attachment A, "Measurement of the [2NMI NM35A(36A)], Log Current Amplifier Output" is N/A based on values being within limits. MENTS:	

,

JPM NUMBER: 2CR-646 JPM TITLE: Perform Nuclear Intermediate Range Channel Functional			
JPM REVISION: 0 Test			
JPM REVISION: 0       Test         STEP ("C" Denotes CRITICAL STEP )         11.C Record the neutron level indication on the [2NMI-NI35B], Intermediate Range Current, when the Drawer Status Light turns ON:         • Verify the indication on [2NMI- NI35B] is within the high and low limits.	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U I1.1C Records, in the space provided the neutron level indication on [2NMI-NI35B], Intermediate Range Current when the Drawer Status Light turns ON. 11.2 Verifies the value recorded is between the Acceptance Criteria Low and High limits listed in the surveillance and initials the space provided. EVALUATOR CUE: If necessary to avoid contact with other candidates, CUE candidate that Benchboard [2NMI-NI35B], Intermediate Range Current is the SAME AS the drawer meter. COMMENTS:		
<ul> <li>12. If necessary, turn the Variable control knob clockwise until the "HIGH LEVEL TRIP" Drawer Status Light remains ON AND doe NOT reset. (Otherwise N/A)</li> </ul>	12.1 Determines N/A. S COMMENTS:		

E: Perform Nuclear Intermediate Range Channel Functional
STANDARD
$(Indicate "S" FOR SAT of "U" FOR UNSAT) \Rightarrow [5]$
<ul> <li>13.1 Verifies the following: Status Panel 308 -9, "INT RNG N35 RX TRIP", is LIT AND NOT flashing. PCS Point N0020D, "INT RNG CHAN 1 HIGH FLUX", indicates TRIP.</li> <li>EVALUATOR CUE: If necessary to avoid contact with other candidates, CUE candidate that Benchboard Status Panel 308 - 9, "INT RNG N35 RX TRIP", is LIT AND NOT flashing. AND PCS Point N0020D, "INT RNG CHAN 1 HIGH FLUX", indicates TRIP.</li> <li>COMMENTS:</li> </ul>
FAULT STATEMENT:         The High level trip bistable WILL NOT reset in the next step.         14.1C SLOWLY Rotates Variable control knob fully counter clockwise.         14.2C Determines "HIGH LEVEL TRIP" Drawer Status Light REMAINS LIT.         COMMENTS:

JPM NUMBER: 2CR-646 JPM TITLE JPM REVISION: 0 Test	E: Perform Nuclear Intermediate Range Channel Functional
STEP ("C" Denotes CRITICAL STEP )	$\frac{\text{STANDARD}}{(\text{Indicate "S" FOR SAT or "U" FOR UNSAT)}} \leq U$
	EVALUATOR NOTE:At this point the Surveillance CANNOT be completed without support from the I&C department. If the Level Trip Switch is returned to NORMAL, the reactor will trip.EVALUATOR NOTE: The candidate SHOULD recognize the impact of returning the level trip switch to normal.
	EVALUATOR CUE: That completes this JPM.
	STOP TIME:

TRAINING MATERIAL TITLE:	Batch To The Refueling Water Storage Tank
TRAINING MATERIAL NUMBER:	2CR-537
PROGRAM TITLE:	Licensed Operator Training (Retraining)
COMPUTER CODE:	2CR-537
REVISION NUMBER:	1

#### TECHNICAL REFERENCES:

20M-7.4.O, Makeup To The Refueling Water Storage Tank, Rev. 13

INSTRUCTIONAL SETT	<u>CING</u> :	Simulator		
APPROXIMATE DURA	<u>ΓΙΟΝ</u> :	15 minutes		
PREPARED BY:	R. J. Brooks			Date
PEER REVIEW BY:				Date
APPROVED FOR USE:		Training Sup	ervisor or Designee	Date

### TRAINING MATERIAL CHANGE FORM

Affected Training Material	s: 2CR-537	
Type of Change:		· · · · · · · · · · · · · · · · · · ·
Changes Requiring Revision	Learning Objective Related Change?	New Rev. # 1
Changes Not Requiring Revision	The Change Does Not Impact Learning Objectives or Material Quality.	Existing Rev. # 0 New Change #
List/Description of Change	(s):	
Update JPM to current pro	cedure and JPM format	
Reason for Change (s): JPM Enhancement		
APPROVALS:		
R. J. Brooks Prepared by	Date	<b>NOTE</b> : Additions, deletions or changes to training materials must be reviewed for their possible impact to the Training Qualification Matrix. See
Training Superintendent/S ("Changes Not Requiring	upervisor/Peer Date Revision" only)	Incumbent Impact Review, NOBP-TR-1104.

JPM NUMBER: 2CR-537 JPM REVISION: 1	JPM TITLE: Batch To	o The Refueling Water Stora	ge Tank
K/A REFERENCE: 004 A4 004 A4 004 A4	4.01(3.8/3.9)4.04(3.2/3.6)4.07(3.9/3.7)	TASK ID: 0071-025-01-	013
JPM APPLICATION: 🛛 REQUALIFICATION 🖾 INITIAL EXAM 🗌 TRAININ			
EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED BY:
Perform     Simulate	<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> <li>Other:</li> </ul>	BVT NRC Other:

EVALUATION RESULTS				
Performer Name:		Performer	SSN:	
Time Ves Critical: No	Allotted Time: 15 mir	utes	Actual Time:	minutes
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:				
	OBSERVE	RS		
Name/SSN:	Nat	ne/SSN:		
Name/SSN: Name/SSN:		ne/SSN:		
	EVALUAT	OR		
Evaluator (Print):			Date:	
Evaluator Signature:				

### **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	Makeup flow to the RWST is initiated AND terminated after discovery of no boric acid flow.
RECOMMENDED STARTING LOCATION:	Control Room
<b>DIRECTIONS:</b>	You are to perform the task Batch To The Refueling Water Storage Tank.
INITIAL CONDITIONS:	The plant is in Mode 2 with reactor power at ~ 3%. The Refueling Water Storage Tank level is currently at 717.5". RWST boron concentration is 2500 ppm and Boric Acid Storage Tank concentration is 7500 ppm. The Spent Fuel Pool was being filled from the RWST. This operation has been secured. Annunciator A6-1D, RWST LEVEL OFF NORMAL has alarmed. Actual RWST level is just below the narrow range low level alarm setpoint.
INITIATING CUE:	Your supervisor directs you to batch 300 gallons of borated water at current RWST boron concentration to the RWST by manual blender operation in accordance with 20M-7.4.O, Makeup To The Refueling Water Storage Tank, beginning at step IV.B.5.
REFERENCES:	20M-7.4.O, Makeup To The Refueling Water Storage Tank, Rev. 13
TOOLS:	Calculator
HANDOUT:	20M-7.4.0, Makeup To The Refueling Water Storage Tank

#### **CANDIDATE DIRECTION SHEET**

#### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

Read:	
TASK:	You are to perform the task Batch To The Refueling Water Storage Tank.
INITIAL CONDITION	NS: The plant is in Mode 2 with reactor power at ~ 3%. The Refueling Water Storage Tank level is currently at 717.5". RWST boron concentration is 2500 ppm and Boric Acid Storage Tank concentration is 7500 ppm. The Spent Fuel Pool was being filled from the RWST. This operation has been secured. Annunciator A6-1D, RWST LEVEL OFF NORMAL has alarmed. Actual RWST level is just below the narrow range low level alarm setpoint.
INITIATING CUE:	Your supervisor directs you to batch 300 gallons of borated water at current RWST boron concentration to the RWST by manual blender operation in accordance with 20M-7.4.0, Makeup To The Refueling Water Storage Tank, beginning at step IV.B.5.
At this time, as	k the evaluator any questions you have on this JPM.
When satisfied	that you understand the assigned task, announce "I am now beginning the JPM".

	Simulate performance or perform as directed the required task. Point to any indicator or component you verify or check and announce your observations.
_	After determining the Task has been met ennounce "I have completed the IDM"

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.

## 2LOIT-08-NRC JPMs S7 & S8

Initial conditions/simulator setup



S7 Perform IRNI Functional Test

ADMIN JPM

.8 Makeup to the RWST

 Initialize

Run

LRTIC file commands

Horns, Printers, Sounds ready

Trg 1 to fail N35 Bistable (Rx trip) 'as is' when actuated

Fails N35 (Rx trip) bistable 'as is'

Fail [2GS-HCV100] open

Trg 5 to remove failure of [2GS-HCV100]

Clear malfunction of [2GS-HCV100]

High failure of liquid waste discharge rad monitor

Close [2CHS\*79] Open [2chs\*87]

JPM NUMBER: 2CR-537 JPM REVISION: 1	JPM TIT	TLE: Batch To The Refueling Water Storage Tank
STEP ( "C" Denotes CRITICAL STEP )		STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U
		START TIME:
		SIMULATOR SETUP: Init IC Verify RWST level set to 717' 5" (ASISRWST = 7.43E6). Update RWST boron concentration placard to 2500 ppm and BA Storage Tank concentration placard to 7500 ppm. Verify LOA BAT6 to open 2CHS*87. Verify 2CHS*79 is overridden in the closed position LOA BAT 004. Set BA & Total Flow totalizers to ZERO and reset.
1. Obtain procedure.		<ul> <li>EVALUATOR NOTE: This step is optional. Evaluator may elect to provide procedure. If provided, N/A this JPM step ⇒.</li> <li>1.1 Candidate locates 2OM-7.4.O, Makeup To The Refueling Water Storage Tank.</li> <li>EVALUATOR CUE: After candidate locates the procedure, provide a copy of 2OM-7.4.O, Makeup To The Refueling Water Storage Tank.</li> <li>COMMENTS:</li> </ul>
2. Place the Boric Acid Makeu Blender Control Switch in S	р ТОР.	<ul><li>2.1 Candidate locates and places Boric Acid Makeup Blender Control Switch in Stop.</li><li>COMMENTS:</li></ul>

JPM NUMBER: 2CR-537 JPM REVISION: 1	TLE: Batch To The Refueling Water Storage Tank
STEP ("C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S'U
3.C Place the Mode Selector Switch in MAN.	<ul> <li>3.1C Candidate locates and places Mode Selector Switch in Manual.</li> <li>COMMENTS:</li> </ul>
<ul> <li>4. Verify the following valves are in the closed position.</li> <li>a. [2CHS*FCV113B], Boric Acid Blender Disch To Chg Pumps</li> <li>b. [2CHS*FCV114B], Blender Outlet To Volume Control Tank</li> <li>c. [2CHS*SOV206], Alt Emergency Boration Vlv</li> <li>d. [2CHS*MOV350], Emergency Boration Isol Vlv</li> </ul>	<ul> <li>4.1 Candidate locates and verifies valves closed.</li> <li>4.2 Candidate verifies green closed light lit and red open light not lit for each valve.</li> <li>COMMENTS:</li> </ul>
<ul> <li>5. If this section is being performed for testing of the blender, THEN perform the following: (otherwise N/A)</li> </ul>	<ul> <li>5.1 Candidate N/A's step.</li> <li>EVALUATOR NOTE: If asked, inform the Candidate that no testing is being performed.</li> <li>COMMENTS:</li> </ul>

JPM NUMBER: 2CR-537 JPM REVISION: 1 JPM TI	TLE: Batch To The Refueling Water Storage Tank
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ SU
<ul> <li>6. Determine Boric Acid Flow from the following calculation:</li> <li>BoricAcidFlow = a x b/c</li> </ul>	EVALUATOR CUE: If asked, inform the Candidate that Desired flowrate is 75 gpm.         6.1. Candidate calculates boric acid flow: $\frac{2500 ppm \ge 75 gpm}{7500} = 25.0 gpm (\pm 1 gpm)$ COMMENTS:
7.C Set [2CHS*FCV113A] as follows: Pot Setting = $\frac{Boric \ Acid \ Flow}{4 \ gpm}$	7.1C Candidate calculates and adjusts 2CHS*FCV113A to desired pot setting. $6.25 (\pm 0.25) = \frac{25.0}{4gpm}$ COMMENTS:
8.C Adjust [2CHS*HIC168], Blender Total Flow Auto Setpoint, to the blender total flow used in Step IV.A.9. Pot Setting = $\frac{Total \ Makeup \ Flow}{16 \ gpm}$	8.1C Candidate locates and adjusts 2CHS*HIC168 to desired pot setting. $4.69 (4.6 - 4.8) = \frac{75}{16 \text{ gpm}}$ COMMENTS:

.

JPM NUMBER: 2CR-537 JPM REVISION: 1 JPM T	TLE: Batch To The Refueling Water Storage Tank
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U
<ul> <li>9.C Adjust [2CHS*FCV114A] pot setting to the blender total flow used in Step IV.A.9.</li> <li>Pot Setting = Total Makeup Flow 16 gpm</li> </ul>	9.1C Candidate locates and adjusts 2CHS*FCV114A to desired pot setting. $4.69 (4.6 - 4.8) = \frac{75}{16 \text{ gpm}}$ COMMENTS:
10.C Set [2CHS-FQIS113], Boric Acid Flow To Blender Flow Totalizer, to the total volume in gallons of boric acid to be added from the following equation: $B.A.Vol = \frac{B.A Flow}{Total Makeup Flow}$ x Total Makeup Vol	<ul> <li>10.1C Candidate locates and sets 2CHS-FQIS113 for the desired total volume of boric acid.</li> <li>100 (96 - 104) = 25 ± 1/75 gpm x 300</li> <li>10.2 Candidate locates and resets 2CHS-FQIS113.</li> <li>COMMENTS:'</li> </ul>
11.C Set [2CHS-FQIS168], Total Makeup From Blender Flow Totalizer, to the desired total volume in gallons of makeup to be added.	<ul> <li>11.1C Candidate locates and sets 2CHS-FQIS168 to 300 gallons.</li> <li>11.2 Candidate locates and resets 2CHS-FQIS168.</li> <li>COMMENTS:</li> </ul>

.

JPM REVISION: 1	ILE: Batch To The Refueling Water Storage Tank
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U
<ul> <li>12. Record the following information into the Narrative Log: Total Makeup + Total Makeup From Blender Flow Totalizer = Total</li> </ul>	<ul> <li>12.1 Candidate indicates the values to be recorded in the Narrative Log.</li> <li>EVALUATOR CUE: Inform the Candidate that another operator will make the log entry.</li> <li>COMMENTS:</li> </ul>
<ul><li>13. Establish communications with an operator at the blender room (Aux. Bldg. 710')</li></ul>	<ul> <li>13.1 Candidate uses page party to contact local operator in the blender room.</li> <li>EVALUATOR CUE: Inform the Candidate that an operator is standing by in the blender room.</li> <li>COMMENTS:</li> </ul>
<ul> <li>14.C Open the following valves: (Aux. Bldg. Blender Rm, 710')</li> <li>a. [2CHS*87], Blender To Refueling Cavity Isolation</li> <li>b. [2CHS*89], Blender To RWST Isolation</li> </ul>	<ul> <li>14.1C Candidate directs local operator to open 2CHS*87 and 2CHS*89.</li> <li>EVALUATOR CUE: Report as local operator that 2CHS*87 and 2CHS*89 are open.</li> <li>COMMENTS:</li> </ul>
JPM NUMBER: 2CR-537 JPM REVISION: 1 JPM TI	TLE: Batch To The Refueling Water Storage Tank
---	--
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U
15.C To initiate makeup, place the Boric Acid Makeup Blender Control Switch to START.	<ul> <li>15.1C Candidate locates and places Boric Acid Makeup Control Switch in Start.</li> <li>15.2. Candidate verifies red makeup light lit.</li> <li>COMMENTS:</li> </ul>
<ul> <li>6.C Verify expected flows for the following parameters are being recorded at [2CHS-FR113], Boric Acid To Blender Total M/U Flow From Blender:</li> <li>a. Boric Acid To Blender (red pen)</li> <li>b. Total M/U Flow From Blender (green pen)</li> </ul>	FAULT STATEMENT: 2CHS*79 is failed closed. In the next step Boric acid flow will be zero with total flow indicating 75 gpm.         16.1       Candidate locates 2CHS-FR113 and verifies boric acid flow and total makeup flow.         16.2C       Candidate takes immediate action to terminate dilution by placing Boric Acid Makeup Control Switch in STOP.         EVALUATOR NOTE:       Stop the JPM after the Candidate secures the dilution.         COMMENTS:       Comments:
	STOP TIME:



TRAINING MATERIAL TITLE:	Safeguards Test of FWI	
TRAINING MATERIAL NUMBER:	2PL-048	<u> </u>
PROGRAM TITLE:	Licensed Operator Training (Retraining)	
COMPUTER CODE:	2PL-048	
REVISION NUMBER:	11	
<u>TECHNICAL REFERENCES:</u> 2OST-1.11A, Rev 15 2OST-1.12A, Rev 19		
INSTRUCTIONAL SETTING:	In-Plant	
APPROXIMATE DURATION:	20 Minutes	
PREPARED BY: R. J. Broc	oks	and a second
		Date
PEER REVIEW BY:		Date
APPROVED FOR USE:	Training Supervisor	Date

# TRAINING MATERIAL CHANGE FORM

Affected Training Material	s: 2PL-048			
Type of Change:				
Changes Requiring Revision	Learning Objective Related Ch	ange? I	New Rev. # 11	
Changes Not Requiring Revision	The Change Does Not Impact I Objectives or Material Quality.	Learning H	Existing Rev. # 10 New Change #	
List/Description of Change	(s):	,~,I		
Updated to current procedu Added 2LOT6 NRC Exam • Split JPM into 2 sej • Added Cabinet mar • Added evaluator cu	are revisions. Validation comments. parate sections for ease of perfor k numbers to first evaluator note e for annunciator A2-2H	mance		
Reason for Change (s):		<u></u>		
JPM Enhancement				
APPROVALS:		/·		
<u>R. J. Brooks</u> Prepared by	Date	- ch mi pc Qu	OTE: Additions, deletions or anges to training materials ust be reviewed for their ossible impact to the Training ualification Matrix. See	
Training Superintendent/Superintendent	apervisor/Peer Date Revision" only)	In N	cumbent Impact Review, OBP-TR-1104.	

\_\_\_\_

JPM NUMBER: 2PL-048 JPM REVISION: 11 JPM TITLE: Safegua		rds Test of FWI	
K/A REFERENCE: 013A3 2.1.23	3.01 3.7/3.9 3.9/4.0	TASK ID: 0011-024-06-	013
JPM APPLICATION:	REQUALIFICATION	N 🛛 INITIAL EXAM	TRAINING
	FAULTED JPM	ADMINISTRAT	IVE JPM
<b>EVALUATION METHOD:</b>	LOCATION:	TYPE:	ADMINISTERED BY:
Perform Simulate	<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	Annual Requal Exam Initial Exam OJT/TPE Training Other:	BVT NRC Other:

EVALUATION RESULTS				
Performer Name:		Performer	SSN:	
Γime ☐ Yes Critical: ⊠ No	Allotted 10 Minu Time: 20 Minu	tes (TRN A) tes (TRN B)	Actual Time:	minutes
JPM RESULTS:       SAT         UNSAT       (Comments required for UNSAT evaluation)         Comments:				
OBSERVERS				
Name/SSN: Name/SSN:				
Name/SSN: Name/SSN:				
EVALUATOR				
Evaluator (Print): Date:				
Evaluator Signature:				

٠

## **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	Relay K622A (K601B and K620B) are tested IAW the surveillance procedure and determined to meet the acceptance criteria.
EVALUATOR NOTE:	This JPM is formatted to use either SSPS Train. During "Protected Train A" weeks, use 2OST 1.12A, Train B test and JPM pages 12-23. During "Protected Train B" weeks, use 2OST 1.11A, Train A test and JPM pages 6-11
RECOMMENDED STARTING LOCATION:	In Plant
<b>DIRECTIONS:</b>	You are to simulate the Main Feedwater Isolation safeguards test. Following completion of this portion of the OST, determine if the test results satisfy the acceptance criteria.
INITIAL CONDITIONS:	The plant is operating under steady-state conditions at 100% power. All plant systems are configured in their normal system arrangement. 2OST 1.11A, Safeguards Protection System Train A Blockable Test, (or 2OST 1.12A, Safeguards Protection System Train B Blockable Test) is in progress and has been completed up to the beginning of Section VII.B. Communications have been established with the control room and the front panel of the Safeguards Test Cabinet is unlocked and open.
INITIATING CUE:	Your supervisor directs you continue with the test by completing Section VII.B, and when complete, determine if the test results satisfy the acceptance criteria.
REFERENCES:	2OST-1.11A Revision 15 2OST-1.12A Revision 19
TOOLS:	Key #79 Train A SSPS -or- Key #126 Train B SSPS
HANDOUT:	2OST-1.11A pages 1-16 (content) and 45-46 (table 1 & table 2) -or- 2OST-1.12A pages 1-21 (content) and 51-52 (table 1 & table 2)

#### CANDIDATE DIRECTION SHEET

#### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

|--|

TASK: You are to simulate the Main Feedwater Isolation safeguards test. Following completion of this portion of the OST, determine if the test results satisfy the acceptance criteria. INITIAL CONDITIONS: The plant is operating under steady-state conditions at 100% power. All plant systems are configured in their normal system arrangement. 2OST 1.11A, Safeguards Protection System Train A Blockable Test, (or 2OST 1.12A, Safeguards Protection System Train B Blockable Test) is in progress and has been completed up to the beginning of Section VII.B. Communications have been established with the control room and the front panel of the Safeguards Test Cabinet is unlocked and open. **INITIATING CUE:** Your supervisor directs you continue with the test by completing Section VII.B. and when complete, determine if the test results satisfy the acceptance criteria.

At this time, ask the evaluator any questions you have on this JPM.

When satisfied that you understand the assigned task, announce "I am now beginning the JPM"

	Simulate performance or perform as directed the required task.
ļ	Point to any indicator or component you verify or check and announce your observations.

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.

JPM NUMBER: 2PL-048 JPM REVISION: 11 JP	M TITLE: Safeguards Test of FWI
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S/U
	START TIME:
EVALUATOR NOTE: This JPM is formatted to us either SSPS Train. During "Protected Train A" weeks, use 20ST 1.12A, Train B test and JPM pages 12-23.	e <b>EVALUATOR NOTE:</b> Normally two operators are assigned to perform this task. One is the performer and the other is the peer checker/placekeeper. It may be necessary to clarify the expectation that the candidate will be the performer, and the other operator will assist in placekeeping.
During "Protected Train B" weeks, use 2OST 1.11A, Train A test and JPM pages 6-11	<b>EVALUATOR CUE:</b> Unlock and open the Safeguards Test Cabinet [2RK*2P-TST-A]. Provide cues as appropriate. Provide a copy of 2OST-1.11A to the candidate.
<ol> <li>Notify SM/US to make a narrative log entry of relay inoperability and Tech Spece entry.</li> </ol>	1.1       Candidate notifies SM/US to make a narrative log entry of relay inoperability and entry into Tech Spec.         EVALUATOR CUE:         Role-play SM/US and acknowledge the report AND inform the candidate that the appropriate log entries have been made         COMMENTS:

JPM NUMBER: 2PL-048 JPM REVISION: 11 JPM	TITLE: Safeguards Test of FWI
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S/U
2. Verify white test lamps ON.	2.1. Candidate verifies white test lamps 040, 041, 042 ON.
	EVALUATOR CUE: White test lamps are ON.
	COMMENTS:
3.C Rotate test switch to the PUSH TO TEST position.	3.1.C Candidate rotates test switch TRN A S811 to the PUSH TO TEST position.
	<b>EVALUATOR CUE:</b> Test switch is in the <b>PUSH TO TEST</b> position.
	3.2. Candidate contacts the control room to verify annunciator A2-2H is in alarm.
	<b>EVALUATOR CUE:</b> Role-play control room operator and inform the candidate that Annunciator A2-2H is IN ALARM.
	COMMENTS:

`

JPM NUMBER: 2PL-048       JPM TITLE: Safeguards Test of FWI         JPM REVISION: 11       JPM TITLE: Safeguards Test of FWI			
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT) $\Rightarrow$ S/U		
4. Verify red test lamp 081 is ON.	4.1. Candidate verifies red test lamp 081 is ON.		
	EVALUATOR CUE: Red test lamp is ON.		
	COMMENTS:		
5. Verify white test lamps are OFF.	<ul> <li>5.1. Candidate verifies white test lamps 040, 041, 042 are OFF.</li> <li>EVALUATOR CUE: White test lamps are OFF.</li> </ul>		
	COMMENTS:		
6.C Depress and release test switch.	6.1C Candidate depresses and then releases test switch TRN A S811. EVALUATOR CUE: Test switch has been depressed and released. COMMENTS:		

JPM NUMBER: 2PL-048 JPM REVISION: 11 JPM TITLE: Safeguards Test of FWI		
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ SU	
7.C Depress each white test lamp individually and verify each is ON as depressed and OFF when released.	<ul> <li>7.1C Candidate depresses and then releases each lamp 040, 041, 042 and verifies each is ON when depressed and OFF when released.</li> <li>EVALUATOR CUE: Lamps ON when depressed and OFF when released.</li> <li>COMMENTS:</li> </ul>	
8.C Place reset test switch to RESET and allow it to spring return to NORMAL.	<ul> <li>8.1C Candidate places reset test switch TRN A S821 to RESET and allows it to spring return to NORMAL.</li> <li>EVALUATOR CUE: Test switch has been RESET and has spring returned to NORMAL.</li> <li>COMMENTS:</li> </ul>	
9.C Verify white test lamps.	<ul> <li>9.1C Candidate depresses and then releases each lamp 040, 041, 042 and verifies each remains OFF when depressed.</li> <li>EVALUATOR CUE: Lamps remain OFF when depressed.</li> <li>COMMENTS:</li> </ul>	

JPM NUMBER: 2PL-048 JPM REVISION: 11 JPM T	TTLE: Safeguards Test of FWI
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S/U
10. Check for stuck relays.	10.1. Candidate determines that no stuck relays are indicated and proceeds to the next step.
	COMMENTS:
11.C Place test switch in NORMAL.	11.1C Candidate places test switch TRN A S811 in NORMAL         EVALUATOR CUE:         Test switch is in NORMAL.         COMMENTS:
12. Verify test/blocking lamps.	12.1. Candidate verifies white test lamps 040, 041, 042 ON.         EVALUATOR CUE:         White test lamps are ON.         COMMENTS:

JPM NUMBER: 2PL-048 JPM REVISION: 11 JPM 7	ITTLE: Safeguards Test of FWI
STEP ("C" Denotes CRITICAL STEP)	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S/U
13. Verify red test lamp 081 is OFF.	<ul> <li>13.1. Candidate verifies red test lamp 081 is OFF.</li> <li>EVALUATOR CUE: Red test lamp 081 is OFF.</li> <li>13.2. Candidate contacts the control room to verify annunciator A2-2H is OFF.</li> <li>EVALUATOR CUE: Role-play control room operator and inform the candidate that Annunciator A2-2H is OFF.</li> <li>COMMENTS:</li> </ul>
14.C Evaluate results against acceptance criteria.	14.1C       Candidate evaluates results against OST acceptance criteria and determines that this portion of the OST meets the acceptance criteria.         COMMENTS:         EVALUATOR CUE:         That completes this JPM.
A Construct of Manager Parameters	STOP TIME:

JPM NUMBER: 2PL-048 JPM REVISION: 11	PM TIT	LE: Safeguards Test of FWI
STEP ("C" Denotes CRITICAL STEP)		STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT) $\Rightarrow$ S/U
		START TIME:
EVALUATOR NOTE: This JPM is formatted to a either SSPS Train. During "Protected Train A weeks, use 20ST 1.12A, Train B test and JPM page 12-23.	use A" es	<b>EVALUATOR NOTE:</b> Normally two operators are assigned to perform this task. One is the performer and the other is the peer checker/placekeeper. It may be necessary to clarify the expectation that the candidate will be the performer, and the other operator will assist in placekeeping.
During "Protected Train E weeks, use 20ST 1.11A, Train A test and JPM page 6-11	B" es	EVALUATOR CUE: Unlock and open the Safeguards Test Cabinet [2RK*2P-TST-B]. Provide cues as appropriate. Provide a copy of 2OST-1.12A to the candidate.
<ol> <li>Notify SM/US to make a narralog entry of relay inoperability Tech Spec entry.</li> </ol>	ative y and	1.1 Candidate notifies SM/US to make a narrative log entry of relay inoperability and entry into Tech Spec. <b>EVALUATOR CUE:</b> Role-play SM/US and acknowledge the report <b>AND</b> inform the candidate that the appropriate log entries have been made COMMENTS:

JPM NUMBER: 2PL-048 JPM REVISION: 11 JPM TI	TLE: Safeguards Test of FWI
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT) $\Rightarrow$ S/U
2. Determine if the Reactor Trip Breakers are OPEN.	<ul> <li>2.1. Candidate determines that the reactor trip breakers are closed (given in initial conditions), N/As steps B.2.a &amp; B.2.b, and proceeds to step B.3.</li> <li>EVALUATOR CUE: If asked, reactor trip breakers are CLOSED.</li> <li>COMMENTS:</li> </ul>
3. Verify white test lamps ON.	3.1. Candidate verifies white test lamps 002, 004, 006 ON. EVALUATOR CUE: White test lamps are ON. COMMENTS:

JPM NUMBER: 2PL-048 JPM REVISION: 11	M TITLE: Safeguards Test of FWI	
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U	J" FOR UNSAT)⇒ $S/U$
4.C Rotate test switch to the TO TEST position.	<ul> <li>JSH 4.1C Candidate rotates test switch TRN B S80 TO TEST position.</li> <li>EVALUATOR CUE: Test switch is in the PUSH TO TEST position.</li> <li>4.2 Candidate contacts the control room to v A2-2H is in alarm.</li> <li>EVALUATOR CUE: Role-play control room operator and info candidate that Annunciator A2-2H is IN .</li> <li>COMMENTS:</li> </ul>	01 to the PUSH osition. verify annunciator rm the ALARM.
5. Verify red test lamp 081 is	N. 5.1. Candidate verifies red test lamp 081 is C EVALUATOR CUE: Red test lamp is C COMMENTS:	DN.

JPM NUMBER: 2PL-048 JPM REVISION: 11	JPM TITLE: Safeguards Test of FWI		
STEP ( "C" Denotes CRITICAL STEP )		STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	s/U
6. Verify green blocking la ON.	mps are	6.1. Candidate verifies green blocking lamps 001, 003, 005 are ON.	
		EVALUATOR CUE: Green blocking lamps are ON.	
		COMMENTS:	
7.C Depress and release tes	t switch.	7.1C Candidate depresses then releases test switch TRN B S801.	
		<b>EVALUATOR CUE:</b> Test switch has been depressed and released.	
		COMMENTS:	
8. Verify white test lamps	are OFF.	8.1. Candidate verifies white test lamps 002, 004, 006 are OFF. <b>EVALUATOR CUE:</b> White test lamps are <b>OFF</b> .	
		COMMENTS:	

•

JPM NUMBER: 2PL-048 JPM REVISION: 11	JPM TIT	ITLE: Safeguards Test of FWI
STEP ( "C" Denotes CRITICAL STEP	)	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S
9.C Depress each white test individually and verify ON as depressed and C released.	t lamp each is PFF when	<ul> <li>9.1C Candidate depresses and then releases each lamp 002, 004, 006 and verifies each is ON when depressed and OFF when released.</li> </ul>
		EVALUATOR CUE: Lamps ON when depressed and OFF when released.
		COMMENTS:
10.C Place reset test switch t RESET and allow it to return to NORMAL.	o spring	10.1C Candidate places reset test switch TRN B S821 to RESET and allows it to spring return to NORMAL <b>EVALUATOR CUE:</b> Test switch has been <b>RESET</b> and has spring returned to <b>NORMAL</b> .
		COMMENTS:
11.C Verify white test lamps	5.	11.1C Candidate verifies white test lamps 002, 004, 006 ON.  EVALUATOR CUE: White test lamps are ON.
		COMMENTS:

JPM NUMBER: 2PL-048       JPM TITLE: Safeguards Test of FWI         JPM REVISION: 11       JPM TITLE: Safeguards Test of FWI		
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S/U	
12. Check for stuck relays.	12.1. Candidate determines that no stuck relays are indicated and proceeds to the next step.	
	COMMENTS:	
13.C Place test switch in NORMA	L. 13.1C Candidate places test switch TRN B S801 in NORMAL. EVALUATOR CUE: Test switch is in NORMAL. COMMENTS:	
14. Verify test/blocking lamps.	<ul> <li>14.1. Candidate verifies green blocking lamps 001, 003, 005 are OFF.</li> <li>EVALUATOR CUE: Green Blocking lamps are OFF.</li> <li>COMMENTS:</li> </ul>	

JPM I JPM I	NUMBER: 2PL-048 REVISION: 11	JPM TI	TLE: Safeguards Test of FWI	
STEP ( "C"	Denotes CRITICAL STEP )		STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S	s/U
15.C	Rotate test switch to the TO TEST position.	PUSH	<ul> <li>15.1C Candidate rotates test switch TRN B S802 to the PUSH TO TEST position.</li> <li>EVALUATOR CUE: Test switch is in the PUSH TO TEST position.</li> <li>COMMENTS:</li> </ul>	
16.	Verify red test lamp 08	1 is ON.	16.1. Candidate verifies red test lamp 081 is ON.         EVALUATOR CUE: Red test lamp is ON.         COMMENTS:	
17.	Verify green blocking l ON.	amps are	<ul> <li>17.1. Candidate verifies green blocking lamps 001, 003, 005 are ON.</li> <li>EVALUATOR CUE: Green blocking lamps are ON.</li> <li>COMMENTS:</li> </ul>	

JPM NUMBER: 2PL-048 JPM REVISION: 11	JPM TITLE: Safeguards Test of FWI
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ 5/
18.C Depress and hold test so depressed.	witch 18.1C Candidate depresses and holds test switch TRN B S802. <b>EVALUATOR CUE:</b> Test switch is being held depressed. COMMENTS:
19. Verify white test lamps OFF.	are       19.1       Candidate verifies white test lamps 002, 004, 006 are OFF.         EVALUATOR CUE:       White test lamps are OFF.         White test lamps are OFF.       COMMENTS:
20.C While holding the test s depressed, depress each test lamp individually a verify each is ON as de and OFF when released	switch n white and opressed 1. 20.1C Candidate holds test switch TRN B S802 depressed AND depresses and then releases each lamp 002, 004, 006 and verifies each is ON when depressed and OFF when released. Lamps ON when depressed and OFF when released. COMMENTS:

JPM NUMBER: 2PL-048 JPM REVISION: 11 JPM TI	<sup>8</sup> JPM TITLE: Safeguards Test of FWI	
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S/U	
21.C Release test switch.	21.1C Candidate releases test switch TRN B S802. <b>EVALUATOR CUE:</b> Test switch released.	
	COMMENTS:	
22.C Place reset test switch to RESET and allow it to spring return to NORMAL.	22.1C Candidate places reset test switch TRN B S821 to RESET and allows it to spring return to NORMAL. EVALUATOR CUE: Test switch has been RESET and has spring returned to NORMAL. COMMENTS:	
23. Verify white test lamps ON.	23.1. Candidate verifies white test lamps 002, 004, 006 ON. EVALUATOR CUE: White test lamps are ON. COMMENTS:	

JPM NUMBER: 2PL-048 JPM REVISION: 11 JPM TI	TLE: Safeguards Test of FWI
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S'U
24. Check for stuck relays.	24.1 Candidate determines that no stuck relays are indicated, and proceeds to the next step.
	COMMENTS:
25.C Place test switch in NORMAL.	25.1C Candidate places test TRN B S802 in NORMAL. EVALUATOR CUE: Test switch is in NORMAL. COMMENTS:
26. Verify green blocking lamps OFF.	<ul> <li>26.1. Candidate verifies green blocking lamps 001, 003, 005 are OFF.</li> <li>EVALUATOR CUE: Green blocking lamps are OFF.</li> <li>COMMENTS:</li> </ul>

JPM NUMBER: 2PL-048 JPM REVISION: 11	JPM TITLE: Safeguards Test of FWI
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S/U
27. Verify red test lamp 081 is	<ul> <li>OFF. 27.1. Candidate verifies red test lamp 081 is OFF.</li> <li>EVALUATOR CUE: Red test lamp 081 is OFF.</li> <li>27.2. Candidate contacts the control room to verify annunciator A2-2H is OFF.</li> <li>EVALUATOR CUE: Role-play control room operator and inform the candidate that Annunciator A2-2H is OFF.</li> <li>COMMENTS:</li> </ul>
28. Step 28 should be N/A.	<ul> <li>28.1. Candidate determines step B.2 was not performed and documents step 28 N/A.</li> <li>COMMENTS:</li> </ul>

JPM NUMBER: 2PL-048 JPM REVISION: 11	PM TITLE: Safeguards Test of FWI
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S/U
29. Step 29 should be N/A.	29.1. Candidate determines step B.2 was not performed and documents step 29 N/A.
	COMMENTS:
30.C Evaluate results against acceptance criteria.	30.1C Candidate evaluates results against OST acceptance criteria and determines that this portion of the OST meets the acceptance criteria.
	COMMENTS:
	EVALUATOR CUE:
1999 - John Martin Martin Martin and Antonia States (1997 - New York States and States	That completes this JPM.
	STOP TIME:

TRAINING MATERIAL TITLE:	Local Shutdown of 2FWE*P22 (IAW 2OST-24.4A)
TRAINING MATERIAL NUMBER:	2PL-069
PROGRAM TITLE:	Licensed Operator Training (Retraining)
COMPUTER CODE:	2PL-069
<b>REVISION NUMBER</b> :	<u>4</u>

#### TECHNICAL REFERENCES:

2OST-24.4A, Steam Driven Auxiliary Feed Pump [2FWE\*P22] Full Flow Test, Rev. 19 2OM-24.4.R, Resetting And Opening TDAFW Pump Trip And Throttle Valve, Rev. 20

INSTRUCTIONAL SETTING:

Plant (Auxiliary Feed Pump Room)

APPROXIMATE DURATION: 15 Minutes

PREPARED BY:	R. J. Brooks		,*
PEER REVIEW BY:			
APPROVED FOR USE:			Date
	<u></u>	Training Superviso, 5. Designee	Date

# TRAINING MATERIAL CHANGE FORM

Affected Training Material	ls:			
Type of Change:				
Changes Requiring Revision	Learning Objective Re	lated Change?	New Rev. # 4	
Changes Not Requiring Revision	The Change Does Not Objectives or Material	Impact Learning Quality.	Existing Rev. # 3 New Change #	
List/Description of Change	e(s):	<u> </u>		
Updated to current procedu Revised initial conditions t	ure revision and JPM for to address full flow testin	mat. ng of 2FWE*P22		
Reason for Change (s):		<u></u>		
Add critical steps Enhance JPM				
APPROVALS:				
R. J. Brooks	·····		NOTE: Additions, deletions or	
Prepared by		Date	changes to training materials must be reviewed for their possible impact to the Training	
Training Superintendent/S ("Changes Not Requiring	upervisor/Peer Revision" only)	Date	Qualification Matrix. See Incumbent Impact Review, NOBP-TR-1104.	

VPM NUMBER: 2PL-069 JPM REVISION: 4	JPM TITLE: Local Shutdown of 2FWE*P22 (IAW 2OST-24.4A)			
K/A REFERENCE: 061A2	.04 3.4/3.8	TASK ID: 0241-024-01-	043	
JPM APPLICATION:	REQUALIFICATION	N 🛛 INITIAL EXAM	TRAINING	
	FAULTED JPM	ADMINISTRAT	IVE JPM	
EVALUATION METHOD:	LOCATION:	TYPE:	ADMINISTERED BY:	
<ul> <li>Perform</li> <li>Simulate</li> </ul>	<ul> <li>Plant Site</li> <li>Simulator</li> <li>Classroom</li> </ul>	<ul> <li>Annual Requal Exam</li> <li>Initial Exam</li> <li>OJT/TPE</li> <li>Training</li> </ul>	BVT NRC Other:	

Other:

EVALUATION RESULTS					
Performer Name:	Performer SSN:				
Гіте 🗌 Yes Critical: 🔀 No	Allotted Time: 15 Min	utes	Actual Time:	minutes	
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:					
	OBSERVER	S			
Name/SSN: Nam		ne/SSN:			
Name/SSN:	ame/SSN:				
	EVALUATO	)R			
Evaluator (Print):		]	Date:		
Evaluator Signature:					

# **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	2FWE*P22 tripped and Reset
RECOMMENDED STARTING LOCATION:	Auxiliary Feed Pump Room
<b>DIRECTIONS:</b>	You are to simulate the task Local Shutdown of [2FWE*P22].
INITIAL CONDITIONS:	<ul> <li>The Plant is in Mode 3 with SG pressures at 700 psig.</li> <li>2OST-24.4A Steam Driven Auxiliary Feed Pump [2FWE*P22] Full Flow Test, is in progress and completed satisfactory through Part V.F.(THE PUMP IS CURRENTLY RUNNING)</li> <li>NO RWDA-G Discharge Authorization was required for this evolution.</li> </ul>
INITIATING CUE:	Your supervisor directs you to perform Part G Pump Shutdown step1.a through step 1.e of 2OST-24.4A Steam Driven Auxiliary Feed Pump [2FWE*P22] Full Flow Test, to shutdown [2FWE*P22].
REFERENCES:	2OST-24.4A, Rev. 19 2OM-24.4.R, Rev.20
TOOLS:	Hardhat, safety glasses, gloves, and Dosimetry
HANDOUT:	2OST-24.4A, Part G step 1.a through 1.e (Rev. 19) 2OM-24.4.R, Rev.20

#### **OPERATIONS JOB PERFORMANCE MEASURE**

#### **CANDIDATE DIRECTION SHEET**

#### \* THIS SHEET TO BE GIVEN TO CANDIDATE \*

Read:	
TASK:	You are to simulate the task Local Shutdown of [2FWE*P22].
INITIAL CONDITIONS:	<ul> <li>The Plant is in Mode 3 with SG pressures at 700 psig.</li> <li>2OST-24.4A Steam Driven Auxiliary Feed Pump [2FWE*P22] Full Flow Test, is in progress and completed satisfactory through Part V.F.(THE PUMP IS CURRENTLY RUNNING)</li> <li>NO RWDA-G Discharge Authorization was required for this evolution.</li> </ul>
INITIATING CUE:	Your supervisor directs you to perform Part G Pump Shutdown step1 a through step 1.e of 2OST-24.4A Steam Driven Auxiliary Feed Pump [2FWE*P22] Full Flow Test, to shutdown [2FWE*P22].
At this time, ask the o	evaluator any questions you have on this JPM.

At this time, ask the evaluator any questions you have on this JPM.

When satisfied that you understand the assigned task, announce "I am now beginning the JPM".

Simulate performance or perform as directed the required task. Point to any indicator or component you verify or check and announce your observations.

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.

JPM NUMBER: 2PL-069 JPM REVISION: 4	TLE: Local Shutdown of 2FWE*P22 (IAW 2OST-24.4A)	
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒	s/U
	START TIME:	
1. Obtain procedure 2OM-24.4.A.	EVALUATOR CUE:         For exam sequencing this step may be omitted, the evaluator may provide a copy of the procedure.         1. Candidate locates 20M-24.4.A.         COMMENTS:	
1.C Stop [2FWE*P22] by pressing the Emergency Trip Manual Lever.	<ul> <li>1.1 Locates the Emergency Trip Manual Lever.</li> <li>1.2C Presses the Emergency Trip Manual Lever.</li> <li>1.3 Verifies that the pump shaft has stopped rotating.</li> <li>EVALUATOR CUE: The pump shaft has stopped rotating.</li> <li>COMMENTS:</li> </ul>	
<ul> <li>2.C Close the following valves: (BB-C)</li> <li>[2MSS*SOV105A], Turb Driven AFW Pump Stm Hdr A Supply Isol Vlv.</li> <li>[2MSS*SOV105D], Turb Driven AFW Pump Stm Hdr A Supply Isol Vlv.</li> </ul>	<ul> <li>2.1 C Contacts the control room and requests operator to close [2MSS*SOV105A], Turb Driven AFW Pump Stm Hdr A Supply Isol Vlv.</li> <li>[2MSS*SOV105D], Turb Driven AFW Pump Stm Hdr A Supply Isol Vlv.</li> <li>EVALUATOR CUE: Role-play the control room operator and inform the candidate that [2MSS*SOV105A], Turb Driven AFW Pump Stm Hdr A Supply Isol Vlv. AND [2MSS*SOV105D], Turb Driven AFW Pump Stm Hdr A Supply Isol Vlv. are CLOSED.</li> <li>COMMENTS:</li> </ul>	

JPM N JPM F	NUMBER: 2PL-069 REVISION: 4	JPM TI	JPM TITLE: Local Shutdown of 2FWE*P22 (IAW 2OST-24.4A)			
STEP ( "C" I	Denotes CRITICAL STEP )		STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ №/	IJ		
3.	Initiate Part I, "Plant Restoration", concurren the remaining steps in t of the test (Part G) and "Remote Closed Positio Verification of [2MSS*SOV105A, B a	ntly with his part Part H, on nd C]".	<b>EVALUATOR CUE:</b> Role-play the Unit supervisor and inform the candidate that another operator will complete (Part G) and Part H, "Remote Closed Position Verification of [2MSS*SOV105A, B and C]".			
4.	Record the necessary information for stoppin discharge on the RWD. Discharge Authorizatio if RWDA-G is NOT re	g the A-G, n. (N/A quired)	N/A NO RWDA-G in progress. COMMENTS:			
5.	WHEN the pump shaft come to a complete sto [2FWE*TTV22], Trip Throttle Valve for 2FW in accordance with 2OI 24.4.R, "Resetting and TDAFW Pump Trip an Throttle Valve".	has p, Reset and /E*P22, M- Opening d	N/A Pump previously verified to be stopped. COMMENTS:			

JPM NUMBER: 2PL-069 JPM REVISION: 4	JPM TITLE: Local Shutdown of 2FWE*P22 (IAW 2OST-24.4A)	
STEP ( "C" Denotes CRITICAL STEP )	$(Indicate "S" FOR SAT or "U" FOR UNSAT) \Rightarrow S$	/U
6. Locates procedure 2OM- 24.4.R, "Resetting and O TDAFW Pump Trip and Throttle Valve" and revi initial conditions, and P&	- 0pening ews &Ls COMMENTS:	
7. Verify closed [2MSS*SOV105A-F].	<ul> <li>7.1 Candidate contacts Control Room to determine valve positions.</li> <li>EVALUATOR CUE: All of the steam supply SOV's, [2MSS*SOV105A, B. C. D. E. Fl. are CLOSED.</li> <li>COMMENTS:</li> </ul>	

JPM NUMBER: 2PL-069 JPM REVISION: 4	JPM TITLE: Local Shutdown of 2FWE*P22 (IAW 2OST-24.4A	)
STEP ("C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNS	$SAT) \Rightarrow S/U$
8. Verify tripped or depres Manual Emergency Trip	8.1 N/A Previously performed Lever.	
	COMMENTS:	
9. Verify [2FWE*TTV22] Throttle valve is unlatch	Trip       9.1       Candidate locates latch hook and verifies that the trilever is not engaged.         EVALUATOR CUE:       Trip Throttle Valve is NOT ENGAGED. (Brass sleeve is full down)         COMMENTS:	p

JPM NUMBER: 2PL-069 JPM REVISION: 4	JPM TITLE: 1	Local Shutdown of 2FWE*P22 (IAW 2OST-24.4A)
STEP ( "C" Denotes CRITICAL STEP )	STAN	NDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S U
		<b>EVALUATOR CUE:</b> The Turbine Driven Aux Feed pump will <b>NOT</b> be started within the next 15-20 minutes.
10.C Reset and latch the ove trip device.	rspeed 10.1	C Candidate turns the handwheel CLOCKWISE until the sliding nut and lever raise to the trip hook.
		<b>EVALUATOR CUE:</b> Brass Sliding nut and lever are all the way up.
	10.20	C Candidate locates and holds the overspeed trip connecting rod to the left, while ensuring the overspeed tappet washer flat side directly faces the overspeed trip lever.
		<b>EVALUATOR CUE:</b> Trip Lever is to the <b>LEFT</b> and <b>ENGAGED</b> in the trip hook with flat side tappet washer directly facing the Overspeed Trip Lever.
	10.30	C Candidate releases the connecting rod, allowing spring tension to maintain the reset condition.
		<b>EVALUATOR CUE:</b> After candidate releases the connecting rod the Overspeed Trip remains <b>RESET</b> .
	10.4	Candidate ensures the washer flat side is flush against the vertical side overspeed trip lever.
		<b>EVALUATOR CUE:</b> Washer flat side is flush against the overspeed trip lever vertical side.
	10.5	Candidate verifies value is latched by observing that the latch on the right side of the value is fully engaged.
		EVALUATOR CUE: The latch is FULLY ENGAGED.
	CON	IMENTS:

JPM NUMBER: 2PL-069 JPM REVISION: 4	JPM TITLE: Lo	ocal Shutdown of 2FWE*P22 (IAW 2OST-24.4A)	
STEP ("C" Denotes CRITICAL STEP)	STANI	DARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S(U	J
11.C Reopen Trip Throttle Val	ve. 11.1C	Candidate locates [2FWE*TTV22] and turns handwheel CCW until it stops in the full open position.	
		<b>EVALUATOR CUE:</b> [2FWE*TTV22] is <b>FULL OPEN</b> .	
	11.2	Candidate verifies that the pump does not accelerate in an uncontrolled manner.	
		<b>EVALUATOR CUE:</b> The pump slowly rotates as you open the Trip	
		<b>EVALUATOR CUE:</b> Acknowledge request for concurrent verification of the valve, inform candidate that other operators will perform this function using step 11 of the procedure. <b>Direct candidate to continue with step 8.</b>	
	11.3	Candidate adjusts the value 1/4 turn off the backseat.	
		<b>EVALUATOR CUE:</b> Valve is 1/4 Turn off its backseat.	
	11.4	Candidate verifies that the overspeed trip mechanism is reset by observing that the flat side of the washer remains engaged with the trip lever.	:
		<b>EVALUATOR CUE:</b> Flat side of the washer remains engaged with the trip lever	
	11.5	Candidate contacts the control room to verify that computer point Y5172D indicates OPER.	
		<b>EVALUATOR CUE:</b> Role-play Control Room operator and inform the candidate that Y5172D indicates <b>OPER</b> .	
	COMI	MENTS:	

JPM NUMBER: 2PL-069 JPM REVISION: 4	JPM TITLE: Lo	ocal Shutdown of 2FWE*P22 (IAW 2OST-24.4A)		
STEP STANE ("C" Denotes CRITICAL STEP )		DAED (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S/U		
		<b>EVALUATOR CUE:</b> IF necessary, Role-play the Unit Supervisor and inform the candidate that the Governor Oil Pressure was <b>NOT</b> previously relieved.		
12.C Relieve governor oil pressu	ire. 12.1	Candidate removes access cover to [2FWE-2CSSOV101].		
		EVALUATOR CUE: Cover is removed.		
	12.2 <b>C</b>	Candidate simultaneously depresses both pushbuttons until governor linkage movement has ceased and pushbuttons have been held for 15 seconds.		
		<b>EVALUATOR CUE:</b> All linkage movement has stopped, 15 seconds has elapsed.		
	12.3	Candidate replaces access cover to [2FWE-2CSSOV101].		
		EVALUATOR CUE: Cover is re-installed.		
	12.4	Candidate notifies Control Room that [2FWE*P22] is available.		
	COM	MENTS:		
		<b>EVALUATOR CUE:</b> That completes this JPM.		
		STOP TIME:		
•

.

## **OPERATIONS JOB PERFORMANCE MEASURE (JPM)**

TRAINING MATERIAL TITLE:	Locally Start the No.1(2) Emergency Diesel Generator
TRAINING MATERIAL NUMBER:	2PL-606
PROGRAM TITLE:	Licensed Operator Training
COMPUTER CODE:	2PL-606
REVISION NUMBER:	1

## TECHNICAL REFERENCES:

.

20M-53A.1.A-1.5, Local Action to Restore AC Power, Issue 1C, Revision 5

INSTRUCTIONAL SETT	T <u>ING</u> :	In Plant		
<u>APPROXIMATE DURA</u>	<u>I'ION</u> :	15 Minutes		
PREPARED BY:	R. J. Brooks			Date
PEER REVIEW BY:				Date
APPROVED FOR USE:		Training Supervisor	ngnee	Date

~

.

## TRAINING MATERIAL CHANGE FORM

Affected Training Material	s: 2PL-606	
Type of Change:		
Changes Requiring Revision	Learning Objective Related Change?	New Rev. # 1
Changes Not Requiring Revision	The Change Does Not Impact Learning Objectives or Material Quality.	Existing Rev. # 0 New Change #
List/Description of Change	(s):	
Renumbered incorrect step Re-formatted JPM to match Reason for Change (s):	s h current JPM format.	
APPROVALS:	N c	OTE: Additions, deletions or hanges to training materials
R. J. Brooks Prepared by	Date P	nust be reviewed for their ossible impact to the Training Qualification Matrix. See noumbent Impact Review,
Training Superintendent/So ("Changes Not Requiring J	upervisor/Peer Date [1] Revision" only)	10DI -11(-1104.

JPM NUMBER: 2PL-606 JPM REVISION: 1	JPM TITLE: Locally Start the No. 1(2) Emergency Diesel Generator			
K/A REFERENCE: 064A4.01 4.0/4.3 TASK ID: 0362-003-01-043 055EA1.01 4.3/4.4				
JPM APPLICATION:	REQUALIFICATION FAULTED JPM	REQUALIFICATION       INITIAL EXAM       TRAINING         FAULTED JPM       ADMINISTRATIVE JPM		
EVALUATION METHOD: Perform Simulate	LOCATION: Plant Site Simulator Classroom	TYPE: Annual Requ Initial Exam OJT/TPE Training Other:	al Exam	ADMINISTERED B Y: BVT NRC Other:
	EVALUATIC	N RESULTS		
Performer Name:		Performer S	SSN:	
Time Ves Critical: No	Allotted Time: 20	) minutes	Actual Time:	minutes
JPM RESULTS: SAT UNSAT (Comments required for UNSAT evaluation) Comments:				
OBSERVERS				
Name/SSN:	Name/SSN: Name/SSN:			
Name/SSN:		Name/SSN:		
	EVALU	JATOR		
Evaluator (Print):		I	Date:	
Svaluator Signature:				

## **EVALUATOR DIRECTION SHEET**

TASK STANDARD:	Locally start the No. 1(2) Diesel Generator.
RECOMMENDED STARTING LOCATION:	In Plant
EVALUATOR NOTE:	This JPM is designed for either Train. Perform on Diesel Generator #? if Protected Train A and on Diesel Generator #1 if Protected Train B. Train B equipment in parentheses.
<b>DIRECTIONS:</b>	You are to simulate the task locally start the No. 1(2) Emergency Diesel Generator.
UNITIAL CONDITIONS:	A station blackout has occurred. OM-53A Procedure ECA-0.0, "Loss of All AC Power," has led the crew to the step which requires local action to restore power. 2SWS*P21A(B) control switch is in AUTO.
INITIATING CUE:	Your supervisor directs you to use Attachment A-1.5 of ECA-0.0 to locally start the No. 1(2) Diesel Generator and energize the 2AE(2DF) bus, but to not load equipment onto the bus. You are given the key for the Diesel Generator (use of keys will be simulated).
REFERENCES:	20M-53A.1.A-1.5, Local Actions to Restore AC Power, Issue 1C, Revision 5
TOOLS:	Key 138 for Excitation Panel will be provided when needed Key for Local Start will be simulated (SR 27/28)
HANDOUT:	20M-53A.1.A-1.5, Local Actions to Restore AC Power, Issue 1C, Revision 5

#### **CANDIDATE DIRECTION SHEET**

#### Use this sheet if Protected Train "A"

\* THIS SHEET TO BE GIVEN TO CANDIDATE \*

Read:

TASK: Locally start No. 2 Diesel Generator

INITIAL CONDITIONS:

A station blackout has occurred. OM-53A Procedure ECA-0.0, "Loss of All AC Power," has led the crew to the step which requires local action to restore power. 2SWS\*P21B control switch is in AUTO.

INITIATING CUE:

Your supervisor directs you to use Attachment A-1.5 of ECA-0.0 to locally start the No. 2 Diesel Generator and energize the 2DF bus, but do not load equipment onto the bus. You are given the key for the Diesel Generator (use of keys will be simulated).

At this time, ask the evaluator any questions you have on this JPM.

When satisfied that you understand the assigned task, announce "I am now beginning the JPM".

Simulate performance or perform as directed the required task. Point to any indicator or component you verify or check and announce your observations.

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.

#### CANDIDATE DIRECTION SHEET

Use this sheet if Protected Train "B"

\* THIS SHEET TO BE GIVEN TO CANDIDATE \*

 Read:

 TASK:
 Locally start No. 1 Diesel Generator

 INITIAL CONDITIONS:
 A station blackout has occurred. OM-53A Procedure ECA-0.0, "Loss of All AC Power," has led the crew to the step which requires local action to restore power. 2SWS\*P21A control switch is in AUTO.

 INITIATING CUE:
 Your supervisor directs you to use Attachment A-1.5 of ECA-0.0 to locally start the No. 1 Diesel Generator and energize the 2AE bus, but do not load equipment onto the bus. You are given the key for the Diesel Generator (use of keys will be simulated).

At this time, ask the evaluator any questions you have on this JPM.

When satisfied that you understand the assigned task, announce "I am now beginning the JPM"

Simulate performance or perform as directed the required task. Point to any indicator or component you verify or check and announce your observations.

After determining the Task has been met announce " I have completed the JPM". Then hand this sheet to the evaluator.

JPM NUMBER: 2PL-606 JPM REVISION: 1	2PL-606       JPM TITLE: Locally Start the No. 1(2) Emergency Diesel Generator         1       1			
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT) $\Rightarrow$ S/U			
	START TIME:			
	<b>EVALUATOR NOTE:</b> A copy of the procedure can be given to the candidate if starting in plant. Key #138 will be needed for the Excitation Panel. Provide key when candidate needs to get into the panel. Uses of Auto/Local key will be simulated.			
1. Place Auto-Local Selector Switch in the LOCAL positio	<ul> <li>1.1 Candidate locates Auto-Local Control key switch.</li> <li>1.2 Inserts key and places in the LOCAL position.</li> <li>EVALUATOR CUE: Diesel Generator is in LOCAL.</li> <li>COMMENTS:</li> </ul>			
<ol> <li>Verify following alarms are r lit: Engine Overspeed and St Failure.</li> </ol>	art       2.1       Candidate locates Alarm Panel.         2.2       Verifies Engine Overspeed and Start Failure alarms not lit.         EVALUATOR CUE:         No alarms present.         COMMENTS:			

JPM NUMBER: 2PL-606 JPM REVISION: 1	JPM TI	ITLE: Locally Start the No. 1(2) Emergency Diesel Generator			
STEP ( "C" Denotes CRITICAL STEP )		STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S	/U		
3. Depress one local start pushbutton and maintair depressed until the diese and is self-sustaining an release pushbutton.	n it el starts d then	<ul> <li>EVALUATOR NOTE: Candidate may depress both pushbuttons, although only one is needed.</li> <li>3.1 Candidate locates Start Pushbutton, Start 1 or Start 2</li> <li>3.2 Depresses it until engine starts and is self-sustaining and then releases.</li> <li>EVALUATOR CUE: Diesel starts and is self-sustaining at 525 rpm.</li> <li>COMMENTS:</li> </ul>			
4.C Adjust Diesel Generator using governor raise-low control to establish an o speed of approximately rpm (510 to 520 rpm)	r speed wer operating 514	<ul> <li>4.1 Candidate locates Governor Raise-Lower control and speed indication.</li> <li>4.2C Candidate simulates turning Governor Raise-Lower to "Lower" position to decrease speed to 514 rpm.</li> <li>4.3 Verifies Engine speed at appx. 514 rpm.</li> <li>EVALUATOR CUE: Diesel speed is 514 rpm. (510-520).</li> <li>COMMENTS:</li> </ul>			

'L-606 JPM TITLE: Locally Start the No. 1(2) Emergency Diesel Generator			
) 5'	TANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒		
or Volts 5	<ul> <li>Candidate locates Diesel Generator Voltmeter.</li> <li>Verifies Engine voltage greater than 4160 VAC.</li> <li>EVALUATOR CUE: Diesel Generator Voltage is ZERO.</li> </ul>		
6 . 6 . 6	<ol> <li>Candidate calls control room.</li> <li>Candidate has operator flash generator field from bench board         <ul> <li>EVALUATOR CUE: Role-play Control room operator and inform the candidate the control room has attempted to flash the field, HOWEVER, Diesel Generator Voltage is still ZERO.</li> </ul> </li> <li>Candidate locates the K2 field flash contactor inside cab. [PNL-2DIGEN-1A (2A)]</li> <li>Candidate simulates DEPRESSING the White Stabs on the K2 Field Flash Contactor until the voltmeter shows a rapid rise.</li> <li>EVALUATOR CUE: Diesel Generator Voltage is now indicating ~4160 VAC and stable.</li> <li>COMMENTS:</li> </ol>		
	JPMI III 2         )       S         or Volts       5         C       5         C       6         L<		

.

JPM NUMBER: 2PL-606 JPM REVISION: 1	JPM TITLE: Locally Start the No. 1(2) Emergency Diesel Generator		
STEP ("C" Denotes CRITICAL STEP)	$(Indicate "S" FOR SAT or "U" FOR UNSAT) \Rightarrow 5/U$		
7. Attempt to Restore Dies Generator Control to the Control Room.	sel 7.1 Candidate locates Auto-Local key switch. re 7.2 Verifies/Places it to AUTO. <b>EVALUATOR CUE:</b> Auto-Local key switch is in <b>AUTO</b> . IF necessary, Role-play the Control Room and confirm control of Diesel Generator in the control room.		
8. Request Control Room Operator verify open or emergency bus tie brea	8.1       Candidate contacts Control Room.         8.2       Has operator open or verify open 2E7(2F7) and 2A10(2D10)         EVALUATOR CUE: Control Room reports both breakers open.         COMMENTS:		

JPM NUMBER: 2PL-606 JPM REVISION: 1	PM TITLE: Locally Start the No. 1(2) Emergency Diesel Generator	
STEP ( "C" Denotes CRITICAL STEP )	STANDARD (Indicate "S" FOR SAT or "U" FOR UNSAT)⇒ S	/U
9.C Request Control Room of close Diesel Generator C Breaker 2E10(2F10).	erator tput       9.1       Candidate contacts Control Room.         9.2C       Candidate has operator close Diesel Generator Output breaker.         EVALUATOR CUE: ACB 2E10(2F10) is closed.         COMMENTS:	
	STOP TIME:	

Append	lix D	Scena	rio Outline	Form ES-D-1
Facility Examin	r: BVPS 2 hers:	Scen:	ario No.: 1 Candidates:	Op Test No.: NRC SRO ATC BOP
Initial Conditions:BOL, ~5% power following Xe free S/U, CB D = 104, 2003 PPM IC-165Conditions: Turnover:Continue plant startup IAW 2OM-52.4.A. [2SAS-C21B] Station Air Compressor OOS, will not be returned this shiftCritical Tasks:1. E-0.I Crew establishes flow from at least one high head ECCS pump before transition out of E-0.				
	2. E on (oran) CSF o ECA- 3. E-2.A valve E-2.	ge path) challenge of or before transition 2.1, whichever occurs Crew isolates the (s) operated from of	levelops to eithe to urs first. faulted SG and utside of the con	directs operator to close isolation trol room before transition out of
Event No.	Malf. No.	Event Type Event Description		Event Description
1		R(RO)	Crew raises po	wer IAW procedure
		N(ALL)	(Must raise por failure)	wer above 10% before N-36
2	NIS07B	SRO T.S.	IRNI N-36 Inte Instrument Inst	ermediate Range Nuclear Pwr fuse blows
3	XMT-RCS019A	I(RO/SRO) SRO T.S.	[2RCS*LT459 Channel fails le	] Controlling PRZR Level ow, L/D isolates
4		N(RO/SRO)	Alternate chan	nel selected and L/D restored
5	CNH-CFW15B	C(BOP/SRO)	'C' BPFRV fai required	ls open in auto, manual control
6	MSS01C	M(ALL)	Steam leak ins Steam line RU CIB	ide CNMT slowly progresses to PTURE inside CNMT, SI, CIA,
7	PMP-CHS002 PPL07A	C(RO/SRO)	[2CHS*P21B] [2CHS*P21A] requires manua	HHSI Pump trips on SI HHSI pump Fails to AUTO, al start on SI
8	PPL10A PPL10B	C(BOP/SRO)	AUTO MSLI f manual actuati	àilure BOTH Trains, requires on

(N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

## Scenario Summary Scenario 1

The crew will assume the shift at approximately 5% power BOL, with station air compressor 2SAS-C21B OOS. Crew instructions are to continue the plant start-up. The crew will perform a Normal Power Increase to > 10%. When power is greater than 10%. the instrument power fuse will fail on Intermediate Range Channel N-36. The crew will respond to the annunciators and implement the actions of AOP 2.2.1B. Intermediate Range Channel Malfunction. After the US implements the required Technical Specification actions, the controlling channel of PRZR level [2RCS\*LT459] will FAIL LOW causing letdown isolation. The crew will respond to the annunciators and implement the actions of instrument failure procedure OM 2.6.4.IF ATT #1. After stabilizing the plant, letdown will be restored IAW normal operating procedure 20M-7.4.AB, Restoring Charging and Letdown. After the US implements the required Technical Specification actions "C" BPFRV will FAIL OPEN in automatic. The crew will be required to take manual control of "C" BPFRV to restore and maintain SG level. After SG levels are stabilized, a steam leak will develop inside containment. The leak will slowly progress to a full steam line RUPTURE causing RX TRIP, SI, CIA and CIB. The crew will respond by implementing the actions of E-0, Reactor Trip or Safety Injection. The actions of E-0, Reactor Trip or Safety Injection will be complicated by HHSI pump 21B tripping after the SI start signal and HHSI pump 21A failing to automatically start on the receipt of the SI signal. The crew must identify these failures and manually start the 21A HHSI pump. The crew must then diagnosis the faulted SG and transition into E-2, Faulted SG Isolation. The actions of E-2, Faulted SG Isolation will be complicated by a failure of SLI. The crew must identify this failure and manually initiate SLI. After completing the actions of E-2, Faulted SG Isolation the crew must determine that the SI termination criteria have been met and transition into ES-1.1, SI Termination. After the crew has terminated HHSI flow the scenario will be terminated.

#### **EOP Flow Path:**

E-0, Reactor Trip or Safety Injection  $\rightarrow$  E-2, Faulted Steam Generator Isolation  $\rightarrow$  ES-1.1, SI Termination.

#### BEAVER VALLE . . . OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

Revision 7

**INITIAL CONDITIONS:** Approx 5% Power, CBD = 104, XE increasing from XE free S/U, BOL, 2003 PPM Boron, IC-165

ADDITIONAL LINEUP CHANGES	STICKERS	VOND MARKINGS
[2SAS-C21B] – PTL	DANGER	
EQUIPMENT STATUS	DATE/TIME OOS	<b>TECHNICAL SPECIFICATION(S)</b>
[2SAS-C21B]	1 week ago	N/A

## **SHIFT TURNOVER INFORMATION**

- 1. Protected Train is Train "B"
- 2. [2SAS-C21B] undergoing a compressor overhaul, will not be returned until 3 days from now
- 3. [2FWS-P21A] operating, SG levels maintained via BPFRVs operating in AUTO
- 4. Continue plant S/U IAW 2OM-52.4.A step 6
- 5. Reactor Engineering has provided the reactivity plan for the continuation of the startup

## SCENARIO SUPPORT MATERIAL REQUIRED

Reactivity plan placard for BOL 20M-52.4.A signed-off through step 5. Placard for [2FWE\*P22] position stating [2FWE\*P22] is aligned to "A" header Place plaque on wall for Protected Train "B"

#### BEAVER VALLE . JOWER STATION 1/2 - ADM - 1357

		-	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
Initialize IC Set 165, and establish initial plant conditions.	Reactor plant at approx 5% power, BOL, equilibrium conditions. RCS boron 2003 PPM, CBD = 104 steps.		
Insert the following per the Simulator Setup section of the HTML File for this drill:	Inserts all pre-loads required to support the drill		
IMF PMP-CAS004 (0 0) 1	[2SAS-C21B] OOS		
IMF PPL10A (0 0)	Prevent auto MSLI Trn "A"		
IMF PPL10B (0 0)	Prevent auto MSLI Trn "B"		
TRGSET 1 'JPPLSI(1) == 1'	Set trigger 1 on SI actuation		
IMF PMP-CHS002 (1 0) 1	[2CHS*P21B] trips on SI initiation		
IMF PPL07A (0 0) 0	[2CHS*P21A] fails to auto start on SI initiation, manual start required		
TRG 1 'IMF MSS01C 1E7'	'C' Steam line rupture inside CNMT on SI actuation		
TRGSET 2 'MCRFNS(3) <= 225'	Set trigger 2 on reactor trip		
TRG 2 'IMF MSS01C 1E7'	'C' Steam line rupture inside CNMT on reactor trip		
TRGSET 3 'TPCSTAAU <= 547'	Set trigger 3 on Tavg < 547F		
TRG 3 'IMF MSS01C 1E7'	'C' Steam line rupture inside CNMT when Tavg decreases below 547F		
BAT STUFFON.DAT	Horns, Printers, Sounds ready		

## BEAVER VALLE . . •OWER STATION 1/2 - ADM - 1357

Conduct of Simulator Training

# **Revision 7** EXPECTED STUDENT RESPONSE PLANT STATUS OR RESPONSE OBJECTIVE INSTRUCTIONAL GUIDELINES Assign shift positions SM: US:\_\_\_\_\_ RO:\_\_\_\_\_ BOP:\_\_\_\_\_ STA:\_\_\_\_\_ Simulator Frozen until after shift turnover Conduct a shift turnover with oncoming unless it needs to be run momentarily for operators. an alignment change. Crew assumes control of the Unit. Simulator running. When the shift turnover is completed, place the simulator to RUN and commence the drill.

#### BEAVER VALLE . POWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

NOT DUOTIONAL OLUDELINEO		
INSTRUCTIONAL GUIDELINES		

#### **EVENT #1:**

Normal Power Increase to > 10%

US directs crew to conduct power increase IAW **2OM-52.4.A** and the reactivity plan provided by Reactor Engineering

Revision 7

BOP Raises turbine reference and setter to raise turbine power.

RO dilutes/withdraws rods to raise reactor power.

Continue with next event <u>AFTER</u> IRNI High Flux Trip has been blocked above 10% AND LE discretion

## <u>EVENT #2:</u>

IRNI N-36 Instrument power fuse blows

#### IMF NIS07B (0 0) 0

#### **IMMEDIATE PLANT RESPONSE:**

A4-4E NIS DETECTOR COMPENSATOR TROUBLE (V0139D, V0132D) [2NMI-NI36B] Intermediate range current indicates low (BB B) N-36 meter at NIS racks indicates low N-36 Inst Pwr fuse indicates blown RO verifies alarms, diagnose failure of N-36 IRNI

Crew identifies blown fuse

BVPS – 2 Scenario 1

Rev. 1 (45 day submittal)

#### BEAVER VALLE. . OWER STATION

1/2 – ADM – 1357

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Light on N-36 rack drawer: CONTROL POWER ON LIT HIGH LEVEL TRIP – LIT HIGH LEVEL ROD STOP – LIT POWER ABOVE P-6 PERMISSIVE – LIT		
	LOSS OF DETECTOR VOLTS – LIT LOSS OF COMP VOLTS – LIT BB B Status panel 308 – LIGHT C-10 – LIT NO PLANT TRANSIENT		Crew refers to <b>ARP and AOP 2.2.1B</b>
	Operable recorders selected on VB B		RO verifies operable recorders selected to VB B recorders
	MODE 1 operation		US refers to TS 3.3.3 for post acc monitoring (when time permits)
	Plant is above P10		US directs actions IAW <b>step 6</b> based on current plant operating conditions
	Both IRNIS block switches to BLOCK position		RO blocks both IRNIS Rod Stop and Reactor Trip functions (previously performed)

#### BEAVER VALLE . . . OWER STATION

## 1/2 – ADM – 1357

Conduct of Simulator Training

			Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Caution tags in place to prompt MANUAL Unblock of SRNI on plant S/D		RO places caution tags on both SRNI Block/Reset switches
			US directs continued plant operations and continue power increase
	Ann A4-5F NIS INT RANGE HIGH FLUX ROD WITHDRAWL STOP actuates		Crew bypasses reactor trip function by placing LEVEL TRIP switch of inoperable channel in BYPASS position
	Ann A4-5E NIS SOURCE/INT RANGE HIGH FLUX TRIP BYPASS – LIT (N0096D) – TRIPPED		
	Status light "LEVEL TRIP BYPASS" – LIT		
	Caution tag in place		BOP places Caution Tag on Level Trip switch for N-35
	Power increase continues		Crew continues power increase IAW <b>2OM</b> - <b>52.4.A</b> and reactivity plan
<u>EVENT #3:</u>			
Power increase continues			

Continue with next event at LE discretion

#### BEAVER VALLE . .-OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE		
EVENT #4:		OBJECTIVE	EXPECTED STUDENT RESPONSE
PZR level Xmitter [2RCS*LT459] fails low			
IMF XMT RCS019A (0 0) 0	PZR level transmitter [2RCS*LT459] fails low. <u>IMMEDIATE PLANT RESPONSE:</u> A4-1C PZR CONTROL LEVEL DEVIATION LOW (L0493D)		RO recognizes problem with PZR level channel, informs US that [2RCS*LT459] failed low.
	A4-1B PZR CONTROL LEVEL LOW (L0491D) [2CHS*LCV460A], [2CHS*AOV200A,B,C] close PZR heaters off.		RO places [2CHS*FCV122] in manual to reduce charging flow and control PZR level
			Crew refers to ARP and <b>OM 2.6.4.IF ATT</b> #1, US directs operator to defeat level control input with PZR level channel and recorder selector switches.
	Level alarms clear, charging flow reduces, high flow alarm clears.		RO places Channels 460 and 461 in service.
	Adequate M/U to VCT exists		RO verifies M/U to VCT
BVPS – 2 Scenario 1	9 of 26	R	ev. 1 (45 day submittal)

÷

## BEAVER VALLE . . OWER STATION

## 1/2 – ADM – 1357

Conduct of Simulator Training

		Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE EXPECTED STUDENT RESPONSE
	PZR heaters energized as desired	RO places PZR heaters in operation as necessary to restore normal PZR pressure control
		US directs operators to restore Letdown flow IAW <b>20M-7.4.AB</b>
	[2CHS*FCV122] - CLOSED	RO places [2CHS*FCV122] in manual and closes the valve
	[2CHS*MOV289] - OPEN	RO verifies [2CHS*MOV289] open
	[2CHS*MOV310] - OPEN	RO verifies [2CHS*MOV310] open
	[2CHS*FCV122] throttled to obtain 30 – 50 gpm on [2CHS*FI122] (VB A)	RO throttles charging pump discharge flow control valve open to provide $30 - 50$ gpm flow as indicated on [2CHS*FI122] (VB A)
	[2CHS*AOV200A, B, C] - CLOSED	RO verifies 3 L/D isolation valves are closed
	[2CHS*AOV204] - OPEN	RO verifies the NRHX L/D inlet valve is open (BB A)
	[2CHS*PCV145] – IN MANUAL AND ADJUSTED TO 50% OPEN DEMAND SIGNAL (BB A)	RO place NRHX Disch Pres control valve in MANUAL and adjusts for 50% output demand

÷

#### BEAVER VALLE, COWER STATION

1/2 – ADM – 1357

			Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	[2CHS*MOV100A] – OPEN [2CHS*MOV100B] – CLOSED		RO verifies positions of [2CHS*MOV100A], [2CHS*MOV100B]
	[2CHS*LCV460A, B] - OPEN		RO verifies Regen HX L/D Inlet valves open
	[2CHS*AOV200A, B] - OPEN		RO opens L/D isol valves to establish L/D flow at previous value
	[2CHS*PCV145] adjusted to maintain 260 psig as indicated on [2CHS*PI145] SETPOINT of [2CHS*PCV145] – SET FOR 260PSIG [2CHS*PCV145] – PLACED IN AUTO [2CHS*FCV122] – PLACED IN AUTO		RO establishes automatic control of letdown flow
	PZR level trending to normal		RO monitors PZR level for proper response
			US refers to <b>TS. 3.3.1 Table 3.3.1-1</b> <b>Function 9, Condition K:</b> Place channel in trip W/I 6 hrs <u>OR</u> Reduce THERMAL POWER to <p7 12="" hrs<br="" i="" w=""><b>TS 3.3.4 and Bases Table B3.3.4 Function</b> <b>4.a:</b> Remote S/D Indication and Controls requires 1 channel of PZR level operable</p7>

#### BEAVER VALLE , COWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
			<b>TS 3.3.3 Table 3.3.3-1 Function 11</b> <b>Condition E:</b> As required by Action D.1 and referenced in Table 3.3.1-1
			Condition E.1: Be in MODE 3 - 6 hrs
			AND
			<b>Condition E.2:</b> Be in MODE 4 – 12 hrs
			RO informs the US that letdown has been reestablished.
<b>IF DESIRED</b> use the following to trip bistable per <b>2MSP-6.23-1</b> :			US directs operators to trip appropriate bistable.
IRF LOA-PCS001 (0 0) 1 IMF BST-PCS097 (0 0) 0 IRF LOA-PCS001 (0 0) 0	Protection rack C1 door open. 2LS/459A-1 (442, BS-1) hi level trip. Protection rack C1 door closed.		US notifies I&C of problem.
Inform crew that bistable is tripped.			US is informed that bistable is tripped.
Continue next event when letdown is reestablished <b>OR</b> at LE discretion			

#### BEAVER VALLE . , OWER STATION 1/2 – ADM – 1357

Conduct of Simulator Training

## INSTRUCTIONAL GUIDELINES PLANT STATUS OR RESPONSE OBJECTIVE EXPECTED STUDENT RESPONSE

#### **EVENT #5:**

'C' BPFRV Controller fails to 100%

IMF CNH-CFW15B (0 0) 100	'C' BPFRV Controller fails to 100%
	IMMEDIATE PLANT RESPONSE:
	[2FWS*FCV499] travels to the fully open position
	A6-11F LOOP C FEEDWATER FLOW > STEAM FLOW (F0477D)
	'C'SG NR LEVEL (3 indicators VB C) increases rapidly
	RCS Tavg begins to reduce (3 indicators, 1 recorder VB B)
	A6-11E SG 21C LEVEL DEVIATION FROM SETPOINT (L0479D)
	[2FWS*FCV499] in manual & throttled closed
	"C" SG level returning to normal

BOP identifies problem with "C" SG level control, reports to the crew

**Revision 7** 

US directs BOP to take manual control of "C" BPFRV and restore level

Crew refers to ARPs

Continue with next event at LE discretion

#### BEAVER VALLE . . OWER STATION 1/2 - ADM - 1357

Conduct of Simulator Training

## INSTRUCTIONAL GUIDELINES PLANT STATUS OR RESPONSE OBJECTIVE EXPECTED STUDENT RESPONSE

#### **EVENT #6:**

Steam leak develops in CNMT on "C" SG over a ten minute period

IMF MSS01C (0 0) 1E6 600

## Steam leak develops on "C" SG IMMEDIATE PLANT RESPONSE:

SYSTEM TROUBLE

CNMT Temp, Pres and Humidity slowly increase (indicators VB A) A1-1E CONTAINMENT AIR PRESSURE HIGH/LOW (Y5023D, UCP031) A2-2B UNIDENTIFIED LEAKAGE

A1-1F CONTAINMENT AIR AVERAGE TEMP HIGH/LOW (Y5022D) A1-2G INCORE INST ROOM/CNMT SUMP LEVEL HIGH/VALVE NOT RESET (L0002D)

CNMT condition continue to degrade

Crew notes alarms, diagnose steam leak inside CNMT

Revision 7

i:

US directs manual reactor trip manual SI due to degrading plant/CNMT conditions

Crew performs IMAs of E-0.

Crew enters E-0, performs immediate operator actions.

## BEAVER VALLE . . OWER STATION 1/2 - ADM - 1357

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Annunciator A5-6D TURBINE TRIP DUE TO REACTOR TRIP - LIT Power range indication - LESS THAN 5% Neutron flux - DROPPING		RO verifies reactor tripped.
	Throttle Valves - ALL CLOSED OR Governor Valves - ALL CLOSED Main Generator Output Bkrs - OPEN Exciter Circuit Bkr - OPEN		BOP verifies turbine tripped.
	AC Emergency Busses - BOTH ENERGIZED		BOP verifies power to AC Emergency Buses.
	Check SI ACTUATED CNMT Pressure - > 5PSIG PZR Pressure - < 1860 PSIG SG Steam Pressure - < 500 PSIG		RO checks SI status
Crew continues E-0	Manually actuate SI (both trains)		RO manually actuates SI both trains
	Alert Plant Personnel		RO/BOP sound Standby Alarm, announce reactor trip and safety injection

# BEAVER VALLE . . OWER STATION

1/2 – ADM – 1357

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Check [2HVS*FN204A(B)], Leak Collection Filtered Exhaust Fan – AT LEAST ONE RUNNING		BOP checks Leak Collection Exhaust Fan status
CRITICAL TASK	Charging Pumps – <b>NONE</b> RUNNING		RO verifies SI System status
Crew establishes flow from at least one	[2CHS*P21B] TRIPPED ON SI		RO reports trip of [2CHS*P21B]
high head ECCS pump before transition out of E-0.	[2CHS*P21A] – REQUIRED MANUAL START		RO reports manual start of [2CHS*P21A] required
	Charging Pumps – ONE RUNNING		
	HHSI Flow – INDICATED		
	LHSI Pumps – TWO RUNNING		
	Motor-driven AFW Pumps - RUNNING		BOP verifies AFW System status
	Turb driven AFW Pump Stm Supply Isol Valves – OPEN		
	AFW Throttle Vlvs - FULL OPEN		
	Total AFW Flow – GREATER THAN 340 GPM		
	Perform Attachment A-0.11 "Verification Of Automatic Actions" in a timely manner		US directs performance of Attachment A- 0.11 when time/manpower permit
Attachment A-0.11 included with scenario beginning on Pg 21	LIST ATT A-0.11 DICREPANCIES AS APPLICABLE		
	RCPs OPERATING – MONITOR Tavg RCPs STOPPED – MONITOR Tcold		RO/BOP check RCS Tavg stable at or trending to 547°F

## BEAVER VALLE, . OWER STATION

## 1/2 – ADM – 1357

Conduct of Simulator Training

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Check CIB - ACTUATED Recirc Spray HXs - SERVICE WATER		RO checks Recirc Spray Pump status
	FLOW TO ALL 4 HXs Check Recirc Spray Pumps – ANY RUNNING		
	Check Recirc Spray Pumps – ALL RUNNING		
	Check Recirc Spray Pumps – NOT CAVITATING		
	All RCPs – STOPPED		RO Stops all RCPs due to CIB
	PORVs – CLOSED		RO verifies PZR isolated
	Spray Valves – CLOSED		
	Safety relief valves – (PSMS Detailed Data Page 1) – CLOSED		
	Check PRT conditions – CONSISTENT WITH EXPECTED VALUES		
	Power to at least one block valve – AVAILABLE		
	Block valves – AT LEAST ONE OPEN		
	RCPs PREVIOUSLY STOPPED		RO checks if RCPs should be stopped

**Revision 7** 

#### BEAVER VALLE . . OWER STATION

## 1/2 – ADM – 1357

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Pressures in all SGs – ANY DROPPING IN AN UNCONTROLLED MANNER OR ANY SG COMPLETELY DEPRESSURIZED		BOP checks if any SGs are faulted.
			CREW DETERMINES 1 OR MORE SGs ARE FAULTED, TRANSITIONS TO E-2 STEP 1
Crew transitions to E-2 step 1			US directs STA to monitor status trees.
As U-1 operator, when requested, report proper CREVS actuation.	Check CREVS actuated: Control room air intake and exhaust dampers – CLOSED		BOP verifies CREVS actuated, requests Unit 1 CREVS verification.
	[2HVC*FN241A(B)] – AT LEAST ONE RUNNING		
	Request U1 operator to verify CREVS actuation		
	Commence Control Room ventilation actions IAW ATT A-2.4		

#### BEAVER VALLE, ... OWER STATION

## 1/2 – ADM – 1357

		Ũ	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
<b><u>CRITICAL TASK</u></b> Crew manually actuates main steam	AUTO MSLI FAILURE – BOTH TRAINS		Crew verifies steam line isolation.
line isolation before a Severe (orange path) challenge develops to either the Sub-criticality or Integrity CSF or	MSLI MANUALLY ACTUATED		Crew identifies failure of AUTO MSLI, MANUALLY actuates MSLI Both Trains
ECA-2.1, whichever occurs first.	Check All yellow SLI marks – LIT		
	Check all SG pressures – ANY STABLE OR RISING		BOP checks for any non-faulted SG.
	Check all SGs pressure – ANY SG PRESSURE DROPPING IN AN UNCONTROLLED MANOR		BOP identifies "C" SG as faulted.
	OR		
	ANY SG COMPLETELY DEPRESSURIZED		
	"C" SG pressure dropping uncontrollably.		
<b><u>CRITICAL TASK</u></b> Crew isolates the faulted SG and directs operator to close isolation valve(s) operated from outside of the control room before transition out of E-2.	Check FWI – PREVIOUSLY VERIFIED		Crew verifies faulted SG (C) isolated
	[2FWS*HYV-157C] closed		BOP verifies "C" SG CNMT isolation vlv closed.

## BEAVER VALLE . . OWER STATION

# 1/2 – ADM – 1357

		Ū.	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	[2FWS*FCV498] closed.	•	BOP verifies "C" MFRV closed.
	[2FWS*FW499] closed.		BOP verifies "C" BPFRV closed.
	[2FWE*HCV100A, B] closed.		BOP closes [2FWE*HCV100A, B].
	Check Residual Heat Release valve – CLOSED		BOP closes [2SVS*HCV104].
IRF LOA-MSS011 (0 0) 0	Check Residual Heat Release Valve from faulted SG – PREVIOUSLY ISOLATED: SG 21C [2SVS*29]		Crew dispatch operator to close [2SVS*29]
	Close Turbine driven AFW pump steam supply isolation valves from faulted SG: [2MSS*SOV105C,F]		BOP closes [2MSS*SOV105C,F]
IF REQUESTED:	Close atmospheric steam dump on faulted SG [2SVS*PCV101C]		BOP closes "C" SG atmospheric steam dump [2SVS*PCV101C]
IRF LOA-MSS018 (0 0) 0 To close [2SVS*25]			
	Verify SG blowdown isolation valve from faulted SG CLOSED: [2BDG*AOV100C1] OR [2BDG*AOV101C1]		BOP verifies SG blowdown isolated from "C" SG.

#### BEAVER VALLE, .- OWER STATION

## 1/2 – ADM – 1357

Conduct of Simulator Training

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Close [2SSR*AOV117C] SG blowdown sample outside CNMT isolation valves		BOP isolates SG blowdown sample from "C" SG
	Check [2FWE-TK210] PPDWST level - > 85 inches		Crew checks PPDWST level > 85 inches Or Refer to <b>Attachment A-1.8</b> for makeup.
	Check all SG levels – NONE RISING IN AN UNCONTROLLED MANNER		Crew checks if SG tubes are intact.
	Check Secondary Radiation – CONSISTENT WITH PRE-EVENT VALUES [2ARC-RQ100] Air Ejector Discharge (1007) [2SSR-RQ100] SGBD sample		

**Revision** 7

#### BEAVER VALLE . . OWER STATION 1/2 - ADM - 1357

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	RCS Subcooling based on core exit TCs > 41F [59F ADVERSE CNMT]		RO/BOP check if SI flow should be reduced
	Secondary heat sink:		
	Total feed flow to intact SGs – GREATER THAN 340 GPM		
	OR		
	Narrow range level in at least one intact SG – GREATER THAN 12% [31% ADVERSE CNMT]		
	RCS pressure – STABLE OR RISING PRZR level – GREATER THAN 17% [38% ADVERSE CNMT]		Crew determines SI Termination criteria met, transitions to <b>ES-1.1</b>
Crew transitions to ES-1.1 Step 1			US directs STA to monitor status trees.
	SI, CIA & CIB - RESET		RO resets SI, CIA & CIB
	All but one charging pump - STOPPED		RO stops all but one Charging Pump
	RCS Pressure – STABLE OR RISING		RO checks/reports RCS Pressure status

## BEAVER VALLE ... OWER STATION

#### 1/2 – ADM – 1357 Conduct of Simulator Training

# Revision 7 INSTRUCTIONAL GUIDELINES PLANT STATUS OR RESPONSE OBJECTIVE EXPECTED STUDENT RESPONSE HHSI Cold Leg Isol VLVs – CLOSED: RO isolates HHSI injection path [2SIS\*MOV867A] [2SIS\*MOV867B] [2SIS\*MOV867C] [2SIS\*MOV867D]

Drill may be terminated after HHSI flow is isolated

**CLASSIFY EVENT** 

**UE TAB 2.10** 

ŝ

#### BEAVER VALLE . . OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
Attachment A-0.11 'Verification of Automatic Actions' performed as time & manpower permit			US directs operator to perform Attachment A-0.11 as time & manpower permit
	Diesel generators - BOTH RUNNING		Check both EDGs running
	CNMT pressure – GREATER THAN 7 PSIG		Check if MSLI is required
	OR SG Steam Pressure – LESS THAN 500 PSIG OR		If <b>not required</b> , go to step 4
	Steamline pressure high rate of change – 100 PSIG DROP IN 50 SECONDS		
MANUAL MSLI REQUIRED	Yellow SLI marks - LIT		Verify steamline isolation
STEP 4	Open [2CCS-AOV118] Domestic Water to Station Air Compressor		Establish Domestic Water System Cooling to Station Air Compressors
	At least one Station Air Compressor – RUNNING		Start 1 Station Air Compressor as required
	CCP pumps AT LEAST 1 RUNNING		Check CCP Pump status
BVPS 2 Scenario 1	24 of 26	R	ev. 1 (45 day submittal)

#### BEAVER VALLE , . OWER STATION 1/2 - ADM - 1357

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	[2NME-NR45] Nuclear Recorder selected to operable source and intermediate range displays		Align neutron flux monitoring for shutdown
	CNMT pressure – HAS REMAIND LESS THAN 11 PSIG		Check CIB status
	IF NOT		Actuate CIB if required
	Manually initiate CIB BOTH SWITCHES FOR BOTH TRAINS		
	Manually align equipment as required All RCPs – STOPPED BV-1 operator verifies CREVS actuation Service water established to RSS HX(s)		Stop ALL RCPs
	Service Water Pumps – 2 RUNNING Service Water Header Pressure – GREATER THAN 55 PSIG SWS Seal Water Pressure – NOT LOW		Verify Service Water System in service
	[2HCS*SOV100A1, B1] – CNMT Sample amber light – LIT		Verify both CNMT hydrogen analyzers running
#### BEAVER VALLEY . OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		<b>J</b>	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	All Red SIS Marks – LIT All Orange CIA Marks – LIT All Green FWI Marks – LIT		Verify ESF Equipment status – Start/align equipment as required
	Power available to both Emergency AC Busses		Verify power to both AC Emergency busses
			Restore power as required
	Attachment A-0.11 – COMPLETE		Report any discrepancies to SM/US

Append	ix D	Sc	cenario Outline	Form ES-D-1
Facility Examin	: BVPS 2 ers:	S	Scenario No.: 2 Op Test No.: Candidates:	NRC SRO ATC BOP
<u>Initial</u> <u>Conditi</u> <u>Turnov</u>	MOL, 7 ons: er: Maintai	75 % power Equ	1 Xe, CB = 188, 1116 PPM IC-166 conditions	
<u>Critical</u>	<u>Tasks:</u> 1. E-1.C	Crew trips and SI flow	all RCPs when RCS to highest SG D/P cr v verified prior to exiting procedure E-1.	iteria is exceeded
<ol> <li>FR-S.1.C Crew inserts negative reactivity into the core by inserting RCCAs before completing the immediate action steps of FR-S.1.</li> <li>3.</li> </ol>				
Event No.	Malf. No.	Event Type	Event Description	
1	XMT-MSS022A	I(BOP/SRO) SRO T.S.	[2MSS*FT485] "B" SG Selected Steam Flow Channel drifts HIGH	
2	XMT-LDS003A	I(RO/SRO)	VCT Level control channel failure LOW	
3	XMT-RCS032A	SRO T.S.	[2RCS*PT455] PRZR Pressure Proto fails HIGH	ection Channel
4		R(RO)	Power reduction due to TS 3.0.3 requ	uirement
		N(BOP/SRO)	(No TS Action addressing two chanr being inoperable)	els of OT∆T
5	RCP01A	C(RO/SRO)	RCP #1 seal leakoff excessive (requi	res Rx trip)
6	PPL01A PPL01B	M(ALL)	ATWS – Failure of auto/manual Rx	trip
7	LOA-AFW022 PPL07B	C(BOP/SRO)	[2FWE*P22], Turbine driven AFW during S/U, [2FWE-P23B] Motor Dr Pump requires manual start	pump trips riven AFW
8	VLV-RCS032A	M(ALL)	PORV [2RCS*PCV455C] sticks ope open and its block valve [2RCS*MC be closed from CR (PRZR Vapor spa	en after auto V535] cannot ace leak)

(N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

#### Scenario Summary Scenario 2

The crew will assume the shift at approximately 75% power BOL equilibrium Xenon. Power Range Channel N-42 is OOS and remove from service IAW AOP 2.2.1C, Power Range Channel Malfunction. Motor driven AFW pump 2FWE\*P23A is also OOS. Crew instructions are to maintain the plant at 75% power. After the crew assumes the shift, the controlling channel of steam flow on the "B" steam generator [2MSS\*FT485] will drift HIGH. The crew will respond to the alarms and implement the actions of instrument failure procedure OM 2.24.4.IF ATT #3 and take manual control of SGWLC on the "B" SG. The crew will swap controlling channels and return SGWLC to automatic. After the US implements the required Technical Specification actions, VCT level transmitter 2CHS\*LT115 will FAIL LOW causing automatic make-up to VCT to begin. The crew will STOP the automatic make-up to VCT and respond to the alarms and implement the actions of instrument failure procedure OM 2.7.4.IF ATT #1. From this point on in the scenario, all VCT make-ups will need to be initiated manually. After stabilizing the plant, PRZR Pressure Protection channel 2RCS\*PT455 will FAIL HIGH. The crew will respond to the annunciators and implement the actions of instrument failure procedure OM 2.6.4.IF ATT #2. While performing the actions of the procedure and Technical Specifications, the crew MUST recognize that there are NOW 2 channels of  $OT\Delta T$  OOS and Technical Specification 3.0.3 is applicable. Plant management instructs the crew to begin an immediate power reduction to comply with Technical Specification 3.0.3 actions. The crew begins a power reduction IAW 20M-52.4.B, Load Follow. During the power reduction, #1 seal on the "B" RCP will degrade. The crew will respond to the alarms and implement the actions of AOP 2.6.8, RCP Malfunction. The seal degradation will worsen to the point where the AOP 2.6.8, RCP Malfunction will require the crew to initiate a manual reactor trip. The crew will enter E-0, Reactor Trip or Safety Injection only to find that manual and automatic reactor trips will not function. The crew will transition to FR-S.1, Response to Nuclear Power generation - ATWS. The actions of FR-S.1, Response to Nuclear Power generation – ATWS will be complicated by the steam driven AFW pump tripping during start-up and motor driven AFW pump 2FWE\*P23B failing to automatically start. This will require the crew to manually start motor driven AFW pump 2FWE\*P23B. The actions cf FR-S.1, Response to Nuclear Power generation - ATWS will be further complicated by PRZR PORV failing to close, after automatically opening, and its associated block valve cannot be fully closed. (PRZR VAPOR SPACE LEAK). The reactor will be tripped locally by the operator dispatched during FR-S.1, Response to Nuclear Power generation -- ATWS performance. The crew will transition back to E-0, Reactor Trip or Safety Injection and perform the actions to verify ECCS equipment operating and diagnose the vapor space leak. The crew will then transition into E-1, Loss of Reactor or Secondary Coolant and perform the actions to stabilize the plant. The scenario is terminated when the crew transitions into ES-1.2, Post LOCA Cooldown and Depressurization.

#### **EOP** Flow Path:

E-0, Reactor Trip or Safety Injection  $\rightarrow$  FR-S.1, Response to Nuclear Power generation – ATWS  $\rightarrow$  E-0, Reactor Trip or Safety Injection  $\rightarrow$  E-1, Loss of Reactor or Secondary Coolant  $\rightarrow$  ES-1.2, Post LOCA Cooldown and Depressurization

#### BEAVER VALLE , OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

Revision 7

#### **<u>INITIAL CONDITIONS:</u>** 75 % Power, CBD = 188, EQU XE MOL, 1116 PPM Boron, IC-166

ADDITIONAL LINEUP CHANGES	STICKERS	VOND MARKINGS
N-42 Control Pwr fuses – REMOVED N-42 Rod Stop BP sw to BP Channel Comparator Defeat sw to N-42 NR-45 NOT selected to N-42 [2FWE*P23A] - PTL	N-42 meters (2) Chan 2 OTDT Meter Ann OTDT Trip/Rod stop DANGER – [2FWE*P23A] switch	
EQUIPMENT STATUS	DATE/TIME OOS	TECHNICAL SPECIFICATION(S)
N-42	2 Hrs. ago	
[2FWE*P23A]	3 Hrs. ago	

#### **SHIFT TURNOVER INFORMATION**

- 1. Protected Train is Train "B"
- 2. N-42 removed from service per AOP 2.2.1C,
- 3. [2FWE\*P23A] Motor ground, repair estimate is 8 10 Hrs.
- 4. Maintain current plant conditions.

#### SCENARIO SUPPORT MATERIAL REQUIRED

Reactivity plan placard for MOL Placard for [2FWE\*P22] position stating [2FWE\*P22] is aligned to "A" header Place plaque on wall for Protected Train "B"

#### BEAVER VALLE . OWER STATION 1/2 - ADM - 1357

#### Conduct of Simulator Training

		Ū.	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
Initialize IC Set 166, and establish initial plant conditions.	Reactor plant at 75% power, MOL, equilibrium conditions. RCS boron 1116 PPM, CBD = 188 steps.		
Insert the following per the Simulator Setup section of the HTML File for this drill:	Inserts all pre-loads required to support the drill		
IRF LOA-HIV055 (0 0) 1 IMF PPL02A (30 120)	[2FW*P23A] breaker racked out Train A trip BKR open		
IMF PPL02B (30 130)	Train B trip BKR open		
IRF LOA-CRF007 (30 140) 1 IRF LOA CRF008 (30 150) 1	Trip R rod drive MG set		
IMF PPL01A (0 0) 1	Set ATWS condition TRN "A"		
IMF PPL01B (0 0) 1	Set ATWS condition TRN "B"		
IMF VLV-RCS011 (0 0) 1	[2RCS*MOV535] cannot be closed from		
	control room		
TRGSET 1 'RRCH455C >= 0.1'	Set trigger 1 on [2RCS*PCV455C]		
IMF VLV-RCS032A (1.0) 50	[2RCS*PCV455C] sticks open after auto		
	open		
TRGSET 2 'OAFWT22 >= 1000'	Set trigger 2 on [2FWE*P22] speed		
IRF LOA-AFW022 (2 0) 1	[2FWE*P22] trips during startup		
IMF PPL07B (0 0) 5	[2FWE*P23B] fails to auto start, manual		
	successful		
IMF NIS03B (0 0) 0	PRNI N-42 OOS		
IMF BST-PCS158 (0 0) 0	CH II OTDT Reactor trip B/S		
IMF BST-PCS159 (0 0) 0	CH II OTDT Rod Stop/Turbine Runback		
	B/S		

#### BEAVER VALLE . . · OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		J.	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
Assign shift positions			
SM:			
US:			
RO:			
BOP:			
STA:			
Conduct a shift turnover with oncoming operators.	Simulator Frozen until after shift turnover unless it needs to be run momentarily for an alignment change.		
When the shift turnover is completed, place the simulator to RUN and commence the drill.	Simulator running.		Crew assumes control of the Unit.

#### BEAVER VALLE . . . OWER STATION 1/2 - ADM - 1357 Conduct of Simulator Training

		Revision 7	
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
<u>EVENT #1:</u> [2MSS-FT485] drifts high			
IMF XMT-MSS022A (0 0) 5 30	IMMEDIATE PLANT RESPONSE: [2MSS-FI485] begins to drift high [2FWS*FCV488] begins to open "B" SG level begins to increase A6-10F LOOP B FEEDWATERFLOW > STEAM FLOW (F0476D) A6-10E (possible) SG21B LEVEL DEVIATION FROM SETPOINT (L0477D)		BOP notes/verifies alarms, informs US/Crew of apparent instrument failure of [2MSS*FT485]
			US/Crew refer to ARPs & Procedure <b>20M-</b> <b>24.4.IF ATT 3</b>
	[2FWS-FCV488] – MANUAL		BOP places MFRV for "B" SG to manual and restores level
	[2FWS-FR488] – Position FT 487		BOP selects position FT 487 on [2FWS- FR488]

#### BEAVER VALLE , . OWER STATION 1/2 - ADM - 1357 Conduct of Simulator Training

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
When Directed:			
IMF A4-7F-Y0218D (0 0) 0	Process rack door open		US directs personnel to place [2FWS- FR488] to Position FT 484 inside primary
IOR XC11077F (0 0) 0	[2FWS-FR488] – Position FT 484		process rack RK-2PRI-PROC7
to simulate placing [2FWS-FR488] in Position FT 484	A1-4E MAIN STEAM FLOW CHANNEL SELECTED TROUBLE A6-10F CLEARS		
DMF A4-7F-Y0218D	Process rack door closed		

US declares [2FWS\*LT486] SG21B NR Level Transmitter Channel III inoperable

**Revision 7** 

# BEAVER VALLE , . OWER STATION 1/2 – ADM – 1357

Conduct of Simulator Training

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
			US refers to <b>TS 3.3.1, Table 3.3.1-1</b> Function 14 Condition E: <b>E.1</b> : Place channel in TRIP W/I 6 hrs <u>OR</u> <b>E.2</b> : Be in MODE 3 W/I 12 hrs
			US refers to <b>TS 3.3.2, Table 3.3.2-1</b> Functions 5.b and 6.b: 5.b & 6.b Condition D <b>D.1</b> : Place channel in TRIP W/I 6 hrs <u>OR</u> <b>D.2</b> : Be in MODE 3 W/I 12 hrs <u>AND</u> <b>D.2.2</b> : Be in MODE 4 W/I 18 hrs
When directed to trip bistables:			US refers to ATT 1 to trip bistables for the failed channel, contacts I&C
IRF LOA-PCS003 (0 0) 1 IMF BST-PCS041 (0 0) 0 IMF BST-PCS032 (0 0) 0	Protection rack C3 door open 2LS/486A (BS-1) low-low trip 2LS/486C (BS-2) high-high FWI		Crew monitors tripping of B/S
IRF LOA-PCS003 (0 0) 0THEN report actions to CR	Protection rack C3 door closed		US directs BOP to place [2FWS-FCV488] to auto when SG level returned to normal and stable
		_	

#### BEAVER VALLEY ~OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

INSTRUCTIONAL CHIDELINES	PLANT STATUS OF PESDONSE	EXPECTED STUDENT RESPONSE

Proceed with next event at LE discretion

#### **EVENT #2:**

[2CHS\*LT115] fails LOW

IMF XMT-LDS003A (0 0) 0

# IMMEDIATE PLANT RESPONSE:

A2-2G VOLUME CONTROL TANK TROUBLE (L0145D) [2CHS\*LT115] VCT Level indicates 0, VB A Auto M/U initiates (blender station BB A)

RO diagnoses **LOW** failure of [2CHS\*LT115], reports to US/Crew

#1

Revision 7

Actual VCT level is well W/I normal level range and rising as indicated by [2CHS\*LT112] (L2704A) on plant PCS

Auto M/U in progress

RO reports auto M/U in progress

US directs RO to place M/U control switch to OFF after rising VCT level is confirmed.

Crew refers to ARPs or 20M-7.4.IF ATT

RO confirms failure by comparing VB A

[2CHS\*LI115] to PCS point (L2704A)

Auto M/U stopped, VCT level rise stopped

RO places M/U switch to OFF

## BEAVER VALLE . , OWER STATION

# 1/2 – ADM – 1357

Conduct of Simulator Training

		5	Revision_7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
			Crew monitors Tavg for inadvertent boron change
			US directs I&C to investigate problem with [2CHS*LT115]

[2CHS\*LT112] indication SAT, blender controls remain in OFF

Crew controls VCT level in manual control

Continue with next event at LE discretion

#### BEAVER VALLE, . OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	

#### **EVENT #3:**

[2RCS\*PT455] fails high

IMF XMT-RCS032A (0 0) 2500

[2RCS\*PI455] indicates pegged high

#### **IMMEDIATE PLANT RESPONSE:**

A4-2D PRESSURIZER PRESSURE HIGH/LOW ACTUATES (P0480D) [2RCS\*PI455] (CH I) indicates pegged high (2500 psig) on BB B [2RCS\*TI412C] Loop 1 OTDT Setpoint indicates pegged high (150%) BB B RO diagnose high failure of [2RCS\*PT455], reports to US/Crew

**Revision 7** 

US ensures plant is stable

US directs crew to **ARP A4-2D and IF** procedure 2.6.4.IF Att 2

RO selects OPERABLE channel on [2RCS-TR412]

OPERABLE OT/OPDT channel selected on recorder [2RCS-TR412]

#### BEAVER VALLE . . OWER STATION 1/2 – ADM – 1357

Conduct of Simulator Training

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
			US refers to TS 3.3.1 and Table 3.3.1-1 Function 6, 8.a and 8.b, TS 3.3.2 and Table 3.3.2-1 Function 1.d and 8.b, TS 3.3.4 and TS Bases Table B3.3.4-1 Function 2.a
	2TS/412C-1, OTDT trip – <b>CANNOT BE</b> <b>TRIPPED</b> 2TS/412C-2, OTDT rod stop – <b>CANNOT</b> <b>BE TRIPPED</b>		TS 3.3.1, Table 3.3.1-1: (RTS) Function 6: OTDT Condition E.1 – Place in TRIPPED Condition (6 hrs) <u>OR</u> E.2 – Be in MODE 3 (12 hrs)
			US refers to TS, determines that OTDT B/S cannot be tripped W/O causing a reactor trip
			US determines that TS 3.0.3 applies
			US identifies <b>PZR Pressure</b> instrument related TS and <b>MAY</b> trip B/S associated with PZR Pres
			<b>Function 8.a</b> : <b>PZR Press LOW</b> Condition K.1 – Place in TRIPPED Condition (6 hrs) <u>OR</u>
			K.2 – Reduce THERMAL POWER to < P-7 (12 hrs)

**Revision** 7

#### BEAVER VALLEN OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
			<b>Function 8.b: PZR Press HIGH</b> Condition E.1 – Place in TRIPPED Condition (6 hrs) <u>OR</u> E.2 – Be in MODE 3 (12 hrs)
			US refers to <b>ESFAS TS</b> associated with PZR Pres and <b>MAY</b> trip B/S associated with PZR Pres <b>TS 3.3.2, Table 3.3.2-1:</b> (ESFAS)
			<b>Function 1.d</b> : <b>PZR Press LOW</b> Condition D.1 – Place channel in TRIP (6 hrs) <u>OR</u>
			D.2.1 – Be in MODE 3 (12 hrs) $\underline{AND}$
			<b>Function 8.b</b> : <b>PZR Press P-11</b> Condition K.1 – Verify interlock is in required state for existing Unit condition (1 hr) <u>OR</u>
			K.2.1 – Be in MODE 3 (7 hrs) <u>AND</u> K.2.2 – Be in MODE 4 (13 hrs)
As Plant Management, direct US to commence an immediate plant S/D to MODE 3			US informs Plant Management that a plant S/D is required by TS

#### BEAVER VALLE COWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
As I&C use the following to trip the B/S and then inform the CR that repairs will take a minimum of 10 – 12 Hrs.			
IF requested to trip <b>PZR Pres</b> bistables <b>THEN</b> :			US <b>may</b> decide to trip only the B/S associated with SI, HIGH/LOW press Rx Trip, P-11 and PORV Block
IRF LOA-PCS001 (0 0) 1	Protection rack 1 door open.		
IMF BST-PCS117 (0 0) 0	2PS/455A, high pressure trip.		
IMF BST-PCS118 (0 0) 0	2PS/455B, P-11.		
IMF BST-PCS125 (0 0) 0	2PS/455C, low pressure trip.		
IMF BST-PCS126 (0 0) 0	2PS/455D, low pressure SI.		
IMF BST-PCS127 (0 0) 0	2PS/455G, PORV block.		
IRF LOA-PCS001 (0 0) 0	Protection rack 1 door closed.		
Report actions to CR			
<b><u>NOTE</u></b> : IF the US insists on tripping the B/S associated with OTDT <b>THEN</b> :			
IMF BST-PCS151 (0 0) 0	2TS/412C-1, OTDT trip.		
IMF BST-PCS152 (0 0) 0	2TS/412C-2, OTDT rod stop.		
Report actions to CR			
Event #5 will be inserted upon trip, advance to page 15 for <b>E-0</b> actions	Reactor trip <u>SHOULD HAVE</u> OCCURRED		RO announce 1 <sup>st</sup> out reactor trip <b>AND</b> that the reactor <b>DID NOT TRIP</b>
BVPS – 2 Scenario 2	14 of 29	R	ev. 1 (45 day submittal)

#### BEAVER VALLE , OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		5	Revision 7	
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE	
			US directs entry into E-0	
<u>EVENT #4:</u>				
Normal power reduction			Crew commences power reduction IAW <b>20M-52.4.B</b> Load Follow	
Reactor Engineering is currently unavailable. Plant Management directs immediate power reduction to MODE 3 SM recommends 12%/Hr.			Crew develops reactivity plan for 12% Hr. power reduction to MODE 3	
			BOP prepares EHC for load reduction, presses GO when ordered	
			BOP maintains VPL 5% above turbine load	
			RO maintains axial flux W/I target band, rods above RIL and Tavg +/- 2F of Tref during transient	
			BOP maintains Generator Lagging power factor and Base Adjuster at Null	
Continue with next event at LE discretion:				

į

#### BEAVER VALLE . . OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE

#### **EVENT #5:**

[2RCS\*P21A] #1 seal degrades

#### IMF RCP01A (0 0) 8

#### **IMMEDIATE PLANT RESPONSE:**

A2-4D REACTOR COOLANT PUMP SEAL TROUBLE (F0125D) for the "A" RCP

[2CHS-FR154A] RED PEN indicates 6 gpm (off scale high for "A"RCP) RO checks alarms, reports indications of #1 seal failure on [2RCS\*P21A] to US/Crew

**Revision 7** 

US refers to ARPs, AOP 2.6.8 Step 2.g

RO reports that "A" RCP #1 seal leakoff is > 6 gpm

US direct manual reactor trip, Directs RO to trip [2RCS\*P21A] after completion of IMAs of **E-0**, Directs Crew to isolate [2RCS\*P21A] seal leakoff W/I 3 – 5 min after tripping RCP

Crew performs IMAs of E-0.

RO verifies reactor tripped.

RO Attempts manual reactor trip from BB B and BB A, reports reactor has <u>NOT</u> tripped

Crew enters E-0, performs immediate operator actions.

Annunciator A5-6D TURBINE TRIP DUE TO REACTOR TRIP – **NOT LIT** Power range indication – **NOT LESS THAN 5%** Neutron flux – **NOT DROPPING** 

# BEAVER VALLE . . OWER STATION

## 1/2 – ADM – 1357

Conduct of Simulator Training

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
US transitions to FR-S.1	Reactor IS NOT tripped		US/Crew determine <b>FR-S.1</b> entry conditions met, transition to <b>FR-S.1</b> Step 1
When directed to locally trip the reactor:			Crew performs IMAs of <b>FR-S.1</b>
TRG! 30			
Time delays are built in			
Time delays are built in.	Turbine is tripped		BOP manually trips the turbine
<u>CRITICAL TASK</u> Crew inserts negative reactivity into the core by inserting RCCAs before completing the immediate action steps of FR-S.1.	Control Rods are inserting		RO inserts control rods, AUTO at first, THEN MANUAL when required
	[2FWE*P23A] on clearance		Crew verifies AFW status
	[2FWE*P23B] REQUIRE MANUAL		
	START		BOP reports AFW status, manually starts
	[2FWE*P22] TRIPPED during S/U		[2FWE*P23B], verifies flow to SGs
	AFW Throttle Vlvs – FULL OPEN		
SI may not have actuated at this time	Charging Pumps – AT LEAST 1 RUNNING SI – ACTUATED (possibly not at this		Crew initiates Emergency Boration
	time)		
	HHSI flow INDICATED		

#### BEAVER VALLE . . OWER STATION 1/2 - ADM - 1357

Conduct of Simulator Training

		Ų	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
Step 3.e	[2CHS*MOV350] – OPEN In service boric acid Xfer pump – STARTED Emergency Boration Flow - > 30 GPM [2CHS*FCV122] adjusted for > 40 GPM		Crew aligns boration path
	PZR Pressure < 2330 PSIG		RO checks PZR pres < 2330 PSIG
	Plant personnel alerted of ATWS		Crew alerts plant personnel, sounds STBY alarm and announces U2 reactor trip W/O SCRAM
	Turbine – TRIPPED [2MSS-MOV100A,B] – CLOSED Reheater Controller – RESET		BOP verifies turbine tripped and reheat steam isolated
	IF SI – ACTUATED THEN: First NINE steps of E-0 performed when time and manpower permit		Crew checks SI Status
	Power range channels - <5% IRNI channels – NEGATIVE SUR		Crew checks if reactor is subcritical
	Boration continues for SDM considerations		Crew continues boration as necessary

#### BEAVER VALLE , . OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

			Revision 7	
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE	
Scenario assumes the reactor has been locally tripped by this time			US directs return to E-0 step 1	
Crew enters <b>E-0</b> , performs immediate operator actions.			Crew performs IMAs of E-0.	
	Annunciator A5-6D TURBINE TRIP DUE TO REACTOR TRIP - LIT Power range indication - LESS THAN 5% Neutron flux - DROPPING		RO verifies reactor tripped.	
	Throttle Valves - ALL CLOSED OR Governor Valves - ALL CLOSED Main Generator Output Bkrs - OPEN Exciter Circuit Bkr - OPEN		BOP verifies turbine tripped.	
	AC Emergency Busses - BOTH ENERGIZED		BOP verifies power to AC Emergency Buses.	
	Check SI – ACTUATED CNMT Pressure - > 5PSIG PZR Pressure - < 1860 PSIG SG Steam Pressure - < 500 PSIG		RO checks SI status CREW DETERMINES SI REQUIRED	
Crew continues E-0	Manually actuate SI (both trains)		RO manually actuates SI both trains	
		_		

Rev. 1 (45 day submittal)

#### BEAVER VALLE , OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
L	Alert Plant Personnel		RO/BOP sound Standby Alarm, announce reactor trip and safety injection
	Check [2HVS*FN204A(B)], Leak Collection Filtered Exhaust Fan – AT LEAST ONE RUNNING		BOP checks Leak Collection Exhaust Fan status
	Charging Pumps – TWO RUNNING HHSI Flow – INDICATED LHSI Pumps – TWO RUNNING		RO verifies SI System status
	Motor-driven AFW Pumps – <b>ONE</b> RUNNING		BOP verifies AFW System status
	Turb driven AFW Pump <b>TRIPPED</b> DURING S/U		
	AFW Throttle Vlvs – FULL OPEN		
	Total AFW Flow – GREATER THAN 340 GPM		
	Perform Attachment A-0.11 "Verification Of Automatic Actions" in a timely manner		US directs performance of Attachment A- 0.11 when time/manpower permit
Attachment A-0.11 included with scenario beginning on Pg 27	LIST ATT A-0.11 DISCREPANCIES AS APPLICABLE: [2EWF*P23B] required manual start		
	[2FWE*P22] tripped during S/u		

#### BEAVER VALLEY . OWER STATION

1/2 – ADM – 1357

Conduct of Simulator Training

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	RCPs OPERATING – MONITOR Tavg		RO/BOP check RCS Tavg stable at or
	RCPs STOPPED – MONITOR Tcold		trending to 547°F
	Check CIB – NOT ACTUATED		RO checks Recirc Spray Pump status
	PORVs NOT ALL CLOSED		RO verifies PZR isolated
	[2RCS*PCV455C] – STUCK OPEN		
	[2RCS*MOV535] – CANNOT BE		RO reports status of [2RCS*PCV455C]
	CLOSED		AND its block valve [2RCS*MOV535]
Transition to E-1			US directs transition to E-1 due to
			PORV/Block Valve status
	Control Room radiation monitor		Crew checks if CREVS should be actuated
	[2RMC*RQ201, 202] (1069, 1072) –		
	NOT IN HIGH ALAKM		
	CIR HAS NOT OCCUPPED		
	CID ~ HAS NOT OCCURRED		
CRITICAL TASK	D/P between RCS pressure and highest SG		RO checks if RCPs should be stopped
Crew trips all RCPs when RCS to highest	pressure – LESS THAN 205 PSID [220		Ro cheeks if Ref 5 should be stopped
SG D/P criteria is exceeded and SI flow	PSID ADVERSE CNMT]		
verified prior to exiting procedure E-1.	AND		
	HHSI Flow – INDICATED		
	RCPs – STOPPED		PO stops PCPs

RO stops RCPs

#### BEAVER VALLEY , OWER STATION

# 1/2 – ADM – 1357

Conduct of Simulator Training

# Revision 7 EXPECTED STUDENT RESPONSE PLANT STATUS OR RESPONSE OBJECTIVE INSTRUCTIONAL GUIDELINES CIB - NOT ACTUATED RO checks Recirc Spray Pump status Pressures in all SGs – ANY DROPPING BOP checks if any SGs are faulted. IN AN UNCONTROLLED MANNER OR ANY SG COMPLETELY DEPRESSURIZED SGs are NOT faulted Narrow Range Levels - GREATER THAN BOP checks intact SG levels 12% [31% ADVERSE CNMT] BOP controls feed flow to intact SGs to maintain NR level between 12% [31% ADVERSE CNMT] and 50%

#### BEAVER VALLE . . OWER STATION

#### 1/2 – ADM – 1357

Conduct of Simulator Training

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Check all SG levels – NONE RISING IN AN UNCONTROLLED MANNER		Crew checks if SG tubes are intact
	Check Secondary Radiation – CONSISTENT WITH PRE-EVENT VALUES		
	[2ARC-RQ100] (1007) Air ejector discharge		
	[2SSR-RQ100] (1062) SGBD sample		
	[2MSS*RQ101A,B,C] Main Steamline discharge (1005, 3005, 5005)		
	SG Tubes are intact		
	Power to the Block Vlvs – AVAILABLE		RO checks PRZR PORVs and Block Valves
	PORVs – [2RCS*PCV455C] – <b>STUCK</b> OPEN		
	Block Vlvs – [2RCS*MOV535] – CANNOT BE CLOSED		
	RCS Subcooling based on core exit TCs LESS THAN 41F [59F ADVERSE CNMT]		RO/BOP check if SI flow can be reduced

# BEAVER VALLE , . OWER STATION $1/2-\mbox{ADM}-1357$

Conduct of Simulator Training

			Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Casendamy heat sinks		
	Secondary neat sink:		
	Total feed flow to intact SGs – GREATER THAN 340 GPM		
	OR		
	Narrow range level in at least one intact SG – GREATER THAN 12% [31-% ADVERSE CNMT]		
	RCS pressure – <b>REDUCING</b>		
	PRZR level – GREATER THAN 17% [38% ADVERSE CNMT]		RO/BOP check if SI flow can be reduced (continued)
	SI FLOW CANNOT BE REDUCED		
	Any Quench spray or recirc spray pump		RO/BOP check if CNMT Spray should be stopped
	SI & CIA - RESET		RO resets SI and CIA
	RCS Pressure - > 225 PSIG [250 PSIG ADVERSE CNMT]		RO checks if LHSI Pmps should be stopped
<b><u>NOTE</u>:</b> RCS pressure <b>MAY</b> appear to be stable and RO will stop LHSI pumps	RCS Pressure – <b>REDUCING</b>		<b>IF STABLE</b> , RO stops LHSI pumps and places them in auto
	Check pressures in all SGs – STABLE OR RISING		RO/BOP check RCS and SG Pressures
	Check RCS Pressure – STABLE OR DROPPING		

#### BEAVER VALLE . .- OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Verify AC emergency busses energized from offsite		BOP checks if EDGs should be stopped
	Stop any unloaded EDG by performing <b>20M-36.4.AF(AG)</b>		Crew stops EDGs
	Recirc capability exists		US directs operators to perform Att A-0.6 and verify cold leg recirculation capability
	Check Aux building and Safeguards radiation – CONSISTENT WITH PRE- EVENT		Crew tries to identify and isolate the leakage
			SM consults with TSC Staff to determine whether samples can be obtained
	Sample: CNMT atmosphere for radioactivity and hydrogen CNMT sump for pH and boron RCS liquid		US directs Chemistry and HP to obtain pertinent samples
	Crew performs ATT A-1.1		US directs crew to perform additional actions as required to aid in plant recovery per ATT A-1.1

# BEAVER VALLE . . OWER STATION 1/2 – ADM – 1357

Conduct of Simulator Training

# Revision 7 INSTRUCTIONAL GUIDELINES PLANT STATUS OR RESPONSE OBJECTIVE EXPECTED STUDENT RESPONSE

RCS Pressure - > 225 PSIG [250 PSIG ADVERSE CNMT] RO checks if cooldown and depressurization is required

US directs crew transition to ES-1.2

Terminate drill when crew transitions to **ES-1.2** 

Classify Event

Site Area Emergency Tab 2.3

#### BEAVER VALLE . . OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		Revision 7	
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
Attachment A-0.11 'Verification of Automatic Actions' performed as time & manpower permit			US directs operator to perform <b>Attachment</b> <b>A-0.11</b> as time & manpower permit
	Diesel generators – BOTH RUNNING		Check both EDGs running
	CNMT pressure – GREATER THAN 7 PSIG		Check if MSLI is required
	<b>OR</b> SG Steam Pressure – LESS THAN 500		If <b>not required</b> , go to step 4
	PSIG		
	Steamline pressure high rate of change – 100 PSIG DROP IN 50 SECONDS		
	Yellow SLI marks - LIT		Verify steamline isolation
STEP 4	Open [2CCS-AOV118] Domestic Water to Station Air Compressor		Establish Domestic Water System Cooling to Station Air Compressors
	At least one Station Air Compressor – RUNNING		Start 1 Station Air Compressor as required
	CCP pumps – AT LEAST 1 RUNNING		Check CCP Pump status

#### BEAVER VALLE 1 - OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		Ũ	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	[2NME-NR45] Nuclear Recorder selected to operable source and intermediate range displays		Align neutron flux monitoring for shutdown
	CNMT pressure – HAS REMAIND LESS THAN 11 PSIG		Check CIB status
	IF NOT		Actuate CIB if required
	Manually initiate CIB – BOTH SWITCHES FOR BOTH TRAINS		
	Manually align equipment as required All RCPs – STOPPED BV-1 operator verifies CREVS actuation Service water established to RSS HX(s)		Stop ALL RCPs

Service Water Pumps – 2 RUNNING Service Water Header Pressure – GREATER THAN 55 PSIG SWS Seal Water Pressure – NOT LOW

[2HCS\*SOV100A1, B1] – CNMT Sample amber light – LIT

Verify Service Water System in service

Verify both CNMT hydrogen analyzers running

#### BEAVER VALLEY -OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

			Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	All Red SIS Marks – LIT All Orange CIA Marks – LIT All Green FWI Marks – LIT		Verify ESF Equipment status – Start/align equipment as required
	Power available to both Emergency AC Busses		Verify power to both AC Emergency busses
			Restore power as required
	Attachment A-0.11 – COMPLETE		Report any discrepancies to SM/US

Append	lix D	Sci	enario Outline		Form E	S-D-1
Facility Examin	: BVPS 2 lers:	S	cenario No.: 3 Candidates:	Op Test No.:	NRC	SRO ATC BOP
Initial Conditions:MOL, 75 % power Equ Xe, CB = 188, 1116 PPM IC-167Imitial Conditions:MOL, 75 % power Equ Xe, CB = 188, 1116 PPM IC-167Turnover: Full power at 12%/Hr IAW 20M-52.4.B, Load Follow, and the reactivity plan provided by Reactor Engineering. [2FWE*P23A] Motor Driven AFW Pump is on clearance for motor replacement and is due to be returned tomorrow. [2SAS-C21E] Station Air Compressor is on clearance for bearing replacement and due to be returned 2 days from now.Critical Tasks: Define 1. E-0.QCrew manually trips the main turbine before a Severe (orange path) challenge develops to either the Sub-criticality or the Integrity CSF or before transition to ECA-2.1, whichever occurs first.						
	2. FR-H	1.A Crew establish and bleed is re	nes feedwater flow i equired.	into at least one S	G before	RCS feed
Event No.	Malf. No.	Event Type*		Event Descriptio	n	
1	NIS03D	I (RO/SRO) SRO T.S.	PRNI N-44 fails H insertion	IIGH causing auto	omatic co	ntrol rod
2	CRF03-H14	SRO T.S.	Misaligned rod. D H-14 will drop to then remain stuck	uring control rod some position belo at that position	motion, ( ow the gr	Control Rad oup and
3		R (RO) N (BOP/SRO)	Normal power red	uction		
4	PMP-CFW05	C (BOP/SRO)	[2FWS-P21B], Ma	ain Feedwater Pur	np trips	
5	PMP-CFW04	M (ALL)	[2FWS-P21A], 2 <sup>nd</sup>	<sup>d</sup> Main Feedwater	Pump tri	ps
6	EHC08A	C (BOP/SRO)	Main Turbine fails	s to auto trip, man	ual trip s	uccessful
7	LOA-AFW022 PMP-AFW002	M (ALL)	[2FWE*P22] Turb startup [2FWE*P2 resulting in Entry Sink.	bine driven AFW 23B] Motor driven into FR-H.1 Loss	Pump trij 1 AFW P of Secon	ps during ump Trip Idary Hea

(N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

#### Scenario Summary Scenario 3

The crew will assume the shift at approximately 75% power BOL equilibrium Xenon. Motor driven AFW pump 2FWE\*P23A is OOS. Station air compressor 2SAS-C21B is also OOS. Crew is to raise power at 12%/hr IAW 2OM-52.4.B, Load Follow. Before the crew can begin raising power. Power range channel N-44 FAILS HIGH which causes automatic control rod insertion at 72 SPM. During the rapid rod insertion, rod H-14 drops to a position below the group and becomes stuck at this position. The crew responds to the alarms and implements the actions of AOP 2.2.1C, Power Range channel Malfunction and AOP 2.1.3, RCCA Control Bank Inappropriate Continuous Movement. The crew will manually stop the inward rod motion and stabilize the plant. After the plant is stable, the US will then implement AOP 2.1.8, Rod Inoperability and implement the required Technical Specification actions for both the failed N44 and stuck rod. After the Technical Specifications have been addressed, reactor engineering/plant management directs an immediate power reduction to 50% to gather data and assess the impact of the stuck control rod. The crew begins the power reduction. During the power reduction, Main feed pump 2FWS-21B trips. The crew responds to the alarms and implements the actions of AOP 2.24.1, Loss of Feedwater. When the crew attempts to start the startup feed pump 2FWS-P24 it will NOT start. The crew will be required to commence a rapid load reduction to 50% power as part of the loss of feedwater AOP. During the load reduction, the 2<sup>nd</sup> main feed pump trips. This will require the crew to manually trip the reactor and enter E-0, Reactor Trip or Safety Injection. The actions of E-0, Reactor Trip or Safety Injection will be complicated by a failure of the turbine to automatically trip. The crew will be required to manually trip the turbine. The actions of E-0, Reactor Trip or Safety Injection will be further complicated by a failure of the steam driven and only operable motor driven AFW pumps. The crew will transition into ES-0.1, Reactor Trip Response. While in ES-0.1, a RED PATH will be identified on Heat sink No AFW flow and NR levels less than 12%. This will require the crew to transition into FR-H.1, Loss of Heat Sink (RED PATH). The crew will remain in FR-H.1 and restore the heat sink by depressurizing the steam generators and establishing condensate flow to the steam generators. After establishing condensate flow, the crew will transition back to ES-0.1, Reactor Trip Response The scenario is terminated when condensate flow is established and a transition has been made back to ES-0.1.

#### **EOP Flow Path:**

E-0, Reactor Trip or Safety Injection  $\rightarrow$  ES-0.1, Reactor Trip Response  $\rightarrow$  FR-H.1, Loss of Heat Sink  $\rightarrow$  ES-0.1, Reactor Trip Response

#### BEAVER VALLE ) . OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

Revision 7

#### **INITIAL CONDITIONS:** 75 % Power, CBD = 188, EQU XE, MOL, 1116 PPM Boron IC-167 (bighorn21)

ADDITIONAL LINEUP CHANGES	STICKERS	VOND MARKINGS
[2FWE*P23A] PTL [2SAS-C21B] PTL	DANGER DANGER	
EQUIPMENT STATUS	DATE/TIME OOS	TECHNICAL SPECIFICATION(S)
[2FWE*P23A] [2SAS-C21B]	12 hrs ago 1week ago	

#### SHIFT TURNOVER INFORMATION

- 1. Protected Train is Train "B"
- 2. [2SAS-C21B] Motor bearing replacement, due back in 2 days
- 3. [2FWE\*P23A] Motor replacement, due back tomorrow
- 4. Return to 100% power at 12%/Hr IAW 2OM-52.4.B Load Follow AND Reactivity Plan provided by Reactor Engineering
- 5. Plant has been at 75% power for 3 days at System request
- 6. Time in life is MOL (10,000 MWD/MTU)
- 7. All notifications have been made and permission has been received to return the Unit to full power

#### SCENARIO SUPPORT MATERIAL REQUIRED

Reactivity plan placard for MOL AND Reactivity Plan from Reactor Engineering 20M-52.4.B Load Follow Placard for [2FWE\*P22] position stating [2FWE\*P22] is aligned to "A" header Place plaque on wall for Protected Train "B"

# BEAVER VALLE , . OWER STATION

#### 1/2 – ADM – 1357

#### Conduct of Simulator Training

			Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
Initialize IC - 167, and establish initial plant conditions.	Reactor plant at 75 % power, MOL, equilibrium conditions. RCS boron 1116 PPM, CBD = 188 steps.		
Insert the following per the Simulator Setup section of the HTML File for this drill	Inserts all pre-loads required to support the drill		
IRF LOA-HIV055 (0 0) 1 IMF PMP-CAS004 (0 0) 1 IMF EHC08A (0 0)	[2FW*P23A] breaker racked out [2SAS-C21B] OOS Turbine fails to auto trip, manual successful		
TRGSET 1 'FNISPR(4) >= 120' IMF CRF08-H14 (0 0) 0	Set trigger 1 on N-44 indication Control rod H14 remains stuck at 188 steps during rod motion		
TRGSET 2 'OAFWT22 > 50' IRF LOA-AFW022 (2 0) 1	Set trigger 2 on [2FWE*P22] start [2FWE*P22] trips during startup/sequencing		
IMF VLV-CFW027 (0 0) 0	[2FWS-P24] will not start, set up <b>FR-H.1</b> conditions		
TRGSET 3 'MCRFNS(3) <= 225' IMF PMP-AFW002 (3 90) 1	Set trigger 3 on reactor trip [2FWE*23B] trips 90 seconds after reactor trip		

#### BEAVER VALLET . OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

			Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
Assign shift positions			
SM:			
US:			
RO:			
BOP:			
STA:			
Conduct a shift turnover with oncoming operators.	Simulator Frozen until after shift turnover unless it needs to be run momentarily for an alignment change.		
When the shift turnover is completed, place the simulator to RUN and commence the drill.	Simulator running.		Crew assumes control of the Unit.

Γ

#### BEAVER VALLE ... OWER STATION 1/2 - ADM - 1357 Conduct of Simulator Training

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE

#### EVENT #1 & 2

N-44 fails high **AND** Rod H-14 drops to a position below the group and then remains stuck at that position (Pre-load)

IMF NIS03D (0 0) 200 IMF CRF08-H14 (5 0) 0 TRGSET 4 'FNISPR(4) >= 80' TRG 4 'SET MCRFNS(44) = 168' TRGSET 5 'XB2I040H == 1'

N-44 fails high AND Rod H-14 drops to a position below the group and then remains stuck at that position

RO diagnose & reports high failure of PRNI N-44

**Revision 7** 

#### **IMMEDIATE PLANT RESPONSE:**

Annunciators actuate: A4-4F NIS POWER RANGE COMPARATOR DEVIATION (Y0130D) A4-4H NIS POWER RANGE HIGH SETPOINT OVERPOWER ROD STOP BLOCK ROD WD (Y0131D) A4-5G NIS POWERRANGE HIGH/LOW SP NEUTRON FLUX HIGH(N0004D)
NSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	FAST SPEED		
	[2NMP-NI44B] pegs high (BB B)		
	N-44 indication at NI rack pegs high		
	RCS Temperature and Pressure begin to reduce		

PZR Level begins to reduce

US directs RO to place Control Rods in manual upon determining an instrument failure has caused rod motion

**Revision 7** 

US directs crew actions for AOP 2.1.3

#### **AOP 2.1.3 STARTS HERE**

#### **ADDITIONAL ANNUNCIATORS:**

A4-8G ROD POSITION DEVIATION (C5680D) A4-1D PRESSURIZER CONTROL PRESSURE HIGH/LOW A4-1E PRESSURIZER CONTROL PRESSURE DEVIATION HIGH/LOW (P0501D) PRESSURE RELIEF BLOCK (P0496D) PRESSURIZER BACKUP HEATER GROUP AUTO ON/OFF (P0503D) TAVG DEVIATION FROM TREF (T0508D)

#### BEAVER VALLEY , OWER STATION

# 1/2 – ADM – 1357

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	NO LOAD REJECTION		Crew reports no load rejection in progress
	Rod Motion – STOPPED		US directs RO to place Control Rods in MANUAL
	Tavg – <b>REDUCING</b> Restore Tavg by load reduction		US directs preparation for load reduction to match Tavg/Tref
	OPERABLE PRNIS – <b>W/I <u>+</u> 2%</b> OF EACH OTHER		Crew checks core power distribution NORMAL
	CHANNEL DEVIATION light – LIT (due to failed inst)		
	A4-4F – NIS POWER RANGE COMPARATOR – LIT (due to failed inst)		
	Delta Flux Indicators – W/I TARGET BAND		
	Control Rod Positions – GREATER THAN RIL		RO reports Rods above RIL
	Reactor Power $\geq$ 50%		RO reports power level
	QPTR in progress		STA previously directed to perform QPTR
	0 - ( 00	Davi	1 (45 day outprotital)

# BEAVER VALLE . . OWER STATION

## 1/2 – ADM – 1357

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	A4-3C TAVG DEVIATION FROM TREF - may/may not be lit depending on progress of load reduction at this time		Crew refers to ARPs as required
	Power operation continues Minimize turbine load changes Adjust boron to control Tavg		US directs recovery efforts to restore Tavg/Tref
			Crew completes actions of AOP 2.1.3
AOP 2.2.1C STARTS HERE			US directs crew actions for AOP 2.2.1C
	ONLY N-44 has failed		Crew checks only ONE PRNI has failed
			US refers to TS when time permits
			W/I 1 hr verify P-8 and P-9 interlocks are SAT for current plant conditions (TS 3.3.1 Function 17.c & 17.d: Be in MODE 2 W/I 7 hrs.)
			Crew verifies P-8 and P-9 interlocks are SAT (power $> 50\%$ )

#### BEAVER VALLE . . OWER STATION 1/2 - ADM - 1357

			Revision 7	
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE	
			Crew verifies P-10 interlock is SAT (power > 10%)	
			W/I 1 hr verify <b>P-10</b> interlocks are SAT for current plant conditions ( <b>TS 3.3.1 Function 17.e: Be in MODE 3 W/I 7 hrs.</b> )	
			BOP removes N-44 Control Power fuses	
	A4-4G actuates when fuses pulled		W/I 6 hrs trip nuclear B/S by removing the Control Power fuses from drawer 'A' for the failed channel (TS 3.3.1 Function 2.a, 2.b and 3: Be in MODE 3 W/I 12 hrs.)	
	N-44 has failed high		RO ensures Control Rod group Selector Switch is in MANUAL (previously performed)	
	At NIS Rack 50 – 'Detector Current Comparator' – 'Rod Stop Bypass Switch' to <b>BYPASS for N-44</b> Panel 308 status light D-14 'Overpower Rod Stop Bypass' – <b>LIT</b> A4-4 clears		BOP operates switches as directed	
	Power > 50%		RO reports power $> 50\%$	

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
			US directs STA to perform QPTR
	ALL PRNI Upper and Lower channel inputs to QPTR – <b>OPERABLE</b>		Crew determines all inputs to QPTR are OPERABLE
	At NIS Rack N37/N46 – 'Comparator and Rate' – 'Comparator Channel Defeat Switch' to <b>N-44</b>		BOP operates switches as directed
	A4-4F clears		
	Vertical board 'A' recorders selected to monitor OPERABLE channels		RO selects OPERABLE channels to N-45 recorder
			Crew completes AOP 2.2.1C for N-44
			US directs crew actions for AOP 2.1.8
	NO Control Rods Have Dropped		RO reports No Dropped Rods
	ROD H-14 - <b>Stuck at a position &gt; 12</b> steps below its respective group		RO reports Rod H-14 is at a position > 12 steps below its respective group
	Control Rods – MANUAL Control Rod motion – STOPPED		US directs RO to place Control Rods in MANUAL ( <b>PREVIOUS</b> )

INSTRUCTIONAL GUIDELINES PLANT STATUS OR RESPONSE OBJECTIVE EXPECTED STUDENT RESPONSE

Reactor IS critical Tavg - > 541F Tavg - NOT W/I  $\pm$  4F of Tref Tavg - Stable (after rods placed in MANUAL)

> US refers to **TS 3.1.4** (Rod Group Alignment Limits) when time permits:

Revision 7

#### **MODES 1&2:**

All SD and CR shall be operable <u>AND</u> <u>Individual indicated rod positions shall be</u> W/I 12 steps of their group step counter demand position.

#### **Condition B:**

**B.1** Restore rod to W/I alignment limit (1Hr)

# <u>OR</u>

**B.2.1.1** Verify SDM to be W/I the limits specified in the COLR (1Hr)

## <u>OR</u>

**B.2.1.2** Initiate boration to restore SDM to W/I limits (1Hr) <u>AND</u>

**B2.2.2** Reduce THERMAL POWER to <= 75% RTP (2Hrs) <u>AND</u>

**B.2.3** Verify SDM is W/I the limits specified in the COLR (once/12 Hrs) <u>AND</u>

			Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
		£	<b>B.2.4</b> Perform SR 3.2.1.1 and SR 3.2.1.2 (72 Hrs) <u>AND</u>
			TS 3.1.4 (continued) B.2.5 Perform SR 3.2.2.1 (72 Hrs) <u>AND</u> B.2.6 Re-evaluate safety analysis and confirm results remain valid for duration of operation under these conditions (5 days)
	OPERABLE PRNIS – <b>W/I <u>+</u> 2%</b> OF EACH OTHER		Crew checks core power distribution NORMAL
	CHANNEL DEVIATION light – LIT (due to failed inst)		
	A4-4F – NIS POWER RANGE COMPARATOR – LIT (due to failed inst)		
	Delta Flux Indicators – W/I TARGET BAND		
	Control Rod Positions – GREATER THAN RIL		RO reports Rods above RIL

#### BEAVER VALLE 1 . OWER STATION 1/2 - ADM - 1357

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Reactor Power $\geq$ 50%	d	RO reports power level
	QPTR in progress		STA previously directed to perform QPTR
	A4-3C TAVG DEVIATION FROM TREF - may/may not be lit depending on progress of load reduction at this time		Crew refers to ARPs as required
			Crew completes actions of AOP 2.1.8
<u>EVENT #3:</u>			Crew develops a reactivity plan for power reduction of 12%/hr
Normal Power reduction			
			US contacts Reactor Engineering for a complete reactivity plan to complete the load reduction
After appropriate delay, provide the crew with a reactivity plan that will allow the continued power reduction			Crew refers to <b>20M-52.4.B</b> Load Follow for the load reduction
	Power < 100% <b>AND</b> load change will be GREATER than 2%		
	Turbine control – 1 <sup>ST</sup> STG IN		BOP transfers turbine control in 1 <sup>st</sup> STG IN mode

#### BEAVER VALLE . . OWER STATION 1/2 - ADM - 1357

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Setter - SET TO LOWER VALUE		BOP sets the EHC SETTER to a lower value as directed by the US
	1%/min selected		BOP selects 1%/min load rate on EHC panel
	Turbine load – REDUCING		BOP depresses the GO pushbutton on the EHC control panel when directed
	Blender controls set as desired per the reactivity plan		RO sets the blender controls for the desired boration rate/amount as determined by the reactivity plan
	MAINTAIN: Tavg/Tref W/I ± 2F AFD W/I limits of CB-14 (TS 3.2.3 'AXIAL FLUX DIFFERENCE') Control Rods ABOVE RIL as defined by COLR Fig 4.1-1 VPL at 5% above turbine load Generator parameters W/I limit of 'Calculated Capability Curve' 2OM- 52.5.A.5 (Figure 52-5) between a power factor of 0.90 lagging and 1.0 [2GSS-MOV204] - ADJUSTED as necessary to maintain gland steam pressure		Crew maintains plant/turbine & generator parameters as specified by <b>2OM-52.4.B</b> during the load reduction

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE

Continue with next set of events at LE discretion:

## <u>EVENT #4</u>

Loss of 1 Main Feedwater Pump

IMF PMP-CFW005 (0 0) 1	[2FWS-P21B] trips	BOP reports [2FWS-P21B] has tripped
	<b>IMMEDIATE PLANT RESPONSE:</b> A6-10A SG FEED PUMP 21 A/B AUTO- STOP (Y0438D) SG levels begin to reduce 2 Main Feed Deer Values begin to smar	
	SG Levels recover in automatic control	BOP monitors SG levels, reports levels recovering
		Crew refers to <b>AOP 2.24.1 and ARPs</b> for loss of Main Feedwater Pump
	[2CNM-P21B,C] Condensate Pumps – RUNNING [2HDH-P21A,B] Heater Drain Pumps – RUNNING [2HDH-P22A,B] Separator Drains Pumps – NOT RUNNING	BOP checks status of Condensate & Drains pumps

**Revision 7** 

	Conduct of Simulator Train	iing	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
			BOP starts pumps as necessary
<b>NOTE:</b> When crew discovers that [2FWS-P24] is unavailable, they may	Reactor Power > 52%		BOP reports [2FWS-P21A] is Running
conservatively trip the reactor and go to E-0. If so, go to page of this scenario	ONLY ONE MFP RUNNING		Crew attempts use of [2FWS-P24], Startup Feed Pump
	[2CNM-DCV100] – <b>OPEN</b>		BOP opens [2CNM-DCV100] Condensate Demin Diff Control Vlv
IMF-VLVCFW027 (0 0) 0 Prevent opening of [2FWR-FCV155] (PRE-LOAD)	[2FWR-FCV155] – <b>DOES NOT OPEN</b>		BOP attempts start of [2FWS-P24] by placing pump start switch to START and holding until [2FWR-FCV155] opens
	[2FWS-P24] – DOES NOT START		BOP reports [2FWS-P24] did not start
	Rx power < 80% - TRIP NOT REQUIRED		RO reports reactor power < 80%
			Crew begins Emergency S/D to 50% power IAW <b>AOP 2.51.1</b> Emergency Shutdown
<b>NOTE:</b> The Emergency S/D is scripted for a reduction to an end point of approximately 50% power and 4KV busses <b>WILL NOT</b> be transferred to offsite power.	Standby Alarm sounded Emergency S/D announced EPP evaluated		Crew alerts plant personnel of emergency S/D

# BEAVER VALLE . OWER STATION 1/2 - ADM - 1357

			0	Revision 7
ſ	INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
		3 PORVs – AVAILABLE (3 block vlvs open, 3 PORVs in auto)		RO reports PORVs available
	<b><u>NOTE</u></b> : Proceed to the next event at any time during the Emergency S/D at the LE discretion	For 2%/min – USE 2OM-7.4.AR BLENDER OPERATION IN MODE 1 For 5%/min – USE 2OM-7.4.Q EMERGENCY BORATION		RO begins boration at directed rate
		Turbine Control – 1 <sup>st</sup> STG IN MODE Load reduction rate thumbwheel set as directed GO Pushbutton – PRESSED		BOP starts power reduction at directed rate
		Governor valves function properly		BOP monitors turbine operation during transient
		Control rods in AUTO or Manual as desired		RO maintains Tavg/Tref within +/- 5F with auto/manual rods as directed
		PZR HTRS – ALL ON		RO places all PZR heaters to ON
		VPL at 5% above GV position		BOP maintains VPL at proper position during transient
		4KV BUSSES – <b>NOT TRANSFERRED</b> TO OFFSITE		Crew does not transfer 4KV busses to offsite

			Revision 7	
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE	
<b><u>NOTE</u></b> : If crew tripped the reactor earlier, <b>DO NOT</b> trip [2FWS-P21B] until after transition to ES-0.1			Crew notifies SYSTEM CONTROL of emergency power reduction	
EVENT #5	Reactor Power approximately 50% Turbine Control – HOLD		Crew stops power reduction	
Loss of the 2 <sup>nd</sup> Main Feedwater Pump				
IMF PMP-CFW004 (0 0) 1	[2FWS-P21A] trips, no Main Feedwater Pumps operating		BOP reports trip of only running Main Feedwater Pump	
			US directs RO to manually trip the reactor	
	Reactor Tripped		RO manually trips the reactor	
Crew enters <b>E-0</b> , performs immediate operator actions.			Crew performs IMAs of E-0.	
	Annunciator A5-6D TURBINE TRIP DUE TO REACTOR TRIP - LIT Power range indication - LESS THAN 5% Neutron flux - DROPPING		RO verifies reactor tripped.	

			Revision 7	
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE	
<b>EVENT #6</b> Main turbine fails to auto trip, manual	Auto Turbine trip failure, manual successful		BOP verifies turbine tripped <b>REPORTS</b> <b>AUTO TRIP FAILURE</b> and manually trips the Main Turbine	
successful (PRE-LOAD)	Throttle Valves - ALL CLOSED OR			
IMF EHC08A (0 0)	Governor Valves - ALL CLOSED Main Generator Output Bkrs - OPEN			
CRITICAL TASK	Exciter Circuit Bkr - OPEN			
Crew manually trips the main turbine before a Severe (orange path) challenge develops to either the Sub-criticality or the Integrity CSF or before transition to ECA-2.1, whichever occurs first.				
	AC Emergency Busses - AT LEAST ONE ENERGIZED		BOP verifies power to AC Emergency Buses.	
	Check SI – ACTUATED CNMT Pressure - > 5PSIG		RO checks SI status	
	PZR Pressure - < 1860 PSIG SG Steam Pressure - < 500 PSIG		CREW DETERMINES SI IS NOT REQUIRED, TRANSITIONS TO ES-0.1 STEP 1	
Crew transitions to ES-0.1 Step 1			US directs STA to monitor status trees.	

# BEAVER VALLE . . OWER STATION

# 1/2 – ADM – 1357

		-	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	SOUND Standby Alarm U2 Rx Trip – ANNOUNCED		Crew alerts plant personnel of reactor trip
	RCS Temp – STABLE AT OR TRENDING TO 547F:		Crew monitors RCS temperature for proper response
	Tavg – RCPs RUNNING Tcold – RCPs NOT RUNNING		
	RCS temperature maintained by Condenser Stm Dmps:		Crew sets Condenser Steam Dumps to maintain RCS temperature in AUTO
	MSIVs – AT LEAST 1 OPEN		OR
	Condenser - AVAILABLE Stm Dmps adjusted to slightly above Stm HDR Pres		Crew uses SG Atmospheric Stm Dmp Vlvs
	Stm Dmps Controller – MANUAL Output Demand – ZERO		OR
	Stm Dmps – STM PRESS MODE Tayg Interlock – DEFEATED (if reg)		RHR Vlv
	Stm Dmps Controller – AUTO		
	Controller Setpoint – ADJUST AS NECESSARY		

		R		
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE	
<b>IF NOT previously performed</b> trip [2FWS-P21B] at this time				
Loss of the 2 <sup>nd</sup> Main Feedwater Pump				
IMF PMP-CFW004 (0 0) 1	[2FWS-P21A] trips, no Main Feedwater Pumps operating		BOP reports trip of only running Main Feedwater Pump	
<u>EVENT #7 &amp; 8</u>				
Complete loss of all feedwater – <b>FR-</b> <b>H.1</b> conditions ( <b>PRE-LOAD</b> )				
IRF LOA-AFW022 (2 0) 1 IMF PMP-CFW008 (0 0) 2 IMF PMP-AFW002 (3 180) 1	[2FWE*P22] trips during startup [2FWS-P24] cannot be started [2FWE*P23B] trips 180 seconds after startup			
	All feedwater pumps – STOPPED Annunciators A5-2C(3C)(4C) 'SG 21A(21B)(21C) LEVEL LOW-LOW REACTOR TRIP' – ANY LIT AS FIRST OUT NO AFW Pumps RUNNING		Crew checks Feedwater Status	
	NU AFW Flow to SGs		STA reports <b>FR-II.1</b> entry conditions are met	

#### BEAVER VALLE , . OWER STATION

## 1/2 – ADM – 1357

Conduct of Simulator Training

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
Crew transitions to <b>FR-H.1</b>			US directs crew transition to FR-H.1 step 1
	RCS Pressure is > SG pressure RCS Hot Leg Temperature > 350F		Crew checks if Secondary Heat Sink is required
	WR level in at least 2 SGs is above 14% [32% ADVERSE CNMT] PZR pressure is <2330 psig		Crew checks if RCS Bleed and Feed should be initiated
	PPDWST > 85 inches		BOP checks PPDWST level > 85 inches
	[2BDG*AOV100A1,B1,C1] SGBD ISOLATION VALVES – CLOSED [2SSR*AOV117A,B,C] BLOWDOWN SAMPLE OUTSIDE CNMT ISOL VLVS – CLOSED No Motor Driven AFW pumps available		BOP try to establish AFW flow to at least one SG

Revision 7

# BEAVER VALLE, . OWER STATION

#### 1/2 – ADM – 1357 -

	1/2 - ADW - 1557		
	Conduct of Simulator Trair	ning	
		-	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Turbine Driven AFW Pump Steam Supply		
	Valves – OPEN		
	SG 21A [2MSS*SOV105A D]		
	SG 21R [2MSS*SOV105R E]		
	30 21B [2NI35 30V 103B,E]		
	SG 21C [2MSS*SOV105C,F]		
	AFW throttle valves – OPEN		
	Computer point Y5172D Turb DR AFW		
	PP Tripped FWE*P22 Inop – IN ALARM		
	STATE		
	FW-P-2 Tripped/mechanical damage		
			Crew continues to try to restore AFW
	Total Flow - LESS THAN 340 GPM		US/Crew continues with FR-H.1
	RCPs – Stopped		RO stop RCPs
			···· F -··· F
CDITICAL TASK	Condensate system AVAII ARLE IN		ROP try to establish MEW flow to at least 1
CALLIASK	SERVICE		SG
Crew establishes feedwater flow into at	SERVICE		50
least one SG before RUS feed and bleed	$[2FWS^*HYVI5/A,B,C] = OPEN$		
is required.			

[2FWS-P24] Startup Feed Pump -UNAVAILABLE [2FWS-P21A,B] – UNAVAILABLE BOP reports Both Main feed pumps and the Startup Feed Pump are unavailable

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	All SGNR Levels – LESS THAN 12% [31% ADVERSE CNMT]		BOP reports status of SGNR levels
	Letdown – NOT IN SERVICE		Crew prepares for RCS depressurization to less than 2000 psig
	ONE PORV – OPEN		RO opens ONE PORV to perform the depressurization
	RCS pressure - < 2000 psig		RO closes PORV and stops the depressurization
	PORV – CLOSED		
	[2CHS*MOV310] – OPEN [2CHS*FCV122] – ADJUSTED TO MAINTAIN PZR LEVEL		RO restores normal charging flow
	Low Steamline Press SI – BLOCKED Low PZR Pressure SI – BLOCKED		RO blocks SI Signals

Revision
----------

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	MSIVs – 1 OPEN Condenser – Available Steam DMPS – Manual Demand – Zero		Crew begins SG depressurization to less than 440 psig to establish condensate flow by dumping steam to the condenser at the max rate
	STEAM DUMPS – IN STM PRES MODE TAVG - > 541F A12-3F NOT LIT Steam Dump Rate – GRADUALLY RAISED		Crew uses SG Atmospheric Steam Dumps IF MSLI occurs
	Tavg approaches 541 F (A12-3F lit) Tavg INTERLOCK BLOCKED		BOP blocks low Tavg interlock when required
	FOLLOWING CONDITIONS ESTABLISHED:		Crew establishes condensate flow to at least one SG per <b>Attachment A-1.10</b>
	[2FWE*P23A,B] – PTL [2FWS-P21A,B] – PTL [2FWS-P24] – PTL [2FWS*FCV478,488,498] – CLOSED [2FWS-MOV154A,B,C] – CLOSED [2FWS*FCV479,489,499] – CLOSED [2FWS-MOV155A,B,C] – OPEN		
			US dispatches operators to MCCs to assist in establishing conditions per Att. A-1.10

			Revision 7	
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE	
WHEN OPEN:				
IMF VLV-CFW043 (0 0) 0	[2FWS-MOV150A] – OPEN		BOP opens [2FWS-MOV150A]	
IMF VLV-CFW044 (0 0) 0	[2FWS-MOV150B] – OPEN		BOP opens [2FWS-MOV150B]	
IMF VLV-CFW045 (0 0) 0	[2FWS-MOV152] – OPEN		BOP opens [2FWS-MOV152]	
When directed to locally close [2FWS-HCV200]:				
IRF LOA-CFW037 (0 0) 2	[2FWS-HCV200] - CLOSED		US dispatches operator to locally close [2FWS-HCV200]	
Then report valve is closed				
	[2CNM-DCV100] – OPEN		BOP checks [2CNM-DCV100] open	
	[2CNM-P21B,C] - RUNNING		BOP checks condensate pumps operating	
	SI – HAS NOT OCCURRED		Crew checks SI Status	
	[2FWS*HYV157A,B,C] – OPEN		Crew checks FWI valves open	
	[2FWS-FCV479,489,499] – Throttled open to establish feed flow to each SG		BOP operates [2FWS-FCV479,489,499] as directed to establish feed flow to each SG	

.

#### BEAVER VALLE . . OWER STATION

## 1/2 – ADM – 1357

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Level rising on [2FWS-LR477]		Crew checks SG level rising
			Crew continues with FR-H.1
	Feed Flow verified to at least one SG		Crew verifies feed flow established
	<b>IF ON SCALE</b> – SGNR Level rising in SG/SGs selected for feeding		Crew checks SGNR levels
			BOP maintains feed flow to SGs until SGNR level > 12% [31% ADVERSE CNMT] in at least one SG
	Core Exit TCs – <b>DROPPING</b> SG Wide Range Level – <b>RISING IN AT</b> LEAST ONE SG		
	Heat Sink Restored		US/Crew returns to Procedure/step in effect, returns to <b>ES-0.1</b>
Scenario may be terminated when Condensate flow is established			
Classify Event at the end of the scenario			<b>SAE Tab 2.2</b> – CSF RED PATH on HEAT SINK

Append	lix D	S	cenario Outline	Form ES-D-1
Facility Examin	: BVPS 2 lers:		Scenario No.: 4 Op Test No.: Candidates:	NRC SRO ATC BOP
Initial Conditions: Turnover:BOL, 100% power Equ Xe, CB 229, 1459 PPM IC-168Maintain current plant conditions 2CHS*P21C HHSI Pump OOS. Will be returned in approximately 1 weekCritical Tasks:1. E-0.ACrew manually trips the reactor from the control room before performing the mitigation strategy of FR-S.1.2. E-0.DCrew manually actuates at least one train of SIS-actuated safeguards before transition to any ORP.3. ECA-3.1.BCrew initiates cool down of the RCS to cold shutdown conditions at the highest rate achievable but less than 100°F per hour in all BCS cold legs				
Event No.	Malf. No.	Event Type*	Event Description	1
1	XMT-MSS042A	I(ALL) SRO T.S.	2MSS*PT446 Selected First Stage Transmitter fails LOW	Pressure
2	PMP-CHS002	C(RO/SRO) SRO T.S.	2CHS*P21B HHSI Pump trips	
3	N/A	R(RO) N(BOP/SRO)	Crew begins power reduction	
4	XMT-RCS030A	I(RO/SRO)	2RCS-PT444 PRZR Pressure Cont HIGH	rol Channel fails
5	VLV-RCS032	C(RO/SRO)	[2RCS*PCV455C] PRZR PORV s lifting, block valve closure required	ticks open after I
6	IMF PPL01A IMFPPL01B IOR XB11021T	I(RO/SRO)	Automatic reactor trip failure Manu BB 'B' UNSUCCESSFUL, Manua BB 'A' SUCCESSFUL	al RX trip from RX trip from
7	RCS04C <i>VLV-MSS003</i> <i>VLV-MSS004</i> <i>VLV-MSS005</i>	M(ALL)	350 GPM SGTR on "C" SG with a open	ll MSIVs stuck
8	PPL05A PPL05B	C(RO/SRO)	Auto SI failure, both trains, manual required	actuation

(N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor

#### Scenario Summary Scenario 4

The crew will assume the shift at 100% power BOL equilibrium xenon. HHSI pump 2CHS\*P21C is OOS. The crew is instructed maintain current plant conditions. After the crew assumes the shift, Selected first stage pressure transmitter 2MSS\*PT446 will FAIL LOW. Control rods will begin stepping inward. The crew will verify no load rejection and then place rod control to manual. The crew will then implement the actions of instrument failure procedure OM-24.4.IF Att.# 5 and stabilize the plant. The crew will swap controlling first stage pressure transmitters. After the US implements the required Technical Specification actions, HHSI pump 2CHS\*P21B will trip. The crew will implement the actions of AOP 2.7.1, Loss of Charging/Letdown. Crew will isolate letdown and start the standby HHSI pump 2CHS\*P21A. After the standby HHSI pump is started and letdown restoration is underway, and the US has implemented the appropriate Technical Specification actions, plant management will direct a power reduction to comply with the Technical Specification actions for only one operable HHSI pump. During the power reduction PRZR pressure control channel 2RCS-PT444 will FAIL HIGH. This will cause PRZR PORV 2RCS\*PCV455C to open. PRZR PORV 2RCS\*PCV455C will stick open forcing the crew to manually close the block valve. When the crew stabilizes the plant, a 350 GPM tube rupture will occur. The reactor will fail to trip automatically but can be tripped from the control room BB-A switch ONLY (BB-B switch will not work). The crew will enter E-0, Reactor Trip or Safety Injection. The actions of E-0 will be complicated by the failure of SI to automatically actuate, this will require the crew to manually actuate SI. The crew will verify ECCS equipment operating and diagnose a SGTR. The crew will transition into E-3, SGTR. The actions of E-3 will be complicated by the failure of all MSIVs to CLOSE. This will require the crew to transition into ECA-3.1, SGTR With Loss Of Reactor Coolant – Subcooled Recovery Desired. The scenario is terminated when a cooldown to mode 5 has commenced in ECA-3.1.

#### **EOP Flow Path:**

E-0, Reactor Trip or Safety Injection  $\rightarrow$  E-3, SGTR  $\rightarrow$  ECA-3.1, SGTR With Loss Of Reactor Coolant – Subcooled Recovery Desired.

Revision 7

#### **INITIAL CONDITIONS:** 100% Power, BOL, CB D = 229, 1459 PPM Boron IC-168

ADDITIONAL LINEUP CHANGES	<b>STICKERS</b>	VOND MARKINGS
EQUIPMENT STATUS	<b>DATE/TIME OOS</b>	<b>TECHNICAL SPECIFICATION(S)</b>
[2CHS*P21C]	Yesterday 1300	

#### **SHIFT TURNOVER INFORMATION**

- 1. Protected Train is Train "B"
- 2. [2CHS\*P21C] is OOS for motor replacement and will not be returned until next week
- 3. Maintain current plant conditions
- 4.

#### SCENARIO SUPPORT MATERIAL REQUIRED

Reactivity plan placard for BOL Placard for [2FWE\*P22] position stating [2FWE\*P22] is aligned to "A" header Place plaque on wall for Protected Train "B"

#### BEAVER VALLET . OWER STATION

#### 1/2 – ADM – 1357

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
Initialize IC Set 168, and establish initial plant conditions.	Reactor plant at 100% power, BOL, equilibrium conditions. RCS boron 1459 PPM, CBD = 229 steps.		
Insert the following per the Simulator Setup section of the HTML File for this	Inserts all pre-loads required to support the drill		
IMF PLP05A (0 0) 0 IMF PLP05B (0 0) 0	Auto SI failure (both trains)		
IMF VLV-MSS003 (0 0) 1 IMF VLV-MSS004 (0 0) 1 IMF VLV-MSS005 (0 0) 1	3 MSIVs fail open and cannot be closed		
IMF PPL01A (0 0) 0	Failure of auto Rx trip TRN "A"		
IMF PPL01B (0 0) 0	Failure of auto Rx trip TRN "B"		
IMF RCS04C (30 0) 350	'C' SGTR 350 gpm		
IMF VLV-RCS032 (30 0) 1	[2RCS*PCV455C] sticks open		
IMF XMT-RC\$030A (30 0) 2500	[2RCS-PT444] fails high		
IOR XB11021T (0 0) 0	Prevent manual trip from BB B		
TRGSET 1 'RRCH535 <= 0.899'	Trigger 1 on [2RCS*MOV535] position		
IMF VLV-RCS011 (1 0) 3	[2RCS*MOV535] sticks partially open until a reactor trip occurs		
TRGSET 2 'MCRFNS(3) <=225'	Trigger 2 on reactor trip		
TRG 2 'DMF VLV-RCS011'	Trigger 2 allows closure of		
	[2RCS*MOV535]		
TRGSET 3 'XB11042C == 1'	Trigger 3 on [2RCS*MOV535] switch		
	position to close		

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
IOD V010040D (2.0) 1	T 2 fails DED light on far		
IOR XB10042R (3 0) 1	Ingger 3 fails RED light on for		
TRCSFT 4 'PPCH535 <= 0.1'	Trigger 4 on [2RCS*MOV535] position		
$TROSET 4 RRCH355 \sim 0.1$	This yes 4 allows DED light to go out for		
IRG 4 DOR XB10042R	1 ngger 4 allows KED light to go out for		
Assign shift positions			
SM:			
US:			
PO:			
KO			
DOD			
BOb:			
STA:			
Conduct a shift turnover with oncoming	Simulator Frozen until after shift turnover		
operators.	unless it needs to be run momentarily for		
	an alignment change.		
When the shift turnover is completed,	Simulator running.	C	rew assumes control of the Unit.
place the simulator to RUN and			
commence the drill.			
BVPS – 2 Scenario 4	5 of 33	F	Rev. 1 (45 day submittal)

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE

# **EVENT #1:**

[2MSS\*PT446] fails low

IMF XMT-MSS042A (0 0) 0	IMMEDIATE PLANT RESPONSE:1A FIRST STAGE STM PRESS[2MSS*PI446] Ch III indicates low (VBC)(P2840D) TURB 1 <sup>ST</sup> STAGE PRESSTref (green pen) indicates 547F onrecorder [2RCS-TR408] (VB B)Control rods begin to step in at fast speedAnn A4-3C TAVG DEVIATION FROMTREF actuates (T0507D)Ann A6-12G AMSAC TROUBLE actuates(Y2522D)Panel 18 Status light D-10 STM DUMPTRIP OPEN actuates	Crew reports no load rejection, diagnose failure of [2MSS*PT446]
	Control rod motion stops	US directs RO to place control; rods in manual
AOP 2.1.3 STARTS HERE		US directs crew actions for AOP 2.1.3
	NO LOAD REJECTION	Crew reports no load rejection in progress

**Revision 7** 

#### BEAVER VALLE ... OWER STATION

## 1/2 – ADM – 1357

		-	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Rod Motion – <b>STOPPED</b>		US directs RO to place Control Rods in MANUAL
	Tavg – <b>REDUCING</b> Restore Tavg by load reduction		US directs preparation for load reduction to match Tavg/Tref
	OPERABLE PRNIS – W/I + 2% OF EACH OTHER		Crew checks core power distribution NORMAL
	CHANNEL DEVIATION light – <b>NOT</b> LIT		
	A4-4F – NIS POWER RANGE COMPARATOR – <b>NOT LIT</b>		
	Delta Flux Indicators – W/I TARGET BAND		
	Control Rod Positions – GREATER THAN RIL		RO reports Rods above RIL
	Reactor Power > 50%		RO reports power level
	QPTR in progress		STA previously directed to perform QPTR
	A4-3C TAVG DEVIATION FROM TREF – LIT (due to failed inst.)		Crew refers to ARPs as required
VPS 2 Secondria 4	7 of 33		Rev. 1 (45 day submittal)

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Power operation continues Minimize turbine load changes Adjust boron to control Tavg		US directs recovery efforts to restore Tavg/Tref
			Crew completes actions of AOP 2.1.3
	<b>180 SECONDS</b> after the transmitter failure Ann A12-1E AMSAC BYPASSED BY C-20 PERMISSIVE actuates		Crew refers to appropriate ARPs
			Crew refers to IF procedure 24.4.IF ATT 5
	[2MSS*PT446] has failed low		BOP reports [2MSS*PT446] failed low
	Control Rods previously placed in Manual		RO reports Control Rods in Manual, rod motion stopped
	[2MSS*PT447] selected A4-3C Clears (possible)		BOP selects redundant channel [2MSS*PT447] on BB C

#### BEAVER VALLE . , OWER STATION

#### 1/2 – ADM – 1357

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	[2MSS*PK464] IN Manual with zero % output signal [2MSS*PK464] setpoint adjusted for 1005		BOP places Steam Dump control in the <b>STEAM PRESSURE</b> mode
	Train A/B Steam Dump Bypass Selector Switches in OFF/RESET		
	Steam Dump Mode Selector Switch in STM PRESS		
	[2MSS*PK464] in AUTO		
	[2RCS-TI408B] Tavg Steam Dump Demand, indicates 0%		
	Train A/B Steam Dump Bypass Selector Switches in ON		
	All Steam Dumps – CLOSED		
			Crew refers to <b>20M-1.4.ACJ</b> for AMSAC restoration
	Control Rods <b>MAY</b> be returned to AUTO if desired		RO places Control Rods to AUTO IF Directed
			US refers to TS 3.3.1 and Table 3.3.1-1 Function 17.f
			<b>TS 3.3.1 W/I 1 Hr:</b> Verify interlock is in required state for existing plant conditions

\_\_\_\_\_

\_\_\_\_\_

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
When directed to locally rearm AMSAC:			US directs additional personnel to rearm AMSAC IAW <b>20M-1.4.ACJ</b>
IMF BST-PCS014 (0 0) 0	Test switch [TPS/2MSS 446] in test (up) position		
Then report actions to the Control Room	Following test lights are <b>ON:</b> [TL/2MSS446] [TL/2MSS447] [TL/2MSS440A] (2/2 impulse pres ≥ 40%) [TL/2MSS440B] (C-20 permissive)		
	Ann A12-1E AMSAC BYPASSED BY C- 20 PERMISSIVE clears		
Proceed with the next event at LE discretion			

**Revision 7** 

INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
EVENT #2:			
	<b>IMMEDIATE PLANT RESPONSE:</b>		
2CHS*P21B Trips	[2CHS*P21B] bright white LIT (BB A)		
IMF PMP-CHS002 (0 0) 1	[2CHS*II21B] 21B CHG Pump Amps indicates 0 (VB A)		Crew diagnose trip of [2CHS*P21B]
	[2CHS*FI122A] charging flow indicates 0 (VB A)		
Role-play field operator and report	[2CHS*FI130A, FI127A, FI124A],RCPs Seal injection indicates 0 (VB A) Annunciators Actuate:		US dispatch personnel to investigate the loss of [2CHS*P21B]
motor ground.	A2-3D CHARGING PUMP AUTO- START/AUTO-STOP (Y0116D)		
	A2-3E CHARGING FLOW PATH TROUBLE (F0101D)		
	A2-4D REACTOR COOLANT PUMP SEAL TROUBLE(F0112D, F0116D, F0118D)		
	[2CHS*TI140] Regen HX Letdown Temp begins to increase (VB A)		
	[2CHS*TI144] Letdown Temp begins to increase (VB A)		
	[2RCS*LI459A, LI461, LI460] PZR level CH I, III, II begin to decrease (BB B)		
	DELAYED RESPONSE: Ann A2-3F LETDOWN FLOW PATH TROUBLE actuates (T0127D)		

**Revision 7** 

#### BEAVER VALLE . .- OWER STATION

# 1/2 – ADM – 1357 Conduct of Simulator Training

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Charging Pumps – <b>NONE</b> RUNNING		US implements AOP 2.7.1 Loss of Charging/Letdown
	[2CHS*AOV200A,B,C] - CLOSED		RO closes L/D orifice isolation valves
	[2CHS*LCV115C,E] - OPEN		RO verifies CHP suction valves from VCT open
	VCT Level – NORMAL VCT Pressure – NORMAL		Crew verifies CHP <b>did not trip/stop</b> due to cavitation
	[2CHS*FCV122] - CLOSED		RO closes charging pumps discharge flow control valve
	[2CHS-HCV186] - CLOSED		RO closes RCP seal injection flow controller
	[2CHS*P21A] – RUNNING		RO starts the standby charging pump
	[2CHS*P21B] – PTL		RO places tripped charging pump in PTL
	[2CHS-HCV186] adjusted to obtain 6 to 9 gpm on [2CHS-FI130A, 127A, 124A]		RO adjusts RCP seal injection flow to 6 to 9 gpm for each RCP
	[2CHS*FCV122] adjusted as required to restore PZR level AND THEN placed in AUTO		RO adjusts charging pump discharge flow control valve to restore level as required and then places valve in auto
BVPS – 2 Scenario 4	12 of 33		Rev. 1 (45 day submittal)

#### BEAVER VALLE . . OWER STATION 1/2 - ADM - 1357

		•	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
After appropriate delay report that [2CHS*P21A] is operating properly	[2CHS*P21A] operating properly		US dispatch operator to ensure proper operation of [2CHS*P21A]
			US directs operators to restore Letdown flow IAW <b>20M-7.4.AB</b>
	[2CHS*FCV122] - CLOSED		RO places [2CHS*FCV122] in manual and closes the valve
	[2CHS*MOV289] - OPEN		RO verifies [2CHS*MOV289] open
	[2CHS*MOV310] - OPEN		RO verifies [2CHS*MOV310] open
	[2CHS*FCV122] throttled to obtain 30 – 50 gpm on [2CHS*FI122] (VB A)		RO throttles charging pump discharge flow control valve open to provide 30 – 50 gpm flow as indicated on [2CHS*FI122] (VB A)
	[2CHS*AOV200A, B, C] - CLOSED		RO verifies 3 L/D isolation valves are closed
	[2CHS*AOV204] - OPEN		RO verifies the NRHX L/D inlet valve is open (BB A)
	[2CHS*PCV145] – IN MANUAL AND ADJUSTED TO 50% OPEN DEMAND SIGNAL (BB A)		RO place NRHX Disch Pres control valve in MANUAL and adjusts for 50% output demand

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	[2CHS*MOV100A] – OPEN [2CHS*MOV100B] – CLOSED		RO verifies positions of [2CHS*MOV100A], [2CHS*MOV100B]
	[2CHS*LCV460A, B] - OPEN		RO verifies Regen HX L/D Inlet valves open
	[2CHS*AOV200A, B] - OPEN		RO opens L/D isol valves to establish L/D flow at previous value
	[2CHS*PCV145] adjusted to maintain 260 psig as indicated on [2CHS*PI145] SETPOINT of [2CHS*PCV145] - SET		RO establishes automatic control of letdown flow
	FOR 260 PSIG		
	[2CHS*PCV145] – PLACED IN AUTO		US directs personnel to perform <b>20ST-6.4</b>
	[2CHS*FCV122] – PLACED IN AUTO		
	PZR level trending to normal		RO monitors PZR level for proper response
## BEAVER VALLE , . OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		Ū.	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
			US refers to TS 3.5.2, 3.5.3 and LRM 3.1.3, 3.1.4
			<b>TS 3.5.2:</b> 2 ECCS TRAINS SHALL BE OPERABLE: Restore 2 Trains W/I 72 Hrs <u>OR</u>
			MODE 3 W/I 6 Hrs
			OR
			MODE 4 W/L12 Hrs
			TS 3.5.3: Applicable MODE 4 ONLY
			LRM 3.1.3: Applicable MODE 5 ONLY
			LRM 3.1.4: 2 Charging Pumps SHALL be OPERABLE MODE 1 – 4: Restore two pumps to OPERABLE status W/I 72 Hrs OR MODE 3 W/I 6.0 Hrs AND borated to SDM of 1% DK/K at 200E AND restore the
			required charging pump to OPERABLE status W/I 174 Hrs
When informed as plant management, direct the US to begin power reduction at 12 % hr			US informs plant management of the loss of [2CHS*P21B] and the requirement to S/D due to the status of [2CHS*P21C]

### BEAVER VALLE . . OWER STATION 1/2 -- ADM -- 1357 Conduct of Simulator Training

		-	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
<u>EVENT #3:</u>			Crew develops a reactivity plan for power reduction of 12%/hr
Normal Power reduction			US contacts Reactor Engineering for a complete reactivity plan to complete the load reduction
After appropriate delay, provide the crew with a reactivity plan that will allow the continued power reduction			Crew refers to <b>20M-52.4.B</b> Load Follow for the load reduction
	Turbine control – 1 <sup>ST</sup> STG OUT		BOP verifies turbine control in 1 <sup>st</sup> STG OUT mode
	Setter – SET TO LOWER VALUE		BOP sets the EHC SETTER to a lower value as directed by the US
	1%/min selected		BOP selects 1%/min load rate on EHC panel
	Turbine load – REDUCING		BOP depresses the GO pushbutton on the EHC control panel when directed
	Blender controls set as desired per the reactivity plan		RO sets the blender controls for the desired boration rate/amount as determined by the reactivity plan

# BEAVER VALLEY ,-OWER STATION

1/2 – ADM – 1357

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	<u>MAINTAIN</u> : Tavg/Tref W/I ± 2F AFD W/I limits of CB-14 (TS 3.2.3 'AXIAL FLUX DIFFERENCE') Control Rods ABOVE RIL as defined by COLR Fig 4.1-1 VPL at 5% above turbine load Generator parameters W/I limit of 'Calculated Capability Curve' 2OM- 52.5.A.5 (Figure 52-5) between a power		Crew maintains plant/turbine & generator parameters as specified by <b>2OM-52.4.B</b> during the load reduction
	factor of 0.90 lagging and 1.0		
	[2GSS-MOV204] – ADJUSTED as necessary to maintain gland steam pressure		
	Power – LESS THAN 98%		BOP stops load reduction by pushing HOLD PB on EHC control panel
	Turbine Control – Transferred to 1 <sup>st</sup> STG IN mode		BOP transfers turbine control to 1 <sup>st</sup> STG IN mode by pushing the 1 <sup>st</sup> STG IN PB on EHC control panel
	Turbine Load – REDUCING		BOP pushes GO PB on EHC control panel When Directed to resume load reduction
Continue with next set of events at LE discretion:			

#### BEAVER VALLE . . ·OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

	INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
--	--------------------------	--------------------------	-----------	---------------------------

**NOTE:** the following Events #4 through 7 will occur **simultaneously**. All commands are **PRE-LOADED** and will actuate when **Trigger 30** is fired

## EVENTS#4, 5,6 7

### **IMMEDIATE PLANT RESPONSE:**

Annunciators actuate:

(4)
[2RCS-PT444] Fails high
IMF XMT-RCS030A (30 0) 2500
(5)
[2RCS\*PCV455C] Sticks open
IMF VLV-RCS032 (30 0) 1
(6)
Automatic reactor trip failure
IMF PPL01A (0 0) 0

IMF PPL01B (0 0) 0 Manual trip from BB B unsuccessful

IOR XB11021T (0 0) 0

(7) 350 GPM SGTR on "C" SG IMF RCS04C (30 0) 350

A4-1D PRESSURIZER CONTROL PRESSURE HIGH/LOW (P0501D) A4-1E PRESSURIZER CONTROL PRESSURE DEVIATION HIGH/LOW(P0503D) A4-2F PRESSURE RELIEF BLOCK (P0496D) A4-1A PRESSURIZER POWER/SAFETY **RELIEF TROUBLE (T0480D)** A4-1F - PRESSURIZER PORV OPEN PERMISSIVE (Y6672D) (immediate reset) A2-4B REACTOR COOLANT SYSTEM SUBCOOLING OFF NORMAL (T0761D) A4-5A RADIATION MONITORING SYSTEM TROUBLE (R0003D) A4-5C RADIATION MONITORING LEVEL HIGH (R0004D)

Revision 7

### BEAVER VALLE . . OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
WHEN DIRECTED:			
TRG! 30			
	[2RCS*LI459A, LI461, LI460] PZR level CH I, III, II begin to decrease (BB B)		
	[2RCS*PI455, PI456, PI457] PZR pres CH I, II, III begin to decrease (BB B)		
	[2RCS-PI445] PZR control pres indicator begins to decrease (VB B)		
	[2RCS-PR441] RCS Wide range pressure recorder red/green pens begin to decrease (VB A)		
	RCS pressure rapidly reducing		RO verifies alarms, diagnose [2RCS- PT444] has failed high
	[2RCS*PCV455A,B] – CLOSED		RO closes Spray Valves, reduces MPC output to 0
EVENT #5	[2RCS*PCV455C] – <b>STUCK OPEN</b>		RO attempts to close [2RCS*PCV455C] reports it <b>does not close</b>
	[2RCS*MOV535] – TRAVELING CLOSED		RO closes [2RCS*MOV535]

# BEAVER VALLEY -- OWER STATION

# 1/2 – ADM – 1357

Conduct of Simulator Training

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	<u>1<sup>ST</sup> OUT ANNUNCIATOR:</u> A5-4H PRESSURIZER PRESSURE LOW REACTOR TRIP (P0488D)		RO Reports 1 <sup>st</sup> OUT Annunciator A5-4H
<u>EVENT #6</u>	Reactor – NOT TRIPPED		RO reports failure of automatic trip
<b><u>CRITICAL TASK</u></b> Crew manually trips the reactor from the control room before performing the mitigation strategy of FR-S.1.			
<u>EVENT #6</u>	Reactor – NOT TRIPPED		Ro attempts manual trip from BB B, reports UNSUCCESSFUL
<u>EVENT #6</u>	Reactor – TRIPPED		Ro attempts manual trip from BB A, reports <b>SUCCESSFUL</b>
	[2RCS*MOV535] – CLOSED		RO reports [2RCS*MOV535] closed after reactor trip
<u>EVENT #7</u>	RCS Pressure <b>APPEARS</b> to recover until the effects of the SGTR are seen		RO monitors RCS pressure and MAY report that it is recovering until the SGTR effects are seen
Crew enters <b>E-0</b> , performs immediate operator actions.			Crew performs IMAs of <b>E-0</b> .

Γ

### OWER STATION ، OWER STATION

## 1/2 – ADM – 1357

		•	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Annunciator A5-6D TURBINE TRIP DUE TO REACTOR TRIP - LIT Power range indication - LESS THAN 5%		RO verifies reactor tripped.
	Neutron flux - DROPPING Throttle Valves - ALL CLOSED OR Governor Valves - ALL CLOSED Main Generator Output Bkrs - OPEN Exciter Circuit Bkr - OPEN		BOP verifies turbine tripped.
	AC Emergency Busses - BOTH ENERGIZED		BOP verifies power to AC Emergency Buses.
	Check SI ACTUATED CNMT Pressure - > 5PSIG PZR Pressure - < 1860 PSIG SG Steam Pressure - < 500 PSIG		RO checks SI status CREW DETERMINES SI REQUIRED
Crew continues E-0	Manually actuate SI (both trains)		RO manually actuates SI both trains
	Alert Plant Personnel		RO/BOP sound Standby Alarm, announce reactor trip and safety injection

### BEAVER VALLEY POWER STATION 1/2 - ADM - 1357

Conduct of Simulator Training

		Ũ	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Check [2HVS*FN204A(B)], Leak Collection Filtered Exhaust Fan – AT LEAST ONE RUNNING		BOP checks Leak Collection Exhaust Fan status
<u>EVENT #8:</u>	Charging Pumps – <b>ONE</b> RUNNING HHSI Flow – INDICATED		RO verifies SI System status, reports auto SI failure on <b>BOTH</b> Trains, <b>MANUALLY</b>
(PRE-LOADED)	LHSI Pumps – TWO RUNNING		actuates both trains of St
Both trains of auto SI fail to actuate, manual actuation successful	BOTH TRAINS OF AUTO SI FAILURE		
IMF PLP05A (0 0) 0 IMF PLP05B (0 0) 0	ONLY ONE HHSI PUMP OPERATING		
<b><u>CRITICAL TASK</u></b> Crew manually actuates at least one train of SIS-actuated safeguards before transition to any ORP.			
	Motor-driven AFW Pumps – RUNNING Turb driven AFW Pump Stm Supply Isol Valves – OPEN AFW Throttle Vlvs – FULL OPEN Total AFW Flow – GREATER THAN 340 GPM		BOP verifies AFW System status

ŝ.

#### BEAVER VALLE . , OWER STATION

1/2 – ADM – 1357

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Perform Attachment A-0.11 "Verification Of Automatic Actions" in a timely manner		US directs performance of Attachment A- 0.11 when time/manpower permit
Attachment A-0.11 is included and begins on page 31 of scenario	LIST ATT A-0.11 DISCREPANCIES AS APPLICABLE:		
	Manual SI required – BOTH TRAINS ONLY ONE HHSI PUMP RUNNING		
	<b>RCPs OPERATING – MONITOR Tavg</b> RCPs STOPPED MONITOR Tcold		RO/BOP check RCS Tavg stable at or trending to 547°F
	Check CIB – HAS NOT ACTUATED		RO checks Recirc Spray Pump status
	PORVs – 2 CLOSED – [2RCS*PCV455C] Stuck OPEN, ISOL by [2RCS*MOV535]		RO verifies PZR isolated
	Spray Valves – CLOSED Safety relief valves – (PSMS Detailed Data Page 1) – CLOSED		
	Check PRT conditions – CONSISTENT WITH <b>EXPECTED</b> VALUES		
	Power to at least one block valve – AVAILABLE		
	Block valves – AT LEAST ONE OPEN		

# BEAVER VALLE ... OWER STATION 1/2 - ADM - 1357

Conduct of Simulator Training

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	D/P between RCS pressure and highest SG pressure – LESS THAN 205 PSID [220 PSID ADVERSE CNMT] AND HHSI Flow – INDICATED		RO checks if RCPs should be stopped <b>RO DOES NOT STOP RCPs</b>
	Pressures in all SGs – ANY DROPPING IN AN UNCONTROLLED MANNER		BOP checks if any SGs are faulted.
	OR ANY SG COMPLETELY DEPRESSURIZED		BOP REPORTS SGs NOT FAULTED
	Check all SG levels – <b>"C" IS</b> RISING IN AN UNCONTROLLED MANNER		Crew checks if SG tubes are intact
	Check Secondary Radiation – CONSISTENT WITH PRE-EVENT VALUES [2ARC-RQ100] Air Ejector Discharge (1007)		CREW REPORTS INDICATION OF SGTR ON "C" SG
	[2SSR-RQ100] SG Blowdown Sample (1062)		
	[2MSS*RQ101A,B,C] Main Steamline Discharge (1005, 3005, 5005)		
Crew transitions to E-3 STEP 1			US directs transition to E-3

US directs STA to monitor status trees

### BEAVER VALLE ה-OWER STATION 1/2 - ADM - 1357

	0	Revision 7
PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
CREVS not actuated		BOP checks if CREVS should be activated
CR radiation not in high alarm		
CIB has not occurred		Crew commences control room ventilation action per Attachment A-2.5
D/P between RCS pressure and highest SG pressure – LESS THAN 205 PSID [220 PSID ADVERSE CNMT]		RO checks if RCPs should be stopped
AND		
HHSI Flow – INDICATED		RO does not stop RCPs
"C" SG ruptured		US identifies "C" SG as the ruptured SG
Unexpected rise in NR level		
Rad survey results:		
ANY SAMPLE		
[2MSS*RQ102A,B,C] SG N-16 monitors (1075, 2075, 3075)		
[2MSS*RQ101A,B,C] Main Stm Monitors		
(1005, 3005, 5005)		
High Radiation from any SG BD rad		
monitor		
	PLANT STATUS OR RESPONSECREVS not actuatedCR radiation not in high alarmCIB has not occurredD/P between RCS pressure and highest SG pressure – LESS THAN 205 PSID [220 PSID ADVERSE CNMT] AND HHSI Flow – INDICATED"C" SG rupturedUnexpected rise in NR levelRad survey results: ANY SAMPLE [2MSS*RQ102A,B,C] SG N-16 monitors (1075, 2075, 3075) [2MSS*RQ101A,B,C] Main Stm Monitors (1005, 3005, 5005) 	PLANT STATUS OR RESPONSE       OBJECTIVE         CREVS not actuated       CR radiation not in high alarm         CIB has not occurred       CIB has not occurred         D/P between RCS pressure and highest SG pressure – LESS THAN 205 PSID [220         PSID ADVERSE CNMT]         AND         HHSI Flow – INDICATED         "C" SG ruptured         Unexpected rise in NR level         Rad survey results:         ANY SAMPLE         [2MSS*RQ102A,B,C] SG N-16 monitors         (1005, 3005, 5005)         High Radiation from any SG BD rad monitor

### BEAVER VALLE ... OWER STATION 1/2 - ADM - 1357 Conduct of Simulator Training

		5	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
IF REQUESTED:	Close atmospheric steam dump on ruptured SG [2SVS*PCV101C]		US directs crew to isolate flow from the ruptured SG BOP closes "C" SG atmospheric steam dump [2SVS*PCV101C] Setpoint raised to 100%
To close [2SVS*25]			
	Check Residual Heat Release valve – CLOSED		BOP closes [2SVS*HCV104].
IRF LOA-MSS011 (0 0) 0	Check Residual Heat Release Valve from faulted SG CLOSED:		Crew dispatch operator to close [2SVS*29]
To close [2SVS*29]	SG 21A [2SVS*29]		
	2 RUNNING		BOP checks motor driven AFW pumps
	[2MSS*SOV105C & F] CLOSED		BOP closes [2MSS*SOV105C & F]
	SG-21C blowdown isol valve [2BDG*AOV100C1] CLOSED		BOP closes SG 21C blowdown isol vlv
	SG-21C Main Stm Line drain [2SDS*AOV111C1] CLOSED		BOP closes SG 21C main steamline drain vlv
	RHR Piping Drain [2SDS*AOV129A] CLOSED		BOP closes RHR Piping drain vlv

### BEAVER VALLEY ~OWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

			Revision 7	
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE	
EVENT #7 (continued):	3 BVPASS VLVS - CLOSED		BOP reports Bypass valves closed	
(PRE-LOADED)				
3 MSIVs Stuck open	NO MSIVs can be closed		BOP reports that all <b>3 MSIVs</b> are stuck open and cannot be closed	
IMF VLV-MSS003 IMF VLV-MSS004 IMF VLV-MSS005			RUPTURED SG CANNOT BE ISOLATED FROM 1 INSTACT SG, GO TO ECA-3.1	
Crew transitions to ECA-3.1 Step 1				
	SI, CIA & CIB - RESET		RO resets SI, CIA & CIB	
	Open [2CCS-AOV118] Domestic Water to Station Air Compressor		Establish Domestic Water System Cooling to Station Air Compressors	
			US directs additional personnel to perform <b>Att A-1.20</b> as manpower permits	
	At least one Station Air Compressor – RUNNING		Start 1 Station Air Compressor as required	

## BEAVER VALLE . , OWER STATION

### 1/2 – ADM – 1357 Conduct of Simulator Training

		-	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	[2IAC-MOV131] & [2IAC*MOV130] – OPEN		Crew establishes Inst Air to CNMT
	CNMT Inst Air Press > 85 PSIG		
	All AC Busses – ENERGIZED BY OFFSITE POWER		BOP checks 4KV electrical status
	All PZR HTRS – PULL TO LOCK		RO places PZR HTRS in PTL
	Quench/Recirc Spray Pumps - NONE RUNNING		Crew checks if CNMT spray should be stopped
	"C" SG level > 12% [31% ADVERSE CNMT]		BOP checks ruptured SG level
	[2FWE*HCV100A,B] - CLOSED		Crew isolates feed flow to "C" SG
	[2FWS*HYV157C] CLOSED		Check FWI previously verified

## BEAVER VALLEY POWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	RCS Pressure - > 225 PSIG [250 PSIG ADVERSE CNMT]		RO checks if LHSI Pmps should be stopped
	Pressure – STABLE OR RISING		
	LHSI Pmps stopped and in auto		RO stops LHSI Pmps and places them in auto
	Aux Bldg/Safeguards radiation – CONSISTENT WITH PRE-EVENT LEVELS		Crew evaluates plant status
	Obtain Pertinent samples		
	Pressures in all SGs – ANY DROPPING IN AN UNCONTROLLED MANNER		BOP checks if any SGs are faulted.
	OR ANY SG COMPLETELY DEPRESSURIZED		Crew checks faulted SGs previously isolated unless needed or C/D
	SGs ARE NOT FAULTED		
	Total AFW flow maintained >340 GPM until SG level > 12% [31% adverse CNMT] THEN CONTROL AFW flow to maintain level between 26% [33% adverse CNMT] and 50%		BOP checks intact SG levels, controls AFW flow to intact SGs

### BEAVER VALLE - POWER STATION 1/2 - ADM - 1357 Conduct of Simulator Training

		•	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
	Shutdown margin requirements are satisfied for cooldown		US directs chemistry to sample as required, Crew maintains SDM during C/D
<u>CRITICAL TASK</u>	C/D rate - < 100F/Hr		Crew initiates cooldown to MODE 5 at <
Crew initiates cool down of the RCS to cold shutdown conditions at the highest	Trend initiated/initialed at 1/2 hr interval		100F/hr
	RHR used if in service		
hour in all RCS cold legs.	SI blocked when PZR Pres < 2000 PSIG		
	Condenser Stm Dmps operated in		required to maintain C/D rate W/I limits
	Taya interlock blocked < 541F		
	Tavg interfock offered < 5411		
Terminate drill after proper C/D rate established or at LE discretion	RWST Level - $> 600$ inches		Crew checks if subcooled recovery desired
	Ruptured (C) SG level - < 95% [79% ADVERSE CNMT]		
			IF NOT TRANSITION TO ECA 3.2 STEP
			I

Classify event at the end of the scenario

ALERT based on TAB 2.3 entry into E-3

### BEAVER VALLE , POWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE OBJECTIVE	EXPECTED STUDENT RESPONSE
Attachment A-0.11 'Verification of Automatic Actions' performed as time & manpower permit		US directs operator to perform Attachment A-0.11 as time & manpower permit
	Diesel generators – BOTH RUNNING	Check both EDGs running
	CNMT pressure – GREATER THAN 7 PSIG	Check if MSLI is required
	OR	If not required go to step 4
	SG Steam Pressure – LESS THAN 500 PSIG OR	n not required, 50 to stop 1
	Steamline pressure high rate of change – 100 PSIG DROP IN 50 SECONDS	
	Yellow SLI marks - LIT	Verify steamline isolation
STEP 4	Open [2CCS-AOV118] Domestic Water to Station Air Compressor	Establish Domestic Water System Cooling to Station Air Compressors
	At least one Station Air Compressor – RUNNING	Start 1 Station Air Compressor as required
	CCP pumps – AT LEAST 1 RUNNING	Check CCP Pump status
BVPS – 2 Scenario 4	31 of 33	Rev. 1 (45 day submittal)

### BEAVER VALLEY POWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		0	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE EXPECTED STUDENT RE	SPONSE
	[2NME-NR45] Nuclear Recorder selected to operable source and intermediate range displays	Align neutron flux monitoring	for shutdown
	CNMT pressure – HAS REMAIND LESS THAN 11 PSIG	Check CIB status	
	IF NOT	Actuate CIB if required	
	Manually initiate CIB – BOTH SWITCHES FOR BOTH TRAINS		
	Manually align equipment as required All RCPs – STOPPED BV-1 operator verifies CREVS actuation Service water established to RSS HX(s)	Stop ALL RCPs	
	Service Water Pumps – 2 RUNNING Service Water Header Pressure – GREATER THAN 55 PSIG SWS Seal Water Pressure – NOT LOW	Verify Service Water System i	n service
	[2HCS*SOV100A1, B1] – CNMT Sample amber light – LIT	Verify both CNMT hydrogen a running	ınalyzers

.

## BEAVER VALLE . POWER STATION 1/2 – ADM – 1357 Conduct of Simulator Training

		-	Revision 7
INSTRUCTIONAL GUIDELINES	PLANT STATUS OR RESPONSE	OBJECTIVE	EXPECTED STUDENT RESPONSE
MANUAL SI REQUIRED ONLY ONE HHSI PMP RUNNING	All Red SIS Marks - LIT All Orange CIA Marks – LIT All Green FWI Marks – LIT		Verify ESF Equipment status – Start/align equipment as required
	Power available to both Emergency AC Busses		Verify power to both AC Emergency busses
			Restore power as required
	Attachment A-0.11 – COMPLETE		Report any discrepancies to SM/US

÷