FirstEnergy Nuclear Operating Company

5501 North State Route 2 Oak Harbor, Ohio 43449

Barry S. Allen Vice President - Nuclear 419-321-7676 Fax: 419-321-7582

December 16, 2008 L-08-317

ATTN: Document Control Desk U. S. Nuclear Regulatory Commission Washington, DC 20555-0001

SUBJECT: Davis-Besse Nuclear Power Station, Unit 1 Docket Number 50-346, License No. NPF-3 <u>Core Operating Limits Report and</u> Pressure and Temperature Limits Report

Enclosed please find the current Davis-Besse Nuclear Power Station, Unit 1 (DBNPS) Core Operating Limits Report (COLR) and the Pressure and Temperature Limits Report (PTLR). Both reports support the implementation of License Amendment No. 279, Improved Technical Specifications. Enclosure 1 contains the COLR and is submitted in accordance with the DBNPS Technical Specification 5.6.3. Enclosure 2 contains the PTLR and is submitted in accordance with the DBNPS Technical Specification 5.6.4.

There are no regulatory commitments contained in this letter. If there are any questions or if additional information is required, please contact Mr. Thomas A. Lentz, Manager – Fleet Licensing, at (330) 761-6071.

Sincerely,

Bary S. Alle

Barry S. Allen

Enclosures:

- A. FirstEnergy Nuclear Operating Company, Davis-Besse Unit 1, Cycle 16, Core Operating Limits Report, Revision 2
- B. FirstEnergy Nuclear Operating Company, Davis-Besse Unit 1, 21 Effective Full Power Years Pressure and Temperature Limits Report, Revision 0



Davis-Besse Nuclear Power Station, Unit 1 L-08-317 Page 2

.

.

cc: NRC Region III Administrator NRC Resident Inspector NRR Project Manager Utility Radiological Safety Board Enclosure A L-08-317

• •

FirstEnergy Nuclear Operating Company, Davis-Besse Unit 1, Cycle 16, Core Operating Limits Report, Revision 2

.

(34 Pages)

Cycle 16 COLR Page 1 of 34 Revision 2

FIRSTENERGY NUCLEAR OPERATING COMPANY

DAVIS-BESSE UNIT 1

CYCLE 16

CORE OPERATING LIMITS REPORT

D. B. Kelley 9/11/08 Prepared by 9 and £1 Reviewed by P. R. Gilles 9/2/08 Approved by Berland

LIST OF EFFECTIVE PAGES

Page 1 through 34 Rev. 2

1.0 Core Operating Limits

This CORE OPERATING LIMITS REPORT for DB-1 Cycle 16 has been prepared in accordance with the requirements of Improved Technical Specification 5.6.3. The Core Operating Limits have been developed using the methodology provided in reference 2.0 (1). The licensed length of Cycle 16 is 730 EFPDs (based on a reactor thermal rating of 2817 MWt).

The following cycle-specific core Operating Limits, Protective Limit and Flux - Δ Flux - Flow Reactor Protection System Allowable Values are included in this report:

- 1. SL 2.1.1.1 Reactor Core Safety Limits
- 2. LCO 3.1.1 SHUTDOWN MARGIN (SDM)
- 3. LCO 3.1.3 Moderator Temperature Coefficient (MTC)
- 4. LCO 3.1.7 Position Indicator Channels
- 5. LCO 3.1.8 PHYSICS TESTS Exceptions MODE 1
- 6. LCO 3.1.9 PHYSICS TESTS Exceptions MODE 2
- 7. LCO 3.2.1 Regulating Rod Insertion Limits
- 8. LCO 3.2.2 AXIAL POWER SHAPING ROD (APSR) Insertion Limits
- 9. LCO 3.2.3 AXIAL POWER IMBALANCE Operating Limits
- 10. LCO 3.2.4 QUADRANT POWER TILT (QPT)
- 11. LCO 3.2.5 Power Peaking Factors
- 12. LCO 3.3.1 Reactor Protection Systems (RPS) Instrumentation

Function 8: (Flux - ∆Flux – Flow) Allowable Value

- 13. LCO 3.9.1 Boron Concentration
- 14. TRM 8.1.3 Rod Program

2.0 References

- 1) BAW-10179P-A, Rev. 6, "Safety Criteria and Methodology for Acceptable Cycle Reload Analyses", August, 2001.
- BAW-10164P-A, Rev. 6, "RELAP5/MOD2-B&W An Advanced Computer Program for Light Water Reactor LOCA and Non-LOCA Transient Analysis", June, 2007.
- 3) BAW-10243P-A, "Statistical Fuel Assembly Hold Down Methodology", September, 2005.

Table of Contents

• •

| . | | Page |
|----------------------------------|--|---------|
| Reactor Core Figure 1 | a Safety Limits AXIAL POWER IMBALANCE Protective Limits | 5 |
| SHUTDOWN Table 1 | MARGIN (SDM) Shutdown Margin Requirements | 6 |
| Moderator Te Table 2 | mperature Coefficient (MTC) Moderator Temperature Coefficient Limit | 7 |
| Position India Table 3 | cator Channels Absolute Position Indicator (API) / Relative Position Indicator (RPI) Agreement Limit |) 8 |
| Regulating R Figure 2a | od Insertion Limits Regulating Group Position Operating Limits – Four RC Pumps From 0 to 300 ± 10 EFPD | 9 |
| Figure 2b | Regulating Group Position Operating Limits – Four RC Pumps After $300 \pm 10 \text{ EFPD}$ | 10 |
| Figure 2c | Regulating Group Position Operating Limits – Three RC Pumps From 0 to $300 \pm 10 \text{ EFPD}$ | 11 |
| Figure 2d | Regulating Group Position Operating Limits – Three RC Pumps After 300 ± 10 EFPD | 12 |
| AXIAL POWE Figure 3 | R SHAPING ROD (APSR) Insertion Limits APSR Position Operating Limits – 2817 MWt RTP | 13 |
| AXIAL POWE Figure 4a | R IMBALANCE Operating Limits AXIAL POWER IMBALANCE Operating Limits – Four RC Pumps From 0 to 350 ± 10 EFPD | 14 |
| Figure 4b | AXIAL POWER IMBALANCE Operating Limits – Four RC Pumps From 350 ± 10 to 600 ± 10 EFPD | 15 |
| Figure 4c | AXIAL POWER IMBALANCE Operating Limits – Four RC Pumps After 600 ± 10 EFPD | 16 |
| Figure 4d | AXIAL POWER IMBALANCE Operating Limits – Three RC Pumps From 0 to 350 ± 10 EFPD | s 17 |
| Figure 4e | AXIAL POWER IMBALANCE Operating Limits – Three RC Pumps From 350 ± 10 to 600 ± 10 EFPD | s 18 |
| Figure 4f | AXIAL POWER IMBALANCE Operating Limits – Three RC Pumps After 600 ± 10 EFPD | s 19 |
| QUADRANT Table 4 | POWER TILT (QPT) QUADRANT POWER TILT Limits – 2817 MW | 20 |

| Power Peaki | ng Factors | |
|--------------------------|---|----|
| Table 5 | Power Peaking Factors – F _Q (NAS) | 21 |
| Table 6 | Power Peaking Factors – F _Q (FIDMS) | 24 |
| Table 7 | Power Peaking Factors - F ^N _{ΔH} | 28 |
| Figure 5 | Maximum Allowable Radial Peak For F ^N ΔH in Mark-B Fuel Assemblies | 28 |
| Figure 6 | Maximum Allowable Radial Peak For F ^N ΔH in Mark-B-HTP Fuel Assemblies | 29 |
| Table 8 | Maximum Allowable Radial Peak For F ^N ΔH in Mark-B Fuel Assemblies | 30 |
| Table 9 | Maximum Allowable Radial Peak For F ^N дн in Mark-B-HTP Fuel Assemblies | 31 |
| Reactor Prot Figure 7 | ection System (RPS) Instrumentation Flux-ΔFlux-Flow (or Power/Imbalance/Flow) Allowable Values | 32 |
| Boron Conce Table 10 | entration Refueling Boron Concentration Limit | 33 |
| Rod Program Figure 8 | Control Rod Core Locations and Group Assignments | 34 |

.

•



Figure 1 AXIAL POWER IMBALANCE Protective Limits 2817MWt RTP

.

Table 1 Shutdown Margin Requirements

.

| APPLICABILITY | REQUIRED SHUTDOWN MARGIN | IMPROVED TECHNICAL SPECIFICATIONS LCO REFERENCE |
|--------------------------------------|-----------------------------|---|
| MODE 1* | ≥ 1 %∆k/k | 3.1.4, 3.1.5 |
| MODE 2* | ≥ 1 %∆k/k | 3.1.4, 3.1.5, 3.3.9 |
| MODE 3 | ≥ 1 %∆k/k | 3.1.1, 3.3.9 |
| MODE 4 | ≥ 1 %∆k/k | 3.1.1, 3.3.9 |
| MODE 5 | ≥ 1 %∆k/k | 3.1.1, 3.3.9 |
| MODE 1 PHYSICS TESTS Exceptions** | ≥ 1 %∆k/k | 3.1.8 |
| MODE 2 PHYSICS TESTS Exceptions | ≥ 1 %∆k/k | 3.1.9 |

Verify SHUTDOWN MARGIN per the table below.

* The required Shutdown Margin capability of 1%∆k/k in MODE 1 and MODE 2 is preserved by the Regulating Rod Insertion Limits specified in Figures 2a through 2d as required by Improved Technical Specification 3.2.1.

** Entry into Mode 1 Physics Tests Exceptions is not supported by existing analyses (Regulating Rod Shutdown Margin Insertion Limits assumptions may not be met) and as such requires actual shutdown margin to be \geq 1 % Δ k/k (via alternate verification or calculation).

Table 2 Moderator Temperature Coefficient Limit

These limits are referred to by Improved Technical Specifications 3.1.3

- 1. <u>Lower Limit:</u> MTC at HFP $\geq -3.76 \times 10^{-4} \Delta k/k/^{\circ}F$
- <u>The following Upper Limits may not be exceeded without prior NRC approval:</u> MTC <0.9 x 10⁻⁴ Δk/k/°F when Thermal Power <95% RTP MTC <0.0 x 10⁻⁴ Δk/k/°F when Thermal Power ≥95% RTP
- 1.0E-04 :9:0E-05 Moderator Temperature Coefficient .8.0E-05 7.0E-05 6.0E-05 (∆k/k/°F) 5:0E-05 4:0E-05 3 0E-05 2.0E-05 1:0E-05 0.0E+00 20 :40 *.*60 800 100 .0 Percent Full Power
- 3. The following Upper Limits may not be exceeded for operation in Modes 1 and 2:

Table 3 Absolute Position Indicator (API) / Relative Position Indicator (RPI) Agreement Limit

• •

This limit is referred to by Improved

Technical Specifications 3.1.7

The absolute position indicator channels and the relative position indicator channels agree within 3.46%.



Note 1: A Rod Group overlap of 25 +/- 5% between sequential withdrawn groups 5 and 6, and 6 and 7, shall be maintained. Note 2: Instrument error is accounted for in these Operating Limits.

Cycle 16 COLR Page 10 of 34 Revision 2



Note 1: A Rod Group overlap of 25 ±5% between sequential withdrawn groups 5 and 6, and 6 and 7, shall be maintained. Note 2: Instrument error is accounted for in these Operating Limits.



Note 1: A Rod Group overlap of 25 +/- 5% between sequential withdrawn groups 5 and 6, and 6 and 7, shall be maintained. Note 2: Instrument error is accounted for in these Operating Limits.



Note 1: A Rod Group overlap of 25 ±5% between sequential withdrawn groups 5 and 6, and 6 and 7, shall be maintained. Note 2: Instrument error is accounted for in these Operating Limits.

Cycle 16 COLR Page 13 of 34 Revision 2

Figure 3 APSR Position Operating Limits – 2817 MWt RTP

.

.

This Figure is referred to by Improved Technical Specifications 3.2.2

Before APSR Pull: 0 EFPD to 675 ± 10 EFPD, <u>Three or Four RC pumps operation</u>

Lower Limit: 0 %WD

Upper Limit: 100 %WD

.

After APSR Pull: 675 ± 10 EFPD to End-of-Cycle Three or Four RC pumps operation

Insertion Prohibited (maintain ≥ 99%WD)

* Power restricted to 75.37% for 3-pump operation.

Figure 4a AXIAL POWER IMBALANCE Operating Limits 0 to 350 <u>+</u>10 EFPD, Four RC Pumps--2817 MWt RTP Davis-Besse 1, Cycle 16



Figure 4b AXIAL POWER IMBALANCE Operating Limits 350 +10 to 600 +10 EFPD, Four RC Pumps--2817MWt RTP Davis-Besse 1, Cycle 16









Figure 4c AXIAL POWER IMBALANCE Operating Limits

Note 1: Instrument error is accounted for in these Operating Limits.

Cycle 16 COLR Page 17 of 34 **Revision 2**



Figure 4d AXIAL POWER IMBALANCE Operating Limits



Figure 4e AXIAL POWER IMBALANCE Operating Limits



1

Cycle 16 COLR Page 20 of 34 Revision 2

Table 4 QUADRANT POWER TILT Limits - 2817 MWt

• •

This Table is referred to by Improved Technical Specifications 3.2.4

| | From 0 EFPD to EOC-16 | | | | |
|---|---|--|------------------------|----------------------|--|
| QUADRANT POWER TILT as measured by: | Steady-state Limit for THERMAL POWER ≤ 60% (%) | Steady-state Limit for THERMAL POWER >60% (%) | Transient Limit (%) | Maximum Limit (%) | |
| Symmetric Incore Detector System | 7.90 | 4.25 | 10.03 | 20.00 | |

Cycle 16 COLR Page 21 of 34 Revision 2

Table 5 Power Peaking Factors - Fq (NAS)

This Table is referred to by Improved Technical Specifications 3.2.5

The measured F_{Q} shall be increased by 1.4% to account for manufacturing tolerances and further increased by 7.5% to account for measurement uncertainty before comparing to the limits.

Heat Flux Hot Channel Factor Fo

2817 MWt RTP

F_Q shall be limited by the following relationships:

 $F_Q \leq LHR^{allow}$ (Bu) / [LHR^{avg} * P] (for P \leq 1.0)

LHR^{allow} (Bu) = See the following tables

LHR^{avg} = 6.4119 kW/ft at 2817 MWt for Batch 9K Mark-B8A fuel LHR^{avg} = 6.4209 kW/ft at 2817 MWt for Batches 15C3 and 15E Mark-B10K fuel LHR^{avg} = 6.4209 kW/ft at 2817 MWt for Batches 16C2, 16D2 and 16E2 Mark-B12 fuel LHR^{avg} = 6.4321 kW/ft at 2817 MWt for Batch 17A-E Mark-B-HTP fuel LHR^{avg} = 6.4209 kW/ft at 2817 MWt for Batch 18A-C Mark-B-HTP fuel

P = ratio of THERMAL POWER / RATED THERMAL POWER

Bu = fuel burnup (MWd/mtU)

| <u>Batch 9K UO2 Fuel (Mark-B8A) LHR^{ALLOW} kW/ft^(a)</u> | | | | | | |
|---|---------------------|--------------------------|--------------------------|--------------------------|--|--|
| Axial Segment | 0 <u>MWd/mtU</u> | 24,500 <u>MWd/mtU</u> | 52,000 <u>MWd/mtU</u> | 60,000 <u>MWd/mtU</u> | | |
| 1 | 16.1 | 16.1 | 12.0 | 10.2 | | |
| 2 | 15.8 | 15.8 | 12.0 | 10.2 | | |
| 3 | 15.0 | 15.0 | 12.0 | 10.2 | | |
| 4 | 15.0 | 15.0 | 12.0 | 10.2 | | |
| 5 | 15.4 | 15.4 | 12.0 | 10.2 | | |
| 6 | 15.4 | 15.4 | 12.0 | 10.2 | | |
| 7 | 14.6 | 14.6 | 12.0 | 10.2 | | |
| 8 | 14.3 | 14.3 | 12.0 | 10.2 | | |

^(a) Linear interpolation for allowable LHR between specified burnup points is valid for these tables.

Table 5 (continued)

.

,

Batch 15C3 and 15E UO2 Fuel (Mark-B10K) LHR KW/ft (a)

| | 0 | 35,000 | 58,000 | 59,000 | 60,000 | 62,000 |
|---------------|----------------|----------------|----------------|----------------|----------------|----------------|
| Axial Segment | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> |
| 1 | 17.6 | 16.8 | 14.7 | 14.4 | 14.1 | 13.5 |
| 2 | 17.5 | 16.7 | 14.7 | 14.4 | 14.1 | 13.5 |
| 3 | 17.0 | 15.6 | 14.6 | 14.4 | 14.1 | 13.5 |
| 4 | 16.6 | 15.3 | 14.4 | 14.4 | 14.1 | 13.5 |
| 5 | 16.0 | 15.3 | 14.2 | 14.1 | 14.1 | 13.5 |
| 6 | 15.3 | 15.3 | 13.7 | 13.7 | 13.6 | 13.5 |
| 7 | 14.7 | 14.7 | 13.2 | 13.1 | 13.1 | 13.0 |
| 8 | 14.5 | 14.5 | 13.0 | 12.9 | 12.9 | 12.8 |

Batch 16C2, 16D2, and 16E2 UO2 Fuel (Mark-B12) LHR^{ALLOW} kW/ft^(a)

| | 0 | 35,000 | 58,000 | 59,000 | 60,000 | 62,000 |
|---------------|----------------|----------------|----------------|----------------|----------------|----------------|
| Axial Segment | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> |
| 1 | 17.6 | 16.8 | 14.7 | 14.4 | 14.1 | 13.5 |
| 2 | 17.5 | 16.7 | 14.7 | 14.4 | 14.1 | 13.5 |
| 3 | 17.0 | 15.6 | 14.6 | 14.4 | 14.1 | 13.5 |
| 4 | 16.6 | 15.3 | 14.4 | 14.4 | 14.1 | 13.5 |
| 5 | 16.0 | 15.3 | 14.2 | 14.1 | 14.1 | 13.5 |
| 6 | 15.3 | 15.3 | 13.7 | 13.7 | 13.6 | 13.5 |
| 7 | 14.7 | 14.7 | 13.2 | 13.1 | 13.1 | 13.0 |
| 8 | 14.5 | 14.5 | 13.0 | 12.9 | 12.9 | 12.8 |

Batch 17A-17E UO2 Fuel (Mark-B-HTP) LHR kW/ft(a)

| | 0 | 40,000 | 62,000 |
|---------------|----------------|----------------|----------------|
| Axial Segment | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> |
| 1 | 17.6 | 17.2 | 13.6 |
| 2 | 17.5 | 17.1 | 13.5 |
| 3 | 17.1 | 16.7 | 13.2 |
| 4 | 17.0 | 16.7 | 13.2 |
| 5 | 16.5 | 16.2 | 13.1 |
| 6 | 15.9 | 16.0 | 13.1 |
| 7 | 15.3 | 15.4 | 12.8 |
| 8 | 15.1 | 15.2 | 12.6 |

^(a) Linear interpolation for allowable LHR between specified burnup points is valid for these tables

Table 5 (continued)

)

.

.

.

| Balch ToA-ToC OO2 Fuel (Mark-B-HTP) LHK KW/IL | | | | | |
|---|----------------|----------------|----------------|--|--|
| | 0 | 40,000 | 62,000 | | |
| Axial Segment | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | | |
| 1 | 17.6 | 17.2 | 13.6 | | |
| 2 | 17.5 | 17.1 | 13.5 | | |
| 3 | 17.1 | 16.7 | 13.2 | | |
| 4 | 17.0 | 16.7 | 13.2 | | |
| 5 | 16.5 | 16.2 | 13.1 | | |
| 6 | 15.9 | 16.0 | 13.1 | | |
| 7 | 15.3 | 15.4 | 12.8 | | |
| 8 | 15.1 | 15.2 | 12.6 | | |
| | | | | | |

Batch 18A-18C UO2 Fuel (Mark-B-HTP) LHR kW/ft(a)

^(a) Linear interpolation for allowable LHR between specified burnup points is valid for these tables

Table 6 Power Peaking Factors - Fo (FIDMS)

This Table is referred to by Improved Technical Specifications 3.2.5

The measured F_Q shall be increased by 1.4% to account for manufacturing tolerances and further increased by 7.5% to account for measurement uncertainty before comparing to the limits.

Heat Flux Hot Channel Factor Fo

.

2817 MWt RTP

 F_Q shall be limited by the following relationships:

 $F_Q \leq LHR^{allow}$ (Bu) / [LHR^{avg} * P] (for P \leq 1.0)

 LHR^{allow} (Bu) = See the following tables

LHR^{avg} = 6.4119 kW/ft at 2817 MWt for Batch 9K Mark-B8A fuel LHR^{avg} = 6.4209 kW/ft at 2817 MWt for Batches 15C3 and 15E Mark-B10K fuel LHR^{avg} = 6.4209 kW/ft at 2817 MWt for Batches 16C2, 16D2 and 16E2 Mark-B12 fuel LHR^{avg} = 6.4321 kW/ft at 2817 MWt for Batch 17A-E Mark-B-HTP fuel LHR^{avg} = 6.4209 kW/ft at 2817 MWt for Batch 18A-C Mark-B-HTP fuel

P = ratio of THERMAL POWER / RATED THERMAL POWER

Bu = fuel burnup (MWd/mtU)

Batch 9K - UO2 Fuel LHR kW/ft*

| Core Elevation | | 24,500 | 52,000 | 60,000 |
|----------------|------------------|----------------|----------------|----------------|
| <u>(ft)</u> | <u>0 MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> |
| 0.000 | 16.3 | 16.3 | 12.0 | 10.2 |
| 2.506 | 15.9 | 15.9 | 12.0 | 10.2 |
| 4.264 | 15.1 | 15.1 · | 12.0 | 10.2 |
| 6.021 | 15.5 | 15.5 | 12.0 | 10.2 |
| 7.779 | 16.0 | 16.0 | 12.0 | 10.2 |
| 9.536 | 15.4 | 15.4 | 12.0 | 10.2 |
| 12.000 | 14.3 | 14.3 | 12.0 | 10.2 |

Linear interpolation for allowable LHR between specified burnup points is valid for these tables

Table 6 (continued)

.

.

Batches 15C3 and 15E - UO2 Fuel LHRALLOW kW/ft*

| Core | | 35,000 | 58,000 | 59,000 | 60,000 | 62,000 |
|----------------|------------------|----------------|----------------|----------------|----------------|----------------|
| Elevation (ft) | <u>0 MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> |
| 0.000 | 17.6 | 16.8 | 14.7 | 14.4 | 14.1 | 13.5 |
| 2.506 | 17.6 | 16.8 | 14.7 | 14.4 | 14.1 | 13.5 |
| 4.264 | 17.1 | 15.7 | 14.7 | 14.4 | 14.1 | 13.5 |
| 6.021 | 16.6 | 15.3 | 14.4 | 14.4 | 14.1 | 13.5 |
| 7.779 | 16.0 | 15.8 | 14.2 | 14.1 | 14.1 | 13.5 |
| 9.536 | 15.3 | 15.3 | 13.7 | 13.7 | 13.6 | 13.5 |
| 12.000 | 14.5 | 14.5 | 13.0 | 12.9 | 12.9 | 12.8 |

^{*} Linear interpolation for allowable LHR between specified burnup points is valid for these tables.

Batch 16C2, 16D2, and 16E2 - UO2 Fuel LHRALLOW kW/ft*

| Core | | 35,000 | 58 000 | 59 000 | 60.000 | 62 000 |
|----------------|--------------|-----------|-----------|------------|---------|---------|
| Elevation (ft) | 0 MM/d/mtl I | MM/d/mtLl | MW/d/mtLl | M\M/d/mtLl | MWd/mtL | MWd/mtL |
| | 17.6 | 16.8 | 14.7 | 14.4 | 14 1 | 13.5 |
| 2.506 | 17.0 | 16.8 | 14.7 | 14.4 | 14.1 | 13.5 |
| 2.000 | 17.0 | 15.7 | 14.7 | 14.4 | 14.1 | 13.5 |
| 6.021 | 16.6 | 15.7 | 14.7 | 14.4 | 14.1 | 13.5 |
| 7 770 | 16.0 | 15.8 | 14.4 | 14.4 | 14.1 | 13.5 |
| 9.536 | 15.3 | 15.0 | 13.7 | 13.7 | 13.6 | 13.5 |
| 12 000 | 14.5 | 14.5 | 13.0 | 12.9 | 12.9 | 12.8 |

^{*} Linear interpolation for allowable LHR between specified burnup points is valid for these tables.

Batch 17A-E - UO2 Fuel LHR kW/ft*

| Core Elevation (ft) | 0 MWd/mtU | 40,000 MWd/mtU | 62,000 MWd/mtU |
|---------------------|-----------|----------------|----------------|
| 0.000 | 17.6 | 17.2 | 13.6 |
| 2.506 | 17.6 | 17.2 | 13.6 |
| 4.264 | 17.2 | 16.8 | 13.3 |
| 6.021 | 17.0 | 16.7 | 13.2 |
| 7.779 | 16.5 | 16.2 | 13.1 |
| 9.536 | 15.9 | 16.0 | 13.3 |
| 12.000 | 15.1 | 15.2 | 12.6 |

* Linear interpolation for allowable LHR between specified burnup points is valid for these tables.

Batch 18A-C - UO2 Fuel LHRALLOW kW/ft*

| Core Elevation (ft) | 0 MWd/mtU | 40,000 MWd/mtU | 62,000 MWd/mtU |
|---------------------|-----------|----------------|----------------|
| 0.000 | 17.6 | 17.2 | 13.6 |
| 2.506 | 17.6 | 17.2 | 13.6 |
| 4.264 | 17.2 | 16.8 | 13.3 |
| 6.021 | 17.0 | 16.7 | 13.2 |
| 7.779 | 16.5 | 16.2 | 13.1 |
| 9.536 | 15.9 | 16.0 | 13.3 |
| 12.000 | 15.1 | 15.2 | 12.6 |

* Linear interpolation for allowable LHR between specified burnup points is valid for these tables.

Table 6 (continued)

.

Batch 15 - 2 wt% Gadolinia Fuel LHR kW/ft*

| Core | | 35,000 | 58,000 | 59,000 | 60,000 | 62,000 |
|----------------|-----------|----------------|----------------|----------------|----------------|----------------|
| Elevation (ft) | 0 MWd/mtU | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> |
| 0.000 | 16.5 | 15.7 | 13.9 | 13.6 | 13.3 | 12.8 |
| 2.506 | 16.5 | 15.7 | 13.9 | 13.6 | 13.3 | 12.8 |
| 4.264 | 16.0 | 14.7 | 13.9 | 13.6 | 13.3 | 12.8 |
| 6.021 | 15.5 | 14.3 | 13.6 | 13.6 | 13.3 | 12.8 |
| 7.779 | 15.0 | 14.8 | 13.4 | 13.3 | 13.3 | 12.8 |
| 9.536 | 14.3 | 14.3 | 13.0 | 12.9 | 12.9 | 12.8 |
| 12.000 | 13.6 | 13.6 | 12.4 | 12.3 | 12.3 | 12.2 |

Linear interpolation for allowable LHR between specified burnup points is valid for these tables.

| Batch 16 – 4 v | vt% Gadolinia | Fuel LHR ^{ALLOW} | kW/ft* |
|----------------|---------------|---------------------------|--------|
| | | | |

| Core | | 35,000 | 58,000 | 59,000 | 60,000 | 62,000 |
|----------------|-----------|---------|----------------|----------------|----------------|----------------|
| Elevation (ft) | 0 MWd/mtU | MWd/mtU | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> | <u>MWd/mtU</u> |
| 0.000 | 15.8 | 15.1 | 13.3 | 13.0 | 12.7 | 12.2 |
| 2.506 | 15.8 | 15.1 | 13.3 | 13.0 | 12.7 | 12.2 |
| 4.264 | 15.3 | 14.1 | 13.3 | 13.0 | 12.7 | 12.2 |
| 6.021 | 14.9 | 13.7 | 13.0 | 13.0 | 12.7 | 12.2 |
| 7.779 | 14.3 | 14.2 | 12.9 | 12.8 | 12.8 | 12.2 |
| 9.536 | 13.7 | 13.7 | 12.4 | 12.3 | 12.3 | 12.2 |
| 12.000 | 13.0 | 13.0 | 11.8 | 11.7 | 11.7 | 11.6 |

^{*} Linear interpolation for allowable LHR between specified burnup points is valid for these tables.

Batches 15 and 16 - 8 wt% Gadolinia Fuel LHRALLOW kW/ft*

| Core | | 35,000 | 58,000 | 59,000 | 60,000 | 62,000 |
|----------------|-----------|------------------|---------|---------|----------------|---------|
| Elevation (ft) | 0 MWd/mtU | MWd/mtU | MWd/mtU | MWd/mtU | <u>MWd/mtU</u> | MWd/mtU |
| 0.000 | 14.9 | 14.2 | 12.4 | 12.1 | 11.9 | 11.4 |
| 2.506 | 14.9 | 14.2 | 12.4 | 12.1 | 11.9 | 11.4 |
| 4.264 | 14.5 | 13.3 | 12.4 | 12.1 | 11.9 | 11.4 |
| 6.021 | 14.0 | 12.9 | 12.2 | 12.2 | 11.9 | 11.4 |
| 7.779 | 13.5 | 13.4 | 12.0 | 11.9 | 11.9 | 11.4 |
| 9.536 | 12.9 | 12. 9 | 11.6 | 11.5 | 11.5 | 11.4 |
| 12.000 | 12.2 | 12.2 | 11.0 | 10.9 | 10.9 | 10.8 |

^{*} Linear interpolation for allowable LHR between specified burnup points is valid for these tables.

Batches 17 and 18 – 4 wt% Gadolinia Fuel LHR^{ALLOW} kW/ft*

| Core Elevation (ft) | 0 MWd/mtU | 40,000 MWd/mtU | 62,000 MWd/mtU |
|---------------------|-----------|----------------|----------------|
| 0.000 | 15.8 | 15.7 | 12.3 |
| 2.506 | 15.8 | 15.7 | 12.3 |
| 4.264 | 15.4 | 15.2 | 12.0 |
| 6.021 | 15.2 | 15.1 | 11.9 |
| 7.779 | 14.8 | 14.7 | 11.8 |
| 9.536 | 14.3 | 14.5 | 12.0 |
| 12.000 | 13.6 | 13.8 | 11.4 |

^{*} Linear interpolation for allowable LHR between specified burnup points is valid for these tables.

Cycle 16 COLR Page 27 of 34 Revision 2

Table 6 (continued)

43

5

Batches 17 and 18 - 8 wt% Gadolinia Fuel LHR KW/ft*

| Core Elevation (ft) | <u>0 MWd/mtU</u> | 40,000 MWd/mtU | 62,000 MWd/mtU |
|---------------------|------------------|----------------|----------------|
| 0.000 | 14.9 | 14.9 | 11.5 |
| 2.506 | 14.9 | 14.9 | 11.5 |
| 4.264 | 14.5 | 14.6 | 11.2 |
| 6.021 | 14.4 | 14.5 | 11.1 |
| 7.779 | 13.9 | 14.0 | 11.0 |
| 9.536 | 13.4 | 13.9 | 11.2 |
| 12.000 | 12.7 | 13.2 | 10.6 |

Linear interpolation for allowable LHR between specified burnup points is valid for these tables.

Cycle 16 COLR Page 28 of 34 Revision 2

<u>Table 7 Power Peaking Factors - $F^{N}_{\Delta H}$ </u>

This Table is referred to by Improved Technical Specifications 3.2.5

Enthalpy Rise Hot Channel Factors - $F^{N}_{\Delta H}$

 $F_{\Delta H}^{N} \leq MARP [1 + (1/RH) (1 - P/P_m)]$ (see note below) MARP = Maximum Allowable Radial Peak, see MARP Figures and data Tables P = THERMAL POWER / RATED THERMAL POWER and P \leq 1.0 P_m = 1.0 for 4-RCP operation P_m = 0.75 for 3-RCP operation 1/RH = 0.3

Note: The measured $F^{N}_{\Delta H}$ shall be increased by 5.0% to account for measurement uncertainty prior to comparing to the limits.





* This figure is applicable to all Mark-B fuel in the core. Linear interpolation and extrapolation above x/L of 0.8 are acceptable. For axial heights < x/L of 0.2, the value at x/L of 0.2 will be used.

Cycle 16 COLR Page 29 of 34 Revision 2





* This figure is applicable to all Mark-B-HTP fuel in the core. Linear interpolation is acceptable. The MARP values are based on an active fuel height of 142.75 inches.

Cycle 16 COLR Page 30 of 34 Revision 2

| <u>Axial Peak</u> | <u>x/L</u> | Axial Height (inches) | MAP Limit | MARP Limit |
|-------------------|------------|-----------------------|-----------|------------|
| | 0.2 | 28.12 | 2.0415 | 1.9264 |
| | 0.4 | 56.24 | 2.0345 | 1.9198 |
| 1.1 | 0.6 | 84.36 | 2.0221 | 1.9081 |
| | 0.8 | 112.48 | 1.9934 | 1.8810 |
| | 0.2 | 28.12 | 2.2918 | 1.9824 |
| 4.0 | 0.4 | 56.24 | 2.2749 | 1.9678 |
| 1.2 | 0.6 | 84.36 | 2.2470 | 1.9437 |
| | 0.8 | 112.48 | 2.1601 | 1.8685 |
| | 0.2 | 28.12 | 2.5521 | 2.0378 |
| 4.0 | 0.4 | 56.24 | 2.5197 | 2.0119 |
| 1.3 | 0.6 | 84.36 | 2.4387 | 1.9472 |
| | 0.8 | 112.48 | 2.2719 | 1.8140 |
| | 0.2 | 28.12 | 3.0022 | 2.0775 |
| 4 5 | 0.4 | 56.24 | 2.8272 | 1.9564 |
| 1.5 | 0.6 | 84.36 | 2.6367 | 1.8246 |
| | 0.8 | 112.48 | 2.4553 | 1.6991 |
| | 0.2 | 28.12 | 3.1839 | 1.9441 |
| 4 7 | 0.4 | 56.24 | 2.9911 | 1.8263 |
| 1.7 | 0.6 | 84.36 | 2.7902 | 1.7037 |
| | 0.8 | 112.48 | 2.6084 | 1.5927 |
| | 0.2 | 28.12 | 3.2865 | 1.7955 |
| 10 | 0.4 | 56.24 | 3.0945 | 1.6906 |
| 1.9 | 0.6 | 84.36 | 2.9062 | 1.5877 |
| | 0.8 | 112.48 | 2.7279 | 1.4903 |

Table 8 Maximum Allowable Radial Peak for F^N_{ΔH} in Mark-B Fuel Assemblies

•

1

| Table 9 | Maximum Allowable Radial Peak for F ^N AH in Mark-B-HTP Fuel |
|---------|--|
| | Assemblies |

•

,

| Axial <u>Peak</u> | <u>x/L</u> | Axial Height <u>(inches)</u> | MAP Limit | MARP <u>Limit</u> | Axial <u>Peak</u> | <u>x/L</u> | Axial Height <u>(inches)</u> | MAP Limit | MARP Limit |
|----------------------|---|---|---|---|----------------------|---|---|---|---|
| 1.1 | 0.0 0.1 0.14 0.2 0.4 0.5 0.6 0.8 0.88 0.9 1.0 | 0.000 14.275 19.985 28.550 57.100 71.375 85.650 114.200 125.620 128.475 142.750 | 2.03286 2.03375 2.03379 2.03355 2.03179 2.03107 2.03099 2.03178 1.98623 1.98774 1.86518 | 1.91828 1.91912 1.91916 1.91893 1.91727 1.91659 1.91652 1.91726 1.87428 1.87570 1.76005 | 1.6 | 0.0 0.1 0.14 0.2 0.4 0.5 0.6 0.8 0.88 0.88 0.9 1.0 | 0.000 14.275 19.985 28.550 57.100 71.375 85.650 114.200 125.620 128.475 142.750 | 2.79510 2.66285 2.63106 2.69787 2.75779 2.79658 2.71189 2.46394 2.36299 2.37234 2.21845 | 1.81332 1.72752 1.70690 1.75024 1.78912 1.81428 1.75934 1.59848 1.53299 1.53906 1.43922 |
| 1.2 | 0.0 0.1 0.2 0.4 0.5 0.6 0.8 0.88 0.9 1.0 | 0.000 14.275 19.985 28.550 57.100 71.375 85.650 114.200 125.620 128.475 142.750 | 2.33414 2.33416 2.33413 2.33248 2.33024 2.32955 2.32916 2.15618 2.07666 2.07869 1.95649 | 2.01903 2.01905 2.01902 2.01760 2.01566 2.01506 2.01472 1.86510 1.79631 1.79807 1.69236 | 1.7 | 0.0 0.1 0.2 0.4 0.5 0.6 0.8 0.88 0.9 1.0 | 0.000 14.275 19.985 28.550 57.100 71.375 85.650 114.200 125.620 128.475 142.750 | 2.81571 2.66718 2.63022 2.69195 2.76735 2.80468 2.77165 2.52074 2.42051 2.43041 2.27373 | 1.71924 1.62855 1.60598 1.64367 1.68971 1.71250 1.69234 1.53913 1.47793 1.48398 1.38831 |
| 1.3 | 0.0 0.1 0.2 0.4 0.5 0.6 0.8 0.88 0.9 1.0 | 0.000 14.275 19.985 28.550 57.100 71.375 85.650 114.200 125.620 128.475 142.750 | 2.66591 2.64485 2.62777 2.66761 2.65903 2.58224 2.46978 2.24712 2.15963 2.16184 2.02976 | 2.12863 2.11181 2.09817 2.12998 2.12313 2.06182 1.97202 1.79424 1.72438 1.72615 1.62069 | 1.8 | 0.0 0.1 0.2 0.4 0.5 0.6 0.8 0.88 0.9 1.0 | 0.000 14.275 19.985 28.550 57.100 71.375 85.650 114.200 125.620 128.475 142.750 | 2.83401 2.66992 2.62789 2.68772 2.7774 2.80694 2.82218 2.57398 2.47403 2.48254 2.32589 | 1.63428 1.53965 1.51542 1.54992 1.60163 1.61867 1.62746 1.48433 1.42669 1.43160 1.34126 |
| 1.4 | 0.0 0.1 0.2 0.4 0.5 0.6 0.8 0.88 0.9 1.0 | 0.000 14.275 19.985 28.550 57.100 71.375 85.650 114.200 125.620 128.475 142.750 | 2.74599 2.65413 2.69213 2.74771 2.68391 2.56032 2.33307 2.23716 2.24237 2.09699 | 2.03596 1.96785 1.95126 1.99602 2.03723 1.98993 1.89829 1.72980 1.65869 1.66256 1.55477 | 1.9 | 0.0 0.1 0.2 0.4 0.5 0.6 0.8 0.88 0.9 1.0 | 0.000 14.275 19.985 28.550 57.100 71.375 85.650 114.200 125.620 128.475 142.750 | 2.85122 2.67423 2.62778 2.68609 2.78418 2.80567 2.83113 2.62225 2.52166 2.53147 2.37605 | 1.55767 1.46097 1.43560 1.46745 1.52104 1.53278 1.54669 1.43258 1.37762 1.38298 1.29807 |
| 1.5 | 0.0 0.1 0.14 0.2 0.4 0.5 0.6 0.8 0.8 0.8 0.9 1.0 | 0.000 14.275 19.985 28.550 57.100 71.375 85.650 114.200 125.620 128.475 142.750 | 2.77184 2.66225 2.63504 2.69706 2.75139 2.75241 2.64282 2.39919 2.30027 2.30907 2.15988 | 1.91811 1.84228 1.82345 1.86637 1.90396 1.90467 1.82883 1.66024 1.59179 1.59788 1.49464 | | | | | |

Cycle 16 COLR Page 32 of 34 Revision 2



Cycle 16 COLR Page 33 of 34 Revision 2

.

Table 10 Refueling Boron Concentration Limit

.

.

This limit is referred to by Improved Technical Specifications 3.9.1

The minimum required boron concentration for use during refueling shall be sufficient to ensure a K_{eff} of 0.95 or less, plus an additional 1% $\Delta k/k$ conservatism allowance for uncertainties.

Cycle 16 COLR Page 34 of 34 Revision 2



(W)

-1

.

Enclosure B L-08-317

•

•

.

FirstEnergy Nuclear Operating Company, Davis-Besse Unit 1, 21 Effective Full Power Years Pressure and Temperature Limits Report, Revision 0

(7 Pages)

21 EFPY PTLR Page 1 of 7 Revision 0

FIRSTENERGY NUCLEAR OPERATING COMPANY

DAVIS-BESSE UNIT 1

21 EFFECTIVE FULL POWER YEARS

PRESSURE AND TEMPERATURE LIMITS REPORT

from Prepared by: Jessica Kemp

Reviewed by: Dennis Blakely

Approved by: Kevin Zellers 9-10-08

21 EFPY PTLR Page 2 of 7 Revision 0

FirstEnergy Nuclear Operating Company Davis-Besse Unit 1 21 Effective Full Power Year Pressure and temperature Limit Report

1.0 Introduction

This Pressure and Temperature Limit Report (PTLR) provides the information required by Davis-Besse Nuclear Power Station (DBNPS) Technical Specification 5.6.4 to ensure that the Reactor Coolant System Pressure Boundary is operated in accordance with its design.

The PTLR provides the RCS Operating Limits in Section 2.0, which satisfy Technical Specification 5.6.4.a. The Analytical Methods used to develop the limits, including determination of the vessel neutron fluence, are provided in Section 3.0, fulfilling Technical Specification 5.6.4.b. The PTLR Requirements are provided in Section 4.0 of the report, fulfilling Technical Specification 5.6.4.c.

Revisions to the PTLR are to be submitted to the NRC after issuance.

- 2.0 RCS Pressure and Temperature Limits
 - a. The Reactor Coolant System (except the pressurizer) temperature and pressure shall be limited in accordance with the limit lines shown on Figures 1, 2 and 3 during heatup, cooldown, criticality and inservice leak, and hydrostatic testing with (Reference 1):
 - 1. A maximum heatup of 50°F in any one hour period, and
 - 2. A maximum cooldown of 100° F in any one hour period with a cold leg temperature of $\geq 270^{\circ}$ F and a maximum cooldown of 50° F in any one hour period with a cold leg temperature of $< 270^{\circ}$ F.
 - b. During periods of low temperature operation (T_{avg} <280.°F), Technical Specification 3.4.12 provides additional requirements for RCS pressure and temperature limits. Those limits are maintained in the Technical Specifications because they are not determined using methods generically approved by the NRC.

and in:



Indicated Reactor Coolant Inlet Temperature, F

٩.

Reactor Coolant System Pressure-Temperature Limits



Indicated Reactor Coolant Inlet Temperature, F

21 EFPY PTLR Page 5 of 7 Revision 0

n (357

1.23

Figure 3



Indicated Reactor Coolant Inlet Temperature, F

21 EFPY PTLR Page 6 of 7 Revision 0

- 3.0 Analytical Methods
 - 3.1 The limits provided in Figures 1, 2, and 3 are valid until the Reactor Vessel has accumulated 21 Effective Full Power Years (EFPY) of fast (E> 1 MeV) neutron fluence.
 - 3.2 The Pressure-Temperature (P/T) Limits were generated using the methods described in BAW-10046A (Reference 4).
 - 3.3 The P/T limits contained in the PTLR (applicable through 21 Effective Full Power Years (EFPY)) were generated in accordance with the methods described in BAW-10046A (Reference 4), consistent with the requirements of 10 CFR 50 Appendix G, and Regulatory Guide 1.99, Revision 2. The NRC has reviewed the methods described in BAW-10046A (Reference 4) and approved the topical report by issuance of a Safety Evaluation Report (SER) dated April 30, 1986. Section 1.2 of BAW-10046A states that it is applicable to all current B&W nuclear steam systems.
 - 3.4 The neutron fluence is calculated using the methodology described in BAW-2108 (Reference 5). This methodology was approved by the NRC in the SER of Amendment 199 (Reference 1).
 - 3.5 The Davis-Besse Reactor Vessel Material Surveillance Program complies with the requirements of Appendix H to 10 CFR 50 and is described in BAW-1543A (Reference 6). This information was approved by the NRC in the SER of Amendment 199 (Reference 1).
 - 3.6 The PORV (valve RC-2A) is not currently used for Low Temperature Overpressure Protection (LTOP), thus not required in ITS 3.4.12, "Low Temperature Overpressure Protection (LTOP)." Therefore, the PTLR does not include any PORV lift setting requirements.
 - 3.7 Davis-Besse calculates Adjusted Reference Temperature (ART) in accordance with Regulatory Guide 1.99, Revision 2. This information was approved by the NRC in the SER of Amendment 199 (Reference 1).
 - 3.8 The NRC has previously determined that the current limiting ART calculation complies with the NUREG-0800, Standard Review Plan 5.3.2, as documented in the SER of Amendment 199 (Reference 1). This is not meant to infer a commitment to NUREG-0800 by DBNPS.
 - 3.9 The NRC has previously determined that the Davis-Besse P/T limit curves comply with 10 CFR 50 Appendix G as documented in the SER of Amendment 199 (Reference 1).

3.10 Davis-Besse has not tested any plant-specific capsules since the last time P/T limit curves were adjusted and approved by the NRC in Amendment 199. Therefore no changes need be made at this time.

4.0 PTLR Requirements

٩,

4.1 The PTLR has been prepared in accordance with the requirements of Technical Specification 5.6.4. The PTLR shall be provided to the NRC upon issuance for each reactor vessel fluence period and for any revision or supplement thereto. Davis-Besse will continue to meet the requirements of 10 CFR 50, Appendix G and any changes to the Davis-Besse P/T limits will be generated in accordance with the NRC approved methodology described in TS 5.6.4.

5.0 References

- 5.1 Safety Evaluation by the Office of Nuclear Reactor Regulation Related to Amendment No. 199 to Facility Operating License No. NPF-3 Davis-Besse Nuclear Power Station, Unit No. 1. Attached to correspondence dated July 20, 1995.
- 5.2 Improved Technical Specification 5.6.4
- 5.3 Improved Technical Specification 3.4.12
- 5.4 BAW-10046A, Revision 2 "Methods of Compliance with Fracture Toughness and Operational Requirements of 10 CFR 50 Appendix G."
- 5.5 BAW-2108, Revision 1, "Fluence Tracking System," dated May 1992.
- 5.6 BAW-1543A, "Master Integrated Reactor Vessel Material Surveillance Program."
- 5.7 Additional References
 - Technical Specification 5.6.4, Reactor Coolant System (RCS) Pressure and Temperature Limits Report (PTLR)
 - License Amendment 116, Serial No. 1490 Dated March 30, 1988, Attachment 1, Page 5
 - Improved Technical Specification Conversion Project (LAR 06-0003) Section 5.6, Description of Change L03
 - Current Technical Specification 3/4.4.9, Pressure/Temperature Limits