



Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609-2000

December 19, 2008

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Stop: OWFN, P1-35
Washington, D.C. 20555-0001

In the Matter of)
Tennessee Valley Authority)

Docket No. 50-259

**BROWNS FERRY NUCLEAR PLANT (BFN) - UNIT 1 - CORE OPERATING LIMITS
REPORT (COLR), REVISION 1 FOR CYCLE 8 OPERATION**

In accordance with the requirements of Technical Specification 5.6.5.d, enclosed is the Unit 1 Cycle 8, Revision 1, Core Operating Limits Report. Revision 1 is an update of the Unit 1 Cycle 8, Revision 0, COLR that was issued October 23, 2008, on an interim basis, to support fuel loading.

There are no new commitments contained in this letter. If you have any questions, please contact me at (256) 729-2636.

Sincerely,

A handwritten signature in black ink, appearing to read "F. R. Godwin".

F. R. Godwin
Manager of Licensing
and Industry Affairs

Enclosure
cc: See page 2

DO30
NRR

U.S. Nuclear Regulatory Commission
Page 2
December 19, 2008

Enclosure
cc (Enclosure):

Ms. Eva A. Brown, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
(MS 08G9)
11555 Rockville Pike
Rockville, Maryland 20852-2739

Mr. Eugene F. Guthrie, Branch Chief
U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, S.W., Suite 23T85
Atlanta, Georgia 30303-8931

NRC Resident Inspector
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, Alabama 35611-6970

ENCLOSURE

**TENNESSEE VALLEY AUTHORITY
BROWNS FERRY NUCLEAR PLANT (BFN)
UNIT 1**

**CORE OPERATING LIMITS REPORT (COLR), REVISION 1
FOR CYCLE 8 OPERATION**

(SEE ATTACHED)



Nuclear Fuel Design - BWRFE


1101 Market Street, Chattanooga, TN 37402


Browns Ferry Unit 1 Cycle 8


Core Operating Limits Report, (105% OLTP)

TVA-COLR-BF1C8 Revision 1 (Final)

November 2008

Prepared:  Date: 11/6/2008
T. W. Eichenberg, Sr. Specialist

Verified:  Date: 11/7/2008
W. B. Bird, Engineer

Approved:  Date: 11/7/2008
G. C. Storey, Manager, BWR Fuel Engineering

Reviewed:  Date: 11/8/2008
J. M. Keck, Supervisor, Reactor Engineering

Approved:  Date: 11/13/08
Chairman, PORC

Table of Contents

Total Number of Pages = 38 (including review cover sheet)

List of Tables.....	3
List of Figures	4
Revision Log	5
Nomenclature.....	6
References.....	8
1 Introduction	9
1.1 Purpose	9
1.2 Scope	9
1.3 Fuel Loading.....	9
1.4 Acceptability	9
2 APLHGR Limits	11
2.1 Rated Power and Flow Limit: $APLHGR_{RATED}$	11
2.2 Off-Rated Power Dependent Limit: $APLHGR_P$	11
2.3 Off-Rated Flow Dependent Limit: $APLHGR_F$	11
2.4 Single Loop Operation Limit: $APLHGR_{SLO}$	11
2.5 Equipment Out-Of-Service Corrections.....	14
3 LHGR Limits.....	15
3.1 Rated Power and Flow Limit: $LHGR_{RATED}$	15
3.2 Off-Rated Power Dependent Limit: $LHGR_P$	15
3.3 Off-Rated Flow Dependent Limit: $LHGR_F$	15
3.4 Single Loop Operation Limit: $LHGR_{SLO}$	15
3.5 Equipment Out-Of-Service Corrections.....	15
4 OLMCPR Limits	24
4.1 Rated Power and Flow Limit: $MCPR_{RATED}$	24
4.1.1 Scram Timing Dependence	24
4.1.2 Equipment Out-Of-Service (EOOS) Options	25
4.1.3 Exposure Dependent Limits	25
4.2 Flow Dependent MCPR Limit: $MCPR_F$	25
4.3 Single Loop Operation Limit: $MCPR_{SLO}$	26
4.4 Power Dependent MCPR Limit: $MCPR_P$	26
5 APRM Flow Biased Rod Block Trip Settings.....	36
6 Rod Block Monitor (RBM) Trip Setpoints and Operability	37
7 Shutdown Margin Limit.....	38

List of Tables

Nuclear Fuel Types.....10

Analytical RBM Trip Setpoints37

RBM Setpoint Applicability.....37

List of Figures

APLHGR _{RATED} for GE13 Fuel	12
APLHGR _{RATED} for GE14 Fuel	13
LHGR _{RATED} for GE13 UO ₂ Fuel	17
LHGR _{RATED} for GE14 UO ₂ Fuel	18
LHGRFAC _P for All EIS or RPTOOS Conditions	19
LHGRFAC _P for RPTOOS and TBVOOS Conditions	20
LHGRFAC _P for RPTOOS and PLUOOS Conditions	21
LHGRFAC _P for RPTOOS, TBVOOS, and PLUOOS Conditions	22
LHGRFAC _F	23
MCPR _F	27
MCPR _{Rated} for GE13: BOC to MOC Exposure	28
MCPR _{Rated} for GE13: BOC to EOC Exposure	29
MCPR _{Rated} for GE14: BOC to MOC Exposure	30
MCPR _{Rated} for GE14: BOC to EOC Exposure	31
K _P Multiplier and MCPR _P for All Equipment In Service or RPTOOS	32
K _P Multiplier and MCPR _P for RPTOOS and TBVOOS	33
K _P Multiplier and MCPR _P for RPTOOS and PLUOOS	34
K _P Multiplier and MCPR _P for RPTOOS, TBVOOS, and PLUOOS	35

Revision Log

Number	Page	Description
1-R0	All	New document, per NFDP-1, Section 3.2, Item N.
1-R1	2-5	Updated as a consequence of document revision
2-R1	8	Removed Reference 1 and added new References. References 2 & 3 renumbered to become References 7 & 8.
3-R1	9	Revised Section 1.2 for document scope. Revised Section 1.3 text to reflect SRLR applicability.
4-R1	11	Section 2 becomes Section 7, page 38.
5-R1	11-37	Sections 2-6: new material supporting all modes of plant operation.

Nomenclature

APLHGR	Average Planar LHGR
APRM	Average Power Range Monitor
AREVA NP	Vendor (Framatome, Siemens)
ARTS	APRM, Rod Block Monitor, and Technical Specification Improvement Program
BOC	Beginning of Cycle
BWR	Boiling Water Reactor
CAVEX	Core Average Exposure
CD	Coastdown
COLR	Core Operating Limits Report
CPR	Critical Power Ratio
CPRFAC	Multiplier to determine off-rated OLMCPR, relative to rated conditions
CRWE	Control Rod Withdrawal Error
DTSP	Dual TSP
EIS	Equipment-In-Service
EOC	End of Cycle
EOFP	End of Full Power (no ICF or FFWTR)
EOOS	Equipment OOS
EOR	End of Rated Conditions
FFWTR	Final Feedwater Temperature Reduction
FHOOS	Feedwater Heaters OOS
GWd	Giga Watt Day
HPSP	High PSP
HTSP	High TSP
ICF	Increased Core Flow (beyond rated)
IPSP	Intermediate PSP
ITSP	Intermediate TSP
K _p	Vendor Specific Nomenclature for CPRFAC
LHGR	Linear Heat Generation Rate
LHGRFAC	LHGR Multiplier (Power or Flow dependent)
LPRM	Low Power Range Monitor
LPSP	Low PSP
LRNB	Generator Load Reject, No Bypass
LTSP	Low TSP
MAPFAC	MAPLHGR multiplier (Power or Flow dependent)
MCPR	Minimum CPR
MOC	Middle of Cycle
MSIV	Main Steam Isolation Valve
MSIVOOS	MSIV OOS

MSR	Moisture Separator Reheater
MSROOS	MSR OOS
MTU	Metric Ton Uranium
MWd/MTU	Mega Watt Day per Metric Ton Uranium
NEOC	Near EOC
NFT	Nuclear Fuel Type
NRC	United States Nuclear Regulatory Commission
NSS	Nominal Scram Speed
NTSP	Nominal TSP
OLMCPR	MCPR Operating Limit
OOS	Out-Of-Service
OLTP	Original Licensed Thermal Power (100% OLTP, 3293 MW _t)
Pbypass	Power, below which TSV Position and TCV Fast Closure Scrams are bypassed
PLU	Power Load Unbalance
PLUOOS	PLU OOS
PSP	Power Setpoint
RBM	Rod Block Monitor
RPT	Recirculation Pump Trip
RPTOOS	RPT OOS
SDM	Shutdown Margin
SLMCPR	MCPR Safety Limit
SLO	Single Loop Operation
SRV	Safety Relief Valve
SRVOOS	SRV OOS
TAU	Vendor Specific Variable (τ) Representing Scram Timing.
TBV	Turbine Bypass Valve
TBVIS	Turbine Bypass Valves IS
TBVOOS	Turbine Bypass Valves OOS
TCV	Turbine Control Valve
TIP	Transverse In-Core Probe
TIPOOS	TIP OOS
TLO	Two Loop Operation
TSP	Trip Setpoint
TSSS	Technical Specification Scram Speed
TSV	Turbine Stop Valve
TVA	Tennessee Valley Authority

References

1. 0000-0077-8380-SRLR, Revision 0, **Supplemental Reload Licensing Report Browns Ferry 1 Reload 7 Cycle 8**, Global Nuclear Fuels, Inc., August 2008.
2. 0000-0044-1520-SRLR, Revision 0, **Supplemental Reload Licensing Report Browns Ferry 1 Reload 6 Cycle 7**, Global Nuclear Fuels, Inc., January 2007.
3. 0000-0077-8380-FBIR, Revision 0, **Fuel Bundle Information Report Browns Ferry 1 Reload 7 Cycle 8**, Global Nuclear Fuels, Inc., August 2008.
4. 0000-0043-8325-FBIR, Revision 0, **Fuel Bundle Information Report Browns Ferry 1 Reload 6 Cycle 7**, Global Nuclear Fuels, Inc., May 2006.
5. 0000-0079-8898-R0, Revision 0, **Browns Ferry Nuclear Plant Unit 1 Reload 7 Cycle 8 Off-Rated Limits Validation at a Rated Thermal Power of 3458 MW_t**, GE Hitachi Nuclear Energy, July 2008.
6. GNF S-0000-0091-6104, Revision 0, **GESTAR II Re-Examination of Bases for Browns Ferry Unit 1 Cycle 8**, Global Nuclear Fuels, Inc., November 7, 2008.

Methodology References

7. NEDE-24011-P-A-16, **General Electric Standard Application for Reactor Fuel**, October 2007.
8. NEDE-24011-P-A-16-US, **General Electric Standard Application for Reactor Fuel (Supplement for United States)**, October 2007.

PRNM Setpoint References

9. Filtered Setpoints - EDE-28-0990 Rev. 3 Supplement E, "PRNM (APRM, RBM, and RFM) Setpoint Calculations [ARTS/MELLL (NUMAC) - Power-Uprate Condition] for Tennessee Valley Authority Browns Ferry Nuclear Plant", October 1997
10. Unfiltered Setpoints - EDE-28-0990 Rev. 2 Supplement E, "PRNM (APRM, RBM, and RFM) Setpoint Calculations [ARTS/MELLL (NUMAC) - Power-Uprate Condition] for Tennessee Valley Authority Browns Ferry Nuclear Plant", October 1997.
11. GE Letter LB#: 262-97-133, *Browns Ferry Nuclear Plant Rod Block Monitor Setpoint Clarification - GE Proprietary Information*, September 12, 1997
12. NEDC-32433P, **Maximum Extended Load Line Limit and ARTS Improvement Program Analyses for Browns Ferry Nuclear Plant Unit 1, 2, and 3**, GE Nuclear Energy, April 1995

1 Introduction

In anticipation of cycle startup, it is necessary to describe the expected limits of operation.

1.1 Purpose

The primary purpose of this document is to satisfy requirements identified by unit technical specification section 5.6.5. This document may be provided, upon final approval, to the NRC.

1.2 Scope

This document will discuss the following areas:

- Average Planar Linear Heat Generation Rate (APLHGR) Limit
(Technical Specifications 3.2.1 and 3.7.5)
- Linear Heat Generation Rate (LHGR) Limit
(Technical Specification 3.2.3, 3.3.4.1, and 3.7.5)
- Minimum Critical Power Ratio Operating Limit (OLMCPR)
(Technical Specifications 3.2.2, 3.3.4.1, and 3.7.5)
- Average Power Range Monitor (APRM) Flow Biased Rod Block Trip Setting
(Technical Requirements Manual Section 5.3.1 and Table 3.3.4-1)
- Rod Block Monitor (RBM) Trip Setpoints and Operability
(Technical Specification Table 3.3.2.1-1)
- Shutdown Margin (SDM) Limit
(Technical Specification 3.1.1)

1.3 Fuel Loading

The core will contain all Global Nuclear Fuels, Inc., GE13/GE14 fuel. Nuclear fuel types used in the core loading are shown in Table 1.1. The core shuffle and final loading were assessed to determine Reference 1 applicability relative to minor loading changes. The vendor has determined Reference 1 remains applicable, per Reference 6.

1.4 Acceptability

Limits discussed in this document were generated based on NRC approved methodologies per References 7 and 8.

Table 1.1 Nuclear Fuel Types*

Fuel Description	Original Cycle	Number of Assemblies	Nuclear Fuel Type (NFT)	Fuel Names (Range)
GE13-P9DTB156-NOG-100T-146-T6-2887	7	56	3	JLX101-JLX156
GE13-P9DTB163-NOG-100T-146-T6-2888	7	52	12	JLX157-JLX208
GE14-P10DNAB157-NOG-100T-150-T6-2889	7	9	4	JLX209-JLX432
GE14-P10DNAB377-16GZ-100T-150-T6-2890	7	95	5	JLX433-JLX528
GE14-P10DNAB402-16GZ-100T-150-T6-2891	7	32	6	JLX529-JLX560
GE14-P10DNAB350-16GZ-100T-150-T6-2892	7	32	7	JLX561-JLX592
GE14-P10DNAB419-16GZ-100T-150-T6-2894	7	32	9	JLX613-JLX644
GE14-P10DNAB368-15GZ-100T-150-T6-2895	7	72	10	JLX645-JLX716
GE14-P10DNAB402-19GZ-100T-150-T6-2896	7	24	11	JLX717-JLX740
GE14-P10DNAB377-17GZ-100T-150-T6-2897	7	32	13	JLX741-JLX772
GE14-P10DNAB406-16GZ-100T-150-T6-3078	8	48	14	JYE101-JYE148
GE14-P10DNAB406-15GZ-100T-150-T6-3079	8	64	16	JYE245-JYE308
GE14-P10DNAB418-16GZ-100T-150-T6-3080	8	72	18	JYE357-JYE428
GE14-P10DNAB400-17GZ-100T-150-T6-3081	8	96	15	JYE149-JYE244
GE14-P10DNAB417-16GZ-100T-150-T6-3082	8	48	17	JYE309-JYE356

* The table identifies the expected fuel type breakdown in anticipation of final core loading. The final composition of the core depends upon uncertainties during the outage such as discovering a failed fuel bundle, or other bundle damage. Minor core loading changes, due to unforeseen events, will conform to the safety and monitoring requirements identified in this document.

2 APLHGR Limits

(Technical Specifications 3.2.1 & 3.7.5)

The APLHGR limit is determined by adjusting the rated power APLHGR limit for off-rated power, off-rated flow, and SLO conditions. The most limiting of these is then used as follows:

$$\text{APLHGR limit} = \text{MIN} (\text{APLHGR}_P, \text{APLHGR}_F, \text{APLHGR}_{\text{SLO}})$$

where:

APLHGR _P	off-rated power APLHGR limit	[APLHGR _{RATED} * MAPFAC _P]
APLHGR _F	off-rated flow APLHGR limit	[APLHGR _{RATED} * MAPFAC _F]
APLHGR _{SLO}	SLO APLHGR limit	[APLHGR _{RATED} * SLO Multiplier]

2.1 Rated Power and Flow Limit: APLHGR_{RATED}

The rated conditions APLHGR, for the different fuel types, are identified in References 1 & 2, and are shown in Figure 2.1 (GE13) and Figure 2.2 (GE14).

2.2 Off-Rated Power Dependent Limit: APLHGR_P


References 1 & 8, for both GE13 and GE14 fuel, does not specify a power dependent APLHGR. Therefore, MAPFAC_P is set to a value of 1.0.

2.3 Off-Rated Flow Dependent Limit: APLHGR_F

Reference 1 & 8, for both GE13 and GE14 fuel, does not specify a flow dependent APLHGR. Therefore, MAPFAC_F is set to a value of 1.0.


2.4 Single Loop Operation Limit: APLHGR_{SLO}

The single loop operation multiplier for GE13 fuel is 0.87; and for GE14 fuel is 0.93, per Reference 1.



Planar Avg. Exposure (GWd/MTU)	Planar Avg. Exposure (GWd/ST)	APLHGR Limit (kW/R)
0.00	0.00	13.42
21.74	19.72	13.42
30.00	27.22	12.29
70.00	63.50	8.90

Figure 2.1 APLHGR_{RATED} for GE13 Fuel



Planar Avg. Exposure (GWd/MTU)	Planar Avg. Exposure (GWd/ST)	APLHGR Limit (kW/R)
0.00	0.00	12.82
21.09	19.13	12.82
63.50	57.61	8.00
70.00	63.50	5.00

Figure 2.2 APLHGR_{RATED} for GE14 Fuel

2.5 Equipment Out-Of-Service Corrections

The limit shown in Figure 2.1 and Figure 2.2 are applicable for operation with all equipment In-Service as well as the following Equipment Out-Of-Service (EOOS) options; including combinations of the options. All equipment service conditions support 1 SRVOOS.

In-Service	All equipment In-Service
RPTOOS	EOC-Recirculation Pump Trip Out-Of-Service
TBVOOS	Turbine Bypass Valve(s) Out-Of-Service
PLUOOS	Power Load Unbalance Out-Of-Service
FHOOS (or FFWTR)	Feedwater Heaters Out-Of-Service or Final Feedwater Temperature Reduction

Single Recirculation Loop Operation (SLO) requires the application of the SLO multipliers to the rated APLHGR limits as described previously.

3 LHGR Limits

(Technical Specification 3.2.3, 3.3.4.1, & 3.7.5)

The LHGR limit is determined by adjusting the rated power LHGR limit for off-rated power and off-rated flow conditions. The most limiting of these is then used as follows:

$$\text{LHGR limit} = \text{MIN} (\text{LHGR}_P, \text{LHGR}_F)$$

where:

LHGR _P	off-rated power LHGR limit	[LHGR _{RATED} * LHGRFAC _P]
LHGR _F	off-rated flow LHGR limit	[LHGR _{RATED} * LHGRFAC _F]
LHGR _{SLO}	SLO LHGR limit	[LHGR _{RATED} * SLO Multiplier]

3.1 Rated Power and Flow Limit: LHGR_{RATED}

The rated conditions LHGR, for both fuel types, are identified in References 3 & 4, and are shown in Figure 3.1 (GE13) and Figure 3.2 (GE14) for UO2 fuel. Separate, concentration dependent limits apply for rods containing Gadolinium; for each bundle design LHGR limits are provided in References 3 & 4.

3.2 Off-Rated Power Dependent Limit: LHGR_P

For GE13/14 fuel, LHGR limits are adjusted for off-rated power conditions using the LHGRFAC_P multiplier provided in Reference 5. The multiplier is dependent on EOOS conditions. Consequently, the multipliers are shown in Figure 3.3 thru Figure 3.6, for various EOOS conditions/combinations.

3.3 Off-Rated Flow Dependent Limit: LHGR_F

For GE13/14 fuel, LHGR limits are adjusted for off-rated flow conditions using the LHGRFAC_F multiplier provided in Reference 5. LHGRFAC_F is fuel type independent. There are no EOOS dependencies for the multiplier. The multiplier is shown in Figure 3.7.

3.4 Single Loop Operation Limit: LHGR_{SLO}


The single loop operation multiplier for GE13 fuel is **0.87**; and for GE14 fuel is **0.93**, per Reference 1.

3.5 Equipment Out-Of-Service Corrections

The limit shown in Figure 3.1 is applicable for operation with all equipment In-Service as well as the following Equipment Out-Of-Service (EOOS) options; including combinations of the options. All equipment service conditions support 1 SRVOOS.


In-Service	All equipment In-Service
RPTOOS	EOC-Recirculation Pump Trip Out-Of-Service
TBVOOS	Turbine Bypass Valve(s) Out-Of-Service
PLUOOS	Power Load Unbalance Out-Of-Service
FHOOS (or FFWTR)	Feedwater Heaters Out-Of-Service or Final Feedwater Temperature Reduction

Off-rated power corrections shown in Figure 3.3 thru Figure 3.6 cover various EOOS scenarios. The limits have no dependency on FHOOS/FFWTR.




Pellet Exposure (GWd/MTU)	Pellet Exposure (GWd/ST)	LHGR Limit (kW/ft)
0.00	0.00	14.40
14.60	13.24	14.40
30.00	27.22	12.29
70.00	63.50	8.90

Figure 3.1 LHGR_{RATED} for GE13 UO₂ Fuel




Pellet Exposure (GWd/MTU)	Pellet Exposure (GWd/ST)	LHGR Limit (kW/ft)
0.00	0.00	13.40
16.00	14.51	13.40
63.50	57.61	8.00
70.00	63.50	5.00

Figure 3.2 LHGR_{RATED} for GE14 UO₂ Fuel




Core Power (% Rated)	LHGRFAC _p
100.0	1.000
50.0	0.739
50.0	0.688
30.0	0.614
Core Flow > 50% Rated	
30.0	0.460
25.0	0.428
Core Flow <= 50% Rated	
30.0	0.538
25.0	0.533

Figure 3.3 LHGRFAC_p for All EIS or RPTOOS Conditions
(with and without FHOOS)




Core Power (% Rated)	LHGRFAC _p
100.0	1.000
50.0	0.739
50.0	0.688
30.0	0.614
Core Flow > 50% Rated	
30.0	0.371
25.0	0.315
Core Flow <= 50% Rated	
30.0	0.549
25.0	0.473

Figure 3.4 LHGRFAC_p for RPTOOS and TBVOOS Conditions
(with and without FHOOS)




Core Power (% Rated)	LHGRFAC _p
100.0	1.000
70.0	0.843
60.0	0.725
30.0	0.614
Core Flow > 50% Rated	
30.0	0.460
25.0	0.428
Core Flow <= 50% Rated	
30.0	0.538
25.0	0.533

Figure 3.5 LHGRFAC_p for RPTOOS and PLUOOS Conditions
(with and without FHOOS)



Core Power (% Rated)	LHGRFAC _p
100.0	1.000
70.0	0.843
60.0	0.725
30.0	0.614
Core Flow > 50% Rated	
30.0	0.371
25.0	0.315
Core Flow <= 50% Rated	
30.0	0.549
25.0	0.473

Figure 3.6 LHGRFAC_p for RPTOOS, TBVOOS, and PLUOOS Conditions
(with and without FHOOS)



Max. Core Flow of 102.5%	
Core Flow (% Rated)	LHGRFAC _F
30.0	0.69
75.8	1
102.5	1

Max. Core Flow of 107.0%	
Core Flow (% Rated)	LHGRFAC _F
30.0	0.66
80.3	1
107.0	1

Figure 3.7 LHGRFAC_F
(Values bound all EOOS conditions)

(102.5% maximum core flow line is used to support 100% rated flow operation)
(107.0% maximum core flow line is used to support 105% rated flow operation, ICF)

4 OLMCPR Limits

(Technical Specification 3.2.2, 3.3.4.1, & 3.7.5)

The OLMCPR limit is determined by adjusting the rated power MCPR limit for off-rated power and off-rated flow conditions. The most limiting of these is then used as follows:

$$\text{OLMCPR limit} = \text{MAX} (\text{MCPR}_F, \text{MCPR}_P)$$

where:

MCPR_P	off-rated power MCPR limit	$[\text{MCPR}_{\text{RATED}} * K_P]$
MCPR_F	off-rated flow MCPR limit	
MCPR_{SLO}	SLO MCPR limit	$[\text{MCPR}_P + \text{SLO Adder}]$

4.1 Rated Power and Flow Limit: $\text{MCPR}_{\text{RATED}}$

The rated conditions MCPR, for both fuel types, are identified in Reference 1. The rated power and flow limits for various cycle exposure windows, and EOOS scenarios, are shown in Figure 4.2 thru Figure 4.5.

OLMCPR is calculated to be the most limiting of the flow or power dependent values.

4.1.1 Scram Timing Dependence

The $\text{MCPR}_{\text{RATED}}$ has a scram timing dependence which is assessed after control blade timing shortly after startup, and is discussed as follows:

$$\tau = 0.0 \quad \text{or,} \quad \frac{\tau_{\text{ave}} - \tau_B}{\tau_A - \tau_B}, \quad \text{whichever is greater}$$

where: $\tau_A = 1.096 \text{ sec}$ (analytical Option A scram time limit based on dropout time for notch position 36)

$$\tau_{\text{ave}} = \frac{\sum_{i=1}^n \tau_i}{n}$$

$$\tau_B = \mu + 1.65 * \sigma * \left[\frac{N}{n} \right]^{\frac{1}{2}}$$

where: $\mu = 0.830$ sec (mean scram time used in transient analysis based on dropout time for notch position 36)

$\sigma = 0.019$ sec (standard deviation of μ)

$N =$ Total number of active rods measured in Technical Specification Surveillance Requirement SR 3.1.4.1

$n =$ Number of surveillance rod tests performed to date in cycle

$\tau_i =$ Scram time (dropout time) from fully withdrawn to notch position 36 for the i^{th} rod

For reactor startup, Option A limits ($\tau=1.0$) shall be used prior to the determination of τ in accordance with SR 3.1.4.1.

4.1.2 Equipment Out-Of-Service (EOOS) Options

All equipment service conditions support 1 SRVOOS. EOOS options, including combinations, covered by MCPR_F limits are given by the following:

In-Service	All equipment In-Service
RPTOOS	EOC-Recirculation Pump Trip Out-Of-Service
TBVOOS	Turbine Bypass Valve(s) Out-Of-Service
PLUOOS	Power Load Unbalance Out-Of-Service
FHOOS (or FFWTR)	Feedwater Heaters Out-Of-Service (or Final Feedwater Temperature Reduction)

4.1.3 Exposure Dependent Limits

Exposures are tracked on a cycle exposure basis. Higher exposure limits are always more limiting, and may be used for any cycle exposure up to the ending exposure. Cycle Exposure Ranges are defined as follows:

BOC to MOC: where MOC corresponds to **EOR* - 2725 MWd/MTU** (2472 MWd/ST).
BOC to EOC

EOC exposure includes cycle extension options such as final feedwater reduction (FFTR) and power coastdown.

4.2 Flow Dependent MCPR Limit: MCPR_F

MCPR_F limits are dependent upon core flow (% of Rated), and the max core flow limit, (Rated or Increased Core Flow, ICF). MCPR_F limits are shown in Figure 4.1, per Reference 5. Limits are valid for all EOOS combinations. No adjustment is required for SLO conditions.

* EOR is defined as the end of rated power capability for rated core flow and nominal feedwater temperature conditions.

4.3 Single Loop Operation Limit: $MCPR_{SLO}$


The single loop operation adder for both GE13 and GE14 fuel is **0.02**, per Reference 1.

4.4 Power Dependent MCPR Limit: $MCPR_P$

$MCPR_P$ limits are dependent upon core power level (% of Rated) and EOOS conditions. K_P Multipliers and/or $MCPR_P$ values are provided in Figure 4.6 thru Figure 4.9. Determination of power dependent MCPR is differentiated relative to P_{bypass} (30% Rated Power) as follows:

$$P \geq 30\% \text{ (above } P_{bypass}\text{): } MCPR_P = [MCPR_{RATED} * K_P]$$

$$P < 30\% \text{ (below } P_{bypass}\text{): } MCPR_P = MCPR_P$$




Max. Core Flow of 102.5%	
Core Flow	MCPR _F
(% Rated)	
30.0	1.51
66.3	1.30
110.0	1.30

Max. Core Flow of 107.0%	
Core Flow	MCPR _F
(% Rated)	
30.0	1.55
71.9	1.30
110.0	1.30


Figure 4.1 MCPR_F
(Values bound all EOOS, and SLO conditions)

(102.5% maximum core flow line is used to support 100% rated flow operation)
(107.0% maximum core flow line is used to support 105% rated flow operation, ICF)




Out-of-Service Condition	Option A Tau = 1.0	Option B Tau = 0.0
All Equipment In-Service	1.38	1.38
RPTOOS	1.45	1.38
TBVOOS	1.43	1.40
PLUOOS	1.42	1.38
Combined RPTOOS & TBVOOS	1.50	1.43
Combined RPTOOS, TBVOOS, & PLUOOS	1.50	1.43

Figure 4.2 MCPR_{Rated} for GE13: BOC to MOC Exposure
(Values support 1SRVOOS & FHOOS/FFTR conditions)




Out-of-Service Condition	Option A Tau = 1.0	Option B Tau = 0.0
All Equipment In-Service	1.40	1.38
RPTOOS	1.52	1.41
TBVOOS	1.45	1.42
PLUOOS	1.49	1.38
Combined RPTOOS & TBVOOS	1.57	1.46
Combined RPTOOS, TBVOOS, & PLUOOS	1.57	1.46

Figure 4.3 $MCPR_{Rated}$ for GE13: BOC to EOC Exposure
(Values support 1SRVOOS & FHOOS/FFTR conditions)




Out-of-Service Condition	Option A Tau = 1.0	Option B Tau = 0.0
All Equipment In-Service	1.44	1.41
RPTOOS	1.55	1.44
TBVOOS	1.50	1.47
PLUOOS	1.52	1.41
Combined RPTOOS & TBVOOS	1.60	1.49
Combined RPTOOS, TBVOOS, & PLUOOS	1.60	1.49

Figure 4.4 MCPR_{Rated} for GE14: BOC to MOC Exposure
(Values support 1SRVOOS & FHOOS/FFTR conditions)



Out-of-Service Condition	Option A Tau = 1.0	Option B Tau = 0.0
All Equipment In-Service	1.47	1.44
RPTOOS	1.63	1.46
TBVOOS	1.54	1.51
PLUOOS	1.61	1.44
Combined RPTOOS & TBVOOS	1.69	1.52
Combined RPTOOS, TBVOOS, & PLUOOS	1.69	1.52

Figure 4.5 $MCPR_{Rated}$ for GE14: BOC to EOC Exposure
(Values support 1SRVOOS & FHOOS/FFTR conditions)




Core Power (% Rated)	K_p
100.0	1.000
60.0	1.150
50.0	1.237
50.0	1.384
30.0	1.552

Core Flow > 50% Rated	
$MCPR_p$	
30.0	2.640
25.0	2.820


Core Flow <= 50% Rated	
$MCPR_p$	
30.0	2.150
25.0	2.200

Figure 4.6 K_p Multiplier and $MCPR_p$ for All Equipment In Service or RPTOOS
(Values support 1SRVOOS & FHOOS/FFTR conditions)




Core Power (% Rated)	K _p
100.0	1.000
60.0	1.150
50.0	1.237
50.0	1.384
30.0	1.552
Core Flow > 50% Rated	
MCPR_p	
30.0	3.550
25.0	4.290
Core Flow ≤ 50% Rated	
MCPR_p	
30.0	2.630
25.0	3.060

Figure 4.7 K_p Multiplier and MCPR_p for RPTOOS and TBVOOS
(Values support 1SRVOOS & FHOOS/FFTR conditions)



Core Power (% Rated)	K _p
100.0	1.000
70.0	1.150
60.0	1.300
30.0	1.552
Core Flow > 50% Rated	
MCPR_p	
30.0	2.640
25.0	2.820
Core Flow ≤ 50% Rated	
MCPR_p	
30.0	2.150
25.0	2.200

Figure 4.8 K_p Multiplier and MCPR_p for RPTOOS and PLUOOS
(Values support 1SRVOOS & FHOOS/FFTR conditions)



Core Power (% Rated)	K_p
100.0	1.000
70.0	1.150
60.0	1.300
30.0	1.552

Core Flow > 50% Rated	
$MCPR_p$	
30.0	3.550
25.0	4.290

Core Flow <= 50% Rated	
$MCPR_p$	
30.0	2.630
25.0	3.060

Figure 4.9 K_p Multiplier and $MCPR_p$ for RPTOOS, TBVOOS, and PLUOOS
(Values support 1SRVOOS & FHOOS/FFTR conditions)

5 APRM Flow Biased Rod Block Trip Settings

(Technical Requirements Manual Section 5.3.1 and Table 3.3.4-1)

The APRM rod block trip setting is based upon References 9 & 10, and is defined by the following:

$$\text{SRB} \leq (0.66(W - \Delta W) + 61\%) \quad \text{Allowable Value}$$

$$\text{SRB} \leq (0.66(W - \Delta W) + 59\%) \quad \text{Nominal Trip Setpoint (NTSP)}$$

where:

SRB = Rod Block setting in percent of rated thermal power (3458 MW_t)

W = Loop recirculation flow rate in percent of rated

ΔW = Difference between two-loop and single-loop effective recirculation flow at the same core flow ($\Delta W = 0.0$ for two-loop operation)

The APRM rod block trip setting is clamped at a maximum allowable value of 115% (corresponding to a NTSP of 113%).

6 Rod Block Monitor (RBM) Trip Setpoints and Operability (Technical Specification Table 3.3.2.1-1)

The RBM trip setpoints and applicable power ranges, based on References 9 & 10, are shown in Table 6.1. Setpoints are based on an HTSP, unfiltered analytical limit of 117%. Unfiltered setpoints are consistent with a nominal RBM filter setting of 0.0 seconds; filtered setpoints are consistent with a nominal RBM filter setting less than 0.5 seconds.

Table 6.1 Analytical RBM Trip Setpoints*

RBM Trip Setpoint	Allowable Value (AV)	Nominal Trip Setpoint (NTSP)
LPSP	27%	25%
IPSP	62%	60%
HPSP	82%	80%
LTSP - unfiltered	124.7%	123.0%
- filtered	123.5%	121.8%
ITSP - unfiltered	119.7%	118.0%
- filtered	118.7%	117.0%
HTSP - unfiltered	114.7%	113.0%
- filtered	113.7%	112.0%
DTSP	90%	92%

Generic CRWE based OLMCPR values were reported and verified per References 9, 10, 11, and 12. However, Reference 12 generic values were developed assuming a SLMCPR ≤ 1.07 . Consequently, cycle specific CRWE analyses were performed to support the current SLMCPR; values are reported in Reference 1. Cycle specific analysis results indicate the SLMCPR remains protected for RBM inoperable conditions (i.e., unblocked). RBM setpoints in Technical Specification Table 3.3.2.1-1 are applicable as shown in Table 6.2.

Table 6.2 RBM Setpoint Applicability

Thermal Power (% Rated)	Applicable MCPR [†]	Notes from Table 3.3.2.1-1	Comment
> 27% and < 90%	< 1.70	(a), (b), (f), (h)	two loop operation
	< 1.74	(a), (b), (f), (h)	single loop operation
$\geq 90\%$	< 1.40	(g)	two loop operation [‡]

* Values are considered maximums. Using lower values, due to RBM system hardware/software limitations, is conservative, and acceptable.

[†] MCPR values shown correspond with, (support), SLMCPR values identified in Reference 1.

[‡] Greater than 90% rated power is not attainable in single loop operation.

7 Shutdown Margin Limit

(Technical Specification 3.1.1)

Assuming the strongest OPERABLE control blade is fully withdrawn, and all other OPERABLE control blades are fully inserted, the core shall be sub-critical and meet the following minimum shutdown margin:

$$\text{SDM} > 0.38\% \text{ dk/k}$$