


MITSUBISHI HEAVY INDUSTRIES, LTD.
16-5, KONAN 2-CHOME, MINATO-KU
TOKYO, JAPAN

December 25, 2008

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Attention: Mr. Jeffrey A. Ciocco

Docket No. 52-021
MHI Ref: UAP-HF-08290

Subject: MHI's Response to US-APWR DCD RAI No. 116-789 Revision 0

Reference: 1) "Request for Additional Information No. 116-789 Revision 0, SRP Section: 06.02.01.05, Application Section: 6.2.1.5" dated December 3, 2008.

With this letter, Mitsubishi Heavy Industries, Ltd. ("MHI") transmits to the U.S. Nuclear Regulatory Commission ("NRC") a document entitled "Response to Request for Additional Information No. 116-789 Revision 0."

Enclosed is the response to one RAI contained within Reference 1.

Please contact Dr. C. Keith Paulson, Senior Technical Manager, Mitsubishi Nuclear Energy Systems, Inc. if the NRC has questions concerning any aspect of the submittals. His contact information is below.

Sincerely,



Yoshiaki Ogata,
General Manager- APWR Promoting Department
Mitsubishi Heavy Industries, LTD.

Enclosure:

1. Response to Request for Additional Information No. 116-789 Revision 0

CC: J. A. Ciocco
C. K. Paulson

Contact Information

C. Keith Paulson, Senior Technical Manager
Mitsubishi Nuclear Energy Systems, Inc.
300 Oxford Drive, Suite 301
Monroeville, PA 15146
E-mail: ck_paulson@mnes-us.com
Telephone: (412) 373-6466

DOB/
NRC

Docket No. 52-021
MHI Ref: UAP-HF-08290

Enclosure 1

UAP-HF-08290
Docket Number 52-021

Response to Request for Additional Information
No. 116-789 Revision 0

December 2008

RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

12/25/2008

**US-APWR Design Certification
Mitsubishi Heavy Industries
Docket No. 52-021**

RAI NO.: 116-789
SRP SECTION: 06.02.01.05- MINIMUM CONTAINMENT PRESSURE
ANALYSIS FOR EMERGENCY CORE COOLING SYSTEM
PERFORMANCE CAPABILITY STUDIES
APPLICATION SECTION: SRP 6.2.1.5
DATE OF RAI ISSUE: 12/3/2008

QUESTION NO. : 06.02.01.05-2

6.2.1.5: It is not clear, how the containment calculated back pressure is used as a boundary condition in WCOBRA/TRAC calculations. Please explain/clarify.

ANSWER:

Calculated containment back pressure is provided as input data by the pressure versus time table corresponding to the form of the BREAK component of WCOBRA/TRAC. No margin is considered for the calculated back pressure in the procedure.

Impact on DCD

There is no impact on the DCD

Impact on COLA

There is no impact on the COLA

Impact on PRA

There is no impact on the PRA

This completes MHI's response to the NRC's question.