

RI - DNMS Licensee Event Report Disposition

Licensee:	West Virginia Paving Co.		
Event Description:	Proxler Moisture Density Gauge Stolen from the bed of a truck		
License No:	47-1767000	Market No:	0302140
Event Date:	08/14/08	Report Date:	08/15/08
		MLER-RI:	2008-025
		HQ Ops Event #:	

1. REPORTING REQUIREMENT

<input type="checkbox"/> 10 CFR 20.1906 Package Contamination <input checked="" type="checkbox"/> 10 CFR 20.2201 Theft or Loss <input type="checkbox"/> 10 CFR 20.2203 30 Day Report <input type="checkbox"/> Other _____	<input type="checkbox"/> 10 CFR 30.50 Report <input type="checkbox"/> 10 CFR 35.3045 Medical Event <input type="checkbox"/> License Condition
--	---

2. REGION I RESPONSE

<input type="checkbox"/> Immediate Site Inspection <input type="checkbox"/> Special Inspection <input type="checkbox"/> Telephone Inquiry <input type="checkbox"/> Preliminary Notification/Report <input checked="" type="checkbox"/> Information Entered in RI Log <input type="checkbox"/> Report Referred To: _____	<table style="width: 100%;"> <tr> <td style="width: 50%;">Inspector/Date</td> <td style="width: 50%;"></td> </tr> <tr> <td>Inspector/Date</td> <td></td> </tr> <tr> <td>Inspector/Date</td> <td></td> </tr> <tr> <td><input type="checkbox"/> Daily Report</td> <td></td> </tr> <tr> <td><input checked="" type="checkbox"/> Review at Next Inspection</td> <td></td> </tr> </table>	Inspector/Date		Inspector/Date		Inspector/Date		<input type="checkbox"/> Daily Report		<input checked="" type="checkbox"/> Review at Next Inspection	
Inspector/Date											
Inspector/Date											
Inspector/Date											
<input type="checkbox"/> Daily Report											
<input checked="" type="checkbox"/> Review at Next Inspection											

3. REPORT EVALUATION

<input checked="" type="checkbox"/> Description of Event <input checked="" type="checkbox"/> Levels of RAM Involved <input checked="" type="checkbox"/> Cause of Event	<input type="checkbox"/> Corrective Actions <input type="checkbox"/> Calculations Adequate <input type="checkbox"/> Additional Information Requested from Licensee
--	--

4. MANAGEMENT DIRECTIVE 8.3 EVALUATION

<input type="checkbox"/> Release w/Exposure > Limits <input type="checkbox"/> Repeated Inadequate Control <input type="checkbox"/> Exposure 5x Limits <input type="checkbox"/> Potential Fatality <input type="checkbox"/> If any of the above are involved: <input type="checkbox"/> Considered Need for IIT	<input type="checkbox"/> Deliberate Misuse w/Exposure > Limits <input type="checkbox"/> Pkging Failure > 10 rads/hr or Contamination > 1000x Limits <input type="checkbox"/> Large# Indivs w/Exp > Limits or Medical Deterministic Effects <input type="checkbox"/> Unique Circumstances or Safeguards Concerns <input type="checkbox"/> Considered Need for AIT
--	--

Decision/Made By/Date: _____

5. MANAGEMENT DIRECTIVE 8.10 EVALUATION (additional evaluation for medical events only)

<input type="checkbox"/> Timeliness - Inspection Meets Requirements (5 days for overdose / 10 days for underdose) <input type="checkbox"/> Medical Consultant Used-Name of Consultant/Date of Report: _____ <input type="checkbox"/> Medical Consultant Determined Event Directly Contributed to Fatality <input type="checkbox"/> Device Failure with Possible Adverse Generic Implications <input type="checkbox"/> HQ or Contractor Support Required to Evaluate Consequences
--

6. SPECIAL INSTRUCTIONS OR COMMENTS

Issued Dismissed with licensee - No further action except routine.

<input type="checkbox"/> Non-Public	Inspector Signature: _____	Date: _____
<input checked="" type="checkbox"/> Public-SUNSI REVIEW COMPLETE	Branch Chief Initials: <u>Maui Miller</u>	Date: <u>12/17/08</u>

West Virginia Paving Co.
P.O. Box 544
Dunbar, W V 25064

October 31, 2008

US NRC
Region One

Re: Licensee event report as per ss 20.2201

Dear Sirs :

(i) On August 14 , 2008 one 3400 series nuclear density moisture guage was stolen from our technicians vehicle.

(ii) The technician parked his vehicle in the motel lot for the night. The thief or thieves cut through all the security measures and removed the unit.

(iii) My speculation would be , from past incidents of this sort involving other individuals , the unit could be at the bottom of the local river or hidden somewhere . I think it unlikely that the people guilty of this could dispose of it for monetary gain .


(iv) The only people exposed to the unit would be my technician (he is monitered) and the thief or thieves and we may never know .

(v) A report was filed with the local law enforcement and an ad was placed in the newspaper with a description of the unit offering a reward for recovery or information leading to the recovery .

(vi) The technician was in compliance with security regulations . We discussed using heavier security measures (heavier chains etc.) , but the other people would probably get a bigger bolt cutter. I did discuss this matter with my people and stressed the urgency of the matter that the security measures are very important .

If I can be of any other assistance , please call 304 - 720 - 6402 .

Sincerely,



Dallas Boggess

R S O

RECEIVED
REGION 1
2008 NOV - 3 PM 1:09

"The Creston Public School purchased two self-luminous signs in 1990. The signs were SRB model Betalux E 10 with 9.75 curies of tritium in each sign. The school did an inventory in 2005. The School did not return its annual inventory in 2006. The school was dissolved in May of 2006 and the property was transferred to Leigh Public School. Leigh Public Schools informed the Agency [Nebraska Division of Radioactive materials] that the property was transferred to the Village of Creston. Representatives of the Village of Creston, speculate that the school was possibly left unlocked and unattended for a period time and during that time period the signs were removed. The disposition of the signs is unknown. The Agency made numerous attempts to determine the status of the signs and ultimately the Agency determined that the signs are lost."

The licensee discovered that the signs were missing on 01/01/2008.

Manufacturer: SRB Technologies Inc
 Serial Number: 13152 and 13153

Nebraska event NE080006

THIS MATERIAL EVENT CONTAINS A "LESS THAN CAT 3" LEVEL OF RADIOACTIVE MATERIAL

Sources that are "Less than IAEA Category 3 sources," are either sources that are very unlikely to cause permanent injury to individuals or contain a very small amount of radioactive material that would not cause any permanent injury. Some of these sources, such as moisture density gauges or thickness gauges that are Category 4, the amount of unshielded radioactive material, if not safely managed or securely protected, could possibly - although it is unlikely - temporarily injure someone who handled it or were otherwise in contact with it, or who were close to it for a period of many weeks.

This source is not amongst those sources or devices identified by the IAEA Code of Conduct for the Safety & Security of Radioactive Sources to be of concern from a radiological standpoint. Therefore is it being categorized as a less than Category 3 source

TQP

Other Nuclear Material	Event Number: 44415
Rep Org: WEST VIRGINIA PAVING Licensee: WEST VIRGINIA PAVING Region: 1 City: DUNBAR State: WV County: License #: 47-17070-01 Agreement: N Docket: NRC Notified By: DALLAS BOGGESS HQ OPS Officer: STEVE SANDIN	Notification Date: 08/15/2008 Notification Time: 10:07 [ET] Event Date: 08/15/2008 Event Time: 06:00 [EDT] Last Update Date: 08/15/2008
Emergency Class: NON EMERGENCY 10 CFR Section: 20.2201(a)(1)(i) - LOST/STOLEN LNM>1000X	Person (Organization): DANIEL HOLODY (R1) PATRICE BUBAR (FSME) ILTAB via email ()

This material event contains a "Less than Cat 3" level of radioactive material.

Event Text

TROXLER MOISTURE DENSITY GAUGE STOLEN FROM THE BED OF A TRUCK

An authorized gauge user while working at a jobsite site in McDowell County, WV stayed overnight at a motel in Grundy, VA which is just across the state line. Sometime between 2200 hours on 8/14/08 and 0600 hours on 8/15/08, a Troxler Model 3440 (S/N 27535) containing two sources, i.e., 8 millicuries Cs-137 and 40 millicuries Am-241/Be, was stolen from the bed of the employee's pickup truck. The Troxler gauge was locked inside its case and contained inside a

locked transport box chained and bolted to the bed of the truck. The chain had been cut and the lock on the transport box broken to remove both the Troxler gauge and its case.

The licensee notified the NRC Region I Office (Marie Miller) and filed a police report with the Grundy City Police department who are investigating the theft. The licensee has made no determination whether a reward will be offered.

THIS MATERIAL EVENT CONTAINS A "LESS THAN CAT 3" LEVEL OF RADIOACTIVE MATERIAL

Sources that are "Less than IAEA Category 3 sources," are either sources that are very unlikely to cause permanent injury to individuals or contain a very small amount of radioactive material that would not cause any permanent injury. Some of these sources, such as moisture density gauges or thickness gauges that are Category 4, the amount of unshielded radioactive material, if not safely managed or securely protected, could possibly - although it is unlikely - temporarily injure someone who handled it or were otherwise in contact with it, or who were close to it for a period of many weeks.

TOP

Power Reactor	Event Number: 44418
Facility: TURKEY POINT Region: 2 State: FL Unit: [] [4] [] RX Type: [3] W-3-LP,[4] W-3-LP NRC Notified By: DAVID FUNK HQ OPS Officer: MARK ABRAMOVITZ	Notification Date: 08/15/2008 Notification Time: 17:41 [ET] Event Date: 08/15/2008 Event Time: 16:04 [EDT] Last Update Date: 08/15/2008
Emergency Class: NON EMERGENCY 10 CFR Section: 50.72(b)(2)(i) - PLANT S/D REQD BY TS	Person (Organization): RANDY MUSSER (R2)

Unit	SCRAM Code	RX CRIT	Initial PWR	Initial RX Mode	Current PWR	Current RX Mode
4	N	Y	100	Power Operation	0	Hot Standby

Event Text

SHUT DOWN REQUIRED BY TECHNICAL SPECIFICATIONS

"Administratively entered technical specification 3.0.3 and complying with the action statement."

A 0.19 gpm leak developed from a structural weld crack on the charging system (4B reactor coolant pump seal injection line). This leak is isolable. The cause of the crack is being evaluated.

The licensee notified the NRC Resident Inspector.

TOP

Power Reactor	Event Number: 44419
Facility: DIABLO CANYON Region: 4 State: CA Unit: [] [2] [] RX Type: [1] W-4-LP,[2] W-4-LP NRC Notified By: JAMES DILLIS HQ OPS Officer: PETE SNYDER	Notification Date: 08/17/2008 Notification Time: 03:37 [ET] Event Date: 08/17/2008 Event Time: 00:12 [PDT] Last Update Date: 08/17/2008
Emergency Class: UNUSUAL EVENT 10 CFR Section: 50.72(a) (1) (i) - EMERGENCY DECLARED 50.72(b)(3)(iv)(A) - VALID SPECIF SYS ACTUATION	Person (Organization): RYAN LANTZ (R4) JARED WERMIEL (NRR) ELMO COLLINS (R4)