

Southern California Edison Company (San Onofre Nuclear Generating Station) EA-08-296

On December 19, 2008, a Notice of Violation (NOV) was issued for a violation associated with a White Significance Determination Finding involving a violation of 10 CFR Part 50, Appendix B, Criterion V, "Instructions, Procedures, and Drawings." Specifically, maintenance and work control personnel failed to develop appropriate instructions or procedures, and failed to include quantitative or qualitative steps to ensure the maintenance activities on safety-related battery. This failure resulted in a safety-related battery being inoperable between March 2004 and March 25, 2008.