

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

January 8, 2009

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Serial No. 08-0782
NL&OS/ETS R0
Docket Nos. 50-338/339
License Nos. NPF-4/7

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)
NORTH ANNA POWER STATION UNITS 1 AND 2
ONE-TIME RISK-INFORMED EXTENSION TO THE COMPLETION TIME FOR EDG
FUEL OIL STORAGE TANK RECOATING - REVISION TO THE TECHNICAL
SPECIFICATIONS BASES

By letter dated December 17, 2007 (Serial No. 07-0803), Dominion requested license amendments to permit a one-time extended 14-day completion time for each of the two underground diesel fuel oil storage tanks to permit removal of the current coating and recoating of the tanks in preparation for use of ultra-low sulfur diesel fuel oil. Associated TS Bases changes were also provided for information.

Subsequent to the submittal of the license amendment request (LAR), the NRC technical review staff noted that the Bases revision included in the LAR incorporated the discussion associated with the new TS Action A.4 Completion Time Note into the APPLICABILITY section of the TS 3.8.3 Bases. This discussion should have been incorporated into the ACTIONS section of the Bases.

Therefore, following NRC approval of the LAR, but prior to implementation of the license amendments, Dominion will revise the North Anna Units 1 and 2 TS B 3.8.3 Bases to relocate the discussion associated with the new TS Action A.4 Completion Time Note from the APPLICABILITY section to the ACTIONS section.

If you have any questions regarding this submittal, please contact Mr. E. Thomas Shaub at (804) 273-2763.

Sincerely,


J. Alan Price
Vice President – Nuclear Engineering

Commitment made in this letter:

1. Following NRC approval of the LAR, but prior to implementation of the license amendment, Dominion will revise the North Anna Units 1 and 2 TS B 3.8.3 Bases to relocate the discussion associated with the new TS Action A.4 Completion Time Note from the APPLICABILITY section to the ACTIONS section.

cc: U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW
Suite 23T85
Atlanta, Georgia 30303

NRC Senior Resident Inspector
North Anna Power Station

Mr. J. F. Stang, Jr.
NRC Project Manager
U. S. Nuclear Regulatory Commission
One White Flint North
Mail Stop O-8G9A
11555 Rockville Pike
Rockville, Maryland 20852

Ms. D. N. Wright
NRC Project Manager
U. S. Nuclear Regulatory Commission
One White Flint North
Mail Stop O-8H4A
11555 Rockville Pike
Rockville, Maryland 20852