

From: Fred Lyon
Sent: Tuesday, January 13, 2009 8:31 AM
To: 'LORFING, DAVID N'
Cc: 'BURMEISTER, BARRY M'; 'BYRD, RONALD W'; 'BRICE, WILLIAM B'
Subject: Acceptance Review (TAC No. ME0215)

By letter dated December 8, 2008, Entergy Operations, Inc. (Entergy), submitted a license amendment request for River Bend Station, Unit 1. The proposed amendment adds a license condition to allow a one-time extension of surveillance requirements involving the 18-month channel calibration and logic system functional tests for one channel of the reactor water level instrumentation system. The extension is to account for the effects of rescheduling the next refueling outage from early to late 2009.

The purpose of this letter is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the technical specifications) must fully describe the changes requested, and follow as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it provides technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence.

E-mail Properties

Mail Envelope Properties ()

Subject: Acceptance Review (TAC No. ME0215)
Sent Date: 01/13/2009 8:18:56 AM
Received Date: 01/13/2009 8:30:00 AM
From: Fred Lyon

Created By: Fred.Lyon@nrc.gov

Recipients:
DLORFIN@entergy.com ('LORFING, DAVID N')
Tracking Status: None

BBURMEI@entergy.com ('BURMEISTER, BARRY M')

Tracking Status: None

RBYRD@entergy.com ('BYRD, RONALD W')

Tracking Status: None

WBRICE@entergy.com ('BRICE, WILLIAM B')

Tracking Status: None

Post Office:

| Files | Size | Date & Time |
|---------|-------|-------------|
| MESSAGE | 10653 | 01/13/2009 |

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received: