

MANUAL HARD COPY DISTRIBUTION
DOCUMENT TRANSMITTAL 2008-61839

USER INFORMATION:

GERLACH*ROSE M EMPL#:028401 CA#: 0363
Address: NUCSA2
Phone#: 254-3194

TRANSMITTAL INFORMATION:

TO: GERLACH*ROSE M 12/19/2008
LOCATION: USNRC

FROM: NUCLEAR RECORDS DOCUMENT CONTROL CENTER (NUCSA-2)

THE FOLLOWING CHANGES HAVE OCCURRED TO THE HARDCOPY OR ELECTRONIC MANUAL ASSIGNED TO YOU. HARDCOPY USERS MUST ENSURE THE DOCUMENTS PROVIDED MATCH THE INFORMATION ON THIS TRANSMITTAL. WHEN REPLACING THIS MATERIAL IN YOUR HARDCOPY MANUAL, ENSURE THE UPDATE DOCUMENT ID IS THE SAME DOCUMENT ID YOU'RE REMOVING FROM YOUR MANUAL. TOOLS FROM THE HUMAN PERFORMANCE TOOL BAG SHOULD BE UTILIZED TO ELIMINATE THE CHANCE OF ERRORS.

ATTENTION: "REPLACE" directions do not affect the Table of Contents, Therefore no TOC will be issued with the updated material.

TRM2 - TECHNICAL REQUIREMENTS MANUAL UNIT 2

REMOVE MANUAL TABLE OF CONTENTS DATE: 12/17/2008

ADD MANUAL TABLE OF CONTENTS DATE: 12/18/2008

CATEGORY: DOCUMENTS TYPE: TRM2

A001
NRR

ID: TEXT 4.4
ADD: REV: 1

REMOVE: REV:0

CATEGORY: DOCUMENTS TYPE: TRM2
ID: TEXT B3.3.10
REMOVE: REV:0

ADD: REV: 1

CATEGORY: DOCUMENTS TYPE: TRM2
ID: TEXT LOES
REMOVE: REV:47

ADD: REV: 48

ANY DISCREPANCIES WITH THE MATERIAL PROVIDED, CONTACT DCS @ X3107 OR X3136 FOR ASSISTANCE. UPDATES FOR HARDCOPY MANUALS WILL BE DISTRIBUTED WITHIN 3 DAYS IN ACCORDANCE WITH DEPARTMENT PROCEDURES. PLEASE MAKE ALL CHANGES AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX UPON COMPLETION OF UPDATES. FOR ELECTRONIC MANUAL USERS, ELECTRONICALLY REVIEW THE APPROPRIATE DOCUMENTS AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX.

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

Table Of Contents

Issue Date: 12/18/2008

<u>Procedure Name</u>	<u>Rev</u>	<u>Issue Date</u>	<u>Change ID</u>	<u>Change Number</u>
TEXT LOES Title: LIST OF EFFECTIVE SECTIONS	48	12/18/2008		
TEXT TOC Title: TABLE OF CONTENTS	13	01/31/2008		
TEXT 1.1 Title: USE AND APPLICATION DEFINITIONS	0	11/19/2002		
TEXT 2.1 Title: PLANT PROGRAMS AND SETPOINTS PLANT PROGRAMS	1	02/04/2005		
TEXT 2.2 Title: PLANT PROGRAMS AND SETPOINTS INSTRUMENT TRIP SETPOINT TABLE	7	05/23/2008		
TEXT 3.0 Title: APPLICABILITY TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY	4	05/23/2008		
TEXT 3.1.1 Title: REACTIVITY CONTROL SYSTEMS ANTICIPATED TRANSIENT WITHOUT SCRAM ALTERNATE ROD INJECTION (ATWS-ARI) INSTRUMENTATION	1	11/09/2007		
TEXT 3.1.2 Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD DRIVE (CRD) HOUSING SUPPORT	0	11/19/2002		
TEXT 3.1.3 Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD BLOCK INSTRUMENTATION	3	04/09/2007		
TEXT 3.1.4 Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD SCRAM ACCUMULATORS INSTRUMENTATION AND CHECK VALVE	0	11/19/2002		
TEXT 3.2.1 Title: CORE OPERATING LIMITS CORE OPERATING LIMITS REPORT (COLR)	7	04/19/2007		

SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.3.1 0 11/19/2002
Title: INSTRUMENTATION RADIATION MONITORING INSTRUMENTATION

TEXT 3.3.2 2 11/09/2007
Title: INSTRUMENTATION SEISMIC MONITORING INSTRUMENTATION

TEXT 3.3.3 2 11/09/2007
Title: INSTRUMENTATION METEOROLOGICAL MONITORING INSTRUMENTATION

TEXT 3.3.4 5 05/23/2008
Title: INSTRUMENTATION TRM POST-ACCIDENT MONITORING INSTRUMENTATION

TEXT 3.3.5 0 11/19/2002
Title: INSTRUMENTATION THIS PAGE INTENTIONALLY LEFT BLANK

TEXT 3.3.6 2 10/19/2005
Title: INSTRUMENTATION TRM ISOLATION ACTUATION INSTRUMENTATION

TEXT 3.3.7 1 11/09/2007
Title: INSTRUMENTATION MAIN TURBINE OVERSPEED PROTECTION SYSTEM

TEXT 3.3.8 1 10/22/2003
Title: INSTRUMENTATION TRM RPS INSTRUMENTATION

TEXT 3.3.9 2 04/09/2007
Title: INSTRUMENTATION LPRM UPSCALE ALARM INSTRUMENTATION

TEXT 3.3.10 1 12/14/2004
Title: INSTRUMENTATION REACTOR RECIRCULATION PUMP MG SET STOPS

TEXT 3.3.11 1 10/22/2003
Title: INSTRUMENTATION MVP ISOLATION INSTRUMENTATION

TEXT 3.4.1 1 04/26/2006
Title: REACTOR COOLANT SYSTEM REACTOR COOLANT SYSTEM CHEMISTRY

SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.4.2	0	11/19/2002	Title: REACTOR COOLANT SYSTEM STRUCTURAL INTEGRITY
TEXT 3.4.3	1	11/09/2007	Title: REACTOR COOLANT SYSTEM REACTOR COOLANT SYSTEM (RCS)
TEXT 3.4.4	1	12/14/2004	Title: REACTOR COOLANT SYSTEM REACTOR RECIRCULATION FLOW AND ROD LINE LIMIT
TEXT 3.4.5	1	04/26/2006	Title: REACTOR COOLANT SYSTEM REACTOR VESSEL MATERIALS
TEXT 3.5.1	1	02/04/2005	Title: ECCS AND RCIC ADS MANUAL INHIBIT
TEXT 3.5.2	1	11/09/2007	Title: ECCS AND RCIC ECCS AND RCIC SYSTEM MONITORING INSTRUMENTATION
TEXT 3.5.3	0	11/19/2002	Title: ECCS AND RCIC LONG TERM NITROGEN SUPPLY TO ADS
TEXT 3.6.1	0	11/19/2002	Title: CONTAINMENT VENTING OR PURGING
TEXT 3.6.2	0	11/19/2002	Title: CONTAINMENT SUPPRESSION CHAMBER-TO-DRYWELL VACUUM BREAKER POSITION INDICATION
TEXT 3.6.3	0	11/19/2002	Title: CONTAINMENT SUPPRESSION POOL ALARM INSTRUMENTATION
TEXT 3.6.4	0	11/19/2002	Title: CONTAINMENT PRIMARY CONTAINMENT CLOSED SYSTEM BOUNDARIES
TEXT 3.7.1	0	11/19/2002	Title: PLANT SYSTEMS EMERGENCY SERVICE WATER SYSTEM (ESW) SHUTDOWN

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.7.2 0 11/19/2002
Title: PLANT SYSTEMS ULTIMATE HEAT SINK (UHS) AND GROUND WATER LEVEL

TEXT 3.7.3.1 1 04/26/2006
Title: PLANT SYSTEMS FIRE SUPPRESSION WATER SUPPLY SYSTEM

TEXT 3.7.3.2 2 04/26/2006
Title: PLANT SYSTEMS SPRAY AND SPRINKLER SYSTEMS

TEXT 3.7.3.3 2 08/18/2005
Title: PLANT SYSTEMS CO2 SYSTEMS

TEXT 3.7.3.4 1 04/26/2006
Title: PLANT SYSTEMS HALON SYSTEMS

TEXT 3.7.3.5 1 04/26/2006
Title: PLANT SYSTEMS FIRE HOSE STATIONS

TEXT 3.7.3.6 1 04/26/2006
Title: PLANT SYSTEMS YARD FIRE HYDRANTS AND HYDRANT HOSE HOUSES

TEXT 3.7.3.7 1 04/26/2006
Title: PLANT SYSTEMS FIRE RATED ASSEMBLIES

TEXT 3.7.3.8 7 11/09/2007
Title: PLANT SYSTEMS FIRE DETECTION INSTRUMENTATION

TEXT 3.7.4 1 04/26/2006
Title: PLANT SYSTEMS SOLID RADWASTE SYSTEM

TEXT 3.7.5.1 0 11/19/2002
Title: PLANT SYSTEMS MAIN CONDENSER OFFGAS HYDROGEN MONITOR

TEXT 3.7.5.2 0 11/19/2002
Title: PLANT SYSTEMS MAIN CONDENSER OFFGAS EXPLOSIVE GAS MIXTURE

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.7.5.3 1 04/26/2006

Title: PLANT SYSTEMS LIQUID HOLDUP TANKS

TEXT 3.7.6 2 06/27/2008

Title: PLANT SYSTEMS ESSW PUMPHOUSE VENTILATION

TEXT 3.7.7 2 09/05/2008

Title: PLANT SYSTEMS MAIN CONDENSER OFFGAS PRETREATMENT LOGARITHMIC RADIATION MONITORING INSTRUMENTATION

TEXT 3.7.8 6 06/21/2007

Title: PLANT SYSTEMS SNUBBERS

TEXT 3.7.9 1 08/28/2006

Title: PLANT SYSTEMS CONTROL STRUCTURE HVAC

TEXT 3.7.10 1 12/14/2004

Title: PLANT SYSTEMS SPENT FUEL STORAGE POOLS (SFSPS)

TEXT 3.8.1 2 02/04/2005

Title: ELECTRICAL POWER PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

TEXT 3.8.2.1 2 11/09/2007

Title: ELECTRICAL POWER MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - CONTINUOUS

TEXT 3.8.2.2 2 12/14/2004

Title: ELECTRICAL POWER MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - AUTOMATIC

TEXT 3.8.3 0 11/19/2002

Title: ELECTRICAL POWER DIESEL GENERATOR (DG) MAINTENANCE ACTIVITIES

TEXT 3.8.4 1 02/04/2005

Title: ELECTRICAL POWER 24 VDC ELECTRICAL SUBSYSTEM

TEXT 3.8.5 0 11/19/2002

Title: ELECTRICAL POWER DEGRADED VOLTAGE PROTECTION

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.8.6	0	11/19/2002	Title: ELECTRICAL POWER EMERGENCY SWITCHGEAR ROOM COOLING
TEXT 3.8.7	0	12/14/2006	Title: BATTERY MAINTENANCE AND MONITORING PROGRAM
TEXT 3.9.1	0	11/19/2002	Title: REFUELING OPERATIONS DECAY TIME
TEXT 3.9.2	0	11/19/2002	Title: REFUELING OPERATIONS COMMUNICATIONS
TEXT 3.9.3	0	11/19/2002	Title: REFUELING OPERATIONS REFUELING PLATFORM
TEXT 3.10.1	1	04/26/2006	Title: MISCELLANEOUS SEALED SOURCE CONTAMINATION
TEXT 3.10.2	1	04/09/2007	Title: MISCELLANEOUS SHUTDOWN MARGIN TEST RPS INSTRUMENTATION
TEXT 3.10.3	1	04/26/2006	Title: MISCELLANEOUS INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)
TEXT 3.10.4	1	08/28/2006	Title: MISCELLANEOUS LEADING EDGE FLOW METER (LEFM)
TEXT 3.11.1.1	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS LIQUID EFFLUENTS CONCENTRATION
TEXT 3.11.1.2	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS LIQUID EFFLUENTS DOSE
TEXT 3.11.1.3	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS LIQUID WASTE TREATMENT SYSTEM

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.11.1.4	1	12/14/2004	Title: RADIOACTIVE EFFLUENTS LIQUID RADWASTE EFFLUENT MONITORING INSTRUMENTATION
TEXT 3.11.1.5	2	05/02/2007	Title: RADIOACTIVE EFFLUENTS RADIOACTIVE LIQUID PROCESS MONITORING INSTRUMENTATION
TEXT 3.11.2.1	3	04/26/2006	Title: RADIOACTIVE EFFLUENTS DOSE RATE
TEXT 3.11.2.2	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS DOSE - NOBLE GASES
TEXT 3.11.2.3	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS DOSE - IODINE, TRITIUM, AND RADIONUCLIDES IN PARTICULATE FORM
TEXT 3.11.2.4	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS GASEOUS RADWASTE TREATMENT SYSTEM
TEXT 3.11.2.5	3	11/14/2006	Title: RADIOACTIVE EFFLUENTS VENTILATION EXHAUST TREATMENT SYSTEM
TEXT 3.11.2.6	3	05/02/2007	Title: RADIOACTIVE EFFLUENTS RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION
TEXT 3.11.3	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS TOTAL DOSE
TEXT 3.11.4.1	3	04/26/2006	Title: RADIOACTIVE EFFLUENTS MONITORING PROGRAM
TEXT 3.11.4.2	2	04/26/2006	Title: RADIOACTIVE EFFLUENTS LAND USE CENSUS
TEXT 3.11.4.3	1	04/26/2006	Title: RADIOACTIVE EFFLUENTS INTERLABORATORY COMPARISON PROGRAM

SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 3.12.1 0 11/19/2002
 Title: LOADS CONTROL PROGRAM CRANE TRAVEL-SPENT FUEL STORAGE POOL

TEXT 3.12.2 4 04/17/2008
 Title: LOADS CONTROL PROGRAM HEAVY LOADS REQUIREMENTS

TEXT 3.12.3 0 11/19/2002
 Title: LOADS CONTROL PROGRAM LIGHT LOADS REQUIREMENTS

TEXT B3.0 4 05/23/2008
 Title: APPLICABILITY BASES TECHNICAL REQUIREMENT FOR OPERATION (TRO) APPLICABILITY

TEXT B3.1.1 1 11/09/2007
 Title: REACTIVITY CONTROL SYSTEM BASES ANTICIPATED TRANSIENT WITHOUT SCRAM ALTERNATE
 ROD INJECTION (ATWS-ARI) INSTRUMENTATION

TEXT B3.1.2 0 11/19/2002
 Title: REACTIVITY CONTROL SYSTEM BASES CONTROL ROD DRIVE (CRD) HOUSING SUPPORT

TEXT B3.1.3 3 04/10/2007
 Title: REACTIVITY CONTROL SYSTEM BASES CONTROL ROD BLOCK INSTRUMENTATION

TEXT B3.1.4 0 11/19/2002
 Title: REACTIVITY CONTROL SYSTEM BASES CONTROL ROD SCRAM ACCUMULATORS INSTRUMENTATION
 AND CHECK VALVE

TEXT B3.2.1 0 11/19/2002
 Title: CORE OPERATING LIMITS BASES CORE OPERATING LIMITS REPORT (COLR)

TEXT B3.3.1 0 11/19/2002
 Title: INSTRUMENTATION BASES RADIATION MONITORING INSTRUMENTATION

TEXT B3.3.2 1 11/09/2007
 Title: INSTRUMENTATION BASES SEISMIC MONITORING INSTRUMENTATION

TEXT B3.3.3 2 11/09/2007
 Title: INSTRUMENTATION BASES METEOROLOGICAL MONITORING INSTRUMENTATION

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.3.4	3	11/09/2007	Title: INSTRUMENTATION BASES TRM POST ACCIDENT MONITORING (PAM) INSTRUMENTATION
TEXT B3.3.5	2	11/09/2007	Title: INSTRUMENTATION BASES THIS PAGE INTENTIONALLY LEFT BLANK
TEXT B3.3.6	3	10/19/2005	Title: INSTRUMENTATION BASES TRM ISOLATION ACTUATION INSTRUMENTATION
TEXT B3.3.7	1	11/09/2007	Title: INSTRUMENTATION BASES MAIN TURBINE OVERSPEED PROTECTION SYSTEM
TEXT B3.3.8	1	10/22/2003	Title: INSTRUMENTATION BASES TRM RPS INSTRUMENTATION
TEXT B3.3.9	2	04/10/2007	Title: INSTRUMENTATION BASES LPRM UPSCALE ALARM INSTRUMENTATION
TEXT B3.3.10	1	12/18/2008	Title: INSTRUMENTATION BASES REACTOR RECIRCULATION PUMP MG SET STOPS
TEXT B3.3.11	1	10/22/2003	Title: INSTRUMENTATION BASES MVP ISOLATION INSTRUMENTATION
TEXT B3.4.1	0	11/19/2002	Title: REACTOR COOLANT SYSTEM BASES REACTOR COOLANT SYSTEM CHEMISTRY
TEXT B3.4.2	0	11/19/2002	Title: REACTOR COOLANT SYSTEM BASES STRUCTURAL INTEGRITY
TEXT B3.4.3	1	11/09/2007	Title: REACTOR COOLANT SYSTEM BASES HIGH/LOW PRESSURE INTERFACE LEAKAGE MONITOR
TEXT B3.4.4	0	11/19/2002	Title: REACTOR COOLANT SYSTEM BASES REACTOR RECIRCULATION FLOW AND ROD LINE LIMIT

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.4.5	0	11/19/2002
Title: REACTOR COOLANT SYSTEM BASES REACTOR VESSEL MATERIALS		
TEXT B3.5.1	0	11/19/2002
Title: ECCS AND RCIC BASES ADS MANUAL INHIBIT		
TEXT B3.5.2	1	11/09/2007
Title: ECCS AND RCIC BASES ECCS AND RCIC SYSTEM MONITORING INSTRUMENTATION		
TEXT B3.5.3	1	11/09/2007
Title: ECCS AND RCIC BASES LONG TERM NITROGEN SUPPLY TO ADS		
TEXT B3.6.1	0	11/19/2002
Title: CONTAINMENT BASES VENTING OR PURGING		
TEXT B3.6.2	0	11/19/2002
Title: CONTAINMENT BASES SUPPRESSION CHAMBER-TO-DRYWELL VACUUM BREAKER POSITION INDICATION		
TEXT B3.6.3	1	04/19/2007
Title: CONTAINMENT BASES SUPPRESSION POOL ALARM INSTRUMENTATION		
TEXT B3.6.4	1	12/14/2004
Title: CONTAINMENT BASES PRIMARY CONTAINMENT CLOSED SYSTEM BOUNDARIES		
TEXT B3.7.1	0	11/19/2002
Title: PLANT SYSTEMS BASES EMERGENCY SERVICE WATER SYSTEM (SHUTDOWN)		
TEXT B3.7.2	0	11/19/2002
Title: PLANT SYSTEMS BASES ULTIMATE HEAT SINK (UHS) GROUND WATER LEVEL		
TEXT B3.7.3.1	2	01/07/2008
Title: PLANT SYSTEMS BASES FIRE SUPPRESSION WATER SUPPLY SYSTEM		
TEXT B3.7.3.2	2	04/26/2006
Title: PLANT SYSTEMS BASES SPRAY AND SPRINKLER SYSTEMS		

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.7.3.3 0 11/19/2002

Title: PLANT SYSTEMS BASES CO2 SYSTEMS

TEXT B3.7.3.4 1 04/26/2006

Title: PLANT SYSTEMS BASES HALON SYSTEMS

TEXT B3.7.3.5 1 04/26/2006

Title: PLANT SYSTEMS BASES FIRE HOSE STATIONS

TEXT B3.7.3.6 1 04/26/2006

Title: PLANT SYSTEMS BASES YARD FIRE HYDRANTS AND HYDRANT HOSE HOUSES

TEXT B3.7.3.7 0 11/19/2002

Title: PLANT SYSTEMS BASES FIRE RATED ASSEMBLIES

TEXT B3.7.3.8 1 01/12/2004

Title: PLANT SYSTEMS BASES FIRE DETECTION INSTRUMENTATION

TEXT B3.7.4 0 11/19/2002

Title: PLANT SYSTEMS BASES SOLID RADWASTE SYSTEM

TEXT B3.7.5.1 0 11/19/2002

Title: PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS HYDROGEN MONITOR

TEXT B3.7.5.2 0 11/19/2002

Title: PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS EXPLOSIVE GAS MIXTURE

TEXT B3.7.5.3 0 11/19/2002

Title: PLANT SYSTEMS BASES LIQUID HOLDUP TANKS

TEXT B3.7.6 2 06/27/2008

Title: PLANT SYSTEMS BASES ESSW PUMPHOUSE VENTILATION

TEXT B3.7.7 2 01/31/2008

Title: PLANT SYSTEMS BASES MAIN CONDENSER OFFGAS PRETREATMENT LOGARITHMIC RADIATION MONITORING INSTRUMENTATION

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.7.8 3 06/21/2007

Title: PLANT SYSTEMS BASES SNUBBERS

TEXT B3.7.9 1 12/14/2004

Title: PLANT SYSTEMS BASES CONTROL STRUCTURE HVAC

TEXT B3.7.10 1 12/14/2004

Title: PLANT SYSTEMS BASES SPENT FUEL STORAGE POOLS

TEXT B3.8.1 1 02/04/2005

Title: ELECTRICAL POWER BASES PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

TEXT B3.8.2.1 0 11/19/2002

Title: ELECTRICAL POWER BASES MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - CONTINUOUS

TEXT B3.8.2.2 1 09/17/2004

Title: ELECTRICAL POWER BASES MOTOR OPERATED VALVES (MOV) THERMAL OVERLOAD PROTECTION - AUTOMATIC

TEXT B3.8.3 0 11/19/2002

Title: ELECTRICAL POWER BASES DIESEL GENERATOR (DG) MAINTENANCE ACTIVITIES

TEXT B3.8.4 0 11/19/2002

Title: ELECTRICAL POWER BASES 24 VDC ELECTRICAL POWER SUBSYSTEM

TEXT B3.8.5 0 11/19/2002

Title: ELECTRICAL POWER BASES DEGRADED VOLTAGE PROTECTION

TEXT B3.8.6 1 02/04/2005

Title: ELECTRICAL POWER BASES EMERGENCY SWITCHGEAR ROOM COOLING

TEXT B3.8.7 0 12/14/2006

Title: BATTERY MAINTENANCE AND MONITORING PROGRAM

TEXT B3.9.1 0 11/19/2002

Title: REFUELING OPERATIONS BASES DECAY TIME

SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.9.2	0	11/19/2002	Title: REFUELING OPERATIONS BASES COMMUNICATIONS
TEXT B3.9.3	0	11/19/2002	Title: REFUELING OPERATIONS BASES REFUELING PLATFORM
TEXT B3.10.1	0	11/19/2002	Title: MISCELLANEOUS BASES SEALED SOURCE CONTAMINATION
TEXT B3.10.2	1	04/10/2007	Title: MISCELLANEOUS BASES SHUTDOWN MARGIN TEST RPS INSTRUMENTATION
TEXT B3.10.3	0	11/19/2002	Title: MISCELLANEOUS BASES INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)
TEXT B3.10.4	0	11/19/2002	Title: MISCELLANEOUS BASES LEADING EDGE FLOW METER (LEFM)
TEXT B3.11.1.1	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LIQUID EFFLUENTS CONCENTRATION
TEXT B3.11.1.2	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LIQUID EFFLUENTS DOSE
TEXT B3.11.1.3	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LIQUID WASTE TREATMENT SYSTEM
TEXT B3.11.1.4	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES LIQUID RADWASTE EFFLUENT MONITORING INSTRUMENTATION
TEXT B3.11.1.5	0	11/19/2002	Title: RADIOACTIVE EFFLUENTS BASES RADIOACTIVE LIQUID PROCESS MONITORING INSTRUMENTATION
TEXT B3.11.2.1	1	12/14/2004	Title: RADIOACTIVE EFFLUENTS BASES DOSE RATE

SSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT B3.11.2.2	0	11/19/2002
Title: RADIOACTIVE EFFLUENTS BASES DOSE - NOBLE GASES		
TEXT B3.11.2.3	0	11/19/2002
Title: RADIOACTIVE EFFLUENTS BASES DOSE - IODINE, TRITIUM, AND RADIONUCLIDES IN PARTICULATES FORM		
TEXT B3.11.2.4	0	11/19/2002
Title: RADIOACTIVE EFFLUENTS BASES GASEOUS RADWASTE TREATMENT SYSTEM		
TEXT B3.11.2.5	4	11/14/2006
Title: RADIOACTIVE EFFLUENTS BASES VENTILATION EXHAUST TREATMENT SYSTEM		
TEXT B3.11.2.6	1	01/27/2004
Title: RADIOACTIVE EFFLUENTS BASES RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION		
TEXT B3.11.3	0	11/19/2002
Title: RADIOACTIVE EFFLUENTS BASES TOTAL DOSE		
TEXT B3.11.4.1	2	01/06/2006
Title: RADIOACTIVE EFFLUENTS BASES MONITORING PROGRAM		
TEXT B3.11.4.2	0	11/19/2002
Title: RADIOACTIVE EFFLUENTS BASES LAND USE CENSUS		
TEXT B3.11.4.3	0	11/19/2002
Title: RADIOACTIVE EFFLUENTS BASES INTERLABORATORY COMPARISON PROGRAM		
TEXT B3.12.1	1	10/04/2007
Title: LOADS CONTROL PROGRAM BASES CRANE TRAVEL-SPENT FUEL STORAGE POOL		
TEXT B3.12.2	0	11/19/2002
Title: LOADS CONTROL PROGRAM BASES HEAVY LOADS REQUIREMENTS		
TEXT B3.12.3	0	11/19/2002
Title: LOADS CONTROL PROGRAM BASES LIGHT LOADS REQUIREMENTS		

SSSES MANUAL

Manual Name: TRM2

Manual Title: TECHNICAL REQUIREMENTS MANUAL UNIT 2

TEXT 4.1 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS ORGANIZATION

TEXT 4.2 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS REPORTABLE EVENT ACTION

TEXT 4.3 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS SAFETY LIMIT VIOLATION

TEXT 4.4 1 12/18/2008

Title: ADMINISTRATIVE CONTROLS PROCEDURES & PROGRAMS

TEXT 4.5 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS REPORTING REQUIREMENTS

TEXT 4.6 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS RADIATION PROTECTION PROGRAM

TEXT 4.7 0 09/27/2003

Title: ADMINISTRATIVE CONTROLS TRAINING

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 48

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
TOC	TABLE OF CONTENTS	01/30/2008
1.0	USE AND APPLICATION	
	Page TRM / 1.0-1	08/31/1998
	Page TRM / 1.0-2	10/04/2002
	Page TRM / 1.0-3	08/31/1998
2.0	PLANT PROGRAMS	
	Page 2.0-1	08/31/1998
	Pages TRM / 2.0-2 and TRM 2.0-3	01/28/2005
	Page TRM / 2.0-4	06/25/2002
	Page TRM / 2.0-5	04/12/1999
	Page TRM / 2.0-6	03/27/2007
	Page TRM / 2.0-7	05/15/2008
	Page TRM / 2.0-8	12/03/2004
	Pages TRM / 2.0-9 through TRM / 2.0-11	11/15/2004
	Page TRM / 2.0-12	03/27/2007
	Pages TRM / 2.0-13 and TRM / 2.0-14	11/15/2004
	Page TRM / 2.0-15	11/15/2005
3.0	APPLICABILITY	
	Pages TRM / 3.0-1 and TRM / 3.0-2	04/14/2008
	Page TRM / 3.0-3	03/15/2002
	Page TRM / 3.0-4	11/30/2005
3.1	REACTIVITY CONTROL SYSTEMS	
	Page TRM / 3.1-1	10/31/2007
	Pages TRM / 3.1-2 through TRM / 3.1-5	08/31/1998
	Pages TRM / 3.1-6 through TRM / 3.1-8	03/27/2007
	Pages TRM / 3.1-9 and TRM / 3.1-9a	02/18/1999
	Page TRM / 3.1-10	02/18/1999
3.2	CORE OPERATING LIMITS REPORT	
	Page TRM / 3.2-1	08/31/1998
	Pages TRM / 3.2-2 through TRM / 3.2-48	03/30/2007
3.3	INSTRUMENTATION	
	Pages TRM / 3.3-1 through TRM / 3.3-3	07/16/1999
	Pages TRM / 3.3-4 and TRM / 3.3-5	10/31/2007
	Page 3.3-6	08/31/1998
	Page TRM 3.3-7	10/31/2007
	Page 3.3-8	08/31/1998
	Page TRM / 3.3-9	04/12/2007
	Page TRM / 3.3-9a	12/17/1998
	Page TRM / 3.3-10	10/31/2007
	Page TRM / 3.3-11	06/02/2005
	Page TRM / 3.3-11a	04/14/2008

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 48

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Page TRM / 3.3-12	03/30/2001
	Page TRM / 3.3-13	09/13/2005
	Page TRM / 3.3-14	12/14/1998
	Page TRM / 3.3-15	10/22/2003
	Page TRM / 3.3-16	06/27/2001
	Page TRM / 3.3-17	06/14/2002
	Page TRM / 3.3-18	10/31/2007
	Pages TRM / 3.3-19 and TRM / 3.3-20	10/22/2003
	Page TRM / 3.3-21	03/27/2007
	Page TRM / 3.3-21a	11/15/2004
	Pages TRM / 3.3-21b through TRM / 3.3-21d	03/27/2007
	Page TRM / 3.3-22	12/03/2004
	Pages TRM / 3.3-23 and TRM / 3.3-24	05/16/2003
	Page TRM / 3.3-25	10/22/2003
3.4	REACTOR COOLANT SYSTEM	
	Page TRM / 3.4-1	03/31/2006
	Pages 3.4-2 through 3.4-5	10/23/1998
	Pages 3.4-6 through 3.4-9	08/31/1998
	Page 3.4-10	10/31/2007
	Page 3.4-11	08/31/1998
	Page TRM / 3.4-12	12/03/2004
	Page TRM / 3.4-13	03/31/2006
3.5	EMERGENCY CORE COOLING AND RCIC	
	Page TRM / 3.5-1	01/28/2005
	Pages 3.5-2 and 3.5-3	08/31/1998
	Page TRM / 3.5-4	10/31/2007
	Pages 3.5-5 through 3.5-7	08/31/1998
3.6	CONTAINMENT	
	Pages 3.6-1 through 3.6-4	08/31/1998
	Page TRM / 3.6-5	01/07/2002
	Page 3.6-6	08/31/1998
	Pages TRM / 3.6-7 through TRM / 3.6-9	12/31/2002
3.7	PLANT SYSTEMS	
	Pages TRM / 3.7-1 and TRM / 3.7-2	07/29/1999
	Page 3.7-3	08/31/1998
	Pages TRM / 3.7-4 and TRM / 3.7-5	03/31/2006
	Pages TRM / 3.7-6 through TRM / 3.7-8	08/02/1999
	Page TRM / 3.7-9	03/31/2006
	Page TRM / 3.7-10	08/16/2005
	Page TRM / 3.7-11	01/21/2000
	Pages TRM / 3.7-12 and TRM / 3.7-13	08/02/1999
	Page TRM / 3.7-14	08/09/2005
	Pages TRM / 3.7-15 and TRM / 3.7-16	08/02/1999
	Page TRM / 3.7-17	03/31/2006

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 48

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
	Page TRM / 3.7-18	08/02/1999
	Page TRM / 3.7-19	03/31/2006
	Pages TRM / 3.7-20 through TRM / 3.7-22	08/02/1999
	Pages TRM / 3.7-23 and TRM / 3.7-24	03/31/2006
	Pages TRM / 3.7-25 and TRM / 3.7-26	08/02/1999
	Page TRM / 3.7-27	10/31/2007
	Page TRM / 3.7-28	11/29/2006
	Page TRM / 3.7-29	11/16/2001
	Page TRM / 3.7-30	11/30/2005
	Page TRM / 3.7-31	11/16/2001
	Page TRM / 3.7-32	01/09/2004
	Page TRM / 3.7-33	10/05/2002
	Page TRM / 3.7-34	03/31/2006
	Pages TRM / 3.7-35 and TRM / 3.7-36	02/01/1999
	Pages 3.7-37 through 3.7-38	08/31/1998
	Page TRM / 3.7-39	03/31/2006
	Page TRM / 3.7-40	02/14/2005
	Page TRM / 3.7-40a	06/20/2008
	Page TRM / 3.7-41	09/04/2008
	Page TRM / 3.7-42	08/31/1998
	Pages TRM / 3.7-43 through TRM / 3.7-45	10/05/2006
	Page TRM / 3.7-46	06/07/2007
	Page TRM / 3.7-47	10/05/2006
	Page TRM / 3.7-48	06/07/2007
	Page TRM / 3.7-49	03/09/2001
	Page TRM / 3.7-50	08/16/2006
	Page TRM / 3.7-51	12/03/2004
	Page TRM / 3.7-52	04/15/2003
	Page TRM / 3.7-53	07/29/1999
3.8	ELECTRICAL POWER	
	Page TRM / 3.8-1	04/02/2002
	Pages TRM / 3.8-2 and TRM / 3.8-3	01/28/2005
	Page TRM / 3.8-4	01/31/2005
	Pages TRM / 3.8-5 and TRM / 3.8-6	04/02/2002
	Pages TRM / 3.8-7 through TRM / 3.8-10	10/31/2007
	Page TRM / 3.8-11	08/10/2004
	Page TRM / 3.8-12	12/03/2004
	Pages 3.8-13 and 3.8-14	08/31/1998
	Page TRM / 3.8-15	01/28/2005
	Pages TRM / 3.8-16 and TRM / 3.8-17	04/02/2002
	Page 3.8-18	02/01/1999
	Page TRM / 3.8-19	04/02/2002
	Page TRM / 3.8-20	02/01/1999
	Pages TRM / 3.8-21 through TRM / 3.8-23	06/06/1999
	Pages 3.8-24 and 3.8-25	08/31/1998
	Pages TRM / 3.8-26 through TRM / 3.8-29	11/29/2006

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 48

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
3.9	REFUELING OPERATIONS Pages 3.9-1 through 3.9-3	08/31/1998
3.10	MISCELLANEOUS Page TRM / 3.10-1 Pages 3.10-2 through 3.10-4 Pages TRM / 3.10-5 and TRM / 3.10-6 Page TRM / 3.10-7 Page TRM / 3.10-8	03/31/2006 08/30/1998 03/27/2007 03/31/2006 08/16/2006
3.11	RADIOACTIVE EFFLUENTS Page TRM / 3.11-1 Pages 3.11-2 through 3.11-3 Page TRM / 3.11-4 Page 3.11-5 Page TRM / 3.11-6 Pages 3.11-7 through 3.11-9 Page TRM / 3.11-10 Pages 3.11-11 and 3.11-12 Page TRM / 3.11-13 Page TRM / 3.11-14 Pages 3.11-15 and 3.11-16 Page TRM / 3.11-17 Page 3.11-18 Page TRM / 3.11-19 Pages TRM / 3.11-20 and TRM / 3.11-21 Page TRM / 3.11-22 Page TRM / 3.11-23 Page TRM / 3.11-24 Page TRM / 3.11-25 Pages TRM / 3.11-26 through TRM / 3.11-28 Page TRM / 3.11-29 Pages TRM 3.11-30 through TRM / 3.11-32 Page TRM / 3.11-33 Page 3.11-34 Page TRM / 3.11-35 Pages TRM / 3.11-36 through TRM / 3.11-39 Pages 3.11-40 through 3.11-44 Page TRM / 3.11-45 Page 3.11-46 Page TRM / 3.11-47	03/31/2006 08/31/1998 03/31/2006 08/31/1998 03/31/2006 08/31/1998 12/03/2004 08/31/1998 04/12/2007 12/03/1004 09/01/1998 03/31/2006 08/31/1998 08/15/2005 03/31/2006 04/02/2002 11/14/2006 05/13/2005 04/12/2007 01/21/2004 12/03/2004 01/21/2004 03/31/2006 08/31/1998 03/31/2006 11/30/2005 08/31/1998 03/31/2006 08/31/1998 03/31/2006

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 48

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
3.12	LOADS CONTROL PROGRAM	
	Pages TRM / 3.12-1 through TRM / 3.12-3	02/05/1999
	Page TRM / 3.12-4	03/14/2008
	Page TRM / 3.12-5	02/05/1999
4.0	ADMINISTRATIVE CONTROLS	
	Pages TRM / 4.0-1 through TRM / 4.0-3	08/31/1998
	Page TRM / 4.0-4	12/11/2008
	Pages TRM / 4.0-5 through TRM / 4.0-8	08/31/1998

SUSQUEHANNA STEAM ELECTRIC STATION
LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

PPL Rev. 48

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B 3.0	APPLICABILITY BASES	
	Pages TRM / B 3.0-1 through TRM / B 3.0-3	08/31/1998
	Page TRM / B 3.0-4	01/10/2007
	Page TRM / B 3.0-5	04/14/2008
	Page TRM / B 3.0-6	08/31/1998
	Page TRM / B 3.0-7	04/12/2007
	Pages TRM / B 3.0-8 through TRM / B 3.0-10	08/31/1998
	Pages TRM / B 3.0-11 and TRM / B 3.0-12	03/15/2002
	Pages TRM / B 3.0-13 and TRM / B 3.0-14	11/30/2005
	Page TRM / B 3.0-15	03/15/2002
B 3.1	REACTIVITY CONTROL SYSTEMS BASES	
	Page TRM / B 3.1-1	07/13/1999
	Pages TRM / B 3.1-2 and TRM / B 3.1-3	10/31/2007
	Page B 3.1-4	08/31/1998
	Pages TRM / B 3.1-5 through TRM / B 3.1-7	03/27/2007
	Page TRM / B 3.1-8	02/18/1999
B 3.2	CORE OPERATING LIMITS BASES	
	Page B 3.2-1	08/31/1998
B 3.3	INSTRUMENTATION BASES	
	Page TRM / B 3.3-1	04/07/2000
	Pages TRM / B 3.3-2 and TRM / B-3.3-2a	10/31/2007
	Pages TRM / B 3.3-3 and TRM / B 3.3-3a	10/31/2007
	Pages TRM / B 3.3-4 and TRM / B 3.3-5	05/30/2006
	Pages TRM / B 3.3-6 through TRM / B 3.3-9	10/31/2007
	Page B 3.3-10	08/31/1998
	Pages TRM / B 3.3-11 and TRM / B 3.3-12	09/13/2005
	Page TRM / B 3.3-13	12/03/2004
	Page TRM / B 3.3-14	06/25/2002
	Page TRM / B 3.3-14a	10/31/2007
	Page TRM / B 3.3-14b	06/14/2002
	Pages TRM / B 3.3-15 through TRM / B 3.3-17	10/22/2003
	Pages TRM / B 3.3-18 and TRM / B 3.3-19	03/27/2007
	Pages TRM / B 3.3-19a through TRM / B 3.3-19e	03/27/2007
	Page TRM / B 3.3-20	12/11/2008
	Page TRM / B 3.3-21	05/16/2003
	Page TRM / B 3.3-22	10/22/2003
	Page TRM / B 3.3-23	05/16/2003
B 3.4	REACTOR COOLANT SYSTEM BASES	
	Pages B 3.4-1 through B 3.4-3	08/31/1998
	Pages TRM / B-3.4-4 and TRM / B 3.4-4a	10/31/2007
	Page TRM / B 3.4-5	10/15/1999
	Page B 3.4-6	08/31/1998

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B 3.5	ECCS AND RCIC BASES	
	Pages B 3.5-1 and B 3.5-2	08/31/1998
	Pages TRM / B 3.5-3 and TRM / B 3.5-3a	10/31/2007
	Page B 3.5-4	08/31/1998
	Page TRM / B 3.5-5	10/31/2007
B 3.6	CONTAINMENT BASES	
	Page TRM / B 3.6-1	07/26/2001
	Page TRM / B 3.6-2	02/01/1999
	Page B 3.6-3	08/31/1998
	Page TRM / B 3.6-4	03/29/2007
	Page TRM / B 3.6-5	04/04/2007
	Page TRM / B 3.6-6	12/03/2004
	Pages TRM / B 3.6-7 through TRM / B 3.6-11	12/31/2002
B 3.7	PLANT SYSTEMS BASES	
	Pages B 3.7-1 and B 3.7-2	08/31/1998
	Pages TRM / B 3.7-3 and TRM / B 3.7-3a	12/27/2007
	Page TRM / B 3.7-4	03/31/2006
	Page TRM / B 3.7-5	08/02/1999
	Pages TRM / B 3.7-6 and TRM / B 3.7-6a	03/31/2006
	Pages TRM / B 3.7-7 and TRM / B 3.7-7a	08/02/1999
	Page TRM / B 3.7-8	08/02/1999
	Page TRM / B 3.7-9	03/31/2006
	Page TRM / B 3.7-10	08/02/1999
	Pages TRM / B 3.7-10a through TRM / B 3.7-11a	03/31/2006
	Pages TRM / B 3.7-12 through TRM / B 3.7-14	08/02/1999
	Pages TRM / B 3.7-14a and TRM / B 3.7-14b	01/09/2004
	Pages TRM / B 3.7-15 and TRM / B 3.7-16	02/01/1999
	Pages B 3.7-17 through B 3.7-20	08/31/1998
	Page TRM / B 3.7-21	02/14/2005
	Page TRM / B 3.7-21a	06/20/2008
	Pages TRM / B 3.7-22 and TRM / B 3.7-23	01/30/2008
	Pages TRM / B 3.7-24 through TRM / B 3.7-29	10/05/2006
	Page TRM / B 3.7-30	06/07/2007
	Pages TRM / B 3.7-30a and TRM / B 3.7-30b	10/05/2006
	Page TRM / B 3.7-31	12/03/2004
	Page TRM / B 3.7-32	03/09/2001
	Page TRM / B 3.7-33	04/15/2003
	Page TRM / B 3.7-34	12/03/2004
	Page TRM / B 3.7-35	07/05/2000

LIST OF EFFECTIVE SECTIONS (TECHNICAL REQUIREMENTS MANUAL)

<u>Section</u>	<u>Title</u>	<u>Effective Date</u>
B 3.8	ELECTRICAL POWER BASES	
	Page TRM / B 3.8-1	04/02/2002
	Pages TRM / B 3.8-2 and TRM / B 3.8-2a	01/28/2005
	Page TRM / B 3.8-3	04/02/2002
	Page TRM / B 3.8-3a	04/02/2002
	Page TRM / B 3.8-4	04/02/2002
	Page TRM / B 3.8-4a	08/10/2004
	Page TRM / B 3.8-5	08/31/1998
	Pages TRM / B 3.8-6 through TRM / B 3.8-16	04/02/2002
	Page TRM / B 3.8-17	01/28/2005
	Pages TRM / B 3.8-18 through TRM / B 3.8-24	11/29/2006
B.3.9	REFUELING OPERATIONS BASES	
	Pages B 3.9-1 and B 3.9-2	08/31/1998
	Pages B 3.9-3 through B 3.9-7	10/23/1998
B 3.10	MISCELLANEOUS BASES	
	Page B 3.10-1	08/31/1998
	Pages TRM / B 3.10-2 and TRM / B 3.10-3	03/27/2007
	Pages TRM / B 3.10-4 and TRM / B 3.10-5	08/23/1999
	Pages TRM / B 3.10-6 and TRM / 3.10-7	04/17/2002
B.3.11	RADIOACTIVE EFFLUENTS BASES	
	Pages B 3.11-1 through B 3.11-9	08/31/1998
	Page TRM / B 3.11-10	02/01/1999
	Pages TRM/B 3.11-11 and TRM/B 3.11-11a	04/07/2000
	Pages TRM/B 3.11-12 and TRM/B 3.11-13	02/01/1999
	Page TRM / B 3.11-14	12/03/2004
	Page TRM / B 3.11-15	02/01/1999
	Pages B 3.11-16 through B 3.11-19	08/31/1998
	Page TRM / B 3.11-20	04/02/2002
	Page TRM / B 3.11-20a	04/02/2002
	Page TRM / B 3.11-21	05/13/2005
	Pages TRM / B 3.11-22 and TRM / B 3.11-23	11/14/2006
	Page TRM / B 3.11-23a	05/13/2005
	Pages TRM / B 3.11-24 and TRM / B 3.11-25	01/21/2004
	Pages B 3.11-26 through B 3.11-27	08/31/1998
	Pages TRM / B 3.11-28 and TRM / B 3.11-29	11/30/2005
	Page TRM / B 3.11-30	12/03/2004
	Pages B 3.11-31 through B 3.11-35	08/31/1998
	Page TRM / B 3.11-36	02/12/1999
B.3.12	LOADS CONTROL PROGRAM BASES	
	Page TRM / B 3.12-1	09/19/2007
	Pages TRM / B 3.12-2 and TRM / B 3.12-3	02/05/1999

TRM2 text LOES.doc
12/5/08

4.0 ADMINISTRATIVE CONTROLS

4.4 Procedures and Programs

4.4.1 Reserved

4.4.2 Reserved

4.4.3 Reserved

4.4.4 The following programs shall be established, implemented, and maintained:

a. In-Plant Radiation Monitoring

A program, which will ensure the capability to accurately determine the airborne iodine concentration in vital areas under accident conditions. This program shall include the following:

1. Training of personnel
 2. Procedures for monitoring
 3. Provisions for maintenance of sampling and analysis equipment
-

B 3.3.10 Reactor Recirculation Pump MG Set Stops

BASES

TRO

In the case of recirculation control system failures (e.g., transistors, resistors, etc.) causing upscale signal failure, the reactor is protected by high pressure or high flux scram. Such faults have been analyzed in Chapter 15 and include both MG sets going to full speed simultaneously. For this analysis, the master flow controller is assumed to fail such that it causes a speed increase for both recirculation pumps.

Pump overspeed occurs during the course of a LOCA due to blowdown through the broken loop pump. Design studies determined that rotating component failure missiles caused by the overspeed was not sufficient to cause damage to the containment or to vital equipment, consequently no protective or preventative provision is made for this pump overspeed condition.

No credit is taken for electrical or mechanical stops to limit the speed of the recirculation pumps in these analyzed events.

Normally, operator implementation or procedural controls maintains the recirculation system within the system design limits and initial conditions of analyzed events. The reactor recirculation pump MG set stops are set with some operating margin above these limits. As such, the stops serve as backups to the operator control over normal operation. Additionally, in the event of a fault that results in inadvertent MG set speed increases above the normal operating limits, the stops can provide protection from the automatic reactor scram that terminate the analyzed worse case events. Therefore, the MG set stops also serve to provide additional plant reliability protection.

The electrical stop is the primary means for backing up procedural controls and for automatically limiting recirculation flow. The electrical stop is the MG Set Positioner Controller Stop. The mechanical stop provides a diverse and redundant automatic backup to the electrical stop flow limiting mechanism.

ACTIONS

The Actions are modified by a Note allowing separate Condition entry for each recirculation pump. The Required Actions provide appropriate compensatory measures for each recirculation loop independent of the other loop.

(continued)

B 3.3.10 Reactor Recirculation Pump MG Set Stops

BASES

ACTIONS
(continued)A.1

Either the electrical or the mechanical stop can provide backup protection to the procedural controls in place to maintain recirculation pump operation within the system design limits and initial conditions of analyzed events. In the event one of these un-credited backup features is inoperable it is reasonable to extend the restoration time (in the event conditions do not permit more timely corrective action) until the next scheduled required calibration. With the backup protection of the electrical or mechanical stop remaining OPERABLE, backup protection remains and allows time to schedule and plan appropriate repairs. Since there is no assumed credit for either backup function, this Completion Time is considered appropriate.

B.1

With both the electrical and mechanical stops inoperable for any recirculation pump MG set, the automatic backup protection is not available. In this case, the scoop tube is locked in place to protect against unintended / inadvertent speed increases. This action conservatively compensates for lack of backup protection and allows continued operation until at least one MG set stop function (electrical or mechanical) is restored to operable status. The Required Action is modified by a Note allowing intermittent unlocking of the scoop tube. This may be required for power reductions or other power level adjustments. The administrative control consists of stationing a dedicated operator at the controls while the scoop tube is unlocked and the duration should be limited to the time necessary to complete the change in core flow.

TRS

The TRS assures that the stops are demonstrated OPERABLE at least once per cycle. Normal scoop tube positioner calibration is performed after each refueling outage. Inoperable stops are detectable on line during scoop tube positioner calibration.

REFERENCES

1. FSAR Section 5.4.1.4.
2. FSAR Section 7.7.2.3.1.
3. FSAR Section 15.4.5.