



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

January 16, 2009

Mr. Michael W. Rencheck
Senior Vice President and
Chief Nuclear Officer
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

SUBJECT: DONALD C. COOK NUCLEAR PLANT, UNITS 1 AND 2 – CORRECTION
LETTER FOR LICENSE AMENDMENT NOS. 307 AND 289, REGARDING
INCORPORATION OF TSTF-448, REVISION 3, "CONTROL ROOM
HABITABILITY" (TAC NOS. MD7554 AND MD7555)

Dear Mr. Rencheck:

By letter dated December 30, 2008, the U.S. Nuclear Regulatory Commission (NRC) staff issued Amendment No. 307 to Renewed Facility Operating License No. DPR-58 and Amendment No. 289 to Renewed Facility Operating License No. DPR-74 for the Donald C. Cook Nuclear Plant, Units 1 and 2, respectively. The amendments change the Technical Specifications (TSs) in response to your application dated December 27, 2007. The amendment also adds a license condition to support implementation of the TS changes.

Subsequently, Mr. Joe Waters of your staff informed the NRC staff of administrative errors on Page 2 of the license amendment for both units. The errors relate to the license condition information provided in the amendment letter. Specifically, the amendment currently states the following regarding license condition 2.C.(18)(b) for Unit 1 and 2.C.(3)(ff)(II) for Unit 2:

The first performance of the periodic assessment of CRE habitability, Specification 6.5.8.c.(ii), shall be within 3 years, plus the 9-month allowance of TS 4.0.2, as measured from February 19, 2004, the date of the most recent tracer gas test, as stated in the January 31, 2005, letter response to Generic Letter 2003-01, or within the next 9 months if the time period since the most recent tracer gas test is greater than 3 years.

The license condition should read as follows:


The first performance of the periodic assessment of CRE habitability, TS 5.5.16.c.(ii), shall be within 3 years, plus the 9-month allowance of SR 3.0.2, as measured from June 1999, the date of the most recent tracer gas test, as stated in the December 4, 2003, letter response to Generic Letter 2003-01, or within the next 9 months if the time period since the most recent tracer gas test is greater than 3 years.

M. Rencheck

- 2 -

Replacement page 4B for Unit 1, Renewed Facility Operating License No. DPR-58, and replacement page 5B for Unit 2, Renewed Facility Operating License No. DPR-74, was correctly annotated. The incorrect information was only in the license amendment. The correction does not change the approval conveyed by the amendments, or the conclusion reached by the associated safety evaluation. We regret any inconvenience this error may have caused you.

Sincerely,

A handwritten signature in black ink, appearing to read "Terry A. Beltz", with a long horizontal flourish extending to the right.

Terry A. Beltz, Senior Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

cc: Distribution via Listserv

January 16, 2009

M. Rencheck

- 2 -

Replacement page 4B for Unit 1, Renewed Facility Operating License No. DPR-58, and replacement page 5B for Unit 2, Renewed Facility Operating License No. DPR-74, was correctly annotated. The incorrect information was only in the license amendment. The correction does not change the approval conveyed by the amendments, or the conclusion reached by the associated safety evaluation. We regret any inconvenience this error may have caused you.

Sincerely,

/RA/

Terry A. Beltz, Senior Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-315 and 50-316

cc: Distribution via Listserv

DISTRIBUTION:

Public

LPL3-1 R/F

RidsNrrDorlLpl3-1 Resource

RidsOgcRp Resource

RidsNrrLATHarris Resource

RidsNrrPMTBeltz Resource

RidsNrrDirsltsb Resource

RidsRgn3MailCenter Resource

RidsNrrDorlDpr Resource

RidsAcrsAcnw_MailCTR Resource

MHamm, NRR

ADAMS Accession No. **ML090160087**

OFFICE	NRR/LPL3-1/PM	NRR/LPL3-1/LA	NRR/LPL3-1/BC
NAME	TBeltz	THarris	LJames /PST for
DATE	01/16/09	01/16/09	1/16/09

OFFICIAL RECORD COPY