

Meeting: New Plant Seismic Issues
February 9, 2005 at 1:30 pm
NRC Offices O-4B6

Meeting Purpose: To discuss industry ideas and proposals for improving Reg. Guide 1.165 and addressing high frequency seismic issues

Industry participants: Cedric Jobe, NEI
Adrian Heymer, NEI
Bob Kassawara, EPRI
Robert Kennedy, RPK Structural Mechanics
Bill Schmidt, MPR, et al.

Draft Agenda

- 1:30 PM Introduction and Opening Remarks (NEI Letter to NRC dated 11/30/2004)
- 1:40 PM Issues arising from use of RG 1.165
 - Industry proposals to address high frequency ground motion estimates
 - Development of performance based ASCE methodology
 - Characterization of seismic ground motion models
 - Revision of Lower Bound Magnitude Cutoff
 - Truncation of Log-Normal Distribution of Variability
 - Preliminary industry schedule
 - General discussion NRC-NRC
- 3:15 PM Public comments
- 3:25 PM Summary
- 3:30 PM Adjourn

Attachment

B-2

Early Site Permit Seismic Issue Resolution Program

Presentation to USNRC

By NEI/EPRI

February 9, 2005

EPRI

NEI

Industry Goal

- Resolve generic issues in a timeframe to support the Administration's goals for nuclear power expressed in NP 2010
 - Change regulatory guidance, where necessary

NEI

Purpose of Meeting

Discuss:

- Experience and concerns with RG1.165 approach
- Need for revisions to RG1.165 methodology
- Industry program for
 - Evaluating performance-based methodology
 - Improving seismic hazard estimation methods (technology advances)
 - Treatment of non-damaging high frequency motions
 - Recommending revisions to RG1.165
- Future Industry/NRC interactions

EPRI



3

Experience/concerns with RG1.165

- Causes regulatory and technical instability
 - Results for a given site potentially affected by results for 29 diverse, distant sites
- Process likely to deter many utilities from applying for ESP or COL
 - On-going potential for impact on resources and seismic design basis
- Method based on a reference *relative* probability not a *performance-based* (safety-based) approach

EPRI



4

Resolution Plans

- Performance-based approach of ASCE /SEI 43-05 provides more realistic, stable seismic regulation
- ASCE method is performance-based and consistent with
 - NRC regulations
 - Recommendations of Nureg CR 6728
 - Past licensing practice
 - NRC policy statement on Risk-Informed Regulation
- Need to incorporate other technology advances in PSHA implementation

EPRI

NEI

5

Industry program

- Industry program established to address concerns and improve process for determining site SSE spectra
 - EPRI technical lead
 - Expert review/advisory group

EPRI

NEI

6

Industry Program (Cont'd)

- Tasks underway and planned include
 - Demonstrate generic applicability of ASCE/SEI 43-05 application
 - Improve seismic hazard estimation methodology to reflect technology advances
 - Updating and improving methods for addressing non-damaging high frequency portion of spectra
 - Developing proposed revisions to RG1.165

EPRI



7

Task G1.1- Update Ground Motion Hazards and Assess ASCE Performance-Based Methodology

- Update EPRI hazard results to reflect latest codes, attenuation relationships, updated seismic sources, and updated ground motion model
- Compute performance-based seismic spectra for select number of sites
- Demonstrate generic applicability of performance-based methodology

would this factor in site-specific properties?

EPRI



8

Task G1.2 - Revision of Lower Bound Magnitude for Hazard Integration

- Lower bound magnitude (LBM) used in hazard computation (i.e., magnitude at which damage may occur) has major impact on computed hazard levels, particularly for higher frequencies
- A realistic LBM cut-off would reduce hazard consistent with realistic damage potential of small earthquakes
- Task will study new observations of damage to industrial facilities and nuclear plant assessments to support a revised LBM. Higher damage resistance of new nuclear plants vs. industrial facilities will be considered

EPRI

NEI

9

Mw 4.6
how would this
affect
recurrence?
(lower mag
events used
to infer
recurrence
of lg events)

Task G1.3 - Truncation of Lognormal Distribution of Variability on Median Ground Motion

- Current hazard analyses model variability w/*unbounded* lognormal distribution of variability (i.e., aleatory uncertainty) is unbounded
- Practice of using an unbounded distribution is unrealistic; however, no consensus bound exists
- Task objective is to define rational, defensible bound on variability (e.g., point where variability deviates from lognormal distribution)

EPRI

NEI

10

conservative
to be unbounded
but rationally should be
bounded?

Tasks S2.1 and S2.2 - Treatment of High Frequency (HF) Motions

- Analytical and observational data show that ground motion spectra for CEUS sites will contain high spectral accelerations at high frequencies (i.e., over ~ 10 hz), but the HF content has negligible damage potential
- Objectives of tasks S2.1 and S2.2 are to develop generic methods for accommodating HF motions considering
 - Effect of seismic wave incoherence (S2.1), and
 - Effect of limited inelastic behavior on response to HF input motions (S2.2)

EPRI

NEI

11

Task S2.1 - Effects of Seismic Wave Incoherence

- Ground motion is measured at a point; studies show that *coherent* motion input to practical size structures is less than at a single point
- Structures respond effectively to coherent input motion
- Coherency of motion decreases w/ both physical dimensions and frequency of motion
- Task will assess recent work (e.g., for Diablo Canyon and in EPRI TR 102631) and develop incoherence corrections

EPRI

NEI

12

Taking on too much for the amount of time we have?

6

Task S2.2 - Effect of Limited Inelastic Behavior on Response to HF Input

- Several studies have evaluated effects of HF accelerations
 - EPRI NP5930 on OBE exceedance
 - Blast, shock and vibration testing
 - EPRI TR 102470 on effect of limited inelastic behavior
 - IPEEE implementation
 - NRC assessments of HF damage potential on existing plants
- All concluded HF accelerations (>10 Hz) have negligible damage potential for nuclear plants

EPRI

NEI

13

*incoherence
corrections
to the
ground motion
spectrum*

*even most
→ brittle systems
have sufficient
capacity*

Task S2.2 - Effect of Limited Inelastic Behavior on Response to HF Input (cont'd)

- Task will build on available knowledge/data to update and improve results of EPRI TR 102470
- NRC technical participation in task would facilitate timely resolution and is requested

EPRI

NEI

14

Future NRC/Industry Interactions

- Feedback on today's meeting
- Updates and conclusions of on-going tasks
- Possible interactive NRC review/advisory role in Tasks S2.1 and S2.2 (HF issue) and approach for addressing old (1994) questions on EPRI HF study (TR 102470)
- Timing of review and resolution of HF issue
- Planning for revision of regulatory guidance in 2006 to support NP 2010

EPRI



15