
PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

PWR Owners Group Presentation

Public Meeting on the Resolution of Generic
Safety Issue (GSI)-191

January 15, 2009




PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

- Head loss test protocol developed to support WCAP-16793-NP
- Testing investigates:
 - Combinations of debris materials (fibrous, particulate, chemical, etc.)
 - Thin bed debris loading
- Output of test program will be an acceptance criteria:
 - Define maximum debris masses which, if passed through the reactor containment building sump screen, will result in an acceptable pressure drop at the core inlet
 - As part of GSI-191 closure with respect to fuel, each plant may demonstrate acceptable long term core cooling by showing that plant-specific sump screen bypass masses are bounded by the limits of the acceptance criteria

Cold Leg Break Scenario

Considerations


- Earliest time for blockage formation is at switchover from injection to recirculation
 - ~20 minutes for large break LOCA
- Flow rate is determined by boil-off and density difference between downcomer and core inventory
 - Decay heat is low, decreases with increasing time
 - Flows are low
- No flow through alternate paths
- Flow in excess of boil-off
 - “Spills” out the break
 - Is “recycled” through sump screen without passing through core



Hot Leg Break Scenario

Considerations

- Earliest time for blockage formation is at switchover from injection to recirculation
 - ~20 minutes for large break LOCA
- Flow rate is determined by ECCS pump capability
 - Flow exceeds that needed for decay heat removal
 - Limited / no boiling in core
- No flow through alternate paths



PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

- Key Features of Test Protocol
 - Goal of Testing
 - Identify maximum debris loads while achieving acceptable ΔP
 - Test Method Defined
 - Appropriate Test Configuration Defined
 - Debris Preparation Defined
 - Data Collection Defined
 - Test Termination Criteria Defined

PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

Debris Characteristics

Fiber Sizes		
Fiber Length	Target	Range
< 500 μm	77%	67% - 87%
500 μm < 1000 μm	18%	8% - 28%
\geq 1000 μm	5%	0% - 15%

- Fiber size is consistent with that of representative plant data.

- Particulates:
Silicon carbide
 - Represents debris that can be characterized as particulate. (Including, not limited to, coatings, latent debris, dirt, etc.)
 - 10 μm \pm 2 μm
 - Small size provides for maximum transport to and penetration into fiber bed

PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

Debris Characteristics


- Chemical Surrogate:
Aluminum Oxy-hydroxide (AIOOH)
 - Shown by Argonne National Laboratory to produce the highest pressure drop among all of the chemical precipitates
 - Ensure AIOOH surrogate meets settling criteria of WCAP-16530-NP-A and its modification in the associated SER
- Calcium silicate
 - Used in tests designed for plants with calcium silicate.
- Microporous
 - Microtherm is used to represent all microporous material including Min-K.
 - Used in tests designed for plants with microporous material.

PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

- Fuel Assembly Debris Capture Tests
 - Vendor bottom nozzle configurations (AREVA/CE/Westinghouse)
 - Testing performed with limiting nozzle design
 - Hot-leg break flow rates
 - Representative debris loads
 - Set by sump screen bypass data provided by licensees
 - NRC Involvement:
 - Test Protocol shared with NRC, comments received and addressed
 - NRC visited and observed both W and AREVA test


Fiber Survey Data

Survey Fiber Data per Fuel Assembly



Particulate Survey Data

Particulate Survey Data per Fuel Assembly



PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

- Test Rig – Westinghouse F/A (Representative)
 - Assembly Height: 4 ft

Top Nozzle

Inconel top grid

Intermediate grid


Intermediate Flow Mixing (IFM) grid

Intermediate grid

Inconel bottom grid

Standard p-grid

Debris Filtering Bottom Nozzle



PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

- Westinghouse Test Plan
 - Three bottom nozzle designs
 - Alternate P-grid was not tested since it had previously been determined that the standard P-grid was limiting in comparison
 - Initial tests run with same debris loading to determine limiting nozzle design
 - Upper Plenum Injection test to be performed

PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

Westinghouse Tests Performed			
Test No.	Plant Design	Bottom Nozzle	Debris
1	W/B&W	P-Grid	Part/Fiber/Chem
2	W/B&W	P-Grid	Part/Fiber/Chem
3	W/B&W	P-Grid	Part/Fiber/Chem
4	CE	Guardian	Part/Fiber/Chem
5	W/B&W	P-Grid	Part/Fiber/Chem/CalSil
6	W/B&W	P-Grid	Part/Fiber/Chem/Microtherm/ Cal Sil

PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

- AREVA Test Plan
 - B&W & W Designed Plants
 - Three bottom nozzle designs
 - Initial tests run with same debris loading to determine limiting nozzle design
 - CE Designed Plants
 - FUELGUARD fuel filter

PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

AREVA Test Plan			
Test No.	Plant Design	Bottom Nozzle	Debris
1	W/B&W	TRAPPER Fine Mesh	Part/Fiber/Chem
2	W/B&W	FUELGUARD	Part/Fiber/Chem
3	W/B&W	TRAPPER Coarse Mesh	Part/Fiber/Chem
4	W/B&W	Limiting	Max Part/Fiber/Chem/CalSil
5	W/B&W	Limiting	Max Part/Fiber/Chem/Microtherm
6	CE	FUELGUARD	Max Part/Fiber/Chem

PWROG Fuel Nozzle Testing Under Post-LOCA Conditions


- Data Under Review
- Conclusions/Observations to Date
 - “Thin bed” behavior not observed in tests
 - Particulates only a minor impact on head loss
 - Fiber:
 - Provides collection sites for debris
 - **Is the driver for head loss**
 - Chemical precipitates:
 - Are another source of particulates
 - Results show chemical precipitates only a minor impact on head loss
 - Cal Sil and Microporous insulation
 - Are another source of particulates
 - Again, results show only a minor impact on head loss
 - Some debris observed to collect at grids along the height of the bundle

Fuel Nozzle Testing Under Post-LOCA Conditions

- F/A Test Parameters
 - Hot-leg flow rates
 - Scaled on per assembly basis
 - Sequenced addition of debris
 - Particulates
 - Fiber
 - Chemical
 - Microporous and Calcium Silicate debris added with particulate and after chemical addition


PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

Sample Test Set Up (Representative of Both AREVA and Westinghouse)



PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

Westinghouse Fuel Assembly (Representative of AREVA's Set Up)




PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

Sample of Debris Collection at Grid




PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

Sample of Debris Collection on Bottom Nozzle – Side View



PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

Sample of Debris Collection on Bottom of Bottom Nozzle



PWROG Fuel Nozzle Testing Under Post-LOCA Conditions

Sample of Debris Collection on Grids



Looking Ahead

- Week of January 19, 2009
 - Phone Calls to discuss RAIs and Cold Leg Break
- Week of February 23, 2009
 - Submit RAI Responses
- Week of March 16, 2009
 - Submit Proprietary Fuel Assembly Test Data Report (data only, no conclusions)
 - Non-proprietary version also submitted (title and index)
- Week of April 13, 2009
 - Based on NRC head-nod on RAI responses, submit Revision 1 of WCAP-16793