Exelon Nuclear Peach Bottom Atomic Power Station 1848 Lay Road Delta, PA 17314-9032 www.exeloncorp.com

10 CFR 50.55a

-xel 他

Nuclear

January 29, 2009

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

> Peach Bottom Atomic Power Station (PBAPS), Units 2 and 3 Facility Operating License Nos. DPR-44 and DPR-56 <u>NRC Docket Nos. 50-277 and 50-278</u>

Subject: Submittal of Third Interval Inservice Inspection (ISI) Owners Activity Reports

References:

es: 1. Peach Bottom Atomic Power Station (PBAPS), Unit 3 3R12 Submittal of Inservice Inspection Summary Report, dated January 31, 2000.

2. Peach Bottom Atomic Power Station (PBAPS), Submittal of the Third 10-Year Interval First Inspection Period, Inservice Inspection Owners Activity Report for Peach Bottom Atomic Power Station, Unit 3, dated April 26, 2002.

Attached are ISI Owner Activity Reports associated with the PBAPS Units 2 and 3, Third ISI Interval activities. These reports cover ISI activities for refueling outages completed from 2002 through 2008. These reports are submitted pursuant to the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, "Rules for the Inservice Inspection of Nuclear Power Plant Components," Article IWA-6200, "Requirements" (1989 Edition) and ASME Code Case 532 (Alternative Requirements to Repair and Replacement Documentation Requirements and Inservice Summary Report Preparation and Submission as Required by IWA-4000 and Section XI, Division 1).

Attachments 1A, 1B, 2, 3A and 3B are the Owner Activity Reports for the Unit 2, first, second, and 'third (last) periods of the 3rd 10-year ISI interval.

The first period of the 3rd 10-year ISI interval for Unit 3 was reported as a summary report (Reference 1) and an Owners Activity Report (Reference 2) in accordance with ASME Section XI, 1989 Edition. Attachments 4, 5A, and 5B are the Owners Activity Reports for the Unit 3 second and third (last) periods of the 3rd 10-year ISI interval.

If you have any questions, feel free to contact Mr. Nicholas Alexakos at 717-456-4031.

William F. Maguire Site Vice President Peach Bottom Atomic Power Station

cc: F. L. Bower, Senior Resident Inspector, USNRC, PBAPS R. R. Janati, Commonwealth of Pennsylvania Region 1 Administrator, USNRC

CCN: 09-10

Attachments (8):

1A. Owners Activity Report (OAR-1) for Refueling Outage 2R13, Third ISI Interval, First Period

- 1B. Owners Activity Report (OAR-1) for Refueling Outage 2R14, Third ISI Interval, First Period
- 2. Owners Activity Report (OAR-1) for Refueling Outage 2R15, Third ISI Interval, Second Period
- 3A. Owners Activity Report (OAR-1) for Refueling Outage 2R16, Third ISI Interval, Third Period
- 3B. Owners Activity Report (OAR-1) for Refueling Outage 2R17, Third ISI Interval, Third Period
- 4. Owners Activity Report (OAR-1) for Refueling Outage 3R14, Third ISI Interval, Second Period
- 5A. Owners Activity Report (OAR-1) for Refueling Outage 3R15, Third ISI Interval, Third Period
- 5B. Owners Activity Report (OAR-1) for Refueling Outage 3R16, Third ISI Interval, Third Period

Attachment 1A

Peach Bottom Atomic Power Station Unit 2

Owner Activity Report (OAR-1) for Refueling Outage 2R13 Third 10-Year ISI Interval, First Period

FORM OAR-1 OWNER'S ACTIVITY REPORT

Report Number: 2R13

Owner: EXELON NUCLEAR 200 Exelon Way Kennett Square, PA 19348

ATTACHMENT 1A PAGE 1 OF 11

Plant: <u>Peach Bottom Atomic Power Station</u> <u>1848 Lay Road</u> <u>Delta, PA 17314</u>

Unit No.: 2 Commercial Service Date: July 5, 1974

Refueling Outage No.: 13

Current Inspection Interval: 3rd

Current Inspection Period: 1st

Edition and Addenda of Section XI applicable to the Inspection Plan: <u>1989 & 1992 Editions</u>, <u>1992 Addenda</u>

Date and Revision of Inspection Plan: <u>September 7, 2000, Revision # 0 and</u> <u>Changes dated March 27, 2001</u>

Edition and Addenda of Section XI applicable to repairs and replacements: Reference CC N-416-1

CERTIFICATE OF CONFORMANCE

I certify that the statements made in this Owner's Activity Report are correct, and the examinations, tests, repairs, replacements, evaluations, and corrective measures represented by this report for the period November 2, 1998 to October 5,2000 conform to the requirements of Section XI.

3/27/01 Signed:

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of <u>Pennsylvania</u> and employed by <u>Hartford</u>. <u>Steam Boiler Inspection & Insurance Company</u> of <u>Hartford</u>, <u>Connecticut</u> have inspected the components described in the Owner's Data Report during the period November 2, 1998 to October 5, 2000 and state that to the best of my knowledge and belief the Owner has performed examinations and taken corrective measures described in this Owner's Data Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kink arising from or connected with this inspection.

Date: 312701	
Inspector's Signature:	
Commissions: SECSEL PALLES	
National Board, State, Province & No).

ATTACHMENT 1A PAGE 2 OF 11

TABLE 1

ABSTRACT OF EXAMINATIONS AND TESTS

PBAPS U/2 Third Interval Inservice Inspection Abstract of Examinations and Tests

ATTACHMENT 1A PAGE 3 OF 11

	Total Examinations	Total Examinations	Total Examinations Credited (%)	Total Examinations Credited (%) To	
Examination	Required For	Credited For	For The	Date For The	
Category	The Interval	This Period	Period	Interval	Remarks
B-A	31	1	3.2%	3.2%	9 or (29.0%) additional exams sched. 2nd. Outage.of 1st. Period
B-D	62	0	0%	0%	24 or (38.7%) examinations sched. 2nd. Outage of 1st. Period
B-E	62	0	0%	0%	Examine during system hydro pressure test sched, 2nd. Period
B-F	10	1	10%	10%	4 or (40.0%) additional exams sched. 2nd. Outage of 1st. Period
B-G-1	10	0	0%	0%	4 or (40.0%) examinations sched. 2nd. Outage of 1st. Period
B-G-2	11*	1	9.1%	9.1%	3 or (27.3%) additional exams sched. 2nd. Outage of 1st. Period
B-J	107	7	6.5%	6.5%	29 or (27.1%) additional exams sched. 2nd. Outage of 1st. Period
В-К	19	0	0%	0%	6 or (31.6%) examinations sched. 2nd. Outage of 1st. Period
B-L-2	1*	0	0%	0%	Examine when pump is disassembled for maintenance
B-M-2	20*	0%	0%	0%	Examine when pump is disassembled for maintenance
B-N-1	3	0	0%	0%	1 or (33.3%) examinations sched 2nd. Outage of 1st. Period
B-N-2	57	7	12.3%	12.3%	Min. of 3.7% additional exams sched 2nd. Outage of 1st. Period
B-O	E	x	E	м	 Р Т
B-P	5	1	20%	20%	1 or (20.0%) additional exams sched, 2nd, Outage of 1st, Period
C-A	2	0	0%	0%	1 or (50.0%) examinations sched. 2nd. Outage of 1st. Period
С-В	4	0	0%	0%	2 or (50.0) examinations sched. 2nd, Outage of 1st, Period
C-C	14	1	7.1%	7.1%	5 or (33.3%) additional exams sched 2nd, Outage of 1st, Period
C-F-2	78	4	5.1%	5.1%	19 or (24.3%) additional exams sched, 2nd, Outage of 1st, Interval
C-H	27	5	18.5%	18.5%	Expected completion of 1st.Period
D-A	26	4	15.4%	15.4%	5 or (19.2%) additional exams sched, 2nd, Outage of 1st, Period
D-B	q	1	11 1%	11 10/	Expected completion of 1st.Period
F-A	29	24	50%	50%	Includes 100% General Visual /
E-R		FXAMS	NOT		AT DRADS
<u> </u>	1		0%	0%	Per CRR-11, examination sched.
<u> </u>	1	1	100%	100%	100% credit as permitted by IWB-
		EXAMO	NOT		
	OPTIONAL	EXAMS	NUT	PERFORMED	Per CRR-07, exam satisfied with
E-G	76	76	50%	50%	Cat.E-A, General Visual / VT-3
E-P	85	1	100%	100%	taken for Appendix J Tests
F-A	192	40	20.8%	20.8%	sched. 2nd. Outage of 1st. Period

)

ATTACHMENT 1A PAGE 4 OF 11

TABLE 2

ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

ATTACHMENT 1A PAGE 5 OF 11

Their were no flaws or relevant conditions that required evaluation for continued service as a result of the items examined during the period November 2, 1998 to October 5, 2000.



TABLE 3 ABSTRACT OF REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES REQUIRED FOR CONTINUED SERVICE

SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 NOVEMBER 1, 1998 TO OCTOBER 5, 2000 (END OF 2R13 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

ATTACHMENT 1A PAGE 7 OF 11

Flaw or Relevant

SYSTEM 01: MAIN STEAM SYSTEM

	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	Complete	R&R Plan # and W/O #
Class 1	Replacement	RV-2-02-071A	Installed a rebuilt safety relief valve	No	09/26/2000	00-063 R0782758
Class 1	Replacement	RV-2-02-071B	Installed a rebuilt safety relief valve	No	09/26/2000	00-064, R0707129
Class 1	Replacement	RV-2-02-071E	Installed a rebuilt safety relief valve	No	09/26/2000	00-065 R0707117
Class 1	Replacement	RV-2-02-071F	Installed a rebuilt safety relief valve	No	09/26/2000	00-066 R0707122
Class 1	Replacement	RV-2-02-071G	Installed a rebuilt safety relief valve	No	09/26/2000	00-067 R0707466
Class 1	Replacement	RV-2-02-071H	Installed a rebuilt safety relief valve	No	09/26/2000	00-068 R0707102
Class 1	Replacement	RV-2-02-070B	Installed a rebuilt safety relief valve	No	09/26/2000	00-069 R0707124
Class 3	Replacement	1-GG-S-2	Installed new hydraulic snubber	No	09/24/2000	00-015 R0507538
Class 3	Replacement	1-GG-S-6	Installed new hydraulic snubber	No	09/24/2000	00-016 R0507537
Class 3	Replacement	1-GG-S-4	Installed new hydraulic snubber	No	09/24/2000	00-017 R0467877
Class 3	Replacement	1-GG-S-20	Installed new hydraulic snubber	No .	09/21/2000	00-018 R0477405
Class 1	Replacement	SS-A-1	Installed new hydraulic snubber	No	09/24/2000	00-027 R0481800
Class 2	Replacement	7-DB-S-10	Installed new hydraulic snubber	No	09/25/2000	00-028 R0478031
Class 1	Replacement	HV-2-01A-83A	Installed new valve bonnet	No	10/06/2000	00-113 M1283826
Class 1	Replacement	HV-2-01A-84A	Installed new valve bonnet	No	10/06/2000	00-114 M1283827
Class 1	Replacement	HV-2-01A-84C	Installed new valve bonnet	No	10/06/2000	00-115 M1283700
Class 1	Replacement	HV-2-01A-83C	Installed new valve bonnet	No	10/06/2000	00-116, M1283708

ATTACHMENT 1A

PAGE 8 OF 11

SUMMARY OF ASME REPAIRS AND RÉPLACEMENTS COMPLETED FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 NOVEMBER 1, 1998 TO OCTOBER 5, 2000 (END OF 2R13 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 03: CONTROL ROD DRIVE

Code Class	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam <u>Or Test</u>	Date <u>Complete</u>	R&R Plan	<u># and W/O #</u>
Class 1	Replacement	CRD-2-03-2634	Installed new CRD flange tube on CRD	No	03/11/1999	98-172,	C0185393
Class 1	Replacement	CRD-2-03-1295	Installed new CRD flange tube on CRD	No	11/09/2000	00-003,	R0792638
Class 1	Replacement	CRD-2-03-1517	Installed new CRD flange tube on CRD	No	11/09/2000	00-003	R0792638
Class 1	Replacement	CRD's 14-43, 26-27, 26-35, 42-43, 46-35, 50-15, 50-47, 58-35, 30-15, 34-23, 26-43, 22-47, 22-15, and 46-23.	Exchanged CRD's with rebuilt CRD's during 2R13 outage Also installed 35 CRD bolts (incidental replacement)	No	09/29/2000	00-054,	R0788362
Class 2	Replacement	AO-2-03-033	Installed new air operated valve and piping	No	09/29/2000	00-103,	C0192800

SYSTEM 06: FEEDWATER SYSTEM

Codo	Repair, Replacement, or Corrective	Item Description		Flaw or Relevant Condition Found During Scheduled	Dete	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	Date	D&D Dian # and W/O #
					complete	Rok Flan # and W/O #
Class 2	Replacement	MO-2-06D-2163B	Replaced valve bonnet and seal welded leakoff plug.	No	09/18/2000	00-076, C0193081
Class 1	Replacement	6-DDNL-S-6	Installed new hydraulic snubber	No	09/24/2000	00-019 R0481887
Class 1	Replacement	6-DDNL-S-14	Installed new hydraulic snubber	No	09/24/2000	00-020 R0470776
Class 1	Replacement	CHK-2-06-96B	Welded in new seal plate on check valve	No	09/24/2000	00-110 C0195111

SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 NOVEMBER 1, 1998 TO OCTOBER 5, 2000 (END OF 2R13 REFUEL OUTAGE)

ATTACHMENT 1A PAGE 9 OF 11

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 07: PRIMARY CONTAINMENT

	Code	Repair, Replacement, or Corrective	Item Description		Flaw or Relevant Condition Found During Scheduled Section XI Exam	Date	
	Class	Measure	(component I.D.)	Description Of Work Performed	<u>Or Test</u>	<u>Complete</u>	R&R Plan # and W/O #
	М	Replacement	N-006	installed new CRD Hatch bolting, rods, and studs	No	10/02/2000	00-053, R0781380
**	М	Replacement	N-017	RHR Head Spray piping modification per ECR 98-03204	No	10/01/2000	00-104, C0193607
	М	Replacement	N-110G	Replaced stud on RPV stabilizer assembly manhole	No	09/23/2000	00-109, C0195083
	М	Repair	N-002	Seal weld stud to primary cont. equip. access hatch	No	09/30/2000	00-122, R0782035

SYSTEM 10: RESIDUAL HEAT REMOVAL

	Code Class	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	<u>R&R Plan</u>	# and W/O #
	Class 2	Replacement	PB-2-10-M-HX-2BE024	Installation of modified split ring	No	03/11/1999	94-193,	C0158530
	Class 2	Replacement	10-GB-S-12	Installed new pressurized snubber	No	05/31/2000	00-083,	C0193948
**	Class 2	Repair	PB-2-10-M-HX-2BE024	Repaired cracked partition welds at hx waterbox inlet	No	06/23/2000	00-090,	C0193919
	Class 2	Replacement	10-GB-S-54	Installed new hydraulic snubber	No	09/27/2000	00-021	R0481888
	Class 2	Replacement	10-GB-S-58	Installed new hydraulic snubber	No	09/19/2000	00-022	R0480328
	Class 2	Replacement	10-HB-S-7	Installed new hydraulic snubber	No	09/19/2000	00-023	R0477872
	Class 2	Replacement	10-GB-S-80	Installed new mechanical snubber	No	09/19/2000	00-035,	C0192103
**	Class 2	Replacement	MO-2-10-033	RHR Head Spray piping modification per ECR 98-03204	No	10/01/2000	00-104,	C0193607

SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 NOVEMBER 1, 1998 TO OCTOBER 5, 2000 (END OF 2R13 REFUEL OUTAGE) ATTACHMENT 1A

PAGE 10 OF 11

Flaw or Relevant

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 12:	REACTOR WA	TER CLEANUP SYSTE	Ŵ	Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	12-DCN-S-2	Installed new hydraulic snubber	No	09/27/2000	00-024, R0496718



SYSTEM 13: REACTOR CORE ISOLATION COOLING SYSTEM

		Repair,			Condition Found		
		Replacement,			During Scheduled		
	Code	or Corrective	Item Description		Section XI Exam	Date	
	Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
	Class 2	Replacement	VRV-2-13C-139A,B,C,D	Installed new vacuum relief valves	No	01/11/1999	98-173, C0185372
	Class 2	Replacement	PSD-2-13-003	Installed eight new all-thread studs on rupture disc	No	01/11/1999	99-001, C0182404
	Class 2	Replacement	PSD-2-13-004	Installed eight new all-thread studs on rupture disc	No	01/11/1999	99-002, C0184832
**	Class 2	Replacement	CHK-2-13C-38	Replaced check valve and associated piping	No	09/18/2000	00-078, C0192861

1. 0

SYSTEM 14: CORE SPRAY COOLING SYSTEM

					Flaw or Relevant		
		Repair,			Condition Found		
		Replacement,			During Scheduled		
	Code	or Corrective	Item Description		Section XI Exam	Date	
	Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	<u>R&R Plan</u> # and W/O #
**	Class 2	Replacement	RV-2-14-020A	Installed new relief valve	No	07/26/1999	99-072, R0481251

03/10/00, ____age 5 of 5

ATTACHMENT 1A PAGE 11 OF 11

SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 NOVEMBER 1, 1998 TO OCTOBER 5, 2000 (END OF 2R13 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 23: HIGH PRESSURE COOLANT INJECTION SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description	· · ·	Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 2	Replacement	VRV-2-23C-4998B	Installed new vacuum relief valve	No	11/04/1999	99-139, C0191342
Class 2	Replacement	23-DBN-S-3	Installed new hydraulic snubber	No	09/18/2000	00-025, R0468349
Class 2	Replacement	23-HB-S-30	Installed new hydraulic snubber	No	09/20/2000	00-026, R0481889
Class 2	Replacement	23-DBN-S-2	Installed new hydraulic snubber	No	09/18/2000	00-049, R0468348
Class 2	Replacement	23-DBN-S-27	Installed new pressurized reservoir snubber	No	09/22/2000	00-111, C0195126

SYSTEM 33: EMERGENCY SERVICE WATER SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,		and the second se	During Scheduled		
Code	or Corrective	Item Description	and a start the start	Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
3	Replacement	PB-2-33-0BP057	Installed new pump and seismic restraints	No	05/03/2000	00-001, C0191657

Attachment 1B

.

Peach Bottom Atomic Power Station Unit 2

Owner Activity Report (OAR-1) for Refueling Outage 2R14 Third 10-Year ISI Interval, First Period

Refueling Outage No.: 14

FORM OAR-1 OWNER'S ACTIVITY REPORT

Report Number: 2R14

Owner: <u>EXELON NUCLEAR</u> 200 Exelon Way Kennett Square, PA 19348

Plant: <u>Peach Bottom Atomic Power Station</u> <u>1848 Lay Road</u> <u>Delta, PA 17314</u>

Unit No.: 2 Commercial Service Date: July 5, 1974

Current Inspection Interval: 3rd

Current Inspection Period: 1^{st}

Edition and Addenda of Section XI applicable to the Inspection Plan: <u>1989 Edition & 1992 Edition including 1992</u> Addenda

Date and Revision of Inspection Plan: June 28, 2002, Revision 2

Edition and Addenda of Section XI applicable to repairs and replacements: 1989 Edition and Code Case N-416-1

CERTIFICATE OF CONFORMANCE

I certify that the statements made in this Owner's Activity Report are correct, and that the examinations, tests, repairs, replacements, evaluations, and corrective measures represented by this report for the period October 6, 2000 to November 2, 2002 conform to the requirements of Section XI.

Date: 01-24-2009 Signed: Jennut U Hugs

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the Commonwealth of <u>Pennsylvania</u> and employed by <u>Hartford Steam Boiler Inspection &</u> <u>Insurance Company of Connecticut</u>, of <u>Hartford, Connecticut</u>, have inspected the components described in the Owner's Data Report during the period October 6, 2000 to November 2, 2002 and state that to the best of my knowledge and belief the Owner has performed all activities represented by this report in accordance with the requirements of Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, tests, repairs, replacements, evaluations, and corrective measures described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date: Inspector's Signature: Commissions: NB 7592 2263 National Board, State, Province & No.

Peach Bottom Atomic Power Station, Unit 2 Third Interval, First Period OAR-1

ATTACHMENT 1B PAGE 2 OF 9

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Category Description	Total Examinations Required For The Interval	Total Examinations Credited For The 1st Period (2R13 & 2R14)	Total Examinations Credited (%) For The 1st Period (2R13 & 2R14)	Total Examinations Credited (%) To Date for The Interval	Remarks
B-A	RPV Pressure Retaining Welds	31	12	38.7	38.7	RPV Circumferential shell weld exempted per approved Relief request RR-41
B-D	RPV Nozzles, Inner Radius	61	20	32.8	32.8	Case N-598, Alternative Requirements to Required Percentages of Examinations, Section XI, Division 1 per approved Relief Request RR-33
B-E	Partial Penetration Welds in Piping	62	0	0.0	0.0	B-E examinations completed during RPV Hydro performed in second period (P2R15).
B-G-1	Bolting > 2 inch	109	63	57.8	57.8	Code Case N-598 per approved Relief Request RR-33
B-G-2	Bolting ≤ 2 inch	108	38	35.2	35.2	Code Case N-598 per approved Relief Request RR-33
В-К	Integral Attachments (vessels, piping, pumps)	16	6	37.5	37.5	 Code Case N-598 per approved Relief Request RR-33 Use of ASME CC N-509, Alternative Rules for the Selection and Examination of Class 1, 2, and 3 Integrally Welded Attachments Section XI, Division 1, included Category B-H as B-K
B-L-2	Internal Surfaces of Pump Casings	1	1	100.0	100.0	· ·
B-M-2	Internal Surfaces of Valve Bodies	29	13	44.8	44.8	
B-N-1	Reactor Vessel Interior	3	1	33.3	33.3	
B-N-2	Core Support Structures and Interior Attachments	55	16	29.1	29.1	
B-P	All Pressure Retaining Components	6	2	33.3	33.3	
C-A	Welds in Pressure Vessels	2	0	0.0	0.0	Code Case N-598 per approved Relief Request RR-33
С-В	Nozzle Welds in Vessels	8	3	37.5	37.5	

.

Peach Bottom Atomic Power Station, Unit 2 Third Interval, First Period OAR-1

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Category Description	Total Examinations Required For The Interval	Total Examinations Credited For The 1st Period (2R13 & 2R14)	Total Examinations Credited (%) For The 1st Period (2R13 & 2R14)	Total Examinations Credited (%) To Date for The Interval	Remarks
C-C	ASME Class 2 Integral Attachments to Piping	15	5	33.3	33.3	Code Case N-598 per approved Relief Request RR-33
C-H	All Class 2 Pressure Retaining Componnets	51	16	31.4	31.4	
D-A	ASME Class 3 Integral Attachments to Piping	25	0	0.0	0.0	Code Case N-598 per approved Relief Request RR-33
D-B	Class 3 ECCS, Ect. System Pressure Tests	9	3	33.3	33.3	
E-A	Surfaces	57	17	29.8	29.8	General Visual performed in refueling outage P2R13 as ILRT. Not required to count double credit for inspection of Drywell, Torus, or Vent System for both 10CFR50.55a period and ILRT requirements.
E-C	Augmented Exams (Pits, Wall Thickness)	3	0	0.0	0.0	Alternative examination program per approved Request for Alternative CRR-11
E-D		63	63	100.0	100.0	10CFR50 Appendix J examination of seals and gaskets per approved Request for Alternative CRR-01
E-G		76	76	100.0	100.0	10CFR50 Appendix J and Code Category E-A examination per approved Request for Alternative CRR-07
E-P		1	1	100.0	100.0	In accordance with 10CFR50 Appendix J Test Program and Schedule
F-A	Supports	167	77	46.1	46.1	Code Case N-598 per approved Relief Request RR-33
R-A	Risk Informed Welds	135	40	29.6	29.6	Implemented RI-ISI starting 2nd Period, replacing Categories B-F, B-J, and C-F-2.

TABLE 2 **ATTACHMENT 1B** ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE PAGE 4 OF 9

.

Examination Category	Item Number	Item Description Flaw Characterization (IWA-3300)		Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)	
B-A	B1.21	CH-C-1 Closure Head dollar Plate Weld	Twenty (20) recordable indications. Sizing of indications were acceptable.	Yes	
B-A	B1.22	CH-MA Closure Head Meridional Weld at 0 Deg.	One (1) recordable indication. Sizing of indication was acceptable.	Yes	
B-A	B1.22	CH-MB Closure Head Meridional Weld at 60 Deg.	Sixty-five (65) recordable indications. Sixteen evaluated as rejectable. Accepted by flaw evaluation (Ref. GENE-995-004-0902,Rev.1 and GENE-0000- 0007-9747, Rev.0)	Yes	
B-A	B1.22	CH-MC Closure Head Meridional Weld at 120 Deg.	Three (3) recordable indications. Sizing of indications were acceptable.	Yes	
B-A	B1.22	CH-MD Closure Head Meridional Weld at 180 Deg.	Four (4) recordable indications. Sizing of indications were acceptable.	Yes	
B-A	B1.22	CH-ME Closure Head Meridional Weld at 120 Deg.	Three (3) recordable indications. Sizing of indications were acceptable.	Yes	
B-A	B1.22	CH-MF Closure Head Meridional Weld at 120 Deg.	Four (4) recordable indications. Sizing of indications were acceptable.	Yes	
B-A	B1.22	RPV-MB Bottom Head Meridional Weld at 60 Deg.	Four (4) recordable indications. Two (2) indications evaluated as non relevant clad reflectors. Sizing of remaining two (2) indications were acceptable.	Yes	
B-A	B1.22	RPV-ME Bottom Head Meridional Weld at 60 Deg.	Three (3) recordable indications. Sizing of indications were acceptable.	No IWB-2430 Additional Examination.	
B-D	B3.90	N1A Main Recirculation Outlet Nozzle-to-Vessel Weld	One (1) recordable indication. Sizing of indication was acceptable.	Yes	

ATTACHMENT 1B PAGE 5 OF 9

ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
B-N-2	B13.30	H-9 Core Shroud Support Plate Weld	Three (3) recordable indications. Sizing of indications were acceptable.	No Augmented UT Examination in accordance with BWVIP-38
C-C (N-509)	C3.20	14HB-H5(IA) Integral Attachment	One (1) linear (2.7") indication, rejectable. Indication removed, re-examination acceptable.	Yes
F-A (N-491-1)	F1.10	12DE-H33 Spring Hanger	Relevant Condition – Setting out of tolerance. Accepted by engineering evaluation.	Yes
F-A (N-491-1)	F1.20	1DB-H9B Rigid Restraint	Relevant Condition – Unacceptable thread engagement. Accepted by engineering evaluation.	Yes
F-A (N-491-1)	F1.20	10HB-S5 Rigid Restraint	Relevant Condition – Unacceptable thread engagement. Accepted by engineering evaluation.	No N-491-1, -2430 Additional Examination.
F-A (N-491-1)	F1.20	10GB-S56 Rigid Restraint	Relevant Condition – Loose wall plate studs. Repaired, re-examination acceptable.	Yes
N/A	N/A	14 inch High Pressure Service Water Piping	Minimum Wall Thickness Violations.	No

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 OCTOBER 6, 2000 TO NOVEMBER 2, 2002 (INCLUDES 2R14 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 01: MAIN STEAM SYSTEM

Code <u>Class</u>	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	RV-2-02-070A	Installed a rebuilt safety relief valve	No	9/20/2002	02-031, R0783804
Class 1	Replacement	RV-2-02-071A	Installed a rebuilt safety relief valve	No	9/20/2002	02-047, R0876672
Class 1	Replacement	RV-2-02-071C	Installed a rebuilt safety relief valve	No	9/20/2002	02-048, R0782754
Class 1	Replacement	RV-2-02-071D	Installed a rebuilt safety relief valve	No	9/20/2002	02-049, R0782757
Class 1	Replacement	RV-2-02-071J	Installed a rebuilt safety relief valve	No	9/20/2002	02-050, R0783627
Class 1	Replacement	RV-2-02-071K	Installed a rebuilt safety relief valve	No	9/20/2002	02-052, R0782756
Class 1	Replacement	RV-2-02-071L	Installed a rebuilt safety relief valve	No	9/20/2002	02-051, R0782755
Class 2	Replacement	7-DB-S-14	installed new snubber	No	9/14/2002	00-030, R0477959
Class 1	Replacement	AO-2-01A-086A	Installed 20 new bonnet nuts	No	9/20/2002	02-011, C0200315
Class 3	Replacement	1-GG-S-27	Installed new snubber and rod eye	Νο	9/15/2002	02-076, R0467885
Class 3	Replacement	1-GG-S-103-B	Installed new snubber	No	9/15/2002	02-084, C0200967

SYSTEM 02: REACTOR AND RECIRCULATION

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	PB-2-02A-2BP034	Installed new pump cover and internals	No	9/30/2002	02-125, C0194212

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 OCTOBER 6, 2000 TO NOVEMBER 2, 2002 (INCLUDES 2R14 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 03: CONTROL ROD DRIVE

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	CRD's 02-19, 02-31, 14-07, 34-11, 34-47, 34-51, 50-19, 50-23, 54-35	Exchanged CRD's with rebuilt CRD's during 2R14 outage	No	9/18/2002	02-028, R0851351

SYSTEM 06: FEEDWATER SYSTEM

Code)ate	
Class	nplete R&R Plan # and W/O	Ħ
Class 1	7/2002 02-055, R0470771	
Class 1	5/2002 02-151, C0202710	
Class 1 Class 1	7/2002 5/2002	02-055, R0470771 02-151, C0202710

SYSTEM 10: RESIDUAL HEAT REMOVAL

	Code Class	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
	Class 2	Replacement	RV-2-10-181D	Installed new RHR Hx. 2DE024 Shell Side relief valve	No	2/27/2001	00-059, R0601013
**	Class 2	Repair	PB-2-10-M-HX-2CE024	Repaired cracked partition welds at hx waterbox inlet	No	1/18/2001	00-132, C0195473
	Class 2	Replacement	RV-2-10-181C	Installed new RHR Hx. 2CE024 Shell Side relief valve	No	2/20/2001	01-006, R0707120
	Class 2	Replacement	RV-2-10-181B	Installed new RHR Hx. 2BE024 Shell Side relief valve	No	2/26/2002	02-002, R0601014

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 OCTOBER 6, 2000 TO NOVEMBER 2, 2002 (INCLUDES 2R14 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 11: STANDBY LIQUID CONTROL SYSTEM

Code <u>Class</u>	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	 Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
Class 2	Replacement	PB-2-11-M-PP-2BP040	Installed a new fluid end to pump	No	1/2/2001	00-140, C0192156
Class 2 Class 2	Replacement Replacement	RV-2-11-39A RV-2-11-39B	Installed new relief valve Installed new relief valve	No No	9/20/2002 9/20/2002	02-016, R0849828 02-017, R0849827

-

SYSTEM 12: REACTOR WATER CLEANUP SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		·
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
<u>Class</u>	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	12-DCN-S-7	Installed new snubber, rod eye, and pipe clamp	No	9/25/2002	02-056, R0470780
Class 1	Replacement	12-DCN-S-8-A	Installed new snubber	No	9/14/2002	02-119, C0201425

SYSTEM 23: HIGH PRESSURE COOLANT INJECTION SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 2	Replacement	VRV-2-23C-4998B	Installed new vacuum relief valve.	No	3/15/2001	01-088, C0196924
Class 2	Replacement	VRV-2-23C-4998A	Installed new vacuum relief valve.	No	4/2/2002	01-089, C0196928
Class 2	Replacement	CHK-2-23B-62	Installed new hinge pin plugs	No	9/18/2002	02-014, R0781995
Class 2	Replacement	CHK-2-23C-65	Installed new check valve	No	10/3/2002	02-126, C0199297

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 OCTOBER 6, 2000 TO NOVEMBER 2, 2002 (INCLUDES 2R14 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 32: HIGH PRESSURE SERVICE WATER SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,	,		During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
<u>Class</u>	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 3	Replacement	RV-2-32-180B	Installed new RHR Hx. 2BE024 Tube Side relief valve	No	2/26/2001	00-108, R0605930
Class 3	Replacement	RV-2-32-180D	Installed new RHR Hx. 2DE024 Tube Side relief valve	No	5/18/2001	01-110, R0640862

SYSTEM 48: EMERGENCY COOLING WATER

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 3	Replacement	PB-2-48A-00P186	Install seismic restraint, Emergency Cooling Water Pump	No	11/29/2001	01-141, R0050429

Attachment 2

Peach Bottom Atomic Power Station Unit 2

Owner Activity Report (OAR-1) for Refueling Outage 2R15 Third 10-Year ISI Interval, Second Period

FORM OAR-1 OWNER'S ACTIVITY REPORT

Report Number: 2R15

Owner: <u>EXELON NUCLEAR</u> 200 Exelon Way Kennett Square, PA 19348

Plant: <u>Peach Bottom Atomic Power Station</u> <u>1848 Lay Road</u> <u>Delta, PA 17314</u>

Unit No.: 2 Commercial Service Date: July 5, 1974

Refueling Outage No.: 15

Current Inspection Interval: <u>3rd</u>

Current Inspection Period: 2nd

Edition and Addenda of Section XI applicable to the Inspection Plan: <u>1989 Edition & 1992 Edition including 1992</u> Addenda

Date and Revision of Inspection Plan:

September 7, 2004, Revision 1

Edition and Addenda of Section XI applicable to repairs and replacements: 1989 Edition and Code Case N-416-1

CERTIFICATE OF CONFORMANCE

I certify that the statements made in this Owner's Activity Report are correct, and that the examinations, tests, repairs, replacements, evaluations, and corrective measures represented by this report for the period November 3, 2002 to October 9, 2004 conform to the requirements of Section XI.

Signed: Kenned & Hudsen Date: 01-24-2009

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the Commonwealth of <u>Pennsylvania</u> and employed by <u>Hartford Steam Boiler Inspection &</u> <u>Insurance Company of Connecticut</u>, of <u>Hartford, Connecticut</u>, have inspected the components described in the Owner's Data Report during the period November 3, 2002 to October 9, 2004 and state that to the best of my knowledge and belief the Owner has performed all activities represented by this report in accordance with the requirements of Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, tests, repairs, replacements, evaluations, and corrective measures described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date: 126 200 Inspector's Signature: Commissions: NB 7592, PA 2163 National Board, State, Province & No.

Peach Bottom Atomic Power Station, Unit 2 Third Interval, Second Period OAR-1

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Total Examinations Required For The Interval	Total Examinations Credited For The 2nd Period (P2R15)	Total Examinations Credited (%) For The 2nd Period (P2R15)	Total Examinations Credited (%) To Date for The Interval	Remarks
B-A	31	8	25.8	64.5	RPV Circumferential shell weld exempted per approved Relief request RR-41
B-D	61	12	19.7	52.5	Case N-598, Alternative Requirements to Required Percentages of Examinations, Section XI, Division 1 per approved Relief Request RR-33
B-E	62	62	100.0	100.0	B-E examinations completed during RPV Hydro performed in second period.
B-G-1	109	0	0.0	57.8	Code Case N-598 per approved Relief Request RR-33
B-G-2	108	28	25.9	61.1	Code Case N-598 per approved Relief Request RR-33
В-К	16	6	37.5	75.0	 Code Case N-598 per approved Relief Request RR-33 Use of ASME CC N-509, Alternative Rules for the Selection and Examination of Class 1, 2, and 3 Integrally Welded Attachments Section XI, Division 1, included Category B-H as B-K
B-L-2	1	0	0.0	100.0	
B-M-2	29	11	37.9	82.8	
B-N-1	3	1	33.3	66.7	
B-N-2	55	13	23.6	52.7	
B-P	6	1	16.7	50.0	
C-A	2	0	0.0	0.0	Code Case N-598 per approved Relief Request RR-33
C-B	8	2	25.0	62.5	
C-C	15	4	26.7	60.0	Code Case N-598 per approved Relief Request RR-33
C-H	51	16	31.4	62.7	
D-A	25	7	28.0	28.0	Code Case N-598 per approved Relief Request RR-33
D-B	9	3	33.3	66.7	

,

Peach Bottom Atomic Power Station, Unit 2 Third Interval, Second Period OAR-1

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Total Examinations Required For The Interval	Total Examinations Credited For The 2nd Period (P2R15)	Total Examinations Credited (%) For The 2nd Period (P2R15)	Total Examinations Credited (%) To Date for The Interval	Remarks
E-A	57	17	29.8	59.6	General Visual performed in P2R13 (1st Period) prior to ILRT. Not required to count double credit for inspection of Drywell, Torus, or Vent System for both 10CFR50.55a period and ILRT requirements.
E-C	3	2	66.7	66.7	Alternative examination program per approved Request for Alternative CRR-11
E-D	63	0	0.0	100.0	10CFR50 Appendix J examination of seals and gaskets in the 1st period per approved Request for Alternative CRR-01
E-G	76	0	0.0	100.0	10CFR50 Appendix J and Code Category E-A examination in the 1st period per approved Request for Alternative CRR-07
E-P	1	0	0.0	100.0	Examined in the 1st period In accordance with 10CFR50 Appendix J Test Program and Schedule
F-A	167	41	24.6	70.7	Code Case N-598 per approved Relief Request RR-33
R-A	135	37	27.4	57.0	Implemented RI-ISI starting 2nd Period, replacing Categories B-F, B-J, and C-F-2.

TABLE 2 ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE **ATTACHMENT 2** PAGE 4 OF 10

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
B-A	B1.22	CH-MB Closure Head Meridional Weld at 60 Deg.	Two (2) recordable indications. Accepted by flaw evaluation.	No IWB-2420 Successive Examination
B-D	B3.90	N1BOne (1) subsurface flaw indication on adjacentMain Recirculationcircumferential weld RPV-C1. Accepted by flawOutlet Nozzle-to-Vessel Weldevaluation.		Yes
C-C (N-509)	C3.20	10DDN-H91(IA) Integral Attachment	One (1) linear (2.85") indication, rejectable. Indication removed, re-examination acceptable.	Yes
C-C (N-509)	C3.20	14HB-H18(IA) Integral Attachment	One (1) linear (1.25") indication, rejectable. Indication removed, re-examination acceptable.	No N-509, 1.3 (IWC-2430) Additional Examination.
C-F-2	C5.21	23-O-43 Valve to Elbow Weld	ID geometric indication recorded in repair area. Sizing of indication was acceptable.	No Baseline Exam.
C-F-2	C5.21	23-O-44 Valve to Elbow Weld	Eleven (11) relevant indications. Sizing of indications were acceptable.	No Baseline Exam.
E-C	E4.11	Torus Wetted Pressure Boundary	Pitting was inspected and depths measured. Accepted by Engineering Evaluation.	. Yes
F-A (N-491-1)	F1.30	48GB-S12 Rigid Restraint	Relevant Condition – Rust & cracked concrete noted during exam. Acceptable per Section XI.	Yes
F-A (N-491-1)	F1.30	48GB-S17 Rigid Restraint	Relevant Condition – Rust & cracked concrete noted during exam. Acceptable per Section XI.	Yes
F-A (N-491-1)	F1.30	48GB-S32 Rigid Restraint	Relevant Condition – Rust & cracked concrete noted during exam. Acceptable per Section XI.	Yes

ATTACHMENT 2 ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE **PAGE 5 OF 10**

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
F-A (N-491-1)	F1.30	48HB-S33 Rigid Restraint	Relevant Condition – Rust & cracked concrete noted during exam. Acceptable per Section XI.	Yes
R-A	R1.11	23-2TE20-16 Elbow to Pipe Weld	ID geometric indication recorded. Sizing of indication was acceptable.	No Baseline Exam.
R-A	R1.20	10-2DA20-6 Elbow to Pipe Weld	ID geometric indication recorded. Sizing of indication was acceptable.	No Baseline Exam.
N/A	N/A	High Pressure Srvice Water System 14 inch NOD carbon steel piping	Wall thickness measurements less than minimum wall.	No
N/A	N/A	High Pressure Srvice Water System 14x18x18 inch NOD carbon steel pipe tee.	Wall thickness measurements less than minimum wall.	No

.

SYSTEM 01: MAIN STEAM SYSTEM

Code <u>Class</u>	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	<u>R&R Plan</u>	<u># and W/O #</u>
Class 1	Replacement	HV-2-01A-83A & 84A	Installed new valves	No	9/22/2004	04-012,	C0208124
Class 1	Replacement	RV-2-02-071G	Installed a rebuilt safety relief valve	No	10/4/2004	04-045,	R0876673
Class 1	Replacement	RV-2-02-071E	Installed a rebuilt safety relief valve	No	10/4/2004	04-046,	R0851874
Class 1	Replacement	RV-2-02-071H	Installed a rebuilt safety relief valve	No	10/4/2004	04-047,	R0852188
Class 1	Replacement	RV-2-02-071B	Installed a rebuilt safety relief valve	No	10/4/2004	04-048,	R0850766
Class 1	Replacement	RV-2-02-071F	Installed a rebuilt safety relief valve	No	10/4/2004	04-049,	R0851812
Class 1	Replacement	RV-2-02-070B	Installed a rebuilt safety relief valve	No	10/4/2004	04-050,	R0851537
Class 2	Replacement	1DB-H170	Relocated spring hanger support	No	9/23/2004	04-156,	C0210216
Class 1	Replacement	MO-2-01A-077	Installed helicoil for a stripped pressure seal bonnet stud	No	9/22/2004	04-160,	R0487872
Class 1	Replacement	RV-2-02-071F	Installed a rebuilt safety relief valve	No	10/4/2004	04-161,	R0851812
	Code Class 1 Class 1 Class 1 Class 1 Class 1 Class 1 Class 1 Class 2 Class 1 Class 1 Class 2 Class 1 Class 1	Repair, Replacement, or CorrectiveCode Classor Corrective MeasureClass 1ReplacementClass 1Replacement	Repair, Replacement,Code Classor Corrective MeasureItem Description (component 1.D.)Class 1ReplacementHV-2-01A-83A & 84AClass 1ReplacementRV-2-02-071GClass 1ReplacementRV-2-02-071EClass 1ReplacementRV-2-02-071HClass 1ReplacementRV-2-02-071HClass 1ReplacementRV-2-02-071HClass 1ReplacementRV-2-02-071BClass 1ReplacementRV-2-02-071FClass 1ReplacementRV-2-02-070BClass 2Replacement1DB-H170Class 1ReplacementMO-2-01A-077Class 1ReplacementRV-2-02-071F	Repair, Replacement, ClassItem Description (component 1.D.)Description Of Work PerformedClass 1ReplacementHV-2-01A-83A & 84AInstalled new valvesClass 1ReplacementHV-2-02-071GInstalled a rebuilt safety relief valveClass 1ReplacementRV-2-02-071EInstalled a rebuilt safety relief valveClass 1ReplacementRV-2-02-071EInstalled a rebuilt safety relief valveClass 1ReplacementRV-2-02-071EInstalled a rebuilt safety relief valveClass 1ReplacementRV-2-02-071HInstalled a rebuilt safety relief valveClass 1ReplacementRV-2-02-071BInstalled a rebuilt safety relief valveClass 1ReplacementRV-2-02-071FInstalled a rebuilt safety relief valveClass 1ReplacementRV-2-02-070BInstalled a rebuilt safety relief valveClass 2ReplacementRV-2-02-070BInstalled a rebuilt safety relief valveClass 1ReplacementMO-2-01A-077Installed helicoil for a stripped pressure seal bonnet studClass 1ReplacementRV-2-02-071FInstalled a rebuilt safety relief valve	Flaw or RelevantRepair,Condition FoundReplacement,During ScheduledCodeor CorrectiveItem DescriptionSection XI ExamClassMeasure(component I.D.)Description Of Work PerformedOr TestClass 1ReplacementHV-2-01A-83A & 84AInstalled new valvesNoClass 1ReplacementRV-2-02-071GInstalled a rebuilt safety relief valveNoClass 1ReplacementRV-2-02-071EInstalled a rebuilt safety relief valveNoClass 1ReplacementRV-2-02-071EInstalled a rebuilt safety relief valveNoClass 1ReplacementRV-2-02-071EInstalled a rebuilt safety relief valveNoClass 1ReplacementRV-2-02-071FInstalled a rebuilt safety relief valveNoClass 1ReplacementRV-2-02-071FInstalled a rebuilt safety relief valveNoClass 1ReplacementRV-2-02-071FInstalled a rebuilt safety relief valveNoClass 1ReplacementRV-2-02-070BInstalled a rebuilt safety relief valveNoClass 1ReplacementRV-2-02-071FInstalled a rebuilt safety relief valveNoClass 1ReplacementRV-2-02-071F	Flaw or Relevant Condition FoundReplacement,Condition FoundCodeor CorrectiveItem DescriptionDescription Of Work PerformedOuring ScheduledClassMeasure(component 1.D.)Description Of Work PerformedOr TestCompleteClass 1ReplacementHV-2-01A-83A & 84AInstalled new valvesNo9/22/2004Class 1ReplacementRV-2-02-071GInstalled a rebuilt safety relief valveNo10/4/2004Class 1ReplacementRV-2-02-071EInstalled a rebuilt safety relief valveNo10/4/2004Class 1ReplacementRV-2-02-071HInstalled a rebuilt safety relief valveNo10/4/2004Class 1ReplacementRV-2-02-071FInstalled a rebuilt safety relief valveNo10/4/2004Class 2ReplacementRV-2-02-070BInstalled a rebuilt safety relief valveNo10/4/2004Class 1ReplacementRV-2-02-070FInstalled a rebuilt safety relief valveNo10/4/2004Class 1ReplacementRV-2-02-070BInstalled a rebuilt safety relief valveNo10/4/2004Class 1ReplacementRV-2-02-070BInstalled a rebuilt safety	Flaw or Relevant Condition FoundReplacement,CodeCorrectiveItem DescriptionDuring ScheduledCodeor CorrectiveItem DescriptionDescription Of Work PerformedOr TestCompleteR&R PlanClass 1ReplacementHV-2-01A-83A & 84AInstalled new valvesNo9/22/200404-012,Class 1ReplacementRV-2-02-071GInstalled a rebuilt safety relief valveNo10/4/200404-045,Class 1ReplacementRV-2-02-071EInstalled a rebuilt safety relief valveNo10/4/200404-046,Class 1ReplacementRV-2-02-071HInstalled a rebuilt safety relief valveNo10/4/200404-046,Class 1ReplacementRV-2-02-071BInstalled a rebuilt safety relief valveNo10/4/200404-047,Class 1ReplacementRV-2-02-071BInstalled a rebuilt safety relief valveNo10/4/200404-047,Class 1ReplacementRV-2-02-071BInstalled a rebuilt safety relief valveNo10/4/200404-049,Class 1ReplacementRV-2-02-071BInstalled a rebuilt safety relief valveNo10/4/200404-049,Class 1ReplacementRV-2-02-070BInstalled a rebuilt safety relief valveNo10/4/200404-045,Class 1ReplacementRV-2-02-070BInstalled a rebuilt safety relief valveNo10/4/200404-045,Class 1ReplacementRV-2-02-070BInstalled a rebuilt safety relief valveNo10

SYSTEM 02: REACTOR AND RECIRCULATION

					Flaw or Relevant		
		Repair,			Condition Found		
		Replacement,			During Scheduled		
	Code	or Corrective	Item Description		Section XI Exam	Date	
	Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
**	Class 1	Replacement	HV-2-02-15, HV-2-02-16	Installed new valves	. No	10/8/2004	04-152, R0922216

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 NOVEMBER 3, 2002 TO OCTOBER 9, 2004 (INCLUDES 2R15 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 03: CONTROL ROD DRIVE

	Code <u>Class</u>	Repair, Replacement, or Corrective <u>Measure</u>	Item Description	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
	Class 1	Replacement	CRD's 06-27, 10-27, 10-47, 14-15, 14-51, 18-03, 18-39, 18-51, 22-51, 26-55, 30-07, 38-59, 42-03, 42-55, 46-43, 54-15, 54-31, 54-39, 54-43	Exchanged CRD's with rebuilt CRD's	No	10/8/2004	04-080, R0935052
**	Class 1	Replacement	cleanout pipe caps	Remove/install pipe caps to flush scram disch. Header	No	9/22/2004	04-094, C0209098

SYSTEM 06: FEEDWATER SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	CHK-2-06-96B	Installed new bonnet modification	No	10/4/2004	04-039, C0208272

SYSTEM 10: RESIDUAL HEAT REMOVAL

		Densis			Flaw or Relevant		
		Repair,			Condition Found		
		Replacement,			During Scheduled		
	Code	or Corrective	Item Description		Section XI Exam	Date	
	Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
**	Class 2	Replacement	MO-2-10-026B	Installed branch connection over hole for FME retrieval	No	10/6/2004	04-169, C0211427

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 NOVEMBER 3, 2002 TO OCTOBER 9, 2004 (INCLUDES 2R15 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 12: REACTOR WATER CLEANUP SYSTEM

					Flaw or Relevant		
		Repair,			Condition Found		
		Replacement,			During Scheduled		
	Code	or Corrective	Item Description		Section XI Exam	Date	
	Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
**	Class 1	Replacement	MO-2-12-068	Installed new valve	No	10/8/2004	04-077, R0612166

SYSTEM 14: CORE SPRAY SYSTEM

					Flaw or Relevant		
		Repair,			Condition Found		
		Replacement,			During Scheduled		
	Code	or Corrective	Item Description		Section XI Exam	Date	
	Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
**	Class 2	Replacement	RV-2-14-020B	Installed new relief valve	No	9/26/2004	02-013, R0735131

SYSTEM 23: HIGH PRESSURE COOLANT INJECTION SYSTEM

	Repair, Replacement, Code or Corroctivo		Item Description		Flaw or Relevant Condition Found During Scheduled Section XI Exam	Data	
	<u>Class</u>	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	<u>R&R Plan # and W/O #</u>
**	Class 2	Replacement	MO-2-23-014	Installed new valve	No	10/1/2004	02-093, R0786125
	Class 1	Repair	MO-2-23-016	Performed weld overlay on pressure seal bonnet	No	12/19/2002	02-211, C0203523
	Class 2	Replacement	MO-2-23-015	Installed 8 new pressure seal studs and nuts	No	9/23/2004	03-058, C0204882
**	Class 2	Replacement	RV-2-23B-034	Installed new relief valve	No	5/12/2004	04-092, R0781699
	Class 2	Replacement	2-23MO-H47	Replaced spring can all thread rod	No	5/12/2004	04-108, C0209683
**	Class 2	Replacement	AO-2-23-137	Removed & reinstalled piping to perform boroscope insp.	No	9/30/2004	04-151, C0211189

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 NOVEMBER 3, 2002 TO OCTOBER 9, 2004 (INCLUDES 2R15 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 32: HIGH PRESSURE SERVICE WATER SYSTEM

	Code	Repair, Replacement, or Corrective	Item Description	Flaw or Rele Condition Fo During Sched em Description Section XI Ex	Flaw or Relevant Condition Found During Scheduled Section XI Exam	Date	
	Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
	Class 3	Replacement	RV-2-32-180C	Installed new RHR Hx. 2CE024 Tube Side relief valve	No	12/3/2003	00-002, R0752895
	Class 3	Replacement	PB-2-32-2DP042	Installed new pump and pump bowls	No	1/13/2003	02-163, C0202851
**	Class 3	Replacement	PB-2-32-RO-2789B/D	Replaced piping between RO-2789B to RO-2789D	No	1/7/2003	02-170, C0202662
	Class 3	Replacement	RV-2-32-180A	Installed new RHR Hx. 2AE024 Tube Side relief valve	No	1/12/2004	03-107, R0752896
	Class 3	Replacement	RV-2-32-180B	Installed new RHR Hx. 2BE024 Tube Side RV bolting nuts	No	5/27/2004	04-109, C0209424
**	Class 3	Replacement	PB-2-32-RO-2789C	Installed new outlet restricting orifice & associated piping	No	9/20/2004	04-147, C0209471

SYSTEM 52: DIESEL GENERATOR

	Repair,			Flaw or Relevant Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
<u>Class</u>	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 3	Replacement	XJ-70133D	Installed two new studs for thread engagement issue	No	6/23/2004	04-127, R0904428

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2

NOVEMBER 3, 2002 TO OCTOBER 9, 2004

(INCLUDES 2R15 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 65A: HYDRAULIC SNUBBERS

Code <u>Class</u>	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	<u>R&R Plan</u>	<u># and W/O #</u>
Class 2	Replacement	7-DB-S-11	Installed new snubber, rod eye, and extension piece	No	10/2/2004	00-029,	R0707171
Class 1	Replacement	SS-C-6	Installed new snubber, rod eye paddle, & extension piece	No	9/23/2004	04-052,	C0208085
Class 1	Replacement	10-GB-S-50	Installed new pipe end load pin	No	9/24/2004	04-061,	C0208067
Class 1	Replacement	1-GG-S-24	Installed new snubber and rod eye extension piece	No	9/20/2004	04-085,	R0705716
Class 1	Replacement	7-DB-S-13	Installed new snubber	No	9/21/2004	04-093	R0706728
Class 2	Replacement	7-DB-S-15	Installed new snubber	No	9/24/2004	04-153	C0211249
Class 2	Replacement	23-DBN-S-29	Installed new snubber	No	9/27/2004	04-159	C0211296
Class 3	Replacement	1-GG-S-83	Installed new pipe clamp fasteners	No	9/25/2004	04-164	C0211349
Class 3	Replacement	1-GG-S-1	Installed new pipe clamp fasteners	No	9/25/2004	04-165.	C0211358
Class 3	Replacement	1-GG-S-78	Installed new pipe clamp fasteners	No	9/26/2004	04-166,	C0211368
Class 3	Replacement	1-GG-S-80	Installed new pipe clamp fasteners	No	9/26/2004	04-167,	C0211369

SYSTEM 65B: MECHANICAL SNUBBERS

	Repair, Replacement,			Flaw or Relevant Condition Found During Scheduled		
Code Class	or Corrective Measure	Item Description (component I.D.)	Description Of Work Performed	Section XI ExamOr Test	Date <u>Complete</u>	<u>R&R Plan # and W/O #</u>
Class 1 Class 1	Replacement Replacement	1-GG-S-203-A 1-GG-S-206-B	Installed new snubber Installed new snubber	No No	9/20/2004 9/20/2004	04-054, C0208087 04-056, C0208089

Attachment 3A

Peach Bottom Atomic Power Station Unit 2

Owner Activity Report (OAR-1) for Refueling Outage 2R16 Third 10-Year ISI Interval, Third Period
Refueling Outage No.: 16

FORM OAR-1 OWNER'S ACTIVITY REPORT

Report Number: 2R16

Owner: <u>EXELON NUCLEAR</u> 200 Exelon Way Kennett Square, PA 19348

Plant: <u>Peach Bottom Atomic Power Station</u> <u>1848 Lay Road</u> <u>Delta, PA 17314</u>

Unit No.: 2 Commercial Service Date: July 5, 1974

Current Inspection Interval: 3^{rd}

Current Inspection Period: 3rd

Edition and Addenda of Section XI applicable to the Inspection Plan: 1989 & 1992 Editions, 1992 Addenda

Date and Revision of Inspection Plan: <u>February 21, 2006, Revision 2</u>

Edition and Addenda of Section XI applicable to repairs and replacements: 1989 Edition and Code Case N-416-1

CERTIFICATE OF CONFORMANCE

I certify that the statements made in this Owner's Activity Report are correct, and that the examinations, tests, repairs, replacements, evaluations, and corrective measures represented by this report for the period October 10, 2004 to October 4, 2006 conform to the requirements of Section XI.

Signed: Kenneth a Hudsen Date: 01-24-2009

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the Commonwealth of <u>Pennsylvania</u> and employed by <u>Hartford Steam Boiler Inspection &</u> <u>Insurance Company of Connecticut</u>, of <u>Hartford</u>, <u>Connecticut</u>, have inspected the components described in the Owner's Data Report during the period October 10, 2004 to October 4, 2006 and state that to the best of my knowledge and belief the Owner has performed all activities represented by this report in accordance with the requirements of Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, tests, repairs, replacements, evaluations, and corrective measures described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date: 176/2000 Inspector's Signature: PAZI63 A, N, I Commissions: NB 7592 National Board, State, Province & No.

Peach Bottom Atomic Power Station, Unit 2 Third Interval, Third Period OAR-1 - Refueling Outage P2R16

ATTACHMENT 3A PAGE 2 OF 8

. .

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Category Description	Total Examinations Required For The Interval	Total Examinations Credited For The 3rd Period (P2R16)	Total Examinations Credited (%) For The 3rd Period (P2R16)	Total Examinations Credited (%) To Date for The Interval	Remarks
B-A	RPV Pressure Retaining Welds	31	0	0.0	64.5	RPV Circumferential shell weld exempted per approved Relief request RR-41
B-D	RPV Nozzles, Inner Radius	61	18	29.5	82.0	Case N-598, Alternative Requirements to Required Percentages of Examinations, Section XI, Division 1 per approved Relief Request RR-33
B-E	Partial Penetration Welds in Piping	62	0	0.0	100.0	B-E examinations completed during RPV Hydro performed in second period.
B-G-1	Bolting > 2 inch	109	46	42.2	100.0	Code Case N-598 per approved Relief Request RR-33
B-G-2	Bolting ≤ 2 inch	108	23	21.3	82.4	Code Case N-598 per approved Relief Request RR-33
В-К	Integral Attachments (vessels, piping, pumps)	16	4	25.0	100.0	 Code Case N-598 per approved Relief Request RR-33 Use of ASME CC N-509, Alternative Rules for the Selection and Examination of Class 1, 2, and 3 Integrally Welded Attachments Section XI, Division 1, included Category B-H as B-K
B-L-2	Internal Surfaces of Pump Casings	1	0	0.0	100.0	
B-M-2	Internal Surfaces of Valve Bodies	29	5	17.2	100.0	
B-N-1	Reactor Vessel Interior	3	0	0.0	66.7	
B-N-2	Core Support Structures and Interior Attachments	55	14	25.5	78.2	
B-P	All Pressure Retaining Components	6	2	33.3	83.3	
C-A	Welds in Pressure Vessels	2	1	50.0	50.0	Code Case N-598 per approved Relief Request RR-33

Peach Bottom Atomic Power Station, Unit 2 Third Interval, Third Period OAR-1 - Refueling Outage P2R16

ATTACHMENT 3A PAGE 3 OF 8

.

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Category Description	Total Examinations Required For The Interval	Total Examinations Credited For The 3rd Period (P2R16)	Total Examinations Credited (%) For The 3rd Period (P2R16)	Total Examinations Credited (%) To Date for The Interval	Remarks
C-B	Nozzle Welds in Vessels	8	3	37.5	100.0	
C-C	ASME Class 2 Integral Attachments to Piping	15	5	33.3	93.3	Code Case N-598 per approved Relief Request RR-33
C-H	All Class 2 Pressure Retaining Componnets	51 [°]	· 14	27.5	90.2	
D-A	ASME Class 3 Integral Attachments to Piping	25	9	36.0	64.0	Code Case N-598 per approved Relief Request RR-33
D-B	Class 3 ECCS, Ect. System Pressure Tests	9	1	11.1	77.8	
E-A	Surfaces	57	3	5.3	64.9	General Visual performed in P2R13 (1st Period) prior to ILRT. Not required to count double credit for inspection of Drywell, Torus, or Vent System for both 10CFR50.55a period and ILRT requirements.
E-C	Augmented Exams (Pits, Wall Thickness)	3	1	33.3	100.0	Alternative examination program per approved Request for Alternative CRR-11
E-D		63	0	0.0	100.0	10CFR50 Appendix J examination of seals and gaskets in the 1st period per approved Request for Alternative CRR-01
E-G		76	0	0.0	100.0	10CFR50 Appendix J and Code Category E-A examination in the 1st period per approved Request for Alternative CRR-07
E-P		1	0	0.0	100.0	Examined in the 1st period In accordance with 10CFR50 Appendix J Test Program and Schedule
F-A	Supports	167	47	28.1	98.8	Code Case N-598 per approved Relief Request RR-33
R-A	Risk Informed Welds	135	26	19.3	76.3	Implemented RI-ISI starting 2nd Period, replacing Categories B-F, B-J, and C-F 2.

ATTACHMENT 3A PAGE 4 OF 8

TABLE 2

ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
F-A (N-491-1)	F1.20	14GB-H40 Spring Hanger	Relevant Condition – Loose spacer and bent clamp. Accepted by Engineering Evaluation.	Yes
F-A (N-491-1)	F1.40	RHRHX-A-LS Heat Exchanger Lower Support	Relevant Condition – Missing bolts, wrong size bolts, gap in plate. Repaired and the re-examination was acceptable.	Yes
F-A (N-491-1)	F1.20	Spring Hanger 23-HB-H35	Concrete is missing from around one of the four bolts.	Yes
N/A	N/A	6-inch Carbon Steel Emergency Service Water Pipe	Pin-hole leak.	No
N/A	N/A	HPCI Turbine Steam Supply Valve MO-2-23- 014, ASME Class 2	Small steam leak on valve leak-off plug.	No

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 OCTOBER 10, 2004 TO OCTOBER 4, 2006 (INCLUDES 2R16 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 01: MAIN STEAM SYSTEM

Code Class	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	<u>R&R Plan</u>	# and W/O #
Class 1	Replacement	RV-2-02-071D	Installed a rebuilt safety relief valve	No	2/4/2005	04-175,	C0211903
Class 1	Replacement	AO-2-01A-086C	Installed 5 new studs and nuts as incidental replacement	No	10/2/2006	04-136,	R0968832
Class 1	Replacement	AO-2-01A-080C	Installed new studs and nuts as incidental replacement	No	9/30/2006	06-101,	R0978348
Class 1	Replacement	RV-2-02-071A	Installed a rebuilt safety relief valve	No	9/26/2006	06-118,	R0955420
Class 1	Replacement	RV-2-02-071C	Installed a rebuilt safety relief valve	No	9/26/2006	06-119,	R0924536
Class 1	Replacement	RV-2-02-071D	Installed a rebuilt safety relief valve	No	9/26/2006	06-120,	R0918419
Class 1	Replacement	RV-2-02-071J	Installed a rebuilt safety relief valve	No	9/27/2006	06-121,	R0931486
Class 1	Replacement	RV-2-02-071K	Installed a rebuilt safety relief valve	No	9/27/2006	06-122,	R0936216
Class 1	Replacement	RV-2-02-071L	Installed a rebuilt safety relief valve	No	9/27/2006	06-123,	R0924578
Class 1	Replacement	RV-2-02-070B	Installed a rebuilt safety relief valve	No	9/26/2006	06-124,	R0917366

_ _

SYSTEM 03: CONTROL ROD DRIVE

**

Code <u>Class</u>	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	<u>R&R Plan # and W/O</u>
Class 1	Replacement	CRD's 02-27, 06-35, 06-47, 18-11, 22-11, 22-31, 22-55, 22-59, 26-03, 26-59, 30-31, 34-19, 34-23, 34-39, 38-31, 38-47, 38-51, 46-11, 50-31	Exchanged CRD's with rebuilt CRD's	No	9/25/2006	06-046, R0983803
Class 1	Replacement	SVD cleanout pipe caps	Install pipe caps/connections on scram disch. header	No	9/27/2006	06-126, C0216745

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2

OCTOBER 10, 2004 TO OCTOBER 4, 2006

(INCLUDES 2R16 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 10: RESIDUAL HEAT REMOVAL

					Flaw or Relevant			
		Repair,			Condition Found			
		Replacement,			During Scheduled			
	Code	or Corrective	Item Description		Section XI Exam	Date		
	Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O	#
	Class 2	Replacement	RV-2-10-181A	Installed new RHR Hx. 2AE024 Shell Side relief valve	No	2/20/2006	06-001, R0795544	
**	Class 3	Replacement	MO-2-10-089C	Installed new RHR Hx 2CE024 HPSW Outlet Valve	No	9/20/2006	06-134, C0216868	
	Class 3	Replacement	PB-2-10-2AE024	Replaced lower heat exchanger support bolting	Yes	9/22/2006	06-186, C0216303	
	Class 2	Replacement	PB-2-10-2DP035	Installed new pump rotating assembly	No	10/2/2006	06-190, C0218990	

SYSTEM 11: STANDBY LIQUID CONTROL SYSTEM

Code <u>Class</u>	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
Class 2	Replacement	RV-2-11-39A	Installed new relief valve	No	9/23/2006	06-132, R0988018
Class 2	Replacement	RV-2-11-39B	Installed new relief valve	No	9/23/2006	06-133, R0981054
Class 2	Replacement	RV-2-11-39A	Installed new relief valve	No	9/29/2006	06-192, R0988018

SYSTEM 14: CORE SPRAY SYSTEM

				Flaw or Relevant		
	Repair,		· · · · ·	Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
<u>Class</u>	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 2	Replacement	RO-2-14-037D	Installed new studs/nuts due to thread engagement issue	No	8/9/2005	05-116, C0213871
Class 2	Replacement	RV-2-14-020A	Installed new relief valve	No	8/2/2006	06-150, R0813398

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 OCTOBER 10, 2004 TO OCTOBER 4, 2006 (INCLUDES 2R16 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 23: HIGH PRESSURE COOLANT INJECTION SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 2	Repair	MO-2-23-014	Repaired seal weld on threaded bonnet leakoff plug	No	4/26/2005	05-107, C0213614

SYSTEM 33: EMERGENCY SERVICE WATER

	Code <u>Class</u>	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	<u>R&R Plan # and W/O #</u>
	Class 3 Class 3	Replacement Replacement	XJ-70133C AO-2-33-2335G	Installed 8 new bolts due to thread engagement issue Installed 6 new studs/nuts due to thread engagement issue	No No	2/15/2005 4/19/2005	04-177, R0932884 05-003, C0212167
**	Class 3 Class 3	Replacement Repair	HV-2-33-517 CHK-0-33-515A	Installed new valve Weld build up disc arm and valve body stop location	No	9/30/2006 6/13/2005	04-086, C0208469 04-174, R0812619
**	Class 3	Replacement	RTV-0-33-244B	Replaced degraded piping downstream of RTV-0-33-244B	No	5/10/2006	05-147, C0215848

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 OCTOBER 10, 2004 TO OCTOBER 4, 2006 (INCLUDES 2R16 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 65A: HYDRAULIC SNUBBERS

Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
Replacement	13-DBN-S-15	Installed new snubber	No	9/19/2006	06-014, C0216161
Replacement	23-DBN-S-1	Installed new snubber	No	9/19/2006	06-016, C0216163
Replacement	SS-B-6	Installed new snubber	No	9/27/2006	06-017, C0216165
Replacement	1-DB-S-15-A	Installed new snubber	No	9/29/2006	06-084, R0780512
Replacement	1-DB-S-25-A	installed new snubber	No	9/29/2006	06-085, R0780902
Replacement	1-DB-S-2-A	installed new snubber	No	9/29/2006	06-086, R0780903
Replacement	1-DB-S-38-A	Installed new snubber	No	9/29/2006	06-087, R0780974
	Repair, Replacement, or Corrective Measure Replacement Replacement Replacement Replacement Replacement Replacement Replacement	Repair, Replacement, or CorrectiveItem Description (component I.D.)Replacement13-DBN-S-15Replacement23-DBN-S-1ReplacementSS-B-6Replacement1-DB-S-15-AReplacement1-DB-S-25-AReplacement1-DB-S-2-AReplacement1-DB-S-38-A	Repair, Replacement, or CorrectiveItem Description (component I.D.)Description Of Work PerformedMeasure(component I.D.)Description Of Work PerformedReplacement13-DBN-S-15Installed new snubberReplacement23-DBN-S-1Installed new snubberReplacementSS-B-6Installed new snubberReplacement1-DB-S-15-AInstalled new snubberReplacement1-DB-S-25-AInstalled new snubberReplacement1-DB-S-25-AInstalled new snubberReplacement1-DB-S-28-AInstalled new snubberReplacement1-DB-S-38-AInstalled new snubber	Repair, Replacement, or CorrectiveItem Description (component I.D.)Description Of Work PerformedDuring Scheduled Section XI Exam Or TestMeasure(component I.D.)Description Of Work PerformedOr TestReplacement13-DBN-S-15Installed new snubberNoReplacement23-DBN-S-1Installed new snubberNoReplacementSS-B-6Installed new snubberNoReplacementSS-B-6Installed new snubberNoReplacement1-DB-S-15-AInstalled new snubberNoReplacement1-DB-S-25-AInstalled new snubberNoReplacement1-DB-S-25-AInstalled new snubberNoReplacement1-DB-S-26-AInstalled new snubberNoReplacement1-DB-S-26-AInstalled new snubberNoReplacement1-DB-S-26-AInstalled new snubberNoReplacement1-DB-S-26-AInstalled new snubberNoReplacement1-DB-S-38-AInstalled new snubberNo	Flaw or Relevant Condition FoundReplacement, or CorrectiveItem Description (component I.D.)Description Of Work PerformedDuring Scheduled Section XI ExamDate CompleteReplacement13-DBN-S-15Installed new snubberNo9/19/2006Replacement23-DBN-S-1Installed new snubberNo9/19/2006ReplacementSS-B-6Installed new snubberNo9/27/2006Replacement1-DB-S-15-AInstalled new snubberNo9/29/2006Replacement1-DB-S-25-AInstalled new snubberNo9/29/2006Replacement1-DB-S-25-AInstalled new snubberNo9/29/2006Replacement1-DB-S-25-AInstalled new snubberNo9/29/2006Replacement1-DB-S-25-AInstalled new snubberNo9/29/2006Replacement1-DB-S-25-AInstalled new snubberNo9/29/2006Replacement1-DB-S-38-AInstalled new snubberNo9/29/2006Replacement1-DB-S-38-AInstalled new snubberNo9/29/2006

SYSTEM 65B: MECHANICAL SNUBBERS

					Flaw or Relevant		
		Repair,			Condition Found		
		Replacement,			During Scheduled		
	Code	or Corrective	Item Description		Section XI Exam	Date	
-	Class	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
	Class 2	Replacement	14-MO-S-26	Installed new snubber	No	9/28/2006	06-021, C0216175

— ·

Attachment 3B

Peach Bottom Atomic Power Station Unit 2

Owner Activity Report (OAR-1) for Refueling Outage 2R17 Third 10-Year ISI Interval, Third Period

FORM OAR-1 OWNER'S ACTIVITY REPORT

Report Number: 2R17

Owner: <u>EXELON NUCLEAR</u> 200 Exelon Way Kennett Square, PA 19348

Plant: <u>Peach Bottom Atomic Power Station</u> <u>1848 Lay Road</u> <u>Delta, PA 17314</u>

Unit No.: 2 Commercial Service Date: July 5, 1974

Refueling Outage No.: 17

Current Inspection Interval: <u>3rd</u>

Current Inspection Period: <u>3rd</u>

Edition and Addenda of Section XI applicable to the Inspection Plan: <u>1989 Edition & 1992 Edition including 1992</u> Addenda

Date and Revision of Inspection Plan:

September 16, 2008, Revision 2

Edition and Addenda of Section XI applicable to repairs and replacements: 1989 Edition and Code Case N-416-1

CERTIFICATE OF CONFORMANCE

I certify that the statements made in this Owner's Activity Report are correct, and that the examinations, tests, repairs, replacements, evaluations, and corrective measures represented by this report for the period October 5, 2006 to November 4, 2008 conform to the requirements of Section XI.

Signed: Kennah a Hudson Date: 01-24-2009

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the Commonwealth of <u>Pennsylvania</u> and employed by <u>Hartford Steam Boiler Inspection &</u> <u>Insurance Company of Connecticut</u>, of <u>Hartford, Connecticut</u>, have inspected the components described in the Owner's Data Report during the period October 5, 2006 to November 4, 2008 and state that to the best of my knowledge and belief the Owner has performed all activities represented by this report in accordance with the requirements of Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, tests, repairs, replacements, evaluations, and corrective measures described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date: 12 Inspector's Signature: Commissions: NB 7592

Peach Bottom Atomic Power Station, Unit 2 Third Interval, Third Period OAR-1 - Through Refueling Outage 2R17

ATTACHMENT 3B PAGE 2 OF 11

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Total Examinations Required For The Interval	Total Examinations Credited For The 3rd Period (P2R16 & P2R17)	Total Examinations Credited (%) For The 3rd Period (P2R16 & P2R17)	Total Examinations Credited (%) To Date for The Interval	Remarks
B-A	31	11	35.5	100.0	RPV Circumferential shell weld exempted per approved Relief request RR-41
B-D	61	29	47.5	100.0	Case N-598, Alternative Requirements to Required Percentages of Examinations, Section XI, Division 1 per approved Relief Request RR-33
B-E	62	0	0.0	100.0	B-E examinations completed during RPV Hydro performed in second period.
B-G-1	109	46	42.2	100.0	Code Case N-598 per approved Relief Request RR-33
B-G-2	108	42	38.9	100.0	Code Case N-598 per approved Relief Request RR-33
В-К	16	7	43.8	118.8	 Code Case N-598 per approved Relief Request RR-33 Use of ASME CC N-509, Alternative Rules for the Selection and Examination of Class 1, 2, and 3 Integrally Welded Attachments Section XI, Division 1, included Category B-H as B-K
B-L-2	1	0	0.0	100.0	
B-M-2	29	5	17.2	100.0	
B-N-1	3	1	33.3	100.0	
B-N-2	55	26	47.3	100.0	
B-P	6	3	50.0	100.0	
C-A	2	2	100.0	100.0	Code Case N-598 per approved Relief Request RR-33
C-B	8	3	37.5	100.0	
C-C	15	9	60.0	120.0	Code Case N-598 per approved Relief Request RR-33

Peach Bottom Atomic Power Station, Unit 2 Third Interval, Third Period OAR-1 - Through Refueling Outage 2R17

ATTACHMENT 3B PAGE 3 OF 11

.

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Totai Examinations Required For The Interval	Total Examinations Credited For The 3rd Period (P2R16 & P2R17)	Total Examinations Credited (%) For The 3rd Period (P2R16 & P2R17)	Total Examinations Credited (%) To Date for The Interval	Remarks
С-Н	51	19	37.3	100.0	
D-A	25	18	72.0	100.0	Code Case N-598 per approved Relief Request RR-33
D-B	9	3	33.3	100.0	
E-A	57	23	40.4	100.0	General Visual performed in P2R13 (1st Period) prior to ILRT. Not required to count double credit for inspection of Drywell, Torus, or Vent System for both 10CFR50.55a period and ILRT requirements.
E-C	3	1	33.3	100.0	Alternative examination program per approved Request for Alternative CRR-11
E-D	63	_ 0	0.0	100.0	10CFR50.Appendix J examination of seals and gaskets in the 1st period per approved Request for Alternative CRR-01
E-G	76	0	0.0	100.0	10CFR50 Appendix J and Code Category E-A examination in the 1st period per approved Request for Alternative CRR-07
E-P	1	0	0.0	100.0	Examined in the 1st period In accordance with 10CFR50 Appendix J Test Program and Schedule
F-A	167	75	44.9	115.6	Code Case N-598 per approved Relief Request RR-33
R-A	135	58	43.0	100.0	Implemented RI-ISI starting 2nd Period, replacing Categories B-F, B-J, and C-F-2.

ATTACHMENT 3B PAGE 4 OF 11

TABLE 2 ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
B-A	B1.22	RPV Top Head Meridional Weld CH-MB	Identified 17 previously recorded unacceptable indications. Resultes deemed acceptable per GE Report	Yes
C-C	C3.20	10DDN-H92 (IA) Pipe Lugs	Relevant Condition – lugs are not same size as required by drawing. Accepted by Engineering Evaluation.	Yes
D-A	D1.20	33HB-H-148(IA) Integral Attachment	Relevant Condition – missing cotter pin. Repaired, re-examination acceptable.	Yes
E-A	E1.12	Drywell N-1 Equipment Hatch	Relevant Condition – missing cotter pin on swing bolt at 8 o'clock position. Repaired, re-examination acceptable.	Yes
E-C	E4.11	Torus Wetted Pressure Boundary	Relevant Condition – Pitting was inspected and depths measured. Accepted by Engineering Evaluation.	Yes
E-D	E5.30	2-MBAR-INT Moisture Barrier	Relevant Condition – piece of moisture barrier coating torn loose at azimuth 240. Repaired, re- examination acceptable.	No (Found during another scheduled IWE exam)
E-D	E5.30	2-MBAR-INT Moisture Barrier	Relevant Condition – coating is peeling from 050- 090 Azimuth. Repaired, re-examination acceptable.	Yes
F-A (N-491-1)	F1.20	10DDN-H92 Spring Hanger	Relevant Condition – two loose bolts. Accepted by Engineering Evaluation.	Yes
F-A (N-491-1)	F1.20	M-1747-S-7 Rigid Restraint	Relevant Condition – inadequate clearances. Accepted by Engineering Evaluation.	Yes
F-A (N-491-1)	F1.30	32GB-H28 Spring Hanger	Relevant Condition – Load indicator is missing on the North Spring Can. As-found load was acceptable.	Yes

2

ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
F-A (N-491-1)	F1.30	1GG-H711 Guide	Relevant Condtion – distance between pipe and support is less then required. Accepted by Engineering Evaluation.	Yes
F-A (N-491-1)	F1.30	1GG-S35 Snubber	Relevant Condition – jam nut loose. Repaired, re- examination acceptable.	Yes
R-A	R1.11	Core Spray System Pipe to Safe-End Weld 14- A-43 1 Acceptable, previously identified, II		Yes
R-A	R1.11	High Pressure Coolant Injection System elbow to pipe weld 23-2TE20-11.	2 Acceptable ID Root Geometries.	Yes
R-A	R1.20	Residual Heat Removal System elbow to pipe weld 10-2DA20-4	2 Acceptable Backing Ring ID Geometries.	Yes
R-A	R1.20	Residual Heat Removal System elbow to pipe weld 10-2DA20-7	2 Acceptable Backing Ring ID Geometries.	Yes
R-A	R1.20	Residual Heat Removal System pipe to elbow weld 10-2XBO20-3	1 Acceptable Backing Ring ID Geometry.	Yes
N/A	N/A	6-inch Emergency Service Water Piping	Pin-hole leak	No
F-A (N-491-1)	F1.30	High Pressure Service Water Rigid Restraint 2- 32GB-S58, ASME Class 3	Not carring the design load due to gaps. Restraint was shimmed and repaired.	No
F-A (N-491-1)	F1.30	High Pressure Service Water Rigid Restraint 2- 32GB-H43, ASME Class 3	Not carring the design load due to gaps. Restraint was shimmed and repaired.	No

.

TABLE 2 ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

.

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
F-A (N-491-1)	F1.30	High Pressure Service Water Rigid Restraint 2- 32GB-S59, ASME Class 3	Not carring the design load due to gaps. Restraint was shimmed and repaired.	No
F-A (N-491-1)	F1.30	High Pressure Service Water Rigid Restraint 2- 32GB-H27, ASME Class 3	Not carring the design load due to gaps. Restraint was shimmed and repaired.	No
F-A (N-491-1)	F1.30	High Pressure Service Water Rigid Restraint 2- 33HB-S63, ASME Class 3	Not carring the design load due to gaps. Restraint was shimmed and repaired.	No
F-A (N-491-1)	F1.30	High Pressure Service Water Rigid Restraint 2- 33HB-S64, ASME Class 3	Not carring the design load due to gaps. Restraint was shimmed and repaired.	' No
N/A	N/A	6-inch Emergency Service Water Piping, ASME Class 3, ASME Class 3	Pin-hole Leak.	No
N/A	N/A	High Pressure Service Water Check Valve CHK-2-32-502C, ASME Class 3	Pin-hole Leak.	No
N/A	N/A	6-inch Emergency Service Water Piping, ASME Class 3, ASME Class 3	Pin-hole Leak.	No
N/A	N/A	Emergency Service Water Hand Valve HV-0- 33-504D	Pin-Hole Leak.	No
N/A	N/A	6-inch Emergency Service Water Piping, ASME Class 3, ASME Class 3	Pin-hole Leak.	No
N/A	N/A	6-inch Emergency Service Water Piping, ASME Class 3, ASME Class 3	Pin-hole Leak.	No

ATTACHMENT 3B PAGE 7 OF 11

TABLE 2 ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
N/A	N/A	6-inch Emergency Service Water Piping, ASME Class 3, ASME Class 3	Pin-hole Leak.	No
N/A	N/A	Emergency Service Water Hand Valve HV-0- 33-504C	Minimum Wall Thickness Violation	No

ATTACHMENT 3B

PAGE 8 OF 11

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 OCTOBER 5, 2006 TO NOVEMBER 4, 2008 (END OF 10 YEAR INTERVAL INCLUDES 2R17 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 01: MAIN STEAM SYSTEM

Code <u>Class</u>	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	AO-2-01A-080C	Installed 5 new nuts and welded new stellite inbody seat	No	10/2/2008	07-127, R1056916
Class 1	Replacement	RV-2-02-071B	Installed a rebuilt safety relief valve	No	9/24/2008	08-024, R0985094
Class 1	Replacement	RV-2-02-071E	Installed a rebuilt safety relief valve	No	9/24/2008	08-025, R0985084
Class 1	Replacement	RV-2-02-071F	Installed a rebuilt safety relief valve	No	9/24/2008	08-026, R0985095
Class 1	Replacement	RV-2-02-071G	Installed a rebuilt safety relief valve	No	9/24/2008	08-027, R0985093
Class 1	Replacement	RV-2-02-071H	Installed a rebuilt safety relief valve	No	9/24/2008	08-028, R0985091
Class 1	Replacement	RV-2-02-070B	Installed a rebuilt safety relief valve	No	9/25/2008	08-029, R0988101
Class 1	Replacement	RV-2-02-071D	Installed a rebuilt safety relief valve	No	9/25/2008	08-130, R1051573

SYSTEM 03: CONTROL ROD DRIVE

Code <u>Class</u>	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	CRD's 02-43, 06-43, 10-19, 22-31, 22-59, 26-59, 30-03, 30-27, 30-31, 30-39, 30-55, 34-03, 34-07, 34-39, 38-31, 42-59, 46-55, 54-19	Exchanged CRD's with rebuilt CRD's	No	9/23/2008	07-135, R1055889
Class 1	Repair	CV-2-03A-13127BQ	Weld repaired indications in valve tail piece section	No	9/26/2008	08-138, R1086467

ATTACHMENT 3B

PAGE 9 OF 11

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 OCTOBER 5, 2006 TO NOVEMBER 4, 2008 (END OF 10 YEAR INTERVAL INCLUDES 2R17 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 10: RESIDUAL HEAT REMOVAL

	Code <u>Class</u>	Repair, Replacement, or Corrective Measure	Item Description (component I.D.)	Description Of Work Performed	Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
	Class 2	Replacement	RV-2-10-181C	Installed new RHR Hx. 2CE024 Shell Side relief valve	No	2/20/2007	06-209, R0863938
	Class 2	Replacement	PB-2-M-HX-2CE024	New 2CE024 Hx Upper Head Channel Cover Studs/Nuts	No -	2/20/2007	06-211, C0219541
	Class 2	Replacement	RV-2-10-181D	Installed new RHR Hx. 2DE024 Shell Side relief valve	No	1/28/2008	07-035, R0864255
	Class 2	Replacement	PB-2-10-2DE024	Installed new RHR Hx. 2DE024 Floating Head	No	2/1/2008	07-108, C0221745
	Class 2	Replacement	RV-2-10-181B	Installed new RHR Hx. 2BE024 Shell Side relief valve	No	4/14/2008	08-002, R0900643
	Class 1	Replacement	AO-2-10-046A	RHR Loop "A" Check Valve, new weld plugment	No	9/30/2008	08-084, C0223978
**	Class 3	Replacement	MO-2-10-089A	Installed new RHR Hx 2AE024 HPSW Outlet Valve	No	7/11/2008	08-095, C0212558

Elow or Bolovant

SYSTEM 11: STANDBY LIQUID CONTROL SYSTEM

				Flaw or Relevant			
	Repair,			Condition Found			
	Replacement,			During Scheduled			
Code	or Corrective	Item Description		Section XI Exam	Date		
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan #	and W/O #
Class 2	Replacement	RV-2-11-39B	Installed new relief valve	No	12/13/2006	06-212, 0	20219567
Class 2	Replacement	RV-2-11-39A	Installed new relief valve	No	12/14/2006	06-213, 0	0219573
Class 2	Replacement	RV-2-11-39A	Installed new relief valve	No	9/22/2008	07-105, F	R1047769
Class 2	Replacement	RV-2-11-39B	Installed new relief valve	No	9/22/2008	07-106, F	R1047770

ATTACHMENT 3B

PAGE 10 OF 11

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 OCTOBER 5, 2006 TO NOVEMBER 4, 2008 (END OF 10 YEAR INTERVAL INCLUDES 2R17 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 23: HIGH PRESSURE COOLANT INJECTION SYSTEM

	Code	Repair, Replacement, or Corrective	Item Description		Flaw or Relevant Condition Found During Scheduled Section XI Exam	Date		
	<u>Class</u>	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	<u>R&R Plan #</u>	and W/O #
	Class 2	Replacement	VRV-2-23C-140A	Installed new vacuum relief valve.	No	9/20/2008	02-007, F	0783924
	Class 2	Replacement	VRV-2-23C-140B	Installed new vacuum relief valve.	No	9/20/2008	02-007, F	0783924
	Class 2	Replacement	VRV-2-23C-140C	Installed new vacuum relief valve.	No	9/20/2008	02-007, F	0783924
	Class 2	Replacement	VRV-2-23C-140D	Installed new vacuum relief valve.	No	9/20/2008	02-007, F	0783924
**	Class M	Replacement	MO-2-23-031	Replaced leak between MO-2-23-031 and nozzle N-233	No	11/16/2006	06-200, C	0219131
	Class 2	Replacement	MO-2-23-014	Installed new valve yoke studs	No	9/23/2008	08-030, F	1029543

SYSTEM 32: HIGH PRESSURE SERVICE WATER SYSTEM

Repair, Replacement,			Flaw or Relevant Condition Found During Scheduled		
or Corrective Measure	Item Description (component I.D.)	Description Of Work Performed	Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
Replacement	RV-2-32-180D	Installed new RHR Hx. 2DE024 Tube Side Relief Valve	No	1/29/2008	07-033, R0881264
Replacement	RV-2-32-180B	Installed new RHR Hx. 2BE024 Tube Side Relief Valve	No	4/14/2008	08-003, R0862930
Replacement	32GB-S59, 32GB-H27	Install shims on 32GB-S59 & H27 HPSW rigid restraint	No	7/2/2008	08-096, C0224873
Replacement	32GB-S58, 32GB-H43	Install shims on 32GB-S58 & H43 HPSW rigid restraint	No	7/1/2008	08-097, C0224811
Replacement	2-32GB-S60	Re-install I-beam/shims on 32GB-S60 HPSW rigid restrain	No	7/11/2008	08-122, C0212558
	Repair, Replacement, or Corrective Measure Replacement Replacement Replacement Replacement Replacement	Repair, Replacement, or Corrective MeasureItem Description (component I.D.)ReplacementRV-2-32-180DReplacementRV-2-32-180BReplacement32GB-S59, 32GB-H27Replacement32GB-S58, 32GB-H43Replacement2-32GB-S60	Repair, Replacement, or CorrectiveItem Description (component I.D.)Description Of Work PerformedReplacementRV-2-32-180DInstalled new RHR Hx. 2DE024 Tube Side Relief ValveReplacementRV-2-32-180BInstalled new RHR Hx. 2BE024 Tube Side Relief ValveReplacementRV-2-32-180BInstalled new RHR Hx. 2BE024 Tube Side Relief ValveReplacement32GB-S59, 32GB-H27Install shims on 32GB-S59 & H27 HPSW rigid restraintReplacement32GB-S58, 32GB-H43Install shims on 32GB-S58 & H43 HPSW rigid restraintReplacement2-32GB-S60Re-install I-beam/shims on 32GB-S60 HPSW rigid restraint	Repair, Replacement, or CorrectiveItem Description (component I.D.)During Scheduled Section XI Exam Or TestReplacementRV-2-32-180DInstalled new RHR Hx. 2DE024 Tube Side Relief ValveNoReplacementRV-2-32-180BInstalled new RHR Hx. 2BE024 Tube Side Relief ValveNoReplacementRV-2-32-180BInstalled new RHR Hx. 2BE024 Tube Side Relief ValveNoReplacement32GB-S59, 32GB-H27Installed new RHR Hx. 2BE024 Tube Side Relief ValveNoReplacement32GB-S58, 32GB-H43Install shims on 32GB-S59 & H27 HPSW rigid restraintNoReplacement2-32GB-S60Re-install I-beam/shims on 32GB-S60 HPSW rigid restraintNo	Repair, Replacement, or CorrectiveItem Description (component I.D.)Description Of Work PerformedDuring Scheduled Section XI Exam Or TestDate CompleteReplacementRV-2-32-180DInstalled new RHR Hx. 2DE024 Tube Side Relief ValveNo1/29/2008ReplacementRV-2-32-180BInstalled new RHR Hx. 2BE024 Tube Side Relief ValveNo4/14/2008ReplacementRV-2-32-180BInstalled new RHR Hx. 2BE024 Tube Side Relief ValveNo4/14/2008Replacement32GB-S59, 32GB-H27Install shims on 32GB-S59 & H27 HPSW rigid restraintNo7/2/2008Replacement32GB-S58, 32GB-H43Install shims on 32GB-S58 & H43 HPSW rigid restraintNo7/1/2008Replacement2-32GB-S60Re-install I-beam/shims on 32GB-S60 HPSW rigid restraintNo7/11/2008

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 2 OCTOBER 5, 2006 TO NOVEMBER 4, 2008 (END OF 10 YEAR INTERVAL INCLUDES 2R17 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 33: EMERGENCY SERVICE WATER

					Flaw or Relevant		
		Repair,			Condition Found		
		Replacement,			During Scheduled		
	Code	or Corrective	Item Description		Section XI Exam	Date	
	Class	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
**	Class 3	Replacement	HV-0-33-510, HV-0-33-11431A	Installed 16" pipe spool & 2" pipe/valve hot tap connection	No	1/23/2008	07-088, C0220220
**	Class 3	Replacement	HV-0-33-504D	Replaced leak in 6" pipe downstream of HV-0-33-504D	No	7/22/2008	08-123, C0225717
**	Class 3	Replacement	HV-0-33-504A	Replaced leak in 6" pipe downstream of HV-0-33-504A	No	8/1/2008	08-124, C0225613
**	Class 3	Replacement	HV-0-33-504C	Replaced low wall in 6" pipe downstream of HV-0-33-504C	No	8/27/2008	08-125, C0225784

SYSTEM 65A: HYDRAULIC SNUBBERS

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	SS-3-D	Installed new hydraulic snubber load pins	No	10/1/2008	08-076, C0224178
Class 1	Replacement	12-DCN-S-5	Installed new hydraulic snubber	No .	9/25/2008	08-136, C0226356

SYSTEM 65B: MECHANICAL SNUBBERS

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	Complete	R&R Plan # and W/O #
Class 2	Replacement	10-GB-S-75	Installed new mechanical snubber	No	9/26/2008	08-038, C0223573
Class 2	Replacement	1-GG-S-101-B	Installed new mechanical snubber	No	9/20/2008	08-047, C0223839
Class 2	Replacement	1-GG-S-102-A	Installed new mechanical snubber	No	9/21/2008	08-050, C0223842

ATTACHMENT 3B

PAGE 11 OF 11

Attachment 4

Peach Bottom Atomic Power Station Unit 3

Owner Activity Report (OAR-1) for Refueling Outage 3R14 Third 10-Year ISI Interval, Second Period

FORM OAR-1 OWNER'S ACTIVITY REPORT

Report Number: 3R14

Owner: <u>EXELON NUCLEAR</u> 200 Exelon Way Kennett Square, PA 19348

Plant: <u>Peach Bottom Atomic Power Station</u> <u>1848 Lay Road</u> Delta, PA 17314

Unit No.: <u>3</u> Commercial Service Date: <u>December 23, 1974</u>

Refueling Outage No.: 14

Current Inspection Interval: 3^{rd}

Current Inspection Period: 2nd

Edition and Addenda of Section XI applicable to the Inspection Plan: <u>1989 Edition & 1992 Edition including 1992</u> Addenda

Date and Revision of Inspection Plan: December 20, 2002, Revision 0

Edition and Addenda of Section XI applicable to repairs and replacements: 1989 Edition and Code Case N-416-1

CERTIFICATE OF CONFORMANCE

I certify that the statements made in this Owner's Activity Report are correct, and that the examinations, tests, repairs, replacements, evaluations, and corrective measures represented by this report for the period January 1, 2002 to October 12, 2003 conform to the requirements of Section XI.

Signed: WMMM & Hufsen Date: 01-24-2009

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the Commonwealth of <u>Pennsylvania</u> and employed by <u>Hartford Steam Boiler Inspection &</u> <u>Insurance Company of Connecticut</u>, of <u>Hartford, Connecticut</u>, have inspected the components described in the Owner's Data Report during the period January 1, 2002 to October 12, 2003 and state that to the best of my knowledge and belief the Owner has performed all activities represented by this report in accordance with the requirements of Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, tests, repairs, replacements, evaluations, and corrective measures described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date: 126200 Inspector's Signature: PAZILO3 A, NJ Commissions: NB7592 National Board, State, Province & No.

Peach Bottom Atomic Power Station, Unit 3 Third Interval, Second Period OAR-1

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Total Examinations Required For The Interval	Total Examinations Credited For The 2nd Period (3R14)	Total Examinations Credited (%) For The 2nd Period (3R14)	Total Examinations Credited (%) thru 2nd Period of The Interval	Remarks
B-A	31	9.0	29.0	67.7	RPV Circumferential shell weld exempted per approved Relief request RR-41
B-D	61	19.0	31.1	70.5	Case N-598, Alternative Requirements to Required Percentages of Examinations, Section XI, Division 1 per approved Relief Request RR-33
B-E	62	62.0	100.0	100.0	B-E examinations completed during RPV Hydro performed in second period.
B-G-1	109	17.0	15.6	57.8	Code Case N-598 per approved Relief Request RR-33
B-G-2	116	24.0	20.7	57.8	Code Case N-598 per approved Relief Request RR-33
В-К	18	6.0	33.3	66.7	 Code Case N-598 per approved Relief Request RR-33 Use of ASME CC N-509, Alternative Rules for the Selection and Examination of Class 1, 2, and 3 Integrally Welded Attachments Section XI, Division 1, included Category B-H as B-K
B-L-2	2	1.0	50.0	50.0	
B-M-2	11	3.0	27.3	45.5	
B-N-1	3	1.0	33.3	66.7	
B-N-2	49	12.0	24.5	59.2	
B-P	6	1.0	16.7	50.0	
C-A	2	0.0	0.0	50.0	Code Case N-598 per approved Relief Request RR-33
C-B	8	0.0	0.0	12.5	
C-C	17	5.0	29.4	64.7	Code Case N-598 per approved Relief Request RR-33
С-Н	51	15.0	29.4	60.8	RPV flange leakoff drain piping test not completed for 2nd period.
D-A	18	0.0	0.0	0.0	Code Case N-598 per approved Relief Request RR-33
D-B	3	1.0	33.3	66.7	

Peach Bottom Atomic Power Station, Unit 3 Third Interval, Second Period OAR-1

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Total Examinations Required For The Interval	Total Examinations Credited For The 2nd Period (3R14)	Total Examinations Credited (%) For The 2nd Period (3R14)	Total Examinations Credited (%) thru 2nd Period of The Interval	Remarks
E-A	68	17.0	25.0	50.0	An additional GV of Containment was performed in this interval for the ILRT requirements
E-C	3	2.0	66.7	66.7	Alternative examination program per approved Request for Alternative CRR-11
E-D	63	0.0	0.0	0.0	
E-G	76	0.0	0.0	0.0	
E-P	1	0.0	0.0	0.0	
F-A	158	39.0	24.7	66.5	Code Case N-598 per approved Relief Request RR-33
R-A	139	24.0	17.3	63.3	Implemented RI-ISI starting 2nd Period, replacing Categories B-F, B-J, and C-F- 2.

ATTACHMENT 4 PAGE 4 OF 9

TABLE 2 ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
E-C	E4.11	Torus Wetted Pressure Boundary	Relevant Condition – Pitting was inspected and depths measured. Accepted by Engineering Evaluation.	Yes
F-A (N-491-1)	F1.10	12DCN-H150 Spring Hanger	Relevant Condition – Spring setting > 10% from design. Acceptable per engineering evaluation.	Yes
F-A (N-491-1)	F1.20	10DDN-H66A Spring Hanger	Relevant Condition – Spring setting > 10% from design. Acceptable per engineering evaluation.	Yes
F-A (N-491-1)	F1.20	10GB-S56 Rigid Restraint	Relevant Condition – 5 loose bolts on both anchor plates. Unacceptable, reworked, expanded sample.	Yes
F-A (N-491-1)	F1.20	1DB-H32 Spring Hanger	Relevant Condition – Spring setting > 10% from design. Acceptable per engineering evaluation.	Yes
F-A (N-491-1)	F1.20	1DB-H34 Spring Hanger	Relevant Condition – Spring setting > 10% from design. Acceptable per engineering evaluation.	Yes
F-A (N-491-1)	F1.20	1DB-H43 Spring Hanger	Relevant Condition – Spring setting > 10% from design. Acceptable per engineering evaluation.	Yes
F-A (N-491-1)	F1.20	1DB-H44 Spring Hanger	Relevant Condition – Spring setting > 10% from design. Acceptable per engineering evaluation.	Yes
F-A (N-491-1)	F1.20	1DB-H46 Spring Hanger	Relevant Condition – Spring setting > 10% from design. Acceptable per engineering evaluation.	Yes
F-A (N-491-1)	F1.20	23DBN-H40 Spring Hanger	Relevant Condition – Spring setting > 10% from design. Acceptable per engineering evaluation.	Yes

Final U3-I3-P2-3R14 OAR-1

.

ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
F-A (N-491-1)	F1.20	1GG-H290 Spring Hanger	Relevant Condition – Sliding (UCAR) plate chipped. Acceptable per engineering evaluation.	Yes
F-A (N-491-1)	F1.30	33HB-S121 Rigid Restraint	Relevant Condition – No clearance on south side. Accepted per engineering evaluation.	Yes
N/A	N/A	High Pressure Service Water system piping	Relevant Condition – Measured wall thickness less than (Min. Wall) acceptance criteria.	No
N/A	N/A	High Pressure Service Water system piping	Relevant Condition – Measured wall thickness less than (Min. Wall) acceptance criteria.	No
N/A	N/A	High Pressure Service Water system piping	Relevant Condition – Measured wall thickness less than (Min. Wall) acceptance criteria.	No

.

.

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 JANUARY 1, 2002 TO OCTOBER 12, 2003 (INCLUDES 3R14 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 01: MAIN STEAM SYSTEM

	Repair, Replacement,			Flaw or Relevant Condition Found During Scheduled		
Code	or Corrective	Item Description	Description Of Work Porformed	Section XI Exam	Date Complete	RPD Dan # and M/O #
01033	measure	[component i.b.)	Bescription of work Fertornied	OI Test	Complete	Rock Plan # and W/O #
Class 1	Replacement	RV-3-02-071L	Installed a rebuilt safety relief valve	No	10/7/2003	02-186, R0821531
Class 1	Replacement	RV-3-02-071K	Installed a rebuilt safety relief valve	No	10/7/2003	02-187, R0821530
Class 1	Replacement	RV-3-02-071J	Installed a rebuilt safety relief valve	No	10/7/2003	02-188, R0822430
Class 1	Replacement	RV-3-02-071F	Installed a rebuilt safety relief valve	No	10/7/2003	02-189, R0822431
Class 1	Replacement	RV-3-02-071B	Installed a rebuilt safety relief valve	No	10/7/2003	02-190, R0822428
Class 1	Replacement	RV-3-02-070A	Installed a rebuilt safety relief valve	No	10/7/2003	02-191, R0822429
Class 1	Replacement	RV-3-02-071C	Installed a rebuilt safety relief valve	No	10/7/2003	02-209, R0747164
Class 1	Replacement	AO-3-01A-086D	Installed 1 new bonnet stud and 12 new bonnet nuts	Yes	10/2/2003	03-019, R0888761
Class 1	Replacement	RV-3-02-071D	Installed a rebuilt safety relief valve	No	10/7/2003	03-090, C0206707
Class 1	Replacement	RV-3-02-071G	Installed a rebuilt safety relief valve	No	10/7/2003	03-092, C0206710

SYSTEM 02: REACTOR AND RECIRCULATION

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	PB-3-02A-3AP034	Installed new pump cover and internals	No	10/9/2003	03-068, C0202973

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 JANUARY 1, 2002 TO OCTOBER 12, 2003 (INCLUDES 3R14 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 03: CONTROL ROD DRIVE

Code _Class_	Repair, Replacement, or Corrective <u>Measure</u>	Item Description	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam <u>Or Test</u>	Date <u>Complete</u>	<u>R&R Plan # and W/O #</u>
Class 1	Replacement	CRD's 10-31, 18-15, 22-47, 26-27, 26-31, 34-23, 34-27, 34-39, 38-19, 50-39, 54-19, 58-23, 58-31	Exchanged CRD's with rebuilt CRD's during 3R14 outage	No	10/8/2003	03-036, R0882893

SYSTEM 10: RESIDUAL HEAT REMOVAL

	Code Class	Repair, Replacement, or Corrective Measure	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
	Class 2	Replacement	RV-3-10-181A	Installed new RHR Hx. 3AE024 Shell Side relief valve	No	11/12/2002	02-168, R0658138
	Class 2	Replacement	RV-3-10-181D	Installed new RHR Hx. 3DE024 Shell Side relief valve	No	2/2/2003	03-004, R0716858
**	Class 3	Replacement	MO-3-10-089D	Installed new RHR Hx 3DE024 HPSW Outlet Valve	No	6/19/2003	03-007, C0199233
	Class 2	Repair	PB-3-10-3DE024	Repaired seal weld betwn floating head & floating tubesht	No	7/9/2003	03-062, C0202412
	Class 2	Replacement	2" RHR Stayfull Piping	Replaced piping interferring with recirc motor replacement	No	6/23/2003	03-064, C0203872

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 JANUARY 1, 2002 TO OCTOBER 12, 2003 (INCLUDES 3R14 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

SYSTEM 11: STANDBY LIQUID CONTROL SYSTEM

				Flaw or Relevant		
	Repair,	Repair,		Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	<u>R&R Plan # and W/O #</u>
Class 2	Replacement	RV-3-11-39A	Installed new relief valve	No	9/26/2003	02-179, R0880506
Class 2	Replacement	RV-3-11-39B	Installed new relief valve	No	9/26/2003	02-180, R0881500

SYSTEM 13: REACTOR CORE ISOLATION COOLING SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	<u>R&R Plan # and W/O #</u>
Class 2	Replacement	VRV-3-13C-139A	Installed new vacuum relief valve	No	8/14/2002	02-138, R0755065
Class 2	Replacement	VRV-3-13C-139B	Installed new vacuum relief valve	No	8/14/2002	02-139, R0755065
Class 2	Replacement	VRV-3-13C-139C	Installed new vacuum relief valve	No	8/14/2002	02-140, R0755065
Class 2	Replacement	VRV-3-13C-139D	Installed new vacuum relief valve	No	8/14/2002	02-141, R0755065

SYSTEM 14: CORE SPRAY COOLING SYSTEM

	Code	Repair, Replacement, or Corrective	Item Description		Flaw or Relevant Condition Found During Scheduled Section XI Exam	Date	
	Class	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	<u>R&R Plan # and W/O #</u>
**	Class 2	Replacement	RV-3-14-020B	Installed new relief valve	No	5/19/2003	02-019, R0696586
**	Class 2 Class 2	Replacement Replacement	RV-3-14-020A 14GB-H43	Installed new relief valve Installed missing center bolt set on pipe clamp assembly	No Yes	7/15/2003 9/27/2003	03-015, R0702441 03-094, C0206788

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 JANUARY 1, 2002 TO OCTOBER 12, 2003 (INCLUDES 3R14 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-1 was employed in completing the repair / replacement activity

.

SYSTEM 23: HIGH PRESSURE COOLANT INJECTION SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	AO-3-23-018	Installed 3 bearing cover studs (incidental replacement)	No	10/3/2003	03-003, R0874645

SYSTEM 32: HIGH PRESSURE SERVICE WATER SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 3	Replacement	PB-3-32-RO-3789D	Installed blank flange in RO-3789D (new press. boundary)	No	1/29/2003	03-037, C0202412
Class 3	Replacement	RV-3-32-180B	Installed new RHR Hx. 3BE024 Tube Side relief valve	No	7/11/2003	99-142, R0696587

SYSTEM 65A: HYDRAULIC SNUBBERS

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 2	Replacement	1-DB-S-15-A	Installed new snubber and load pin bushings	Yes	10/6/2003	03-009, R0650212
Class 3	Replacement	1-GG-S-53	Installed new snubber load pins	No	9/24/2003	03-026, C0203431

.

Attachment 5A

Peach Bottom Atomic Power Station Unit 3

Owner Activity Report (OAR-1) for Refueling Outage 3R15 Third 10-Year ISI Interval, Third Period

FORM OAR-1 OWNER'S ACTIVITY REPORT

Report Number: 3R15

- Owner: <u>EXELON NUCLEAR</u> 200 Exelon Way Kennett Square, PA 19348
- Plant: <u>Peach Bottom Atomic Power Station</u> <u>1848 Lay Road</u> <u>Delta, PA 17314</u>

Unit No.: <u>3</u> Commercial Service Date: <u>December 23, 1974</u>

Refueling Outages No.: 15

Current Inspection Interval: 3^{rd}

Current Inspection Period: <u>3rd</u>

Edition and Addenda of Section XI applicable to the Inspection Plan: <u>1989 Edition & 1992 Edition including 1992</u> Addenda

Date and Revision of Inspection Plan: September 12, 2005, Revision 1

Edition and Addenda of Section XI applicable to repairs and replacements: 1989 Edition and Code Case N-416-1

CERTIFICATE OF CONFORMANCE

I certify that the statements made in this Owner's Activity Report are correct, and that the examinations, tests, repairs, replacements, evaluations, and corrective measures represented by this report for the period October 13, 2003 to October 16, 2005 conform to the requirements of Section XI.

Signed: Kennuch (1 Huysen Date: 0/-24-2009

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the Commonwealth of <u>Pennsylvania</u> and employed by <u>Hartford Steam Boiler Inspection &</u> <u>Insurance Company of Connecticut</u>, of <u>Hartford, Connecticut</u>, have inspected the components described in the Owner's Data Report during the period October 13, 2003 to October 16, 2005 and state that to the best of my knowledge and belief the Owner has performed all activities represented by this report in accordance with the requirements of Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, tests, repairs, replacements, evaluations, and corrective measures described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date: 126 200 Inspector's Signature: 2163 Commissions:NB 7592 National Board, State, Province & No

Peach Bottom Atomic Power Station, Unit 3 Third Interval, Third Period OAR-1 - Refueling Outage 3R15

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Total Examinations Required For The Interval	Total Examinations Credited For The 3rd Period	Total Examinations Credited (%) For The 3rd Period	Total Examinations Credited (%) thru 3rd Period of The Interval	Remarks
B-A	31	0.0	0.0	67.7	RPV Circumferential shell weld exempted per approved Relief request RR-41
B-D	61	6.0	9.8	80.3	Case N-598, Alternative Requirements to Required Percentages of Examinations, Section XI, Division 1 per approved Relief Request RR-33
B-E	62	0.0	0.0	100.0	B-E examinations completed during RPV Hydro performed in P3R14
B-G-1	109	46.0	42.2	100.0	Code Case N-598 per approved Relief Request RR-33
B-G-2	116	30.0	25.9	83.6	Code Case N-598 per approved Relief Request RR-33
В-К	18	2.0	11.1	77.8	 Code Case N-598 per approved Relief Request RR-33 Use of ASME CC N-509, Alternative Rules for the Selection and Examination of Class 1, 2, and 3 Integrally Welded Attachments Section XI, Division 1, included Category B-H as B-K
B-L-2	2	0.0	0.0	50.0	
B-M-2	11	5.0	45.5	90.9	
B-N-1	3	0.0	0.0	66.7	
B-N-2	49	13.0	26.5	85.7	
B-P	6	1.0	16.7	66.7	
C-A	2	1.0	50.0	100.0	Code Case N-598 per approved Relief Request RR-33
C-B	8	1.0	12.5	25.0	
C-C	17	6.0	35.3	100.0	Code Case N-598 per approved Relief Request RR-33
С-Н	51	11.0	21.6	82.4	RPV flange leakoff drain piping test not completed for 2nd period.
D-A	1,8	5.0	27.8	27.8	Code Case N-598 per approved Relief Request RR-33
D-B	3	0.0	0.0	66.7	
E-A	68	-11.0	16.2	66.2	VT-3 of the submerged portions of the Torus and Vent System have been extended 1 year. Will be performed during first outage in 4th interval per Interval per IWA-2430(d). An additional GV of Containment was performed in this interval for the ILRT requirements

ATTACHMENT 5A PAGE 2 OF 9

.

Peach Bottom Atomic Power Station, Unit 3 Third Interval, Third Period OAR-1 - Refueling Outage 3R15

ATTACHMENT 5A PAGE 3 OF 9

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Total Examinations Required For The Interval	Total Examinations Credited For The 3rd Period	Total Examinations Credited (%) For The 3rd Period	Total Examinations Credited (%) thru 3rd Period of The Interval	Remarks
E-C	3	. 0.0	0.0	66.7	Alternative examination program per approved Request for Alternative CRR-11
E-D	63	63.0	100.0	100.0	10CFR50 Appendix J examination of seals and gaskets during P3R15 per approved Request for Alternative CRR-01
E-G	76	76.0	100.0	100.0	10CFR50 Appendix J and Code Category E-A examination during P3R15 per approved Request for Alternative CRR-07
E-P	1	1.0	100.0	100.0	During P3R15 in accordance with 10CFR50 Appendix J Test Program and Schedule
F-A	158	36.0	22.8	89.2	Code Case N-598 per approved Relief Request RR-33
R-A	139	29.0	20.9	84.2	Implemented RI-ISI starting 2nd Period, replacing Categories B-F, B- J, and C-F-2.

ATTACHMENT 5A PAGE 4 OF 9

ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
		6DDNL-H6	Relevant Condition - loose jam nut; cold setting out	
F-A	F1.10	Spring Hanger	of tolerance. re-examined after repair, acceptable.	Yes
			Relevant Condition – broken tack welds on bolt	
		10HB-S6	head and nut. Load pin on clamp is out of vertical	
F-A	F1.20	Restraint	alignment.	No, expanded sample.
		10HB-S9	Relevant Condition – no thread engagement in site	
F-A	F1.20	Restraint	holes. Accepted as-is by evaluation.	No, expanded sample.
		10GB-S62A	Relevant Condition – anchor plate bolt was missing.	
F-A	F1.20	Rigid Restraint	Accepted by evaluation.	Yes
		10GB-H69	Relevant Condition – cold setting out of tolerance.	
F-A	F1.20	Spring Hanger	Accepted by evaluation.	Yes
		10MO-S79		
F-A	F1.20	Rigid Restraint	Relevant Condition – missing cotter pin.	Yes
		10GB-S46	Relevant Condition – missing jam nut, spherical	
F-A	F1.20	Rigid Restraint	bearing out of paddle.	No, expanded sample.
		10GB-S45	Relevant Condition - missing jam nut, spherical	
F-A	F1.20	Rigid Restraint	bearing out of paddle.	No, expanded sample.
		1GG-H313	Relevant Condition – loose jam nuts on pipe clamp	
F-A	F1.30	Spring Hanger	end.	Yes
		1GG-H299	Relevant Condition – misalignment of ucar plate;	
F-A	F1.30	Spring Hanger	1/3 of ucar plate was missing.	Yes
		High Pressure Service Water system piping		
		(IR 199832)	Relevant Condition Measured wall thickness less	
N/A	N/A		than minimum wall acceptance criteria.	No

.

 TABLE 2

 ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
		High Pressure Service Water system piping	Relevant Condition – Meausred wall thickness less	
N/A	N/A	(IR 293083)	than minimum wall acceptance criteria.	No
		High Pressure Service Water system piping	Relevant Condition - Measured wall thickness less	
N/A	N/A	(IR 267973)	than minimum wall acceptance criteria.	No
		10GB-S44		
		Snubber	Relevant Condition – 10 of 18 bolts found loose on	
F-A	F1.20	(IR 332980)	snubber mounting plates.	No
		23DDN-S300A		
		pipe support	Relevant Condition – lower anchor bolts on HPCI	
F-A	F1.20	(IR 332355)	pipe support are partially pulled out of wall.	No
		10GB-H87	Relevant Condition - Loose nut found on spring can	
F-A	F1.20	Spring Hanger	base plate.	No
		23DDN-S22A	Relevant Condition – Support was found ³ / ₄ " out of	
F-A	F1.20	Rigid Restraint	alignment and one loose bolt on base plate.	No
		23DDN-S23A	Relevant Condition – Support was found out of	
F-A	F1.20	Rigid Restraint	alignment.	No
		23DDN-S31	Relevant Condition – Support was found out of	
F-A	F1.20	Rigid Restraint	alignment.	No
		23DDN-S24	Relevant Condition – Support was found out of	
F-A	F1.20	Rigid Restraint	alignment.	No
ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 OCTOBER 13, 2003 TO OCTOBER 16, 2005 (END OF 3R15 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 01: MAIN STEAM SYSTEM

Code Class	Repair, Replacement, or Corrective Measure	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #	
Class 1	Replacement	AO-3-01A-080A	Installed new bonnet nuts as incidental replacement	No	10/3/2005	05-063, R0948673	
Class 1	Replacement	AO-3-01A-080D	Installed new bonnet nuts as incidental replacement	No	10/3/2005	05-066, R0948673	
Class 1	Replacement	RV-3-02-071A	Installed a rebuilt safety relief valve	No	9/25/2005	05-067, R0892990	
Class 1	Replacement	RV-3-02-071D	Installed a rebuilt safety relief valve	No	9/25/2005	05-068, R0946312	
Class 1	Replacement	RV-3-02-071E	Installed a rebuilt safety relief valve	No	9/24/2005	05-070, R0884101	
Class 1	Replacement	RV-3-02-070B	Installed a rebuilt safety relief valve	No	9/24/2005	05-071, R0885698	
Class 1	Replacement	RV-3-02-071H	Installed a rebuilt safety relief valve	No	9/24/2005	05-072, R0888173	
Class 1	Replacement	RV-3-02-071B	Installed a rebuilt safety relief valve	No	9/25/2005	05-118, R0949234	

SYSTEM 03: CONTROL ROD DRIVE

Code <u>Class</u>		Repair, Replacement, or Corrective <u>Measure</u>	t, e Item Description (component I.D.)Description Of Work Performed		Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	R&R Plan # and W/O #	
	Class 1	Replacement	CRD's 10-11, 10-15, 10-43, 14-27, 14-35, 14-39, 18-27, 18-51, 26-07, 26-19, 26-23, 30-43, 30-55, 38-23, 42-03, 42-35, 46-19, 46-23, 50-35	Exchanged CRD's with rebuilt CRD's	Νο	10/7/2005	05-017, R0960523
*	Class 2	Replacement	SVD cleanout pipe caps	Remove/install pipe caps to flush scram disch. header	No	10/1/2005	05-085, R0967521

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 OCTOBER 13, 2003 TO OCTOBER 16, 2005 (END OF 3R15 REFUEL OUTAGE)

Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity **

SYSTEM 06: FEEDWATER

.

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 1	Penlacement	CHK-3-06-096A	Installed new valve bonnet	No	10/1/2005	02-184 R0873962
Class	Replacement	CI II - 5-00-030A		NO	10/1/2005	02-104, 10075302
Class 1	Repair	MO-3-06-038B	Machined bonnet stem bore dia, per engineering analysis	No	10/4/2005	05-123. R0744837

SYSTEM 10: RESIDUAL HEAT REMOVAL

	Code <u>Class</u>	Repair, Replacement, or Corrective Measure	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	<u>R&R Plan # and W/O #</u>
	Class 2	Replacement	RV-3-10-181B	Installed new RHR Hx. 3BE024 Shell Side relief valve	No	1/29/2004	03-111, R0717546
**	Class 3	Replacement	MO-3-10-089C	Installed new RHR Hx 3CE024 HPSW Outlet Valve	No	10/5/2005	04-170, C0210627
**	Class 3	Replacement	MO-3-10-089B	Installed new RHR Hx 3BE024 HPSW Outlet Valve	No	9/26/2005	05-049, C0211160
	Class 2	Replacement	10GB-S46	Installed new restraint rod end and jam nuts	No	10/9/2005	05-132, C0215324
	Class 2	Replacement	10GB-S45	Installed new restraint eye rod end and jam nuts	No	10/9/2005	05-136, C0215330

SYSTEM 11: STANDBY LIQUID CONTROL SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
<u>Class</u>	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 2	Replacement	RV-3-11-39B	Installed new relief valve	No	9/29/2005	05-031, R0950653
Class 2	Replacement	RV-3-11-39A	Installed new relief valve	No	9/29/2005	05-032, R0950662

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 OCTOBER 13, 2003 TO OCTOBER 16, 2005 (END OF 3R15 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 13: REACTOR CORE ISOLATION COOLING SYSTEM

					Flaw or Relevant		
		Repair,			Condition Found		
		Replacement,			During Scheduled		
	Code	or Corrective	Item Description		Section XI Exam	Date	
	Class	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
**	Class 2	Replacement	CHK-3-13C-133	Installed new check valve	No	4/21/2004	02-130, C0201541

SYSTEM 14: CORE SPRAY COOLING SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,	•		During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 2	Replacement	CHK-3-14-10C	Installed new check valve bonnet bolts	No	7/20/2005	03-080, R0925152
Class 2	Replacement	CHK-3-14-10B	Installed new check valve bonnet bolts	No	5/18/2004	04-098, R0937004
Class 2	Replacement	RO-3-14-037C	Installed new studs and nuts for thread engagement issue	No	7/13/2004	04-146, C0210414
Class 2	Replacement	CHK-3-14-10D	Installed new check valve bonnet bolts	No	5/25/2005	05-012, R0925143

SYSTEM 23: HIGH PRESSURE COOLANT INJECTION SYSTEM

	Code <u>Class</u>	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Date Or Test <u>Complete</u>		R&R Plan # and W/O #	
	Class 2	Replacement	3-23MO-H47	Modified and installed new operator support bracket	No	5/5/2004	04-106, R0741407	
	Class 2	Repair	23DDN-S46	Repaired cracked weld on rigid restraint base plate	No	5/6/2005	05-109, C0213715	
**	Class 2	Replacement	MO-3-23-014	Installed new valve	No	9/27/2005	05-034, C0212707	
	Class 2	Replacement	PSD-3-23-006	Replace rupture disc bolting, incidental replacement	No	9/22/2005	05-077, R0864706	
	Class 2	Replacement	HV-3-23C-31125	Installed a 1" pipe support off of a 2" header	No	4/22/2005	05-106, C0213460	
	Class 2	Replacement	HV-3-23C-31158	Installed new valve bonnet	No	9/29/2005	05-124, C0215211	
	Class 2	Replacement	3-23DBN-S53	Installed shims to pipe clamp on rigid restraint	No	10/4/2005	05-125, C0212707	

ABSTRACT OF ASME REPAIRS, REPLACEMENTS, OR CORRECTIVE MEASURES FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 OCTOBER 13, 2003 TO OCTOBER 16, 2005 (END OF 3R15 REFUEL OUTAGE)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 32: HIGH PRESSURE SERVICE WATER SYSTEM

					Flaw or Relevant		
		Repair,			Condition Found		
		Replacement,			During Scheduled		
	Code	or Corrective	Item Description		Section XI Exam	Date	
	Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
**	Class 3	Replacement	RO-3-32-3789B	Installed new outlet restricting orifice and associated piping	No	6/12/2004	04-110, C0209102
	Class 3	Replacement	RO-3-32-3789D	Installed new outlet restricting orifice and associated piping	No	7/1/2004	04-111, C0208948

SYSTEM 33: EMERGENCY SERVICE WATER (ESW)

					Flaw or Relevant		
		Repair,			Condition Found		
		Replacement,			During Scheduled		
	Code	or Corrective	Item Description		Section XI Exam	Date	
	Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
**	Class 3	Replacement	HV-3-33-518	Installed new valve	No	3/1/2006	03-067, C0204514

SYSTEM 65A: HYDRAULIC SNUBBERS

•

Code Class	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	SS-B-4	Installed new snubber	No	9/24/2005	02-213, R0474912
Class 1	Replacement	SS-C-4	Installed new snubber	No	9/24/2005	02-214, R0474913
Class 1	Replacement	SS-D-3	Installed new snubber	Νο	9/27/2005	02-216, R0474915
Class 3	Replacement	1-GG-S-13	Installed new snubber	No	9/27/2005	05-052, R0474916
Class 3	Replacement	1-GG-S-31	Installed new snubber	No	9/27/2005	05-053, R0474918
Class 3	Replacement	1-GG-S-53	Installed new snubber	No	9/28/2005	05-054, R0474919
Class 3	Replacement	1-GG-S-65	Installed new snubber	No	9/29/2005	05-055, R0474920
Class 3	Replacement	1-GG-S-30	Installed new snubber rod eye extension	No	10/6/2005	05-129, C0215274

Attachment 5B

Peach Bottom Atomic Power Station Unit 3

Owner Activity Report (OAR-1) for Refueling Outage 3R16 Third 10-Year ISI Interval, Third Period

.

.

.

.

FORM OAR-1 OWNER'S ACTIVITY REPORT

Report Number: 3R16

Owner: <u>EXELON NUCLEAR</u> 200 Exelon Way Kennett Square, PA 19348

Plant: <u>Peach Bottom Atomic Power Station</u> <u>1848 Lay Road</u> <u>Delta, PA 17314</u>

Unit No.: <u>3</u> Commercial Service Date: <u>December 23, 1974</u>

Refueling Outages No.: 16

Current Inspection Interval: <u>3rd</u>

Current Inspection Period: <u>3rd</u>

Edition and Addenda of Section XI applicable to the Inspection Plan: <u>1989 Edition & 1992 Edition including 1992</u> Addenda

Date and Revision of Inspection Plan: September 18, 2007, Revision 2

Edition and Addenda of Section XI applicable to repairs and replacements: 1989 Edition and Code Case N-416-1

CERTIFICATE OF CONFORMANCE

I certify that the statements made in this Owner's Activity Report are correct, and that the examinations, tests, repairs, replacements, evaluations, and corrective measures represented by this report for the period October 17, 2005 to November 4, 2008 conform to the requirements of Section XI.

Signed: Kennuch a Hudson Date: 01 ~ 24 - 2009

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the Commonwealth of <u>Pennsylvania</u> and employed by <u>Hartford Steam Boiler Inspection &</u> <u>Insurance Company of Connecticut</u>, of <u>Hartford, Connecticut</u>, have inspected the components described in the Owner's Data Report during the period October 17, 2005 to November 4, 2008 and state that to the best of my knowledge and belief the Owner has performed all activities represented by this report in accordance with the requirements of Section XI.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations, tests, repairs, replacements, evaluations, and corrective measures described in this report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date: 1 Inspector's Signature: B 7592 PA 2163 ANT National Board, State, Province & No. Commissions: NB 7592

Peach Bottom Atomic Power Station, Unit 3 Third Interval, Third Period OAR-1 - Refueling Outage 3R16

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Total Examinations Required For The Interval	Total Examinations Credited For The 3rd Period	Total Examinations Credited (%) For The 3rd Period	Total Examinations Credited (%) thru 3rd Period of The Interval	Remarks
B-A	31	10.0	32.3	100.0	RPV Circumferential shell weld exempted per approved Relief request RR-41
B-D	61	18.0	29.5	100.0	Case N-598, Alternative Requirements to Required Percentages of Examinations, Section XI, Division 1 per approved Relief Request RR-33
B-E	62	0.0	0.0	100.0	B-E examinations completed during RPV Hydro performed in P3R14
B-G-1	109	46.0	42.2	100.0	Code Case N-598 per approved Relief Request RR-33
B-G-2	116	49.0	42.2	100.0	Code Case N-598 per approved Relief Request RR-33
В-К	18	8.0	44.4	111.1	 Code Case N-598 per approved Relief Request RR-33 Use of ASME CC N-509, Alternative Rules for the Selection and Examination of Class 1, 2, and 3 Integrally Welded Attachments Section XI, Division 1, included Category B-H as B-K
B-L-2	2	1.0	50.0	100.0	
B-M-2	11	6.0	54.5	100.0	
B-N-1	3	1.0	33.3	100.0	
B-N-2	49	20.0	40.8	100.0	
B-P	6	3.0	50.0	100.0	
C-A	2	1.0	50.0	100.0	Code Case N-598 per approved Relief Request RR-33
C-B	8	3.0	37.5	50.0	
C-C	17	9.0	52.9	117.6	Code Case N-598 per approved Relief Request RR-33
C-H	51	19.0	37.3	98.0	RPV flange leakoff drain piping test not completed for 2nd period.

,

Peach Bottom Atomic Power Station, Unit 3 Third Interval, Third Period OAR-1 - Refueling Outage 3R16

TABLE 1 ABSTRACT OF EXAMINATIONS AND TESTS

Examination Category	Total Examinations Required For The Interval	Total Examinations Credited For The 3rd Period	Total Examinations Credited (%) For The 3rd Period	Total Examinations Credited (%) thru 3rd Period of The Interval	Remarks
D-A	18	19.0	105.6	105.6	Code Case N-598 per approved Relief Request RR-33
D-B	3	1.0	33.3	100.0	
E-A	68	32.0	47.1	97.1	VT-3 of the submerged portions of the Torus and Vent System have been extended 1 year. Will be performed during first outage in 4th interval per Interval per IWA-2430(d). An additional GV of Containment was performed in this interval for the ILRT requirements
E-C	3	1.0	33.3	100.0	Alternative examination program per approved Request for Alternative CRR-11
E-D	63	63.0	100.0	100.0	10CFR50 Appendix J examination of seals and gaskets during P3R15 per approved Request for Alternative CRR-01
E-G	76	76.0	100.0	100.0	10CFR50 Appendix J and Code Category E-A examination during P3R15 per approved Request for Alternative CRR-07
E-P	1 .	1.0	100.0	100.0	During P3R15 in accordance with 10CFR50 Appendix J Test Program and Schedule
F-A	158	58.0	36.7	103.2	Code Case N-598 per approved Relief Request RR-33
R-A	139	51.0	36.7	100.0	Implemented RI-ISI starting 2nd Period, replacing Categories B-F, B-J, and C-F-2.

.

.

TABLE 2 ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)		
F-A	F1.30	32MO-H57	Relevant Condition – Bent and loose parts.	Yes		
(N-491-1)		Spring Support	Accepted by Engineering Evaluation.			
		N-7 Vent Flange	1/64 in. wide gouge completely across tongue sealing surface of the flange. Repaired.	No, occurred during vessel disassembly		
E-C	E4.11	Torus Wetted Pressure Boundary	Relevant Condition – Pitting was inspected and depths measured. Accepted by Engineering Evaluation.	Yes		
E-D	E5.30	3-MBAR-INT Moisture Barrier	Relevant Condtion – five (5) small areas of degradation. Repaired.	Yes		
F-A (N-491-1)	F1.10	HD-4 Pipe Support	Relevant Condition – all eight (8) bolts and nuts missing. Support plate is welded. Accepted by Engineering Evaluation.	Yes		
E-A	E1.12	Torus Piping in Torus air space	Relevant Condition – six (6) pipes were identified to have surface rust. Accepted by Engineering Evaluation	Yes		
F-A (N-491-1)	F1.30	33HB-S145 Rigid Restraint	Relevant Condition - loose nut on the pipe clamp bolt as well as an incorrectly sized bushing. Accepted by Engineering Evaluation. Loose nut repaired and re-examination acceptable.	Yes		
F-A (N-491-1)	F1.30	33HB-H152 Spring Hanger	Relevant Condition – loose jam nut on threaded rod. Accepted by Engineering Evaluation. Loose nut repaired, re-examination acceptable.	Yes ·		
E-A	E1.12	Drywell N-4 Drywell Head Hatch	Relevant Condition - on the inside of the head access penetration, N-4, paint is peeled off in about a 6" x 10" area. Accepted by Engineering Evaluation.	Yes		
F-A (N-491-1)	F1.20	23HB-S40 Rigid Restraint	Relevant Condition – a washer is missing on the base plate #17 (northwest corner). Repaired.	Yes		

TABLE 2 ITEMS WITH FLAWS OR RELEVANT CONDITIONS THAT REQUIRED EVALUATION FOR CONTINUED SERVICE

Examination Category	Item Number	Item Description	Flaw Characterization (IWA-3300)	Flaw or Relevant Condition Found During Scheduled ASME XI Examination or Test (Yes or No)
E-A	E1.20	Vent Header	Relevant Condition - 4 downcomers at the 270 degree azimuth, coating is peeling near the waterline. Areas are approximately 6-8 inches long and wide. Accepted by Engineering Evaluation	Yes
F-A (N-491-1)	F1.40	RHRHX-D-LS Heat Exchanger Lower Support	Relevant Condition – Missing bolts and gap in plate. Accepted by Engineering Evaluation.	No
F-A	F1.30	33HB-S63 Pipe Restraint	Relevant Condition – pipe restraint found not carrying correct load. Accepted by Engineering Evaluation.	No
F-A	F1.30	33HB-H127	Relevant Condition – pipe restraint found not carrying correct load. Accepted by Engineering Evaluation.	No

,

PAGE 6 OF 10

SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 OCTOBER 17, 2005 TO NOVEMBER 4, 2008 (END OF 10 YEAR INTERVAL)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 01: MAIN STEAM SYSTEM

	Repair,			Flaw or Relevant Condition Found			
	Replacement,			During Scheduled			
Code	or Corrective	Item Description		Section XI Exam	Date		
<u>Class</u>	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	<u>R&R Plan</u>	# and W/O #
Class 1	Replacement	RV-3-02-071G	Installed a rebuilt safety relief valve	No	10/6/2007	05-069,	R0946313
Class 1	Replacement	AO-3-01A-080C	Installed 3 new bonnet studs as incidental replacement	No	10/5/2007	06-180,	R1018560
Class 1	Replacement	AO-3-01A-080D	Installed 4 new bonnet studs & 24 nuts as incid. replace	No	10/5/2007	06-181,	R1018560
Class 1	Replacement	RV-3-02-071F	Installed a rebuilt safety relief valve	No	10/6/2007	07-037,	R0949297
Class 1	Replacement	RV-3-02-070A	Installed a rebuilt safety relief valve	No	10/3/2007	07-042,	R0949210
Class 1	Replacement	RV-3-02-071J	Installed a rebuilt safety relief valve	No	10/6/2007	07-074,	R0949450
Class 1	Replacement	RV-3-02-071K	Installed a rebuilt safety relief valve	No	10/6/2007	07-076,	R0949298
Class 1	Replacement	RV-3-02-071L	Installed a rebuilt safety relief valve	No	10/6/2007	07-078,	R0949503
Class 1	Replacement	RV-3-02-071C	Installed a rebuilt safety relief valve	No	10/6/2007	07-079,	R0949456
Class 1	Replacement	RV-3-02-071D	Installed a rebuilt safety relief valve	No	2/6/2008	07-160,	C0223239

SYSTEM 02: REACTOR AND RECIRCULATION

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	PB-3-02A-3BP034	Installed new pump internals motor	No	10/7/2007	07-049, C0219200

- -

PAGE 7 OF 10

SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 OCTOBER 17, 2005 TO NOVEMBER 4, 2008 (END OF 10 YEAR INTERVAL)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 03: CONTROL ROD DRIVE

	Code <u>Class</u>	Repair, Replacement, or Corrective Measure	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	<u>R&R Plan # and W/O #</u>
	Class 1	Replacement	CRD's 06-19, 10-47, 22-31, 26-11, 26-31, 26-43, 30-15, 30-35, 34-31, 34-39, 34-51, 38-39, 42-23, 42-31, 50-11, 50-19, 58-39	Exchanged CRD's with rebuilt CRD's	No	10/1/2007	06-183, R1018595
**	Class 1	Replacement	SVD cleanout pipe caps	Install pipe caps/connections on scram disch. header	No	10/6/2007	07-048, C0219214

SYSTEM 04: REACTOR PRESSURE VESSEL AND INTERNALS

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	<u>Measure</u>	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 1	Repair	PB-3-04-P-P-N07	Performed skim cut on flange face to remove gouge	No	10/6/2007	07-148, C0222738

PAGE 8 OF 10

SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 OCTOBER 17, 2005 TO NOVEMBER 4, 2008 (END OF 10 YEAR INTERVAL)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 10: RESIDUAL HEAT REMOVAL

Code Class	Repair, Replacement, or Corrective Measure	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date Complete	R&R Plan # and W/O #
Class 2	Replacement	10GB-H132	Installed new hanger rod and clevis	No	9/26/2007	05-143, C0215615
Class 2	Replacement	PB-3-10-3DE024	Installed new RHR Hx. 3DE024 Floating Head	No	2/2/2007	07-005, C0219318
Class 2	Replacement	RV-3-10-181C	Installed new RHR Hx. 3CE024 Shell Side Relief Valve	No	11/26/2007	07-142, R0907460
Class 1	Replacement	AO-3-10-046A	Incidental bonnet bolt replacement	No	10/1/2007	07-146, C0222695

SYSTEM 11: STANDBY LIQUID CONTROL SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 2	Replacement	RV-3-11-39B	Installed new relief valve	No	12/15/2006	06-144, C0217362
Class 2	Replacement	RV-3-11-39B	Installed new relief valve	No	10/1/2007	06-152, R1011381
Class 2	Replacement	RV-3-11-39A	Installed new relief valve	No	10/1/2007	06-153, R1011382
Class 2	Replacement	RV-3-11-39A	Installed new relief valve	No	12/14/2006	06-214, C0219575

SYSTEM 13: REACTOR CORE ISOLATION COOLING SYSTEM

				Flaw or Relevant		
	Repair,			Condition Found		
	Replacement,			During Scheduled		
Code	or Corrective	Item Description		Section XI Exam	Date	
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan # and W/O #
Class 1	Replacement	MO-3-13-015	Installed new valve bonnet	No	10/4/2007	07-102, C0219281

PAGE 9 OF 10

SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 OCTOBER 17, 2005 TO NOVEMBER 4, 2008 (END OF 10 YEAR INTERVAL)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 23: HIGH PRESSURE COOLANT INJECTION SYSTEM

	Code <u>Class</u>	Repair, Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	Flaw or Relevant Condition Found During Scheduled Section XI Exam Or Test	Date <u>Complete</u>	R&R Plan # and W/O #
	Class 2	Replacement	HV-3-23C-55	Installed new bonnet on HPCI turb exh drain to torus valve	No	9/28/2007	07-080, C0220043
**	Class 2	Replacement	HV-3-23C-31158	Installed new valve/piping for HPCI turb exh drain to torus	No	9/28/2007	07-081, C0220043
	Class 2	Replacement	23-DDN-S-300A/B	Installed new base plate hilti anchor bolts	No	9/25/2007	07-089, C0220627
	Class 2	Replacement	VRV-3-23C-140A	Installed new vacuum relief valve.	No	6/16/2008	08-087, R0790436
	Class 2	Replacement	VRV-3-23C-140B	Installed new vacuum relief valve.	No	6/16/2008	08-088, R0790439
	Class 2	Replacement	VRV-3-23C-140C	Installed new vacuum relief valve.	No	6/16/2008	08-089, R0790438
	Class 2	Replacement	VRV-3-23C-140D	Installed new vacuum relief valve.	No	6/16/2008	08-090, R0790440

SYSTEM 32: HIGH PRESSURE SERVICE WATER SYSTEM

				Flaw or Relevant			
	Repair,			Condition Found			
	Replacement,			During Scheduled			
Code	or Corrective	Item Description		Section XI Exam	Date		
Class	Measure	(component I.D.)	Description Of Work Performed	Or Test	<u>Complete</u>	R&R Plan	# and W/O #
Class 3	Replacement	RV-3-32-180A	Installed new RHR Hx. 3AE024 Tube Side Relief Valve	No	11/30/2006	06-157,	R0821600
Class 3	Replacement	RO-3789C	Installed new orifice plate in RO-3789C	No	11/26/2007	06-201,	C0218911
Class 3	Replacement	RV-3-32-180D	Installed new RHR Hx. 3DE024 Tube Side Relief Valve	No	7/30/2007	06-206,	R0875863
Class 3	Replacement	RO-3800D, RO-3789D	Installed new / modified orifice plates in RO-3800D/3789D	No	7/31/2007	07-097,	C0220918
Class 3	Replacement	RV-3-32-180C	Installed new RHR Hx. 3CE024 Tube Side Relief Valve	No	11/26/2007	07-143,	R0889741

PAGE 10 OF 10

SUMMARY OF ASME REPAIRS AND REPLACEMENTS COMPLETED FOR PEACH BOTTOM ATOMIC POWER STATION, UNIT NO. 3 OCTOBER 17, 2005 TO NOVEMBER 4, 2008 (END OF 10 YEAR INTERVAL)

** Denotes that use of Code Case N-416-2 was employed in completing the repair / replacement activity

SYSTEM 65A: HYDRAULIC SNUBBERS

	Repair,			Flaw or Relevant Condition Found		
Code Class	Replacement, or Corrective <u>Measure</u>	Item Description (component I.D.)	Description Of Work Performed	During Scheduled Section XI Exam <u>Or Test</u>	Date <u>Complete</u>	R&R Plan # and W/O #
Class 2	Replacement	10-GB-S-58	Installed new snubber	No	10/5/2007	07-012, R0545777
Class 3	Replacement	1-GG-S-25	Installed new snubber	No	10/1/2007	07-013, R0545115
Class 2	Replacement	10-GB-S-12	Installed new snubber	No	9/26/2007	07-014, R0545327
Class 1	Replacement	6-DDNL-S-12	Installed new snubber	No	9/30/2007	07-015, R0546132
Class 1	Replacement	SS-3-A	Installed new snubber	No	9/27/2007	07-016, R0646441
Class 3	Replacement	1-GG-S-18	Installed new snubber	No	9/30/2007	07-019, C0219939
Class 2	Replacement	10-GB-S-64	Installed new snubber	No	9/26/2007	07-021, C0219945
Class	Replacement	27-HCR-S-187	Installed new snubber	No	9/26/2007	07-026, C0219969
Class 3	Replacement	1-GG-S-205-A	Installed new snubber	No	10/1/2007	07-029, C0219986
Class	Replacement	1-DB-S-38-A	Installed new snubber	No	10/8/2007	07-038, R0815380
Class	Replacement	1-DB-S-25-A	Installed new snubber	No	10/8/2007	07-040, R0815579
Class	Replacement	1-DB-S-2-A	Installed new snubber	No	10/8/2007	07-041, R0815590
Class 1	Replacement	SS-1-B, SS-2-B	Installed temporary struts to allow pump/motor replacement	No	9/30/2007	07-107, C0219219