



- POTENTIAL SETTLEMENT BASED ON 15% C CRITERIA (INCHES)
 POTENTIAL SETTLEMENT BASED ON 8% C CRITERIA (INCHES)
- DESIGN WATER TABLE (24 HR)
- WATER TABLE (24 HR)
- MH SOIL CLASSIFICATION
- 3 BLOW COUNT
- POTENTIALLY LIQUEFIABLE SOIL (SEE NOTE)
- WS WEATHERED SHALE

NOTE:
 I. LIQUEFACTION BASED ON TOP OF GROUND ACCELERATION OF 0.4g AND SEED - IDRIS (1971) CORRELATION FOR SANDS.

Added by Amendment 50

WATTS BAR NUCLEAR PLANT FINAL SAFETY ANALYSIS REPORT
EGROW PIPELINE SECTION A-A SHEET 2 OF 4 FIGURE 2.5-571

A - A