

Sam L. Belcher
Plant General Manager

P.O. Box 63
Lycoming, New York 13093
315.349.5205
315.349.1321 Fax



January 21, 2009

U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

ATTENTION: Document Control Desk

SUBJECT: Nine Mile Point Nuclear Station
Unit No. 1; Docket No. 50-220

Special Report: Inoperable Channel of Suppression Chamber Water Level
Instrumentation

In accordance with Action 4 of Nine Mile Point Unit 1 (NMP1) Technical Specification (TS) Table 3.6.11-2, "Accident Monitoring Instrumentation Action Statements," Nine Mile Point Nuclear Station, LLC (NMPNS), is submitting the following Special Report concerning inoperability of a Suppression Chamber Water Level Instrument.

Description of Event

On January 9, 2009, at 0845, one channel of Suppression Chamber Water Level instrumentation, LT-58-06 (TS Table 3.6.11-1, Item 5) was declared inoperable due to planned maintenance. The redundant channel of Suppression Chamber Water Level instrumentation was operable during the period LT-58-06 was inoperable.

Cause of Inoperability

Suppression Chamber Water Level instrument (LT-58-06) was removed from service for planned maintenance to replace an Environmental Qualification (EQ) splice.

Action Taken

The maintenance activity was completed and LT-58-06 declared operable at 1830 hours on January 9, 2009.

JE22
NRA

Document Control Desk
January 21, 2009
Page 2

Should you have any questions regarding the information in this submittal, please contact T. F. Syrell,
Licensing Director, at (315) 349-5219.

Very truly yours,



SLB/GNS

cc: S. J. Collins, NRC
R. V. Guzman, NRC
Resident Inspector, NRC