

**From:** Justin Poole  
**Sent:** Friday, February 06, 2009 2:21 PM  
**To:** 'JAMES.COSTEDIO@nexteraenergy.com'; 'Flentje, Fritzie'  
**Subject:** AST - From today's phone call

Jim,

Below is first the ML# for the Hatch AST SE followed by the statement clarify (hopefully) what the staff is looking for on the first part of the second issue. Please give me a call if you have any questions. As we stated during the call, your response is due within 15 days of today.

*Justin C. Poole*  
*Project Manager*  
*NRR/DORL/LPL3-1*  
*U.S. Nuclear Regulatory Commission*  
*(301)415-2048*  
*email: [Justin.Poole@nrc.gov](mailto:Justin.Poole@nrc.gov)*

ML081770075 - letter and SE  
ML081960045 - TS pages

In today's phone call, the licensee stated that the Control Room Ventilation System (VNCR) is currently in the scope of the Maintenance Rule program (10 CFR 50.65) and license renewal (10 CFR 54.37(b)). In addition, the licensee stated that the system is also currently in the Technical Specifications (TS). The staff will consider the LIC-109 review comment (related to this system) sufficiently answered if the licensee can confirm that the new alignment proposed in support of the AST submittal would not require new LCOs or surveillances that are not in the current TS.

---

## E-mail Properties

### Mail Envelope Properties ()

**Subject:** AST - From today's phone call  
**Sent Date:** 2/6/2009 1:57:08 PM  
**Received Date:** 2/6/2009 2:21:00 PM  
**From:** Justin Poole

**Created By:** Justin.Poole@nrc.gov

### Recipients:

JAMES.COSTEDIO@nexteraenergy.com ('JAMES.COSTEDIO@nexteraenergy.com')  
Tracking Status: None  
Fritzie.Flentje@nexteraenergy.com ('Flentje, Fritzie')

Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	9900	2/6/2009

Options

Expiration Date:

Priority: oImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: oNormal

Recipients received: