

**From:** Randy Hall  
**Sent:** Wednesday, February 11, 2009 8:28 AM  
**To:** Russell.Stroud@aps.com  
**Cc:** Michael Markley; Janet Burkhardt; Susan Lent  
**Subject:** Acceptance Review for License Amendment Requests for Palo Verde Units 1, 2 and 3, re: Hydrogen Monitoring, TAC Nos. ME0417, ME0418, and ME0419

Russell A. (Rusty) Stroud  
Licensing Section Leader  
Regulatory Affairs  
Palo Verde Nuclear Generating Station  
Arizona Public Service Company

Rusty:

By letter dated January 15, 2009, Arizona Public Service Company (APS) submitted a license amendment request for Palo Verde Nuclear Generating Station (PVNGS), Units 1, 2, and 3.

The proposed amendment would delete the Technical Specification (TS) requirements related to hydrogen recombiners and hydrogen monitors, consistent with the consolidated line item improvement process (CLIIP). This CLIIP TS improvement was published in the Federal Register on September 25, 2003, and is based on the Technical Specification Task Force Change Traveler, TSTF-447, Revision 1, "Elimination of Hydrogen Recombiners and Change to Hydrogen and Oxygen Monitors."

The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the technical specifications) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence.

If you have any questions, please contact me at (301) 415-4032.

James R. (Randy) Hall, Senior Project Manager

Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation  
USNRC  
(301) 415-4032  
[Randy.Hall@nrc.gov](mailto:Randy.Hall@nrc.gov)

---

### E-mail Properties

Mail Envelope Properties (D841D501B2C4D244B75AB897F70C1494862C021CC8)

Subject: Acceptance Review for License Amendment Requests for Palo Verde Units 1,  
2 and 3, re: Hydrogen Monitoring, TAC Nos. ME0417, ME0418, and ME0419  
Sent Date: 2/11/2009 8:28:05 AM  
Received Date: 2/11/2009 8:28:05 AM  
From: Randy Hall

Created By: Randy.Hall@nrc.gov

#### Recipients:

Russell.Stroud@aps.com (Russell.Stroud@aps.com)  
Tracking Status: None  
Michael.Markley@nrc.gov (Michael Markley)  
Tracking Status: None  
Janet.Burkhardt@nrc.gov (Janet Burkhardt)  
Tracking Status: None  
Susan.Lent@nrc.gov (Susan Lent)  
Tracking Status: None

Post Office:  
HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	8117	2/11/2009

#### Options

Expiration Date:  
Priority: o!ImportanceNormal  
ReplyRequested: False  
Return Notification: False

Sensitivity: o!Normal  
Recipients received: