

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

February 9, 2009

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

Serial No.	09-088
NAPS/MPW	R0
Docket No.	50-338
	50-339
License No.	NPF-4
	NPF-7

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)
NORTH ANNA POWER STATION UNITS 1 AND 2
SETTLEMENT MONITORING PROCEDURE REVISION

Enclosed is a summary of changes to North Anna Power Station Settlement Monitoring Procedure 0-PT-115. This information is being transmitted for your review pursuant to Atomic Safety and Licensing Appeal Board Decision ALAB-578 dated February 11, 1980.

Please contact Mr. Michael Whalen at (540) 894-2572 if you have any questions or require additional information.

Sincerely,



Eric S. Hendrixson
Director - Nuclear Station Safety and Licensing

Commitments made in this letter: None

Attachment

ADD
NRK

cc: U. S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, S.W., Suite 23T85
Atlanta, GA 30303-8931

U. S. Nuclear Regulatory Commission
Director – Office of Nuclear Reactor Regulation (Mailstop 13D13)
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

NRC Senior Resident Inspector
North Anna Power Station

Attachment 1

Summary of Settlement Monitoring Procedure Revision

The following items were revised in periodic test procedure 0-PT-115, Survey of Settlement Monitoring Points, approved February 4, 2009:

1. Test procedure references for Reference Monument "K" were removed from the test procedure. Reference Monument "K" is located outside of the station Protective Area adjacent to the west end security gate. Reference Monument "K" was originally installed to provide a turning point for survey loop closure. It has been determined that any solid surface near the west end security will provide the same function. The monument is being removed as a result of site preparation work associated with the proposed North Anna Unit 3. Loop closure is validated using the current Reference Monument "J".
2. The Kern centering heads have been removed from Reference Monuments "A" and "B" to eliminate a human performance concern when performing the surveys. The reference monument illustration, an attachment to the test procedure, has been revised to no longer depict the Kern centering heads. Only Reference Monuments "A" and "B" had Kern centering heads.

The procedure change does not impact the design, function, ability to function, method of performing the function, or control or operation of a system, structure or component.