

ArevaEPRDCPEm Resource

From: Getachew Tesfaye
Sent: Monday, February 23, 2009 4:41 PM
To: 'usepr@areva.com'
Cc: Sara Bernal; Timothy Frye; Surinder Arora; Joseph Colaccino; ArevaEPRDCPEm Resource
Subject: Draft - U.S. EPR Design Certification Application RAI No. 192 (2231), FSAR Ch. 15
Attachments: Draft RAI_192_CHPB_2231.doc

Attached please find draft RAI No. 192 regarding your application for standard design certification of the U.S. EPR. If you have any question or need clarifications regarding this RAI, please let me know as soon as possible, I will have our technical Staff available to discuss them with you.

Please also review the RAI to ensure that we have not inadvertently included proprietary information. If there are any proprietary information, please let me know within the next ten days. If I do not hear from you within the next ten days, I will assume there are none and will make the draft RAI publicly available.

Thanks,
Getachew Tesfaye
Sr. Project Manager
NRO/DNRL/NARP
(301) 415-3361

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 246

Mail Envelope Properties (C56E360E9D804F4B95BC673F886381E71D987AC058)

Subject: Draft - U.S. EPR Design Certification Application RAI No. 192 (2231), FSAR Ch. 15
Sent Date: 2/23/2009 4:40:58 PM
Received Date: 2/23/2009 4:40:58 PM
From: Getachew Tesfaye
Created By: Getachew.Tesfaye@nrc.gov

Recipients:

"Sara Bernal" <Sara.Bernal@nrc.gov>
Tracking Status: None
"Timothy Frye" <Timothy.Frye@nrc.gov>
Tracking Status: None
"Surinder Arora" <Surinder.Arora@nrc.gov>
Tracking Status: None
"Joseph Colaccino" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"ArevaEPRDCPEm Resource" <ArevaEPRDCPEm.Resource@nrc.gov>
Tracking Status: None
"usepr@areva.com" <usepr@areva.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	717	2/23/2009 4:40:58 PM
Draft RAI_192_CHPB_2231.doc		27642

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Draft

Request for Additional Information No. 192 (2231), Revision 0

2/23/2009

U. S. EPR Standard Design Certification
AREVA NP Inc.
Docket No. 52-020

SRP Section: 12.05 - Operational Radiation Protection Program
Application Section: Section 12.5, Operational Radiation Protection Program

QUESTIONS for Health Physics Branch (CHPB)

12.05-1

COL Information Item 12.05-1, Operational Radiation Protection Program, references several Regulatory Guides (RGs) which are outdated according to the consolidated guidance of NUREG 1736. In addition, the reference to Part 72 in this item is incorrect. Please revise COL item 12.05-1 so that the Part 72 reference is changed to Part 71, RGs 8.20, 8.26, and 8.32 are deleted from the listing of RGs, and RG 1.206 is added.