

PMHarrisCOL PEmails

From: Manny Comar
Sent: Wednesday, January 28, 2009 9:20 AM
To: Kitchen, Robert; Wilkins, Tillie; Waters, David
Cc: Manny Comar; HarrisCOL Resource
Subject: draft RAI No. 1808 related to SRP Section: 02.03.04- Short Term Atmospheric Dispersion Estimates for Accident Releases for Shearon Harris Units 2 and 3 Combined License Application
Attachments: RAI 1808.doc

To All,

Attached is a draft RAI no:1808, related to SRP Section: 02.03.04 Short Term Atmospheric Dispersion Estimates for Accident Releases for Shearon Harris Units 2 and 3 Combined License Application.

If you need a conference call to discuss the question(s) please contact me at 301-415-3863. Unless you request additional clarification we will normally issue the RAI as final within 3 to 5 days, from today.

Thanks

Manny Comar
Senior Project Manager
NRO/DNRL/NWE1
Nuclear Regulatory Commission
301-415-3863
<mailto:manny.comar@nrc.gov>

Hearing Identifier: ShearonHarris_COL_Public
Email Number: 364

Mail Envelope Properties (3AF7DEF82ADA8944AD8247B7ED7FD65182B0674053)

Subject: draft RAI No. 1808 related to SRP Section: 02.03.04- Short Term Atmospheric Dispersion Estimates for Accident Releases for Shearon Harris Units 2 and 3 Combined License Application

Sent Date: 1/28/2009 9:20:12 AM

Received Date: 1/28/2009 9:20:14 AM

From: Manny Comar

Created By: Manny.Comar@nrc.gov

Recipients:

"Manny Comar" <Manny.Comar@nrc.gov>

Tracking Status: None

"HarrisCOL Resource" <HarrisCOL.Resource@nrc.gov>

Tracking Status: None

"Kitchen, Robert" <robert.kitchen@pgnmail.com>

Tracking Status: None

"Wilkins, Tillie" <tillie.wilkins@pgnmail.com>

Tracking Status: None

"Waters, David" <David.Waters@pgnmail.com>

Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	608	1/28/2009 9:20:14 AM
RAI 1808.doc	31738	

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received:

Request for Additional Information No. 1808

Shearon Harris
Progress Energy Carolinas, Inc.
Docket No. 52-022 and 52-023

SRP Section: 02.03.04 - Short Term Atmospheric Dispersion Estimates for Accident Releases
Application Section: 2.3.4.4 Control Room Diffusion Estimates

QUESTIONS from Siting and Accident Conseq Branch (RSAC)

02.03.04-***

FSAR Section 2.3.4.4 states that "Plant north is given as 25 degrees counterclockwise." From viewing FSAR Figure 2.1.1-203, it appears that the rotation of the plant is approximately 66 degrees clockwise. Please either correct this error or provide justification for the difference between the statement and the FSAR figure.