

Application NAB-2007-08123-M05
Response to U.S. Army Corps of Engineers Information Request Dated 01/16/09
Calvert Cliffs 3 Project, LLC and UniStar Nuclear Operating Services, LLC
February 12, 2009

Question 3

Provide depth from the top of pipe to mean low water for discharge pipe and fish return.

RESPONSE

The clearance for the top of the fish return at mean low water is approximately 3.4 ft as noted in Revised Figure 4A (attached). The clearance for the top of the discharge pipe at mean low water is approximately 6.0 ft as noted in Revised Figure 5C (attached). The discharge pipe will be identified by markers as required.