

**GENERATION OF IN-EQUIPMENT RESPONSE
SPECTRA FOR SEISMIC QUALIFICATION
OF MSFIS SYSTEM**

Prepared for

WOLF CREEK NUCLEAR OPERATING CORPORATION

Purchase Order No. 736522
ARES Calculation No.: 0620514.01-C-003

January 2007

Prepared By



2101 Webster Street, Suite 1560
Oakland, California 94612
(510) 645-5960



CALCULATION COVER SHEET

Page No.

2 of 25

Calculation No:

0620514.01-C-003

Project No.
0620514.01

Project Title:
Modification of Main Control Panels at WCNOG


Client:
Wolf Creek Nuclear
Operating Corporation

Title:
Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Purpose and Objective:

The purpose of this calculation is to generate In-Equipment Response Spectra for seismic qualification of replacement components inside the MSFIS cabinets.

Rev. No.	Total Pages	Revision Description (Add Continuation Sheet If Required)	Prepared By Name/Date	Checked By Name/Date	PM/TL Approval/Date
0	25	Original Issue	Mohsin R Khan, PhD, P.E. <i>Mohsin Khan</i>	L. T. Nicholson <i>L. T. Nicholson</i>	M. R. Khan, PhD, P.E. <i>Mohsin Khan</i>
			1/09/07	1/09/07	1/09/07





CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 4 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

TABLE OF CONTENTS

1.0 INTRODUCTION	7
2.0 INPUT.....	8
3.0 GENERATION OF IN-EQUIPMENT SPECTRA.....	8
3.1 WCNOC Floor Response Spectra.....	8
3.2 Amplification Factors	15
4.0 CONCLUSION.....	24
5.0 REFERENCES	25



CALCULATION SHEET

Project No. 0620514.01	Calculation No. 0620514.01-C-003	Rev. No. 0	Page No. 5 of 25
------------------------	----------------------------------	------------	------------------

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.	Date: 1/09/07	Checked By: L. T. Nicholson	Date: 1/09/07
---------------------------------------	---------------	-----------------------------	---------------

FIGURES

Figure 3-1. 3% SSE North South Response Spectra for 3 SNUPPS Sites at Elevation 2047'-6" in the AUX/CONTROL Building.....	9
Figure 3-2. SSE 3% East West Response Spectra for 3 SNUPPS Sites at Elevation 2047'-6" in the AUX/CONTROL Building.....	10
Figure 3-3. SSE 3% Vertical Response Spectra for 3 SNUPPS Sites at Elevation 2047'-6" in the AUX/CONTROL Building:.....	11
Figure 3-4. Location of Accelerometers in MSFIS Cabinet (Reference 1).....	16
Figure 3-5. Channel assignments for Accelerometers MSFIS Cabinet (Reference 1).....	17
Figure 3-6. Results from Resonance Search (Reference 1).....	18
Figure 3-7. Calculated Amplification Factors from Reference 2.....	19
Figure 3-8. Comparison of Floor Spectra and Amplified Spectra.....	20
Figure 3-9. Final SSE Horizontal RRS @ 3% Damping With 10% Margin.....	21
Figure 3-10. Final Vertical RRS @ 3% Damping With 10% Margin.....	22



CALCULATION SHEET

Project No. 0620514.01	Calculation No. 0620514.01-C-003	Rev. No. 0	Page No. 6 of 25
------------------------	----------------------------------	------------	------------------

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.	Date: 1/09/07	Checked By: L. T. Nicholson	Date: 1/09/07
---------------------------------------	---------------	-----------------------------	---------------

TABLES

Table 3-1. 3% SSE East West Response Spectra for 3 SNUPPS Sites at Elevation 2047'-6" in the AUX/CONTROL Building.....	12
Table 3-2. 3% SSE Vertical Response Spectra for 3 SNUPPS Sites at Elevation 2047'-6" in the AUX/CONTROL Building.....	13
Table 3-3. 3% SSE North South Response Spectra for 3 SNUPPS Sites at Elevation 2047'-6" in the AUX/CONTROL Building.....	14
Table 3-4. 3% Final SSE Horizontal RRS @ 3% Damping With 10% Margin (Figure 3-9).....	23
Table 3-5. 3% Final SSE Vertical RRS @ 3% Damping With 10% Margin (Figure 3-10).....	23



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 7 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

1.0 INTRODUCTION

The purpose of this calculation is to generate In-Equipment Response Spectra for seismic qualification of replacement components inside the Main Steam and Feedwater Isolation Actuation System (MSFIS) cabinets.

The MSFIS cabinets are installed in the Main Control Room at elevation 2047'-6" at WCNOG.



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 8 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

2.0 INPUT

The seismic qualification of the MSFIS cabinet was performed by shake table testing per Reference 1. Resonance searches in the side-to-side, front-to-back, and in the vertical direction were performed to obtain the dynamic amplification factors at each input frequency. After the resonance search was completed, several bi-axial tests were performed in the side-to-side with vertical, and front-to-back with vertical direction of input motion. The testing demonstrated that the test response spectra conservatively enveloped the required response spectra.

Reference 2 documents the seismic qualification for the components installed inside the Engineered Safety Features Actuation System (ESFAS), Load Shedding and Emergency Load Sequencing System (LSFELS) and, MSFIS cabinets by shake table testing. The information provided in Reference 1 and 2 will be used to generate more realistic in-equipment response spectra for the seismic qualification of replacement components to be performed per Reference 3 and 4.

3.0 GENERATION OF IN-EQUIPMENT SPECTRA

3.1 WCNOC Floor Response Spectra

WCNOC As-Built Response Spectra are provided in Calculation 10-19-F (Reference 5). Figures 3-1 to 3-3 show the As-Built 3% SSE for 3 SNUPPS site envelope Floor Response Spectra for the North South, East West and Vertical direction respectively. The digitized values of the response spectra are provided in Tables 3-1 to 3-3.



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 9 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07




Figure 3-1. 3% SSE North South Response Spectra for 3 SNUPPS Sites at Elevation 2047'-6" in the AUX/CONTROL Building.



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 10 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07




Figure 3-2. SSE 3% East West Response Spectra for 3 SNUPPS Sites at Elevation 2047'-6" in the AUX/CONTROL Building.



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 11 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07




Figure 3-3. SSE 3% Vertical Response Spectra for 3 SNUPPS Sites at Elevation 2047'-6" in the AUX/CONTROL Building.



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 12 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

Table 3-1. 3% SSE East West Response Spectra for 3 SNUPPS Sites at Elevation 2047'-6" in the AUX/CONTROL Building.

Frequency Hz	Acceleration g's
0.263	0.123
0.268	0.123
0.299	0.13
0.375	0.163
0.401	0.186
0.45	0.215
0.498	0.222
0.587	0.258
0.682	0.304
0.798	0.33
0.875	0.3517
0.954	0.381
1.14	0.507
1.447	0.598
1.583	0.698
1.929	0.724
2.189	0.764
2.369	0.862
2.746	0.865
2.759	0.828
3.368	0.862
3.588	0.87
3.763	0.919
4.3453	0.9409
4.348	0.944
4.571	1.137

Frequency Hz	Acceleration g's
4.888	1.179
5.076	1.518
5.45	1.677
5.764	1.699
7.145	1.704
7.394	1.59
7.947	1.292
8.4285	1.1024
8.762	1.105
9.318	1.018
10.114	0.914
10.985	0.607
12.674	0.56
12.967	0.515
13.7573	0.4836
14.147	0.483
15.3383	0.433
15.586	0.433
17.943	0.372
21.221	0.372
25.16	0.321
36.915	0.289
37.244	0.289
100	0.289



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 13 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

Table 3-2. 3% SSE Vertical Response Spectra for 3 SNUPPS Sites at Elevation 2047'-6" in the AUX/CONTROL Building.

Frequency Hz	Acceleration g's
0.222	0.069
0.226	0.069
0.302	0.096
0.333	0.1143
0.352	0.126
0.385	0.144
0.481	0.169
0.5356	0.1832
0.5837	0.1975
0.599	0.204
0.6194	0.2077
0.696	0.228
0.95	0.318
1.124	0.343
1.199	0.361
1.287	0.403
1.3705	0.4208
1.4604	0.4429
1.55	0.468
1.625	0.4689
1.8514	0.5057
1.9	0.523
2.094	0.532
2.1403	0.5553
2.1581	0.5692
2.16	0.605

Frequency Hz	Acceleration g's
2.647	0.719
3.041	0.774
3.257	0.812
4.064	0.817
4.546	0.782
5.219	0.79
6.468	0.795
7.119	0.74
8.49	0.738
10.486	0.683
11.446	0.663
12.517	0.619
15.536	0.587
15.957	0.569
17.464	0.565
17.653	0.539
19.704	0.505
21.818	0.411
26.955	0.264
29.4994	0.2409
30.235	0.237
35.657	0.24
37.619	0.24
100	0.24



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 14 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

Table 3-3. 3% SSE North South Response Spectra for 3 SNUPPS Sites at Elevation 2047'-6" in the AUX/CONTROL Building.

Frequency Hz	Acceleration g's
0.211	0.1
0.2267	0.1
0.277	0.139
0.303	0.147
0.387	0.196
0.503	0.244
0.5694	0.2598
0.581	0.264
0.674	0.323
0.748	0.343
0.862	0.36
1.011	0.401
1.12	0.436
1.173	0.494
1.398	0.5438
1.401	0.545
1.4024	0.5453
1.502	0.581
1.621	0.663
1.6307	0.6627
1.671	0.691
1.914	0.69
2.021	0.69
2.091	0.708
2.1451	0.7161
2.195	0.757
2.2747	0.7911
2.352	0.845
2.878	0.846
2.891	0.777
3.718	0.829
4.052	0.857
4.2463	0.8579
4.264	0.884
4.823	0.884
5.155	1.112
5.865	1.154

Frequency Hz	Acceleration g's
6.045	1.46
6.397	1.586
7.808	1.59
8.239	1.414
8.381	1.228
8.568	1.052
8.622	1.038
9.761	1.038
10.311	0.888
10.892	0.751
11.274	0.6717
11.761	0.607
12.447	0.611
13.3175	0.5519
13.426	0.552
14.21	0.511
14.67	0.485
15.386	0.468
16.47	0.447
17.669	0.446
18.364	0.434
18.871	0.414
19.349	0.398
19.526	0.389
21.623	0.39
22.575	0.385
24.944	0.371
25.927	0.337
27.9553	0.3038
37.188	0.296
100	0.296



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 15 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

3.2 Amplification Factors

In Reference 1, the MSFIS cabinet was tested to obtain the resonant frequencies and amplification factors, and for a conservative 4-site envelope SNUPPS input floor response spectra. Figure 3-4 shows the location of accelerometers that were instrumented in the cabinet. Figure 3-5 illustrates the corresponding channels that collected the data for the resonance searches. Figure 3-6 provides the output accelerations from the resonance search tests. As it can be seen that the highest response in the side-to-side direction is around 8 Hz. Therefore, the amplification factors around this frequency would be the greatest.

In Reference 2, the components to be mounted inside the MSFIS cabinet were separately tested using a generic response spectra. In this test report, the amplification factors for the floor response spectra to obtain in-equipment response spectra were based on the results of the bi-axial tests performed in Reference 1 and no resonance search data was used. These amplification factors used are as shown in column 5 of Figure 3-7. The amplification factor around 8 Hz is close to 1, thus indicating that there was no resonance around 8 Hz. Figure 3-8 shows a comparison of the envelope of the North-South and East-West floor response spectra times the square root of two and amplified floor response spectra using the factors in Figure 3-7. Figure 3-8 also shows a modified amplified floor spectra where the acceleration between 6 and 9 Hz is multiplied by an average amplification factor of 2.8 to account for the resonance frequency observed around 8 Hz. The modified amplified spectra is increased by 10% and plotted in Figure 3-9 and the corresponding digitized values are given in Table 3-4.

From Reference 1, there are no resonant frequencies in vertical direction and thus the floor spectra can be used. Figure 3-10 is the vertical floor spectra from Section 3.1 increased by 10%. The corresponding digitized values are given in Table 3-5.



CALCULATION SHEET

Project No. 0620514.01 Calculation No. 0620514.01-C-003 Rev. No. 0 Page No. 16 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E. Date: 1/09/07 Checked By: L. T. Nicholson Date: 1/09/07




Figure 3-4. Location of Accelerometers in MSFIS Cabinet (Reference 1).



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 17 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

(UNCLASSIFIED)
FACTUAL DATA (Continued)

PG 30 of 64

1.0 RESONANT FREQUENCY SEARCH:
(Horizontal, side to side)

ACCELEROMETER LOCATIONS (See figure 1)

	<u>CHANNEL</u>	<u>LOCATION</u>
INPUT:	1	X - Base of cabinet
OUTPUTS:	2	X - 5
	3	Z - 5
	4	X - 4
	5	Z - 4
	6	X - 3
	7	Z - 3
	8	X - 2
	9	Z - 2
	10	Z - 2

Figure 3-5. Channel assignments for Accelerometers MSFIS Cabinet (Reference 1).



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 18 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

(UNCLASSIFIED)
FACTUAL DATA (Continued)

PG 31 of 64

Frequency (Hz)	Input (g-peak) 1	Outputs (g-peak)							
		3	4	5	6	7	8	9	10
1	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
2	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
3	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
4	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
5	0.2	0.24	0.1	0.2	0.1	0.2	0.1	0.2	0.1
6	0.2	0.42	0.1	0.2	0.1	0.22	0.1	0.2	0.1
7	0.2	0.86	0.18	0.36	0.16	0.32	0.16	0.22	0.13
* 8	0.2	1.1	0.28	0.56	0.24	0.42	0.22	0.24	0.21
9	0.2	0.66	0.14	0.4	0.14	0.32	0.12	0.2	0.1
10	0.2	0.38	0.1	0.26	0.1	0.22	0.1	0.2	0.1
11	0.2	0.24	0.1	0.22	0.1	0.2	0.1	0.2	0.1
12	0.2	0.21	0.1	0.2	0.1	0.2	0.1	0.2	0.1
13	0.2	0.22	0.1	0.2	0.1	0.2	0.1	0.2	0.1
14	0.2	0.22	0.1	0.2	0.1	0.2	0.1	0.2	0.1
15	0.2	0.28	0.1	0.2	0.1	0.2	0.1	0.2	0.1
16	0.2	0.43	0.1	0.26	0.1	0.24	0.1	0.2	0.1
* 17	0.2	0.64	0.14	0.38	0.12	0.28	0.1	0.22	0.1
18	0.2	0.56	0.1	0.29	0.1	0.26	0.1	0.2	0.1
19	0.2	0.4	0.1	0.24	0.1	0.22	0.1	0.2	0.1
20	0.2	0.26	0.1	0.2	0.1	0.2	0.1	0.2	0.1
21	0.2	0.22	0.1	0.2	0.1	0.2	0.1	0.2	0.1
22	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
23	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
24	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
25	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
26	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
27	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
28	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
29	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
30	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
31	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
32	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
33	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
34	0.2	0.2	0.1	0.2	0.1	0.2	0.1	0.2	0.1
35	0.2	0.38	0.1	0.28	0.1	0.2	0.1	0.2	0.1

* Significant resonances observed.

J-104-0334-05

PAGE 3 OF 36 PAGES
(UNCLASSIFIED)

STR. 081177-1
DATA SECTION 2

ER1078 Appx.F-2
Rev. C Sheet 28

Figure 3-6. Results from Resonance Search (Reference 1).



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 19 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

Milford Blueprint PG 18 of 92 DWG NO. KKY7317

FIGURE 12 J-1001-0351-04

OCTAVES ABOVE 1 Hz	FREQUENCY (Hz)	CABINET TOP ACCELERATIONS	COMPOSITE RRS ACCELERATIONS (g)	AMPLIFICATION FACTORS	CURVE D: 3 SITES FRS ACCELERATIONS (g)	CURVE C: ANTICIPATED COMPONENT ACCELERATIONS (g)
0	1	1.2	0.6	2	0.42	0.84
1/3	1.26	1.35	0.9	1.5	0.60	0.90
2/3	1.59	1.9	1.0	1.9	0.75	1.43
1	2	1.9	1.0	1.9	0.84	1.60
1 1/3	2.52	2.1	1.3	1.62	0.92	1.49
1 2/3	3.17	2.15	1.4	1.54	0.96	1.48
2	4	2.25	1.6	1.41	0.99	1.40
2 1/3	5.04	3.2	3.3	1.45	1.36	1.97
2 2/3	6.35	4.15	3.6	1.15	1.90	2.19
3	8	4.85	4.3	1.13	1.90	2.15
3 1/3	10.08	4.95	3.5	1.41	1.51	2.13
3 2/3	12.7	4.9	3.1	1.58	0.82	1.30
4	16	4.55	1.5	3.03	0.78	2.36
4 1/3	20.16	4.15	1.8	2.31	0.66	1.52
4 2/3	25.40	3.15	1.5	2.1	0.60	1.26
5	32	2.9	0.9	3.22	0.46	1.48
5 1/3	40.3	3.15	0.9	3.5	0.45	1.58

SIZE: A
 FSCMNO: 02750
 DWGNO: KKY7317

SCALE: 1" = 1'-0"

REVISION C SHEET 93

Figure 3-7. Calculated Amplification Factors from Reference 2.



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 20 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07




Figure 3-8. Comparison of Floor Spectra and Amplified Spectra.



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 21 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07




Figure 3-9. Final SSE Horizontal RRS @ 3% Damping With 10% Margin.



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 22 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07




Figure 3-10. Final Vertical RRS @ 3% Damping With 10% Margin.



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 23 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

Table 3-4. 3% Final SSE Horizontal RRS @ 3% Damping With 10% Margin (Figure 3-9).

Frequency Hz	Acceleration g's	Accel (g) + 10%
1	1.13	1.24
1.26	1.48	1.63
1.59	1.94	2.13
2	1.94	2.13
2.52	1.94	2.13
3.17	1.94	2.13
6	6.75	7.42
9	6.75	7.42
16	1.95	2.15
40.3	1.47	1.61
100	1.47	1.61

Table 3-5. 3% Final SSE Vertical RRS @ 3% Damping With 10% Margin (Figure 3-10).

Frequency Hz	Acceleration g's	Accel (g) + 10%
0.950	0.32	0.35
3.257	0.81	0.89
6.468	0.81	0.89
19.704	0.55	0.60
30.235	0.24	0.26
100.000	0.24	0.26



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 24 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

4.0 CONCLUSION

ARES has developed composite In-Equipment response spectra for the North-South and East-West direction. The vertical spectra was developed separately, which is much lower than the North-South and East-West response spectra. All spectra are at 3% structural damping. The In-Equipment response spectra are provided in Figure 3-9 and 3-10 for the seismic qualification of components installed inside the MSFIS cabinets.



CALCULATION SHEET

Project No. 0620514.01

Calculation No. 0620514.01-C-003

Rev. No. 0

Page No. 25 of 25

Title: Generation of In-Equipment Response Spectra For Seismic Qualification of MSFIS System

Prepared By: Mohsin R Khan, PhD, P.E.

Date: 1/09/07

Checked By: L. T. Nicholson

Date: 1/09/07

5.0 REFERENCES

1. 10466-J-104-0334-05, SD# ER1078 Appx. F, Consolidated Controls Corp, "Seismic Qualification Test Report Fir MSFIS Logic/Termination Cabinet", Dated December 31, 1981.
2. 10466-J-104-0351-04, SD# KKY7317, Consolidated Controls Corp, "Seismic Test Report for ESFAS, LSELS and MSFIS Components", Dated November 10, 1982.
3. Specification J-105A(Q), Rev. 2, "Technical Specification for Replacement MSFIS System Wolf Creek Generating Station (WCGS)", Dated October 3, 2006.
4. S-128P, Rev.2, "Nutherm Seismic Test Procedure for Replacement MSFIS System, Dated January 8, 2007.
5. Wolf Creek Nuclear Operating Corporation Calculation No. 10-19-F, "Redefined As-Built Floor Response Spectra Curves", Rev. 0.
6. J-105(Q), SNUPPS Equipment Qualification Summary (SQRT forms).
7. Institute of Electrical and Electronic Engineers Standard 323-1974.
8. Institute of Electrical and Electronic Engineers Standard 344-1975.
9. Nuclear Regulatory Commission Regulatory Guide 1.61.
10. Nuclear Regulatory Commission Regulatory Guide 1.92.