

FEB 18 2009

LR-N09-0033



Technical Specification 6.9.1.5

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Salem Generating Station, Units 1 and 2  
Facility Operating License Nos. DPR-50 and 75  
NRC Docket Nos. 50-272 and 50-311

Subject: Technical Specification 6.9.1.5. - Annual Report

PSEG Nuclear LLC (PSEG) submits this report in accordance with the requirements of Salem Units 1 and 2 Technical Specification (TS) 6.9.1.5.c.

PSEG reports that for the period from January 1, 2008, until January 1, 2009, there were no instances when the primary coolant specific activity of either Salem unit exceeded the TS limits of  $DEI \leq 1.0$  microcuries/gram and  $\leq 100$ /E-bar microcuries/gram as stated in TS 3.4.8 for Salem 1 and 3.4.9 for Salem 2, respectively.

Should you have any questions regarding this transmittal, please contact E. H. Villar at (856) 339-5456.

Respectfully,

A handwritten signature in black ink, appearing to be "R. Braun", written over a horizontal line.

Robert C. Braun  
Salem Site - Vice President

A001  
NRR

FEB 18 2009

Mr. Samuel Collins, Administrator - Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

U.S. NRC Resident Inspector Office - Salem (X24)

Mr. R. Ennis, Project Manager - Hope Creek and Salem  
U. S. Nuclear Regulatory Commission  
Mail Stop 08B2  
11555 Rockville Pike  
Rockville, MD 20852

Mr. P. Mulligan, Manager IV  
Bureau of Nuclear Engineering  
P. O. Box 415  
Trenton, NJ 08625