SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

JPM A.1.a

Evaluate Overtime Requirements

NUCLEAR TRAINING REVISION/USAGE LOG					
REVISION NUMBER	DESCRIPTION OF REVISION	v	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
0	Modified JPM	Y		All	

V - Specify if the JPM change will require another validation (Y or N). See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT RO/SRO JOB PERFORMANCE MEASURE

Task:

Evaluate Overtime Requirements

JA/TA task:

3430050302 (SRO) 0001650302 (SRO) 1190030301 (RO)

K/A Ratings:

2.1.5 Ability to use procedures related to shift staffing, such as minimum crew complement, overtime limitations, etc. 2.9* / 3.9

Task Standard:

1) The candidate identifies the need for on 2 occasions: On 01/30/09 to allow exceeding 24hours in a 48 hour period On 02/04/09 to allow exceeding 72 hours in 7 days

Evaluation Method :	Classroom <u>X</u>		
======================================	NAME		Start Time
Performance Rating :	SAT UNSAT	Performance Time	Finish Time
Evaluator:	SIGNATURE	/ DATE	
		COMMENTS	

JPM A.1.a Page 4 of 7

SPECIAL INSTRUCTIONS TO EVALUATOR:

1. JPM can be administered in any setting

Validation Time: CR. 13 min Local _____

Tools/Equipment/Procedures Needed:

References:

	Reference	Title	Rev No.
1.	SPP-1.5	Overtime Restrictions (Regulatory)	0005
2.	0-PI-OPS-000-027.0	Shift Manager Clerk Duty Station Shift Relief and	0034
		Office Round Sheets.	

READ TO OPERATOR

Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

Initial Conditions:

You are a Licensed Operator that has worked the following schedule:

Date	Hours	Status	Notes
01/26/09	OFF		
01/27/09	OFF		
01/28/09	OFF		
01/29/09	0630 -2230	Normal Off Day	Worked on an Off day and stayed over 4 hours until relief arrived
01/30/09	1830-0645	Normal Work Day	15 minute turnover
01/31/01	1830-0645	Normal Work Day	15 minute turnover
02/01/09	1830-0645	Normal Work Day	15 minute turnover
02/02/09	1830-0645	Normal Work Day	15 minute turnover
02/03/09	OFF	Normal Off Day	
02/04/09	0630-1845	Normal Off Day	Called in to cover shift(15 minute turnover)
02/05/09	1300-1845	Normal Off Day	Called in to cover shift to relieve a sick operator. (15 minute turnover)
02/06/09	A/L	Normal Work Day	Took Annual Leave for the shift
02/07/09	0630-1845	Normal Work Day	15 minute turnover
02/08/09	0630-1845	Normal Work Day	15 minute turnover
02/09/09	OFF	Normal Off Day	

INITIATING CUES:

Determine the date(s) that would require an Overtime Limitation Exception Report to be completed prior to you completing the identified working hours and the reason(s) for the report(s) being required.

	STEP/STANDARD	SAT/UNSAT
<u>STEP 1.</u> :	Evaluate the hours worked against the requirements.	Start Time
<u>STANDARD</u> :	Candidate identifies an Overtime Limitation Exception Report is required prior to completing the 01/30/09 shift to allow exceeding 24 hours in a 48 hour period	SAT UNSAT Critical Step
<u>STEP 2.</u> : Evalu <u>STANDARD</u> :	Tate the hours worked against the requirements. Candidate identifies an Overtime Limitation Exception Report is required prior to completing the 02/04/09 shift to allow exceeding 72 hours in a 7 day period	SAT UNSAT Critical Step
<u>COMMENTS:</u>		

End of JPM

CANDIDATE CUE SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

DIRECTION TO TRAINEE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

Initial Conditions:

Date	Hours	Status	Notes
01/26/09	OFF		
01/27/09	OFF		
01/28/09	OFF		
01/29/09	0630 -2230	Normal Off Day	Worked on an Off day and stayed over 4 hours until relief arrived
01/30/09	1830-0645	Normal Work Day	15 minute turnover
01/31/01	1830-0645	Normal Work Day	15 minute turnover
02/01/09	1830-0645	Normal Work Day	15 minute turnover
02/02/09	1830-0645	Normal Work Day	15 minute turnover
02/03/09	OFF	Normal Off Day	
02/04/09	0630-1845	Normal Off Day	Called in to cover shift(15 minute turnover)
02/05/09	1300-1845	Normal Off Day	Called in to cover shift to relieve a sick operator. (15 minute turnover)
02/06/09	A/L	Normal Work Day	Took Annual Leave for the shift
02/07/09	0630-1845	Normal Work Day	15 minute turnover
02/08/09	0630-1845	Normal Work Day	15 minute turnover
02/09/09	OFF	Normal Off Day	

You are a Licensed Operator that has worked the following schedule:

INITIATING CUES:

Determine the date(s) that would require an Overtime Limitation Exception Report to be completed prior to you completing the identified working hours and the reason(s) for the report(s) being required.

SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

A.1.b

Calculate Manual Makeup to the Volume Control Tank

NUCLEAR TRAINING REVISION/USAGE LOG					
REVISION NUMBER	DESCRIPTION OF REVISION	v	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:

V - Specify if the JPM change will require another validation (Y or N). See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT RO/SRO JOB PERFORMANCE MEASURE

Task:

Calculate Manual Makeup to the Volume Control Tank

JA/TA task # : 0040250101 (**RO**)

K/A Ratings:

004A1.06 (3.0/3.2)	004A4.07 (3.9/3.7)
004A4.13 (3.3/2.9)	004A4.15 (3.6/3.7)

Task Standard:

Manual make up to the VCT to bring level up 10% is determined to be 168 ± 2 gallons water and 32 ± 2 gallons of boric acid.

Evaluation Method :	Simulator <u>X</u>	In-Plant	
Performer:	NAME		Start Time
Performance Rating :	SAT UNSAT	Performance Time	Finish Time
Evaluator:	SIGNATURE	/ DATE	
		COMMENTS	

SPECIAL INSTRUCTIONS TO EVALUATOR:

- 1. Sequenced steps identified by an "s"
- 2. Any <u>UNSAT</u> requires comments
- 3. Initialize the simulator in IC-176. Ensure VCT level is approximately 24% prior to start of JPM.
- 4. Ensure operator performs the following required actions for **SELF-CHECKING**;
 - a. Identifies the correct unit, train, component, etc.
 - b. Reviews the intended action and expected response.
 - c. Compares the actual response to the expected response.

Validation Time: CR. 22 mins Local _____

Tools/Equipment/Procedures Needed:

- 1. 0-SO-62-7, "Boron Concentration Control", Section 6.5, Appendix C
- 2. TI-44, Boron Tables.

References:

	Reference	Title	Rev No.
1.	0-SO-62-7	Boron Concentration Control	51
2.	TI-44	Boron Tables	12

READ TO OPERATOR

Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- 1. Unit is at 100% full power, steady state.
- 2. Reactor coolant system boron concentration is 1117 ppm and BAT boron concentration is 6820 ppm.
- 3. B-10 depletion value is 15 ppm
- 4. REACTF software is not available for boron calculations.

INITIATING CUES:

- 1. You are the Unit 1 OATC and are to perform a calculation for a manual blended makeup to the Chemical Volume Control System to increase Volume Control Tank level from 41% to 51%.
- 2. Notify the SRO when the calculation is completed.

Job Performance	e Checklist: STEP/STANDARD	SAT/UNSAT
<u>STEP 1.</u> :	Operator obtains appropriate copy of procedure and determines the appropriate section to perform.	SAT UNSAT
<u>STANDARD</u> :	Operator obtains copy of 0-SO-62-7 and determines that section 6.5 is the appropriate section.	Start Time
<u>STEP 2.</u> :	[2] PERFORM Appendix C Calculation of Boric Acid and Primary Water Integrator setting for manual makeup.	SAT UNSAT
STANDARD:	Operator goes to Appendix C	
NOTE: Folic BOR MAK	owing steps are contained in 0-SO-62-7, Appendix C CALCULATION OF IC ACID AND PRIMARY WATER INTEGRATOR SETTING FOR MANUAL EUP TO VCT (RCS).	
<u>STEP 3.:</u>	[1] OBTAIN Current RCS Boric Acid Concentration	SAT
STANDARD:	Operator obtains current RCS boron concentration or uses initial conditions. RCS Boric acid concentration 1117 ppm	UNSAT
<u>STEP 4.:</u>	[2] OBTAIN Current BAT Boric Acid Concentration	SAT
<u>STANDARD</u> :	Operator obtains current BAT boron concentration from Chem Lab or uses initial conditions. BAT Boric acid concentration 6820 ppm	UNSAT
<u>STEP 5.:</u>	[3] OBTAIN B-10 depletion value from Rx Eng Information page	SAT
<u>Cue:</u>	<i>Current depletion value is 15 ppm, after operators asks for information page.</i>	UNSAT
STANDARD:	Operator obtains current boron depletion value and records 15 ppm.	
NOTE	Result in Step [4] should be rounded to the second decimal place.	
<u>STEP 6.:</u>	[4] CALCULATE BAT Boric Acid Concentration Ratio (BACR):	SAT
NOTE:	6820 ppm ÷ 6820 ppm (from step 2) = 1.0	UNSAT
STANDARD:	Operator observes that BACR is one (1.0).	Critical Step

Job Performance	e Checklist: STEP/STANDARD	SAT/UNSAT
<u>STEP 7.:</u>	[5] CALCULATE B-10 corrected boron concentration: =	SAT UNSAT
NOTE:	1117 ppm – 15 ppm (from step 2) = 1102 ppm	
STANDARD:	Operator calculates corrected B-10 concentration	
<u>STEP 8.:</u>	 [6] DETERMINE Corrected Boric Acid Flow Rate and Controller Setting using appropriate table from TI-44 Appendix C. [a] RECORD Corrected Boric Acid Flow Rate from TI-44 Appendix C Table 1 	SAT UNSAT
<u>NOTE:</u>	TI-44, Appendix C, Table 1, BA flow for 1100 ppm is 13.32 gpm; BA flow rate for 1110 ppm is 13.46 gpm. Interpolating for 1102 ppm. BA flow rate is <u>13.35 gpm</u>	
<u>STANDARD</u> :	Operator calculates the Corrected Boric Acid Flow rate from TI-44 Appendix C Table 1. 13.35 gpm	Critical Step
<u>STEP 9.:</u>	[b] RECORD Correct Boric Acid Controller Setting from TI-44 Appendix C <u>Table 2</u>	SAT
<u>NOTE:</u> STANDARD:	TI-44, Appendix C, Table 2, BA controller setting for 1100ppm is 26.6%; BA controller setting for 1110 ppm is 26.9%. Interpolating for 1102 ppm, BA controller setting for is 26.66% (26.7%). Operator calculates the Corrected Boric Acid Controller Setting from TI-44 Appendix C Table 2 for a value of 26.77% (26.7%)	Critical Step
<u>STEP 10.:</u>	 [7] Calculate Boric Acid Controller Setting [Corrected BA Controller Setting] x [BACR] = [Boric Acid Controller Setting] 	SAT UNSAT
NOTE:	26.66% (26.7%) x 1.0 = 26.66% (26.7%)	
STANDARD:	Operator calculates the Boric Acid Controller Setting.	Critical Step
<u>STEP 11.:</u>	[8] Desired VCT level - Actual VCT level X 20 gal =	SAT
<u>NOTE:</u>	(51% - 41) X 20 gal = 200 gal	UNSAT
<u>STANDARD</u> :	Operator calculates total volume of water to raise VCT level 10% to be 200 gallons.	
		Critical Step

Job Performance	e Checklist: STEP/STANDARD	SAT/UNSAT
<u>STEP 12.:</u>	[9] [Corrected BA Flow Rate] x [BACR] + 70 gpm = [Total Flow Rate]	SAT
NOTE:	13.35 gpm x 1.0 + 70 gpm = 83.35 gpm (~ 83.4 gpm)	UNSAT
<u>STANDARD</u> :	Operator determines total flow rate of ~ 83.4 gpm \pm 1% (82.52-84.18)	Critical Step
<u>STEP 13.:</u>	[Corrected BA Flow Rate) X BACR] ÷ Total Flow Rate X Total Volume Change = BORIC ACID INTEGRATOR SETTING	SAT UNSAT
<u>NOTE</u> :	((13.35 x 1.0) / (83.35)) x 200 = 32.03 gal. Note tolerance in previous step's calculation.	Critical Step
<u>STANDARD</u> :	Operator establishes correct integrator setting as below [13.4 gpm X 1(BACR) ÷ 83.4 gpm] X 200 gal = ~ 32.1 gal	
<u>STEP 14.:</u>	70 GPM (PW) ÷ Total Flow Rate X Total Volume = PRIMARY WATER INTEGRATOR SETTING	SAT UNSAT
<u>NOTE:</u>	The total of this step and the previous step should be ~ the same as the total volume needed to raise level 10% in the VCT. (32.1 gal +167.9 gal. = 200 gal)	Critical Step
<u>NOTE:</u>	Operator may <u>CHECK</u> calculation using INFORMATION ONLY SPREADSHEET.	Stop Time
<u>STANDARD</u> :	Operator establishes correct integrator setting as below [70 gpm ÷ 84.1gpm] X 200 gal = ~ 167.9gal (167.97 using 83.35)	

End of JPM

READ TO OPERATOR

Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- 1. Unit is at 100% full power, steady state.
- 2. Reactor coolant system boron concentration is 1117 ppm and BAT boron concentration is 6820 ppm.
- 3. B-10 depletion value is 15 ppm.
- 4. REACTF software is not available for boron calculations.

INITIATING CUES:

- 1. You are the Unit 1 OATC and are to perform a calculation for a manual blended makeup to the Chemical Volume Control System to increase Volume Control Tank level from 41% to 51%.
- 2. Notify the SRO when the calculation is completed.

SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

RO ADMIN A.2 JPM

Perform Monthly Shift Log 0-SI-OPS-000-003.M

NUCLEAR TRAINING REVISION/USAGE LOG							
REVISION NUMBER	DESCRIPTION OF REVISION	v	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:		
0		Y		All			

V - Specify if the JPM change will require another validation (Y or N). See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT RO/SRO JOB PERFORMANCE MEASURE

Task:

Perform Monthly Shift Log 0-SI-OPS-000-003.M

JA/TA task:

1190090301 (RO)

K/A Ratings:

2.2.12 Knowledge of surveillance procedures. 3.7 / 4.1 (CFR: 41.10 / 45.13) |

Task Standard:

Candidate performs the identified portion of 0-SI-OPS-000-003.M and identifies instruments that do do meet the acceptable range indentified in the instruction.

Evaluation Method :	Simulator <u>X</u>	In-Plant	
Performer:	NAME		Start Time
Performance Rating :	SAT UNSAT	Performance Time	Finish Time
Evaluator:	SIGNATURE	/ DATE	
		COMMENTS	

SPECIAL INSTRUCTIONS TO EVALUATOR:

- 1. Sequenced steps identified by an "s"
- 2. Any <u>UNSAT</u> requires comments
- 3. Place MODE 1 sign on the simulator.
- 4. This task is to be performed using the simulator in IC 178. If not available then reset to 1C-16. perform step 5 below.
- 5. Insert overrides: ZAOPI18C to 845 ZAOPI126C to 830 ZAOPI119C to 805 ZAOFI3163C to 36
 - ZAOFI3147C to 10
- 6. Ensure operator performs the following required actions for **SELF-CHECKING**;
 - a. Identifies the correct unit, train, component, etc.
 - b. Reviews the intended action and expected response.
 - c. Compares the actual response to the expected response.

Validation Time: CR. 20 min Local

Tools/Equipment/Procedures Needed:

1-SI-OPS-000-003.M

References:

	Reference	Title	Rev No.
1.	1-SI-OPS-000-003.M	Monthly Shift Log	0038

READ TO OPERATOR

Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

1. Unit 1 is in service at 100% rated power.

INITIATING CUES:

- 1. You are an RO on shift.
- 2. You are to perform 1-SI-OPS-000-003.M, "Monthly Shift Log", Appendix A pages 1 through 4 in accordance with the requirement of the Surveillance Instruction.
- 3. After completing pages 1 through 4 and complying with the requirements of the instruction, return the surveillance instruction to the Unit Supervisor.

STEP/STANDARD	SAT/UNSAT
STEP 1.: Obtain the appropriate procedure.	Start Time
STANDARD: Operator obtains 1-SI-OPS-000-003.M, "Monthly Shift Log'", Appendix A.	UNSAT
STEP 2.: Turbine Driven AFW Pump Speed Control Light Green	SAT
SK Reference Mode INDE IS Limits Instrument No. Units Data REMAIN Turb. Driven AFW N/A 1.2.3 1.2 N/A 1-HC-48-57 (v) Image: Control Light Green (v) Image: Control Light Green Image: Control Light Green </td <td>UNSAT</td>	UNSAT
STANDARD: Candidate determines green light lit on 1-HC-46-57-S on 1-M-3.	
COMMENTS:	
STEP 3.: Auxiliary Feedwater Valve Mode Indicator Light Blue	SAT
Auxiliary Feedwater N/A 1.2.3 1.3 N/A 1-LCV-3-164 (v) Valve Mode Indicator 1 1.2.3 1.3 N/A 1-LCV-3-164 (v) Light Blue 1 <td< td=""><td>UNSAT</td></td<>	UNSAT

STEP/STANDARD	SAT/UNSAT
STEP 4.: Auxiliary Feedwater Valve Position Indication	SAT
SR Reference Mode Note TS Limits Instrument No. Units Data REMARKS Auxiliary Feedwater 4.33.7.a.11.b 1.2.3 4 OPERABLE 1-LCV-3-150A (1-XX-55-6K) Lit Interpretation Int	UNSAT
<u>COMMENTS:</u>	
STEP 5.: Motor Driven AFW Flowrate	SAT
Motor Driven AFW 4.3.3.5.A.11 1.2.3 5 OPERABLE 1-FI-3-163A (PAM Instrument) gpm Flowrate 4.3.3.7.a.11.a 1.2.3 5 OPERABLE 1-FI-3-165C gpm 1-FI-3-165C gpm 1-FI-3-165C gpm 1-FI-3-147A (PAM Instrument) gpm 1-FI-3-147A (PAM Instrument) gpm 1-FI-3-147C gpm 1-FI-3-147C gpm 1-FI-3-170A (PAM Instrument) gpm 1-FI-3-170A (PAM Instrument) gpm 1-FI-3-170A (PAM Instrument) gpm	Critical Step
⁵ COMPARE Auxiliary Control Room indication to Main Control Room indication for each loop. Acceptable deviation between channels is equal to or less than 25 gpm. With no AFW pumps running, indicated flow should be less than or equal to 30 gpm.	n
STANDARD: Using note 5 at the bottom of page the candidate determines 1-FI-3-1630 does not meet acceptance criteria. Candidate determines the reading from the identified flow instruments. A are '0' to '5' except for 1-FI-3-163C which reads between slightly over 30 gpm and 1-FI-3-147C which reads approximately 15 gpm. COMMENTS:	

STEP/STANDARD								SAT/UNSAT	
STEP 6.: ERCW to AFW Valve Position Indication									SAT
	CD Deferrer	Mada	Nete	TO Lineite	la si su su si bla	11-3-	Data	DEMADIKO	
ERCW to AEW	4 2 2 7 a 19 a	Mode 122	Note		Instrument No.	Units	Data	REMARKS	UNSAT
Valve Position	4.3.3.7.a.16.a	1,2,3	0	OPERABLE	1-HS-3-1168/A	Lit			
Indication				1	1-HS-3-126B/A	Lit			
		1		1	1-HS-3-126A/A	Lit		1 1	
	4.3.3.7.a.18.b	1,2,3	6	OPERABLE	1-HS-3-136B/A	Lit		1 1	
] []	1-HS-3-136A/A	Lit]]	
[] []	1-HS-3-179B/A	Lit]]	
		_			1-HS-3-179A/A	Lit			
<u>STANDAR</u>	<u>STANDARD</u> : Candidate verifies green lights lit above each of the listed handswitches located on 1-M-3.								
STEP 7.: C	ontainmen	1.2,3	ation	Valve P	XX-55-8K (Cont vent, Phase A, Phase B, Manual)				SAT UNSAT
		100	_	00504045	TRAIN A				
		1,2,3	/	OPERABLE	(Comt vent, Phase A, Phase B, Manual) TRAIN B	(v)			
				1	Operate	or's Initials			
 ⁷ VERIFY Containment Isolation Valve Position Indicators are operable by performing a Lamp Test of panels XX-55-6K and 8L. Both bulbs for each position indicator should illuminate when tested. <u>STANDARD</u>: Candidate pushes TEST pushbuttons on both 1-XX-55-6K (white push button) and 1-XX-55-6L 6K (red push button) control panels and verifies both bulbs(red and green) for each position indicator illuminate in accordance with note 7 at bottom of page. <u>COMMENTS:</u> 									

SAT/UNSAT

STEP/STANDARD

<u>STEP 8.</u> : Ma	ain Steam L	ine P	ressu	re				SAT
	SR Reference	Mode	Note	TS Limits	Instrument No.	Units Data	REMARKS	LINGAT
Main Steam Line	4.3.3.5.A.6	1.2.3	8		1-PI-1-1C	PSIG		
Pressure	4.3.3.7.a.8	1		OPERABLE	1-PI-1-2A (PAM Instrument)	PISG		
		1		t i i i i i i i i i i i i i i i i i i i	1-PI-1-2B (PAM Instrument)	PSIG		Critical
·		1			1-PI-1-8C	PSIG		Official
r i		1		OPERABLE	1-PI-1-9A (PAM Instrument)	PSIG		Step
r		1			1-PI-1-9B (PAM Instrument)	PSIG		•
		1			1-PI-1-19C	PSIG		
r		1		OPERABLE	1-PI-1-20A (PAM Instrument)	PSIG		
ľ		1		ł	1-PI-1-20B (PAM Instrument)	PSIG		
ľ		1			1-PI-1-28C	PSIG		
		1		OPERABLE	1-PI-1-27A (PAM Instrument)	PSIG		
r		1		ł	1-PI-1-27B (PAM Instrument)	PSIG		
		-			Operator's	s Initials:		
<u>STANDARD</u>	<u>e</u> : Using no does not Candidat Aux Con instrume difference	Acceptate Gri 1-P 1-P te 8 at meet : trol Ro nts (1- e (only	he deviation oup 1 I-1-1C I-1-2A I-1-2B the b acceptor ormine toom in: PI-1-22 7 53 ps	Group 2 1-PI-1-8C 1-PI-1-9A 1-PI-1-9B ottom of p tance critic s the reador strument 20A & 1-P sig is allow	Group 3 Group 1-PI-1-19C 1-PI-1-2 1-PI-1-20A 1-PI-1-2 Dage the candidate eria. ding from the identif 1-PI-1-19C reads 8 I-20B) read 880 psi wed for acceptance	determines ied flow ins 10 psig and g for a 70 p criteria.)	s 1-PI-1-19C struments. d the MCR osig	
<u>STEP 9.</u> : PL da wi N/	ACE initials ta listed in t th acceptan A).	s in the he colu ce crite	e lowe umn is eria or	r block of complete has a DN	the column in appe e, satisfies specified Nassigned. (mark n	ndix A to si d NOTES, a ion - applica	ignify that all and complies able steps	SAT UNSAT Critical
STANDARD	: Candidat Steam Li deviation <u>S:</u>	e iden ne Pre range	tifies t essure es.	he Motor instrume	Driven AFW Flow For Flow Flow Flow Flow Flow Flow Flow Flow	Rate and th the accept	e the Main table	Step

SAT/UNSAT
SAT
UNSAT
Oton Time
Stop Time

END of JPM

CANDIDATE CUE SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

DIRECTION TO TRAINEE:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

1. Unit 1 is in service at 100% rated power.

INITIATING CUES:

- 1. You are an RO on shift.
- 2. You are to perform 1-SI-OPS-000-003.M, "Monthly Shift Log", Appendix A pages 1 through 4 in accordance with the requirement of the Surveillance Instruction.
- 3. After completing pages 1 through 4 and complying with the requirements of the instruction, return the surveillance instruction to the Unit Supervisor.

SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

ADMIN RO A-3 JPM

(#180)

2A RHR Heat Exchanger Radiological Work Permit and Survey Map Usage

NUCLEAR TRAINING REVISION/USAGE LOG								
REVISION NUMBER	DESCRIPTION OF REVISION	v	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:			
0								

V - Specify if the JPM change will require another Validation (Y or N). See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT RO/SRO JOB PERFORMANCE MEASURE

Task:

2A RHR Heat Exchanger Radiological Work Permit and Survey Map Usage

Task Number	Task Title	Cont TRN
1190100301	Apply radiation and contamination safety procedures	Ν
3430290302	Knowledge of 10CFR20 and related facility radiation control requirements	Ν

K/A Rating:

2.3.7 Ability to comply with radiation work permit requirements during normal or abnormal conditions. 3.5 / 3.6

Task Standard: Using the RWP and Survey Map provided: the trainee will determine the anti-contamination clothing and dosimetry requirements also dose and dose rate alarm limits.

Evaluation Method :	SimulatorX	In-Plant		
======================================	NAME			Start time
Performance Rating :	SAT UNSAT	Performance Tin	ne	Finish time
Evaluator:	SIGNATURE	/ DATE		
		COMMENTS		

SPECIAL INSTRUCTIONS TO EVALUATOR:

- 1. A **Critical step** is identified bold type in the SAT/UNSAT column.
- 2. Sequenced steps identified by an "s".
- 3. Any <u>UNSAT</u> requires comments.
- 4. Task should begin at the Plant, Classroom, or Simulator.
- 5. Insure operator performs the following required actions for SELF-CHECKING;
 - a. Identifies the correct unit, train, component, etc.
 - b. Reviews the intended action and expected response.
 - c. Compares the actual response to the expected response.

Validation Time: CR 16 min Local _____

Tools/Equipment/Procedures Needed:

RWP 08000003 & Survey #051508-10

REFERENCES:

	Reference	Title	Rev No.
1	Permit Number 08000003	Radiological Work Permit	0
2	Survey #051508-10	Map: A414 RHR & Containment Spray Heat	5/15/08
		Exchanger ZA-A	

READ TO OPERATOR

Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. I will provide initiating cues and reports on other actions when directed by you. All steps shall be simulated for this task. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- 1. Both Units are operating at 100% power.
- 2. System alignment and inspection will result in you being in the 2A-A RHR and Containment Spray Heat Exchanger Room for 3 hours.

INITIATING CUES:

You are to use the supplied RWP and survey Map to determine the following:

- 1. Anti-contamination clothing requirements to enter the Contamination Area between the heat exchangers on the top elevation.
- 2. Which of the electronic dosimeter alarms would alarm if an individual was exposed to the General Area Dose Rate near the lead shielded line on the lower elevation for the entire time spent in the room.
- 3. How often an individual is required to be briefed on the requirements of the RWP.

STEP/STANDARD

SAT/UNSAT

<u>STEP 1</u> :	Anti-contamination clothing requirements to enter the Contamination Area between the heat exchangers on the top elevation.	SAT UNSAT
<u>STANDARD</u>	: On the RWP in the Anti-Contamination Clothing Requirements Matrix list every item that has a 2 in its block.	Critical Step
	The list will include: Rubber, One Pair; Lab Coat; Surgeon's Cap; Secure Gloves/Booties; Cloth Inserts; Booties, Cloth, One Pair; Shoe Covers, One Pair;	
<u>STEP 2</u> :	Which of the electronic dosimeter alarms would alarm if an individual was exposed to the General Area Dose Rate near the lead shielded line on the lower elevation for the entire time spent in the room.	SAT UNSAT Critical Step
<u>STANDARD</u>	: Candidate identifies that the "Dose Alarm" would alarm. 20mr/hr X 3hr = 60mr which is greater than the dose alarm setpoint of 50mr.	
<u>STEP 3</u> :	How often an individual is required to be briefed on the requirements of the RWP.	SAT UNSAT
<u>STANDARD</u>	: Candidate identifies a briefing is required quarterly.	Critical Step

End Of JPM

Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. I will provide initiating cues and reports on other actions when directed by you. All steps shall be simulated for this task. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- 1. Both Units are operating at 100% power.
- 2. System alignment and inspection will result in you being in the 2A-A RHR and Containment Spray Heat Exchanger Room for 3 hours.

INITIATING CUES:

You are to use the supplied RWP and survey Map to determine the following:

- 1. Anti-contamination clothing requirements to enter the Contamination Area between the heat exchangers on the top elevation.
- 2. Which of the electronic dosimeter alarms would alarm if an individual was exposed to the General Area Dose Rate near the lead shielded line on the lower elevation for the entire time spent in the room.
- 3. How often an individual is required to be briefed on the requirements of the RWP.

K:\SCANDOCS\OPERATOR LICENSING\BALDWIN\SEQUOYAH DRAFT MATERIAL\ADMIN JPMS\SEQUOYAH 2009-301 ADMIN JPM REVIEW SPREAD SHEET.DOC Sequoyah 2009-301 Admin JPM

		APPENDIX E - REGION II OPERATING TEST JOB PERFORMANCE MEASURE QUALITY REVIEW MATRIX										
Admin	1. Safety	2. Dyn	3. LOD	4. Attributes				5. Job Content Errors		6. U/E/S	7. Explanation	
	Tunction	(D/S)	(1-5)	IC Focus	Cues	Critical Steps	Scope (N/B)	Over- lap	Job- Link	Minutia		
COO 1 RO/SRO												No Comments.
COO 2 RO/SRO												Step #12 – \pm 1% acceptable range is too wide. This would allow applicants that incorrectly applied the B-10 Depletion correction to achieve satisfactory results (i.e. 13.58 gpm + 70 gpm = 83.58 gpm). For this critical step, suggest \pm 0.1 gpm range. Carry adjusted acceptable range forward throughout the calculations.
EC 3 RO Only												Step #8 – Revise the standard from "the identified flow instruments." to "the identified pressure instruments."
EC 3 SRO Only												 Initiating Cue – Reword second paragraph from current run-on sentence. See below You are to determine the adequacy of the SDM calculation performed by Reactor Engineering based on the following assumptions: A low Tavg of 530°F over the next 24 hours No change in boron concentration
RC 4 RO Only												No comments.
RC 4 SRO Only												 General Comments – 1) Other than step 1, I couldn't find in the references supplied to the applicant the information that would lead to the determinations expected in the standards for steps 2 and 3 of this JPM. 2) The initial conditions state that 0-RM-90-118A is inoperable. However, the supplied references only address the operability of 0-RM-90-118. Are these the same instruments or is it a typo in the initial conditions?
E Plan 5 SRO Only												No comments.

Instructions for Completing Matrix

This form is not contained in or required by NUREG-1021. Utilities are not required or encouraged to use it. The purpose of this form is to enhance regional consistency in reviewing operating tests. Check or mark any item(s) requiring comment and explain the issue in the space provided.

- 1. Safety function characteristics: RO & SRO-I JPMs should evaluate different safety functions for the simulator/control room, and spearately for the in-plant JPMs. SRO-Us should evaluate 5 different safety functions. One SRO-U should evaluate an engineered safety feature. At least one should be shutdown or low power, 4-6 should be alternate path for the RO/SRO-I and 2-5 for the SRO-Us.
- 2. Determine whether the task is dynamic (D) or static (S). A dynamic task is one that involves continuous monitoring and response to varying parameters. A static task is basically an system reconfiguration or realignmen
- 3. Determine level of difficulty (LOD) using established 1-5 rating scale. Levels 1 and 5 represent inappropriate (low or high) discriminatory level for the license being tested.
- 4. Check the appropriate box when an attribute weakness is identified:

- The initiating cue is not sufficiently clear to ensure the operator understands the task and how to begin.
- The JPM does not contain sufficient cues that are objective (not leading).
- All critical steps (elements) have not been properly identified.
- Scope of the task is either too narrow (N) or too broad (B).
- Excessive overlap with other part of operating test or written examination.
- Check the appropriate box when a job content error is identified:
- Topics not linked to job content (e.g., disguised task, not required in real job).
 - Task is trivial and without safety significance.

5.

- 6. Based on the reviewer's judgment, is the JPM as written (U)nacceptable (requiring repair or replacement), in need of (E)ditorial enhancement, or (S)satisfactory?
- 7. Provide a brief description of problem in the explanation column. Provide conclusion on whether JPM <u>SET</u> criteria satisfied (i.e., number/distribution of safety functions, A.3 and A.4 integrated with parts B/C, Admin topics per section meet ES).
- 1. Should attempt to have 5 ALT PATH JPMs to add flexibility to prep week and the exam.

SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

ADMIN SRO A-2 JPM

JPM 175-AP

Review SDM Calculation - Incorrect Tavg

NUCLEAR TRAINING REVISION/USAGE LOG							
REVISION NUMBER	DESCRIPTION OF REVISION	v	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:		
0		Y					

V - Specify if the JPM change will require another Validation (Y or N). See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT RO/SRO JOB PERFORMANCE MEASURE

Task Review shutdown margin calculations Perform/Verify shutdown margin calculations using REACTINF **JA/TA task #** 0010040101 (RO) 0010040102 (SRO)

K/A Ratings:

001A4.11 (3.5/4.1)

Task Standard:

Review Shutdown Margin Calculation and Identify Incorrect Tavg Parameter Entry.

Evaluation Method : Simulator ____X___ In-Plant _____

Performer:			
	NAME		Start time
Performance Ra	ating:SAT UNSAT	Performance Time	Finish time
Evaluator:	/SIGNATURE	DATE	

COMMENTS

SPECIAL INSTRUCTIONS TO EVALUATOR:

- 1. A **Critical step** is identified in bold type in the SAT/UNSAT column.
- 2. Sequenced steps identified by an "s"
- 3. Any <u>UNSAT</u> requires comments
- 4. Task should begin at the at any location.
- 5. Insure operator performs the following required actions for **SELF-CHECKING**;
 - a. Identifies the correct unit, train, component, etc.
 - b. Reviews the intended action and expected response.
 - c. Compares the actual response to the expected response.

Validation Time: CR 16

Tools/Equipment/Procedures Needed:

Appendix A of this JPM. NOTE: ENSURE JPM NUMBER IS NOT LEGIBLE ON COPY PROVIDED TO PERFORMER.

REFERENCES:

	Reference	Title	Rev No.
Α.	0-SI-NUC-000-038.0	Shutdown Margin	54

Task Number	Task Title	Cont TRN
0010040101	Review shutdown margin calculations	Y
0010040102	Perform/Verify shutdown margin calculations using REACTINF	Y

READ TO OPERATOR

Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. I will provide initiating cues and reports on other actions when directed by you. All steps shall be **Performed** for this task When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

Unit 1 Tripped 48 Hours ago on 01-20-09 at 0700 after a 60 day continuous run at 100% steady state power. All shutdown and control rods fully inserted on the trip.

The unit is being maintained in mode 3 at Approx. 547°F Tavg until repairs are completed when the Unit will be started back up.

The Duty Reactor Engineer has performed a Shutdown Margin (SDM) Calculation using the QA Certified Software program ReactINF.

Current Conditions are:

UNIT 1 Cycle 16 Burnup: 5750 MWD/MTU Current Boron Concentration: 1250 ppm Current M-P Factor: 0 ppm Date/Time: 01/22/09 / 0700

INITIATING CUES:

You are the Unit 1 Unit Supervisor.

You to Review the SDM Calculation performed by Reactor Engineering to ensure that SDM is adequate assuming a conservatively low Tavg of 530°F anytime during the next 24 hours and no boron concentration changes.

After you have reviewed the SDM calculation, determine if the SDM calculation by the Reactor Engineer is correct and meets the requirements for the conditions established for the calculation.

STEP/STANDARD

SAT/UNSAT

-1

<u>STEP :</u>	Obtains Copy of SDM Calculation.	SAT
<u>NOTE</u> :	ENSURE JPM NUMBER IS NOT LEGIBLE ON COPY PROVIDED TO PERFORMER.	UNSAT
STANDARD:	Operator obtains Copy of Appendix A SDM Calculation from Evaluator.	Start Time
<u>STEP</u> :	Operator Reviews the following Parameters on the SDM calculation in any order: Correct Unit and Cycle: Sequoyah Unit 1 Cycle 16 Previous Conditions: Xanon Conc 100% EP EO	SAT UNSAT
	Date and Time Unit Was Shutdown: 01/20/09 / 0700 Current Date and Time: 01/22/09 / 0700 Mode for SDM: 3 Minimum Expected Core Avg Temp (Tavg): 547°F (Critical - Should be 530°F) Time Since Shutdown: 48 Hours	Critical Step
	Reactor Power Prior to Shutdown: 100% Core Avg Burnup: 5750 MWD/MTU Current/Projected Boron Conc: 1250 ppm Correction to Boron Conc (M-P): 0 ppm Rx Conditions Prior to Shutdown: Steady State Surveillance Interval: 24 Hours Number of Immovable or Untrippable Rods: 0	
<u>STANDARD</u> :	Operator Reviews all parameters and notes that Min Expected Tavg (547°F) is not consistent with the Unit Supervisors SDM requirements of 530°F.	Stop Time

End Of JPM

READ TO OPERATOR

Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. I will provide initiating cues and reports on other actions when directed by you. All steps shall be **Performed** for this task When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

Unit 1 Tripped 48 Hours ago on 01-20-09 at 0700 after a 60 day continuous run at 100% steady state power. All shutdown and control rods fully inserted on the trip.

The unit is being maintained in mode 3 at Approx. 547°F Tavg until repairs are completed when the Unit will be started back up.

The Duty Reactor Engineer has performed a Shutdown Margin (SDM) Calculation using the QA Certified Software program ReactINF.

Current Conditions are:

UNIT 1 Cycle 16 Burnup: 5750 MWD/MTU Current Boron Concentration: 1250 ppm Current M-P Factor: 0 ppm Date/Time: 01/22/09 / 0700

INITIATING CUES:

You are the Unit 1 Unit Supervisor.

You to Review the SDM Calculation performed by Reactor Engineering to ensure that SDM is adequate assuming a conservatively low Tavg of 530°F anytime during the next 24 hours and no boron concentration changes.

After you have reviewed the SDM calculation, determine if the SDM calculation by the Reactor Engineer is correct and meets the requirements for the conditions established for the calculation.

SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

ADMIN SRO A.3 JPM

Approval of a Waste Gas Tank Release

NUCLEAR TRAINING REVISION/USAGE LOG							
REVISION NUMBER	DESCRIPTION OF REVISION	v	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:		
0	New	Y		All			

V - Specify if the JPM change will require another validation (Y or N). See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT RO/SRO JOB PERFORMANCE MEASURE

Task:

Approval of a Waste Gas Tank Release

JA/TA task:

5030010102 (SRO) 0690150102 (SRO)

K/A Ratings:

2.3.11 Ability to Approve Release Permits. (CFR: 41.13 / 45.4 / 45.10) 2.0 / 3.8

Task Standard:

Candidate identifies ...

- (1) the US/SRO must approve the release if the tank if the release is to be made at 2300.
- (2) the required actions to allow a release with 0-RM-90-118A out of service as identified in ODCM 1/21.2.
- (3) the required action if it takes 40 days to get parts to restore the monitor to Operable status.

valuation Method :	Simulator <u>X</u>	In-Plant	
Performer:	NAME		Start Time
Performance Rating :	SAT UNSAT	Performance Time	Finish Time
Evaluator:	SIGNATURE	/ DATE	
		COMMENTS	

SPECIAL INSTRUCTIONS TO EVALUATOR:

- 1. Any <u>UNSAT</u> requires comments
- 2. This task can be performed in a classroom setting.

Validation Time: CR. 24 min Local _____

Tools/Equipment/Procedures Needed:

OPDP-1, Conduct of Operations

References:

	Reference	Title	Rev No.
1.	SQN ODCM	Offsite Dose Calculation Manual	53
2.	0-SI-CEM-077-410.4	Waste Gas Decay Tank Release	0014
3.	0-SI-77-15	Waste Gas Decay Tank Release	15

READ TO OPERATOR

Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- The operating crew is preparing to release the Waste Gas Tank 'D'.
- 0-RM-90-118A, Waste Gas Radiation Monitor, is inoperable.
- The monthly projected offsite dose limits have not been exceeded.

INITIATING CUES:

You are to identify...

- (1) Who must approve the release if the tank is to be released on the night shift at 2300.
- (2) The required actions to allow a release with 0-RM-90-118A out of service.
- (3) The required action if it takes 40 days to get parts to restore the monitor to Operable status.

STEP/STANDARD	SAT/UNSAT
STEP 1.: Identify who must approve the release if the tank is to be released on the night shift at 2300.	Start Time
<u>STANDARD</u> : Candidate identifies the approval of the US/SRO is required.	SAT UNSAT Critical Step
STEP 2.: The required actions to allow a release with 0-RM-90-118A out of service.	SAT UNSAT
 STANDARD: Candidate identifies the ODCM 1/2/1/2 required Action 40 With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, the contents of the tank(s) may be released to the environment provided that prior to initiating the release: a. At least two independent samples of the tank's contents obtained by two technically qualified members of the facility staff are analyzed, and b. At least two technically qualified members of the Facility Staff independently verify the release rate calculations and; c. At least two technically qualified members of the Facility Staff independently verify the discharge valve lineup. Otherwise, suspend release of radioactive effluents via this pathway. 	Critical Step
COMMENTS:	
STEP 3.: The required action if it takes 40 days to get parts to restore the monitor to Operable status.	SAT UNSAT
STANDARD: Candidate identifes that if the inoperable instruments cannot be restored to OPERABLE status within 30 days, the next Annual Radioactive Effluent Report, pursuant to ODCM Administrative Control 5.2, is to explain why the inoperability could not be corrected within 30 days.	Step
COMMENTS:	

STEP/STANDARD

SAT/UNSAT

CANDIDATE CUE SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

READ TO OPERATOR

Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS:

- The operating crew is preparing to release the Waste Gas Tank 'D'.
- 0-RM-90-118A, Waste Gas Radiation Monitor, is inoperable.
- The monthly projected offsite dose limits have not been exceeded.

INITIATING CUES:

You are to identify...

- (1) Who must approve the release if the tank is to be released on the night shift at 2300.
- (2) The required actions to allow a release with 0-RM-90-118A out of service.
- (3) The required action if it takes 40 days to get parts to restore the monitor to Operable status.

SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

ADMIN SRO –A-4 JPM18

Classify the Event per the REP (Primary System Leakage with Potential Loss of Cntmt)

NUCLEAR TRAINING

REVISION/USAGE LOG

REVISION	DESCRIPTION OF	v	DATE	PAGES	PREPARED/
NUMBER	REVISION	N	11/22/00	AFFECTED	REVISED BY:
1	a critical steps. They do not meet the definition of critical step in TRN-11.12.		11/23/99	All	SK TAYIOI
pen/ink	EPIP-1 Rev Change only	Ν	3/21/00	4	SR Taylor
8	EPIP-4 revision	Y	9/5/00	All	J P Kearney
pen/ink	EPIP-1 and 4 Rev Change only	Ν	12/21/00	4	W. R. Ramsey
pen/ink	EPIP-1 and 4 Rev Change only	Ν	07/31/01	4	W. R. Ramsey
pen/ink	Minor clarifications for to be consistent with other REP JPMs.	N	12/27/01	All	L. Pauley
9	Incorporated pen/ink changes; revised to recent EPIP changes; no impact on JPM flow	N	8/16/02	4,7,8,9	J P Kearney
10	Incorporated changes to EPIP-1 and 4	Y	9/9/03	All	G S Poteet
12	Incorporated changes in EPIP-1 and 4.	Y	10/07/05	All	JJ Tricoglou
13	Incorporated changes in EPIP-1 and 4. Add EAL 1.3.2 L as possible barrier loss. Several minor chgs based on proced chgs. Add non action step at ODS notification step to address EPS failure. Split NRC notification step into 2 steps. Added "should be made in 5 min" to ODS std	Ν	8/18/08	All	H J Birch

V - Specify if the JPM change will require another Validation (Y or N). See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT SRO JOB PERFORMANCE MEASURE

Task:

Classify the Event per the REP (Primary System Leakage with Leakage Outside Cntmt)

JA/TA task #: 3440030302 3440190302	(SRO) (SRO)	
K/A Ratings: 2.4.29 (2.6/4.0) 2.4.30 (2.2/3.6) 2.4.37 (2.0/3.5)	2.4.38 (2.2/4.0) 2.4.40 (2.3/4.0) 2.4.41 (2.3/4.1)	
Task Standard: The event is classified a pump with Leakage Out	as an SAE based on Primary System Leak tside Cntmt. All notifications are made per	age exceeding capacity of one charging the EPIP.
Evaluation Method : Simulat * This J	or <u>X</u> In-Plant PM will be simulated	
Performer:	NAME	Start Time
Performance Rating: SAT	UNSAT Performance Time _	Finish Time
Evaluator:	/ SIGNATURE DATE	
	COMMENTS	

SPECIAL INSTRUCTIONS TO EVALUATOR:

- 1. Sequenced steps identified by an "s"
- 2. Any UNSAT requires comments
- 3. Initialize the simulator in IC-10 and leave in FREEZE.
- 4. Insure operator performs the following required actions for **SELF-CHECKING**;
 - a. Identifies the correct unit, train, component, etc.
 - b. Reviews the intended action and expected response.
 - c. Compares the actual response to the expected response.

5. Caution: DO NOT LET THE EXAMINEE FAX THE NOTIFICATION FORM

Validation Time: CR. 19 mins Local

Tools/Equipment/Procedures Needed:

EPIP-1 and EPIP-4

References:

	Reference	Title	Rev No.
Α.	EPIP-1	Emergency Plan Initiating Conditions Matrix	40
В.	EPIP-4	Site Area Emergency	30

READ TO OPERATOR

Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All steps of this JPM shall be simulated. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

The simulator is NOT representative of the scenario you are about to address.

INITIAL CONDITIONS:

- 1. Unit 1 was operating at 100% (BOL) when indications of a primary system leak developed.
- 2. AOP-R.05, "RCS Leak and Source Identification" has been implemented; a second CCP was started due to decreasing Pressurizer level.
- 3. The operators are attempting to identify the source of the leak.
- 4. Unit 2 is in MODE 6 with refueling operations in progress (core being unloaded).

INITIATING CUES:

- 1. The US has informed you, the SED, of the leak.
- 2. The operators have not identified the leak source but, AOP-R.05 is in progress at this time.
- 3. Using the following parameters provided to you by the control room operating crew, classify the event according to the EPIPs and perform any required actions.
 - PZR level is 58% and stable.
 - Charging flow is 140 gpm.
 - Letdown flow is 0 gpm.
 - Cntmt. pressure is +0.2 psid and steady.
 - Cntmt. radiation (RM-90-106 & 112) has not changed since the event began.
 - RHR Pipe Break White Lights have just illuminated.
 - RM-90-101B is increasing.
 - Several Area Rad Monitors on El 669 and 690 are in Hi Rad.

Elements of this JPM are time critical

Job Performance Checklist:

STEP/STANDARD

SAT/UNSAT

<u>STEP 1.</u> :	Refers to EPIP-1 to determine level of event.	SAT
<u>NOTE</u> :	The leak rate is ~128 gpm (140 - 12 gpm RCP seal leakoff).	UNSAT
<u>NOTE:</u>	If the Operator declares an NOUE and enters EPIP-2 based on 2.5 "RCS leakage greater than 10 gpm" then the critical step is not satisfied.	Critical Step
<u>STANDARD</u> :	Operator refers to EPIP-1, Section 1, Fission Product Barrier Matrix. Operator determines that they have met the conditions for SITE AREA EMERGENCY based on EAL 1.2.2 Potential LOSS (RCS Leakage/LOCA) AND EAL 1.3.4 Potential LOSS (Containment Bypass) [OR EAL 1.3.2 LOSS (Cntmt Normal w/ LOCA.)]	Task Start Time
<u>STEP 2.</u> :	Implements EPIP-4 SITE AREA EMERGENCY.	SAT
	Enter time Declaration made	UNSAT
	Time from Task Start Time to Declaration:	
<u>STANDARD</u> :	Operator implements an SITE AREA EMERGENCY utilizing EPIP-4, Section 3.1. Operator should classify the event within 15 minutes of the time the task was accepted. Declaration Time should be consistent with the time the examinee transitions from EPIP-1 to EPIP-4.	
<u>STEP 3.:</u>	IF TSC is OPERATIONAL, (SED ttransferred to TSC), THEN	SAT
<u>CUE:</u>	TSC is not manned at this time. You are the SED.	UNSAT
STANDARD:	Operator N/As the step and continues with the procedure	
<u>STEP 4.</u> :	RECORD time of Declaration.	SAT
<u>STANDARD</u> :	Operator writes time of Declaration and continues	UNSAT

	STEP/STANDARD	SAT/UNSAT
<u>STEP 5.</u> :	Activate Emergency Paging System (EPS).	SAT
<u>Cue:</u>	If operator asks if EPS has already been activated, respond that the "EPS has not been activated."	UNSAT
	If Operator asks if Security Events are in progress, respond that "There are no security events in progress."	Critical Step
	If Operator asks if any ongoing events make site access dangerous to the life and health of emergency responders, respond that "There are no ongoing events that make site access dangerous to the life and health of emergency responders.	
<u>STANDARD</u> :	Operator utilizes "Touch Screen" to activate the EPS.	
STEP 6.:	Complete Appendix B, TVAN Initial Notification for Site Area Emergency.	SAT UNSAT
<u>STANDARD</u>	 Operator completes the Appendix using information from turnover sheet and EPIP-1. 	
STEP 7.	IF EPS failed to activate from SQN THEN DIRECT ODS to activate SQN EPS	SAT UNSAT
STANDARD	: Operator will N/A this step and the next step since EPS did not fail	

	STEP/STANDARD	SAT/UNSAT
STEP 8.	READ completed Appendix B to ODS.	SAT
<u>NOTE</u> :	Enter time call is made to the ODS	UNSAT
	Time from Declaration (step 2) to ODS Notification:	Critical Step
	 a. This is a Drill b. Their name, Shift Manager at SQN Plant. c. SAE declared on UNIT 1 d. EAL No. Potential LOSS 1.2.2 and Potential LOSS 1.3.4 [Also accept LOSS 1.3.2] e. Brief description of incident: [Leak exceeding one CCP capacity AND Unexpected VALID increase in Area or Vent Rad Monitors OR Cntmt Normal w/ LOCA] f. Radiological Conditions [Minor releases within federally approved limits g. Event Declared: [Time and Date] h. Protective Action Recommendation: [NONE] i. Ask the ODS to repeat the information he has received to ensure accuracy. j. Fax information to ODS 	
Cue:	Role play as the ODS and acknowledge report.	
<u>STANDARD</u> :	Operator should notify the ODS within 5 minutes after declaration is made giving the above information from Appendix B. ODS Shall be notified in 10 minutes.	
<u>STEP 9.</u> :	FAX Notification Form to the ODS.	SAT
<u>Cue</u> :	The support AUO will send the FAX for you.	UNSAT
Caution:	DO NOT LET THE EXAMINEE FAX THE FORM	
STANDARD:	Operator addresses Faxing the Notification Form to the ODS.	
STEP 10.: complete.	Monitor for confirmation call from ODS that State/Local notifications are	
<u>Cue</u> :	The support AUO will monitor for confirmation call.	
<u>STANDARD</u> :	Operator addresses monitoring for the call.	

	STEP/STANDARD	SAT/UNSAT
<u>STEP 11.:</u>	IF ODS CANNOT be contacted within 10 minutes of declaration	SAT
STANDARD	: Operator N/As this step and continues.	UNSAT
<u>STEP 12.:</u>	ENSURE MSS/WWM in the OSC (X6428) is monitoring Emergnecy Response Organization (ERO) responses.	SAT UNSAT
<u>Cue</u> :	Role play as person directed and report all positions responded.	
<u>STANDARD</u>	Operator monitors responses by using touch screen or directs another person to do this task.	
<u>STEP 13.:</u>	PERFORM Appendix A, Notifiations and Announcements.	
<u>CUE:</u>	If Operator attempts to delegate the assignment, inform them that no one is available to delegate this function.	
The following s	teps are from Appendix A of EPIP-4.	
<u>STEP 14.</u> :	IF there has been a security threat THEN, NOTIFY Security Shift Supervisor to IMPLEMENT SSI-1.	SAT
<u>Cue</u> :	There have been no reports of a security threat.	
<u>STANDARD</u> :	Operator should N/A this step.	
<u>STEP 15.:</u>	NOTIFY Radiation Protection: STATE: "A SITE AREA EMERGENCY	SAT
	CAPACITY AND UNEXPECTED VALID INCREASE IN AREA OR VENT RAD MONITORS [OR Cntmt Normal w/ LOCA], AFFECTING UNIT 1".	UNSAT
<u>Cue:</u>	Acknowledge the report.	
<u>STANDARD</u> :	Operator makes the notification and directs Radcon to implement EPIP- 14 AND CECC EPIP-9.	

	STEP/STANDARD	SAT/UNSAT
<u>STEP 16.</u> :	NOTIFY personnel in the Chemistry Lab: STATE "A SITE AREA EMERGENCY HAS BEEN DECLARED BASED ON LEAK EXCEEDING ONE CCP CAPACITY AND UNEXPECTED VALID INCREASE IN AREA OR VENT RAD MONITORS [OR Cntmt Normal w/ LOCA], AFFECTING UNIT 1".	SAT UNSAT
<u>Cue:</u>	Acknowledge the report.	
<u>STANDARD</u> :	Operator makes the notification and directs Chemistry to implement EPIP-14.	
<u>STEP 17.</u> :	Announce to plant personnel on the old Plant PA and x4800:	SAT
	"ATTENTION PLANT PERSONNEL. ATTENTION PLANT PERSONNEL. A SITE AREA EMERGENCY HAS BEEN DECLARED BASED ON Potential LOSS (RCS LEAKAGE/LOCA) AND POTENTIAL LOSS (CONTAINMENT BYPASS) [OR Cntmt Normal w/ LOCA]. AFFECTING UNIT 1. ALL TSC AND OSC PERSONNEL REPORT TO THE EMERGENCY FACILITIES IMMEDIATELY." Repeat the announcement.	UNSAT
STANDARD:	Operator makes the PA announcements.	
<u>STEP 18.</u> :	Notify the Plant Management in accordance with SPP-3.5.	SAT
<u>NOTE</u> :	Activation of the EPS will make the Plant Management aware of the REP actuation, however administrative procedures require notification.	UNSAT
<u>Cue:</u>	Acknowledge the report as: Plant Manager Senior Vice President (SVP), Nuclear Operations Duty Plant Manager 	
<u>STANDARD</u> :	Operator contacts Plant Management and informs him of the REP classification and provides SAE information (Appendix B)	
<u>STEP 19.</u> :	Notify the "On Call" resident inspector and NRC via ENS in accordance with SPP-3.5.	SAT
<u>Cue:</u>	As the NRC, acknowledge the report.	Critical Stop
<u>STANDARD</u> :	Operator should notify the NRC (headquarters) as soon as practicable, but within 1 Hr. of declaration of the event. Operator provides SAE information (Appendix B)	

	STEP/STANDARD	SAT/UNSAT
<u>STEP 20.</u> :	Notify the NRC of plan activation via ENS phone.	SAT
<u>Cue:</u>	As the NRC, acknowledge the report.	UNSAT
<u>STANDARD</u> :	Operator should notify the NRC (headquarters) as soon as practicable, but within 1 Hr. of declaration of the event. Operator provides SAE information (Appendix B).	Time Critical Step Time of Notification:
The following s	teps are from Section 3.3, MONITOR CONDITIONS OF EPIP-4.	
<u>STEP 21.</u> :	MONITOR radiation monitors. When indication of an unplanned radiological release, Then ENSURE Dose Assessment is performed.	SAT UNSAT
<u>Cue</u> :	Per initiating cues, RM 101B is increasing. When examinee uses ICS or RM indication to determine effluent radiation levels per Tables 7-1and 7-2 of EPIP-1, cue the operator: 0-RM-90-101B: ~ 7.9E+4 cpm 1-RM-90-400: ~ 4E+4 μCi/s 0-RM-90-400: ~ 1E+3 mr/hr All other RM reading ~ normal Field Surveys are in progress	Critical Step
<u>STANDARD</u> :	Operator directs Radiation Protection to perform a dose assessment per EPIP-13, provides type of event, release path, and expected duration. The event type is a LOCA outside containment, release path through the AB stack.	
<u>STEP 22.</u> :	If personnel accountability has not been previously initiated, THEN Activate assembly & accountability using EPIP-8, Appendix C.	SAT
<u>Cue</u> :	The U2 CRO will perform EPIP-8 Appendix C or Role play as Security Shift Supervisor and acknowledge.	Critical Step
<u>STANDARD</u> :	1. Operator addresses EPIP-8, Appendix C.	
<u>STEP 23.</u> :	MONITOR plant conditions AND EVALUATE using EPIP-1	SAT
<u>Cue</u> :	<i>If operator begins Monitoring plant conditions, THEN tell him "The TSC is staffed and will COMPLETE SAE follow-up Form".</i>	Stop Time
STANDARD	2 Operator addresses completing SAE follow-up Form.	

STEP/STANDARD End of JPM SAT/UNSAT

CANDIDATE CUE SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All steps of this JPM shall be simulated. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

The simulator is NOT representative of the scenario you are about to address.

INITIAL CONDITIONS:

- 1. Unit 1 was operating at 100% (BOL) when indications of a primary system leak developed.
- 2. AOP-R.05, "RCS Leak and Source Identification" has been implemented; a second CCP was started due to decreasing Pressurizer level.
- 3. The operators are attempting to identify the source of the leak.
- 4. Unit 2 is in MODE 6 with refueling operations in progress (core being unloaded).

INITIATING CUES:

- 1. The US has informed you, the SED, of the leak.
- 2. The operators have not identified the leak source but, AOP-R.05 is in progress at this time.
- 3. Using the following parameters provided to you by the control room operating crew, classify the event according to the EPIPs and perform any required actions.
 - PZR level is 58% and stable.
 - Charging flow is 140 gpm.
 - Letdown flow is 0 gpm.
 - Cntmt. pressure is +0.2 psid and steady.
 - Cntmt. radiation (RM-90-106 & 112) has not changed since the event began.
 - RHR Pipe Break White Lights have just illuminated.
 - RM-90-101B is increasing.
 - Several Area Rad Monitors on El 669 and 690 are in Hi Rad.

Elements of this JPM are time critical