

**ENGELHARD INDUSTRIES, INC.**

D. E. MAKEPEACE DIVISION  
ATTLEBORO, MASS.

DATE August 2, 1961

TO MR. C. A. Canham

SUBJECT Visitation from Mass. Dept.  
of Public Health 8/1/61.

COPIES TO

Mr. R. Ware

An inspection of our waste disposal facilities was made on August 1, 1961 by Mr. Gerald Parker of the Mass. Dept. of Public Health. He seemed concerned about the fact that there is considerable overflowing of water from our leaching pits whenever a waste water tank is discharged into them. Evidently, there is something which is preventing our water from leaching into the ground as it should do.

He recommended the installation of three (3) leaching trenches in combination with our present pits, which in his opinion, would relieve this problem. The trenches would be lined with crushed stone and each one will contain 100 ft. of perforated pipe to facilitate leaching. A formal report containing these recommendations will be sent to us in the near future.

At the present time, Ray Ware and myself will draw up specifications and obtain quotes on the leaching trenches which will then be presented to management for approval.



Norton M. Weiss

NMW/sam

I/25

1054