

PMSTPCOL PEmails

From: STPCOL
Sent: Thursday, March 19, 2009 12:41 PM
To: PMSTPCOL PEmails
Subject: Conference Calls
Attachments: FW_ NRC Conference Call_ Meteorology Issues from March Audit; RAIs 2.3.1-3, 2.3.1-4(a), 2.3.1-8(b), and DEP T1 5.0-1; and Meeting with NRC on NOV 6..doc; FW_ Telecon with STP on Ch. 6 Containment Issues.doc

The message is ready to be sent with the following file or link attachments:

FW_ NRC Conference Call_ Meteorology Issues from March Audit; RAIs 2.3.1-3, 2.3.1-4(a), 2.3.1-8(b), and DEP T1 5.0-1; and Meeting with NRC on NOV 6..doc FW_ Telecon with STP on Ch. 6 Containment Issues.doc

Note: To protect against computer viruses, e-mail programs may prevent sending or receiving certain types of file attachments. Check your e-mail security settings to determine how attachments are handled.

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1140

Mail Envelope Properties (B4ECC0E252653F48B3F57C3B833465E80E35A68F91)

Subject: Conference Calls
Sent Date: 3/19/2009 12:40:53 PM
Received Date: 3/19/2009 12:41:23 PM
From: STPCOL

Created By: STP.COL@nrc.gov

Recipients:
"PMSTPCOL PEmails" <PMSTPCOL.PEmails@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	503	3/19/2009 12:41:23 PM
FW_ NRC Conference Call_ Meteorology Issues from March Audit; RAIs 2.3.1-3, 2.3.1-4(a), 2.3.1-8(b), and DEP T1 5.0-1; and Meeting with NRC on NOV 6..doc	5221	
FW_ Telecon with STP on Ch. 6 Containment Issues.doc	4168	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Attachments:

From: [Tekia Govan](#) on behalf of [Bense, Richard](#)
To: [STPCOL](#); [Tekia Govan](#); [Brad Harvey](#)
Subject: FW: NRC Conference Call: Meteorology Issues from March Audit; RAIs 2.3.1-3, 2.3.1-4(a), 2.3.1-8(b), and DEP T1 5.0-1; and Meeting with NRC on NOV 6. | [Preliminary Info-STP COLA Chap 2 -RAI Conference Call and November 6 Meeting in Rockville.msg Preliminary list of information needs relative to the STP COLA FSAR Chapter 21.doc](#)

Comment [1]:

Comment [2]:

-----Original Appointment-----From: Bense, Richard Sent: Thursday, October 16, 2008 3:35 PM To: Bense, Richard; Tekia Govan; Brad Harvey Subject: NRC Conference Call: Meteorology Issues from March Audit; RAIs 2.3.1-3, 2.3.1-4(a), 2.3.1-8(b), and DEP T1 5.0-1; and Meeting with NRC on NOV 6. When: Monday, October 20, 2008 10:00 AM-11:00 AM (GMT-05:00) Eastern Time (US & Canada). Where:

Call in Number: 866-803-2146
Participant Code: 8488464

Conference room 210 at the CED has been reserved for this call.

NRC has requested a conference call for Monday, October 20, to discuss the following items:

1. Meteorology Items related to the March Site Audit, specifically the following (See Attached List):

Items 8, 17, 22, 24, 25, 35, 38, 40, 41 (NRC identified these as items for which STP will have responses)

Items 11, 18, 29, 30, 31, 32, 37 (NRC identified these items as further work required)

2. Potential RAI Questions related to the previous responses to RAI Questions 02.03.01-3, 02.03.01-4(a), and 02.03.01-8(b) and STD DEP T1 5.0-1. These potential RAIs were previously discussed with the NRC in a teleconference on September 25, 2008. Details of the potential RAIs are included in an email (copy attached) from the NRC Project Manager, Tekia Govan. NRC requested additional discussion before a decision is made to move forward with these RAI Questions.

3. Status of RAI 02.04.04-3, which NRC tracking indicated was overdue as of September 11, 2008. NRC Project Manager has already been informed that STP requested an extension for this RAI in a letter dated August 27, 2008 (STP Number ABR-AE-0800065, Accession Number ML 082550111).

4. Brief discussion of Agenda for meeting between NRC and STP in NRC's Rockville Office for November 6, 2008. Preliminary discussion indicated that agenda would include:

- a. Changes to FSAR Chapter 2 included in Revision 2
- b. Changes to FSAR Chapter 2 anticipated for Revision 3
- c. Milestones for Rev 3 Changes.

From: [Stacy Joseph](#)
To: "jetomkins@stpegs.com"; [Hanry Wagage](#); [STPCOL](#); [Andrzej Drozd](#); [Michael Snodderly](#); [George Wunder](#); [Eric Miller](#)
Subject: FW: Telecon with STP on Ch. 6 Containment Issues

When: Thursday, October 23, 2008 3:00 PM -5:00 PM Eastern Time (US & Canada). Where: O3-B6 *~*~*~*~*~*~*~*~*~*

Telecon Agenda

Discuss the ECCS suction strainers design basis and how the method used by STP (essentially meeting RG 1.82 Rev 2) is sufficient to meet or more conservative than the requirements of RG 1.82 Rev 3. Downstream Fuel Effects – how does STP plan on meeting the RG 1.82 Rev 3 requirements for Downstream Fuel Effects if the fuel to be used is not known at this time? Containment Analytical Model – STP to identify which code will be used to calculate the containment P/T and pool hydrodynamic loads, including all relevant non-GE proprietary references to be used. WCAP Report on GOTHIC model for subcompartment analysis – STP to identify the process for submitting this report to the NRC for review

Jim-The Conference Room phone number you can dial into is 301-415-8566. If you need a bridge line, please let me know.

Thank you,
Stacy

Stacy Joseph Project
Manager
U. S. Nuclear Regulatory Commission Office of New Reactors Division of New Reactor Licensing

(Office) 301-415-2849 (Fax): 301-415-5399 Mail Stop T7-F31 Washington DC 20555-0001