



Nuclear Regulatory Commission
 Exhibit # - NRC000052-00-BD01
 Docket # - 05200011
 Identified: 03/16/2009

Admitted: 03/16/2009 withdrawn:
 Rejected: Stricken:

NRC000052

Cumulative Withdrawals of All Four Vogtle Units as Percentage of River Flow
 These percentages combine the revised Unit 1 and 2 withdrawal rate with the normal combined withdrawal for Units 3 and 4 using AP1000 DCD Revision 15

Withdrawal from
 Savannah River for Units
 1 and 2

Savannah River Streamflow (cfs)	90 cfs	98 cfs	104 cfs	Percentage change from 90 cfs to 104 cfs
8830	2.0	2.0	2.1	0.1
3800	4.6	4.8	4.9	0.3
3000	5.8	6.0	6.2	0.4
2000	8.7	9.1	9.4	0.7

Cumulative Withdrawals of All Four Vogtle Units as Percentage of River Flow
 These percentages combine the revised Unit 1 and 2 withdrawal rate with the normal combined withdrawal for Units 3 and 4 under AP1000 DCD Revision 16

Withdrawal from
 Savannah River for Units
 1 and 2

Savannah River Streamflow (cfs)	90 cfs	98 cfs	104 cfs	Percentage change from 90 cfs to 104 cfs
8830	2.0	2.1	2.2	0.2
3800	4.6	4.9	5.0	0.4
3000	5.9	6.2	6.4	0.5
2000	8.8	9.2	9.5	0.7