



Nuclear Regulatory Commission
 Exhibit # - NRC000052-00-BD01
 Docket # - 05200011
 Identified: 03/16/2009

Admitted: 03/16/2009 withdrawn:
 Rejected: Stricken:

NRC000052

Cumulative Withdrawals of All Four Vogtle Units as Percentage of River Flow
 These percentages combine the revised Unit 1 and 2 withdrawal rate with the normal combined withdrawal for Units 3 and 4 using AP1000 DCD Revision 15

Withdrawal from
Savannah River for Units
1 and 2

| Savannah River Streamflow (cfs) | 90 cfs | 98 cfs | 104 cfs | Percentage change from 90 cfs to 104 cfs |
|---------------------------------|--------|--------|---------|--|
| 8830 | 2.0 | 2.0 | 2.1 | 0.1 |
| 3800 | 4.6 | 4.8 | 4.9 | 0.3 |
| 3000 | 5.8 | 6.0 | 6.2 | 0.4 |
| 2000 | 8.7 | 9.1 | 9.4 | 0.7 |

Cumulative Withdrawals of All Four Vogtle Units as Percentage of River Flow
 These percentages combine the revised Unit 1 and 2 withdrawal rate with the normal combined withdrawal for Units 3 and 4 under AP1000 DCD Revision 16

Withdrawal from
Savannah River for Units
1 and 2

| Savannah River Streamflow (cfs) | 90 cfs | 98 cfs | 104 cfs | Percentage change from 90 cfs to 104 cfs |
|---------------------------------|--------|--------|---------|--|
| 8830 | 2.0 | 2.1 | 2.2 | 0.2 |
| 3800 | 4.6 | 4.9 | 5.0 | 0.4 |
| 3000 | 5.9 | 6.2 | 6.4 | 0.5 |
| 2000 | 8.8 | 9.2 | 9.5 | 0.7 |