Facility:	Vermo	nt Ya	anke	e NF	RC	Dat	e of	Exar	n:		Fe	brua	ry 2009	)				
				F	RO K	/A C	ateg	ory F	Point	s				SR	0-01	nly P	oints	
Tier	Group	K 1	K 2	К 3	K 4	K 5	K 6	A 1	A 2	A 3	A 4	G *	Tota I	A	2	G	*	Total
1.	1	3	3	4				3	3			4	20	4	ļ	3	5	7
Emergency &	2	1	1	1				1	2			1	7	1		2	2	3
Plant Evolutions	Tier Totals	4	4	5				4	5			5	27	5	5	5	5	10
_	1	2	3	2	3	2	2	2	3	3	2	2	26	(r)	3	2	2	5
2. Plant	2	1	1	1	1	1	1	1	1	1	1	2	12	0	-	2	2	3
Systems	Tier Totals	3	4	3	4	3	3	3	4	4	3	4	38	2	ļ	4	Ļ	8
3. Generic K	nowledg	je &	Abili	ties		1	2	2	;	3	4	1	10	1	2	3	4	7
C	ategorie			2		3		2		3	10	2	2	1	2	/		
Note: 1.	Note: 1. Ensure that at least two topics from every applicable WA category are sampled within each tier of the RO and SRO-only outlines (i.e., except for one category in Tier 3 of the SRO-only outline, the "Tier Totals" in each WA category shall not be less than two)																	

- 2. The point total for each group and tier in the proposed outline must match that specified in the table. The final point total for each group and tier may deviate by ±1 from that specified in the table based on NRC revisions. The final RO exam must total 75 points and the SRO-only exam must total 25 points.
- 3. Systems/evolutions within each group are identified on the associated outline; systems or evolutions that do not apply at the facility should be deleted and justified; operationally important, site-specific systems that are not included on the outline should be added. Refer to section D.1.b of ES-401, for guidance regarding elimination of inappropriate WA statements.
- 4. Select topics from as many systems and evolutions as possible; sample every system or evolution in the group before selecting a second topic for any system or evolution.
- 5. Absent a plant specific priority, only those KAs having an importance rating (IR) of 2.5 or higher shall be selected. Use the RO and SRO ratings for the RO and SRO-only portions, respectively.
- 6. Select SRO topics for Tiers 1 and 2 from the shaded systems and WA categories.
- 7.\* The generic (G) K/As in Tiers 1 and 2 shall be selected from Section 2 of the WA Catalog, but the topics must be relevant to the applicable evolution or system. Refer to Section D.1.b of ES-401 for the applicable K/A's
- 8. On the following pages, enter the WA numbers, a brief description of each topic, the topics' importance ratings (IR) for the applicable license level, and the point totals (#) for each system and category. Enter the group and tier totals for each category in the table above. If fuel handling equipment is sampled in other than Category A2 or G\* on the SRO-only exam, enter it on the left side of Column A2 for Tier 2, Group 2 (Note #1 does not apply). Use duplicate pages for RO and SRO-only exams.
- **9.** For Tier 3, select topics from Section 2 of the WA Catalog, and enter the WA numbers, descriptions, I**Rs**, and point totals (#) on Form ES-401-3. Limit SRO selections to **K/As** that are linked to 10CFR55.43

### Vermont Yankee Written Written Examination Outline Emergency and Abnormal Plant Evolutions – Tier 1 Group 1

EAPE # / Name Safety Function	K1	К2	кз	A1	A2	G	K/A Topic(s)	Imp.	Q#
	•		-	·			<u> </u>		
295019 Partial or Total Loss of Inst. Air / 8					х		AA2.02 - Ability to determine and/or interpret the following as they apply to PARTIAL OR COMPLETE LOSS OF INSTRUMENT AIR : Status of safety- related instrument air system loads (see AK2.1 - AK2.19)	3.7	76
295005 Main Turbine Generator Trip / 3					x		AA2.02 - Ability to determine and/or interpret the following as they apply to MAIN TURBINE GENERATOR TRIP : Turbine vibration	2.7	77
295004 Partial or Total Loss of DC Pwr / 6					x		AA2.03 - Ability to determine and/or interpret the following as they apply to PARTIAL OR COMPLETE LOSS OF D.C, POWER : Battery voltage	2.9	78
295006 SCRAM / 1						х	2.1.19 - Conduct of Operationis: Ability to use plant computers to evaluate system or component status.	3.8	79
295001 Partial or Complete Loss of Forced Core Flow Circulation 1 & 4						х	2.2.40 - Equipment Control: Ability to apply technical specifications for a system.	4.7	80
295025 High Reactor Pressure / 3						х	2.4.45 - Ability to prioritize and interpret the significance of each annunciator or alarm.	4.3	81
295028 High Drywell Temperature / 5					x		EA2.02 - Ability to determine and/or interpret the following as they apply to HIGH DRYWELL TEMPERATURE : Reactor pressure	3.9	82
295005 Main Turbine Generator Trip / 3	x						AK1.01 - Knowledge of the operational implications of the following concepts as they apply to MAIN TURBINE GENERATOR TRIP : Pressure effects on reactor power	4.0	39
295028 High <b>Drywell</b> Temperature∎ 5	x						EK1.01 - Knowledge of the operational implications of the following concepts as they apply to HIGH DRYWELL TEMPERATURE : Reactor water level measurement	3.5	40
295030 Low Suppression Pool Water Level 15	x						EK1O1 - Knowledge of the operational implications of the following concepts as they apply to LOW SUPPRESSION POOL WATER LEVEL: Steam condensation	3.8	41
295026 Suppression Pool High Water Temp. / 5		x					EK2.06 - Knowledge of the interrelations between SUPPRESSION POOL <b>HIGH</b> WATER TEMPERATURE and the following: Suppression pool level	3.5	42
295019 Partial or Total Loss of Inst. Air / 8		x					AK2.04 - Knowledge of the interrelations between PARTIAL OR COMPLETE LOSS OF INSTRUMENT AIR and the following: Reactor water cleanup	2.8	43
600000 Plant Fire On-site 18		x					AK2.04 - Knowledge of the interrelations between PLANT FIRE ON SITE and the following: Breakers, relays, and disconnects	2.5	44
295023 Refueling Accidents			x				AK3.03 - Knowledge of the reasons for the following responses as they apply to REFUELING ACCIDENTS: Ventilation isolation.	3.3	45

## Vermont Yankee Written Written Examination Outline Emergency and Abnormal Plant Evolutions – Tier 1 Group 1

2

EAPE # / Name Safety Function	<b>K</b> 1	K2	КЗ	<b>A</b> 1	A2	G	K/A Topic(s)	lmp.	Q#
295018 Partial or Total Loss of CCW / 8			x				AK3.04 - Knowledge of the reasons for the following responses as they apply to PARTIAL OR COMPLETE LOSS OF COMPONENT COOLING WATER : Starting standby pump	3.3	46
295016 Control Room Abandonment / 7			x				AK3.03 - Knowledge of the reasons for the following responses as they apply to CONTROL ROOM ABANDONMENT: Disabling control room controls	3.5	47
700000 Generator Voltage and Electric Grid Disturbances				x			AA1.05 - Ability to operate and/or monitor the following as they apply to GENERATOR VOLTAGE AND ELECTRIC GRID DISTURBANCES: Engineered safety features.	3.9	48
295004 Partial or Total Loss of DC Pwr / 6				x			AA1.01 - Ability to operate and/or monitor the following as they apply to PARTIAL OR COMPLETE LOSS OF D.C. POWER : D.C. electrical distribution systems	3.3	49
295006 SCRAM / 1				x			AA1.06 - Ability to operate and/or monitor the following as they apply to SCRAM : CRD hydraulic system	3.5	50
295021 Loss of Shutdown Cooling / 4					х		AA2.05 - Ability to determine and/or interpret the following as they apply to LOSS OF SHUTDOWN COOLING : Reactor vessel metal temperature	3.4	51
295037 SCRAM Conditions Present and Reactor Power Above APRM Downscale or Unknown / 1					x		EA2.04 - Ability to determine and/or interpret the following as they apply to SCRAM CONDITION PRESENT AND REACTOR POWER ABOVE APRM DOWNSCALE OR UNKNOWN : Suppression pool temperature	4.0	52
295001 Partial or Complete Loss of Forced Core Flow Circulation / 1 & 4					x		AA2.06 - Ability to determine and/or interpret the following as they apply to PARTIAL OR COMPLETE LOSS OF FORCED CORE FLOW CIRCULATION : Nuclear boiler instrumentation	3.2	53
295024 High <b>Drywell</b> Pressure / 5						x	2.1.30 - Conduct of Operations: Ability to locate and operate components, including local controls.	4.4	54
295038 High Off-site Release Rate / 9						×	2.1.23 - Conduct of Operations: Ability to perform specific system and integrated plant procedures during all modes of plant operation.	4.3	55
295031 Reactor Low Water Level / 2						x	2.4.46 - Emergency Procedures Plan: Ability to verify that the alarms are consistent with the plant conditions.	4.2	56
295003 Partial or Complete Loss of AC / 6			x				AK3.01 - Knowledge of the reasons for the following responses as they apply to PARTIAL OR COMPLETE LOSS OF A.C. POWER : Manual and auto bus transfer	3.3	57
295025 High Reactor Pressure / 3						x	2.4.34 • Emergency Procedures/ Plan: Knowledge of RO tasks performed outside the main control room during an emergency and the resultant operational effects.	4.2	58
WA Category Totals:	3	3	4	3	<b>3/</b> 4	4/3	Group Point Total:		20/7

## Vermont Yankee Written Written Examination Outline Emergency and Abnormal Plant Evolutions – Tier 1 Group 2

EAPE # / Name Safety Function	K1	K2	КЗ	A1	A2	G	K/A Topic(s)	lmp.	Q#
295002 Loss of Main Condenser Vac / 3					x		AA2.04 - Ability to determine andior interpret the following as they apply to LOSS OF MAIN CONDENSER VACUUM : Offgas system flow	2.9	83
295017 High Off-site Release Rate / 9						x	2.1.23 - Conduct of Operations: Ability to perform specific system and integrated plant procedures during all modes of plant operation.	4.4	84
295013 High Suppression Pool Temperature 1 5						x	2.1.25 - Ability to interpret reference materials, such as graphs, curves. tables, etc.	4.2	85
295010 High <b>Drywell</b> Pressure / 5	x						AK1.03 - Knowledge of the operational implications of the following concepts as they apply to HIGH DRYWELL PRESSURE : Temperature increases	3.2	59
295029 High Suppression Pool Water Level / 5		x					EK2.02 - Knowledge of the interrelations between HIGH SUPPRESSION POOL WATER LEVEL and the following: HPCI: Plant-Specific	3.4	<del>6</del> 0
295033 High Secondary Containment Area Radiation Levels / <b>9</b>			x				EK3.01 - Knowledge of the reasons for the following responses as they apply to HIGH SECONDARY CONTAINMENT AREA RADIATION LEVELS : Emergency depressurization	3.3	61
500000 High CTMT Hydrogen Conc. / 5				x			EA1.03 - Ability to operate and monitor the following as they apply to HIGH CONTAINMENT HYDROGEN CONTROL: Containment atmosphere control system	3.4	62
295032 High Secondary Containment Area Temperature 15					x		EA2.01 • Ability to determine and/or interpret the following as they apply to HIGH SECONDARY CONTAINMENT AREA TEMPERATURE : Area temperature	3.8	63
295015 Incomplete SCRAM / 1						x	2.1.28 - Conduct of Operations: Knowledge of the purpose and function of major system components and controls.	4.1	64
295036 Secondary Containment High <b>Sump/Area</b> Water Level / 5					x		EA2.03 - Ability to determine and/or interpret the following as they apply to SECONDARY CONTAINMENT HIGH SUMP/AREA WATER LEVEL : Cause of the high water level	3.4	65
K/A Category Totals:	1	1	1	1	2/1	1/2	Group Point Total:		713

System # / Name	к 1	К 2	К 3	K 4	K 5	K 6	A 1	A2	A 3	A 4	G	2 <u></u>	Imp	Q#
203000 RHRILPCI: Injection Mode	IRILPCI: Injection       X       Impacts of the following on the RHRILPCI: INJECTION MODE (PLANT SPECIFIC) ; and (b) based on those predictions, use procedures to correct. control, or mitigate the consequences of those abnormal conditions or operations: Initiating logic failure         A2.01 - Ability to (a) predict the impacts of the following on the RHRILPCI: Injection		3.9	86										
259002 Reactor Water Level Control								x				A2.01 - Ability to (a) predict the impacts of the following on the REACTOR WATER LEVEL CONTROL SYSTEM : and (b) based on ttiose predictions, use procedures to correct. control, or rnitigate the consequences of those abnormal conditions or operations: Loss of any number of rnain steam flow inputs	3.4	87
400000 Component Cooling Water											x	2.4.49 - Etnergency Procedures I Plan: Ability to perform without reference to procedures those actions that require immediate operation of system components and controls.	4.4	88
262002 UPS (AC/DC)											x	2.1.20 - Ability to interpret and	4.6	89
211000 SLC								x				A2.07 - Ability to (a) predict the impacts ot the following on the STANDBY LIQUID CONTROL SYSTEM; and (b) based on those predictions, use procedures to correct. control, or mitigate ttie consequences of those abnormal conditions or operations: Valve closures	3.2	90
211000 SLC	x											K1.03 - Knowledge of the physical connections and/or cause- effect relationships between STANDBY LIQUID CONTROL SYSTEM and the following: Plant air systems: Plant-Specific	2.5	1
400000 Component Cooling Water	x											K1.03 - Knowledge of the physical connections and / or cause-effect relationships between CCWS and the following: Radiation monitoring systems	2.7	2
263000 DC Electrical Distribution		x										K2.01 - Knowledge of electrical power supplies to the following: Major D.C. loads	3.1	3
205000 Shutdown Cooling		x										K2.02 - Knowledge of electrical power supplies to the following: Motor operated valves	2.5	4

System # / Name	K 1	К 2	к 3	К 4	К 5	K 6	A 1	A2	А З	A 4	G		Imp	Q#
262001 AC Electrical Distribution			x									K3.04 - Knowledge of the effect that a loss or malfunction of the A.C. ELECTRICAL DISTRIBUTION will have on following: Uninterruptible power supply	3.1	5
264000 EDGs			x									K3.02 - Knowledge of the effect that a loss or malfunction of the EMERGENCY GENERATORS (DIESEUJET) will have on following: A.C. electrical distribution	3.9	6
261000 SGTS				x								K4.01 - Knowledge of STANDBY GAS TREATMENT SYSTEM design feature(s) and/or interlocks which provide for the following: Automatic system initiation	3.7	7
203000 RHR/LPCI: Injection Mode				x								K4.05 - Knowledge of RHWLPCI: INJECTION MODE (PLANT SPECIFIC) design feature(s) and/or interlocks which provide for the following: Prevention of water hammer	3.2	8
212000 RPS					x							K5.01 • Knowledge of the operational implications of the following concepts as they apply to REACTOR PROTECTION SYSTEM : Fuel thermal time constant	2.7	9
218000 ADS					x							K5.01 - Knowledge of the operational implications of the following concepts as they apply to AUTOMATIC DEPRESSURIZATION SYSTEM : ADS logic operation	3.8	10
209001 LPCS						x						K6.01 - Knowledge of the effect that a loss or malfunction of the following will have on the LOW PRESSURE CORE SPRAY SYSTEM : A.C. power	3.4	11
239002 SRVs						x						K6.04 - Knowledge of the effect that a loss or malfunction of the following will have on the RELIEF/SAFETY VALVES : D.C. power: Plant-Specific	3.0	12
259002 Reactor Water Level Control							x					A1.01 - Ability to predict <b>and/or</b> monitor changes in parameters associated with operating the REACTOR WATER LEVEL CONTROL SYSTEM controls including: Reactor water level	3.8	13
215004 Source Range Monitor							x					A1.04 - Ability to predict and/or monitor changes in parameters associated with operating the SOURCE RANGE MONITOR (SRM) SYSTEM controls including: Control rod block status	3.5	14

System # / Name	К 1	К 2	К 3	К 4	K 5	К 6	A 1	A2	A 3	A 4	G		Imp	Q#
215003 IRM								x				A2.04 • Ability to (a) predict the impacts of the following on the INTERMEDIATE RANGE MONITOR (IRM) SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: Up scale or down scale trips	3.7	15
262002 UPS ( <b>AC/DC</b> )								x				A2.01 • Ability to (a) predict the impacts of the following on the UNINTERRUPTABLE POWER SUPPLY (A.C./D.C.); and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: Under voltage	2.6	16
223002 <b>PCIS/Nuclear</b> Steam Supply Shutoff									x			A3.01 - Ability to monitor automatic operations of the PRIMARY CONTAINMENT ISOLATION SYSTEM/NUCLEAR STEAM SUPPLY SHUT-OFF including: System indicating lights and alarms	3.4	17
215005 APRM / LPRM									x			A3.05 - Ability to monitor automatic operations of the AVERAGE POWER RANGE MONITOR/LOCAL POWER RANGE MONITOR SYSTEM including: Flow converter/comparator alarms	3.3	18
217000 RCIC										x		A4.05 - Ability to manually operate and/or monitor in the control room: Reactor water level	4.1	19
206000 HPCI										x		A4.02 - Ability to manually operate and/or monitor in the control room: Flow controller: BWR-2,3,4	4.0	20
300000 Instrument Air											x	2.4.4 - Emergency Procedures / Plan: Ability to recognize abnormal indications for system operating parameters which are entry-level conditions for emergency and abnormal operating procedures.	4.5	21
262001 AC Electrical Distribution											x	2.4.30 - Emergency Procedures / Plan; Knowledge of events related to system operation status that must be reported to internal organizations or external agencies, such as the state, the NRC, or the transmission system operator.	2.7	22

System # / Name	K 1	К 2	к 3	K 4	K 5	К 6	A 1	A2	A 3	A 4	G		lmp	Q#
203000 RHWLPCI: Injection Mode								x				A2.14 - Ability to (a) predict the impacts of the following on the RHWLPCI: INJECTION MODE (PLANT SPECIFIC); and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: Initiating logic failure	3.8	23
218000 ADS				x								K4.03 - Knowledge of AUTOMATIC DEPRESSURIZATION SYSTEM design feature(s) and/or interlocks which provide for the following: ADS logic control	3.8	24
215004 Source Range Monitor									x			A3.02 - Ability to monitor automatic operations of the SOURCE RANGE MONITOR (SRM) SYSTEM including: Annunciator and alarm signals	3.4	25
215005 APRM / LPRM		x										K2.02 - Knowledge of electrical power supplies to the following: APRM channels	2.6	26
K/A Category Totals:	2	3	2	3	2	2	2	33	3	2	2/2	Group Point Total:	26/	

286000 Fire Protection								X			A2.08 - Ability to (aj predict the impacts of the following on the FIRE PROTECTION SYSTEM ; and (b) based on those predictions, use procedures to correct, control. or mitigate the consequences ot those abnormal conditions or operations: failure to actuate when required	3.3	91
268000 Radwaste										x	2.2.36 - Equipment Control: Ability to analyze the effect of maintenance activities, such as degraded power sources. on the status of limiting conditions for operations.	4.2	92
204000 RWCU										x	2.4.6 - Emergency Procedures / Plan: Knowledge symptom based EOP mitigation strategies.	4.7	93
201006 RWM	x										K1.04 - Knowledge of the physical connections and/or cause- effect relationships between ROD WORTH MINIMIZER SYSTEM (RWM) (PLANT SPECIFIC) and the following: Steam flowlreactor power: P-Spec(Not-BWR6)	3.1	27
223001 Primary CTMT and Aux.		x									K2.08 - Knowledge of electrical power supplies to the following: Containment cooling air handling units: Plant-Specific	2.7	28
256000 Reactor Condensate			x								K3.04 - Knowledge of the effect that a loss or malfunction of the REACTOR CONDENSATE SYSTEM will have on following: Reactor Feedwater System	3.6	29
230000 RHWLPCI: Torus/Pool Spray Mode				x							K4.02 - Knowledge of RHR/LPCI: TORUS/SUPPRESSION POOL SPRAY MODE design feature(s) and/or interlocks which provide for the following: Redundancy	3.1	30
290002 Reactor Vessel Internals					x						K5.07 - Knowledge of the operational implications of the following concepts as they apply to REACTOR VESSEL INTERNALS : Safety Limits	3.9	31
201002 RMCS						x					K6.01 - Knowledge of the effect that a loss or malfunction of the following will have on the REACTOR MANUAL CONTROL SYSTEM : Select matrix power	2.5	32
233000 Fuel Pool Cooling/Cleanup							x				A1.07 - Ability to predict and/or monitor changes in parameters associated with operating the FUEL POOL COOLING AND CLEAN-UP controls including: System temperature	2.7	33

System # / Name	K 1	К 2	К 3	K 4	K 5	K 6	<b>A</b> 1	A2	A 3	A 4	G		Imp.	Q #
202001 Recirculation	202001 Recirculation X A2.08 - Ability to (a) impacts of the follow RECIRCULATION S and (b) based on the predictions, use prov correct, control, or m consequences of the abnormal conditions		A2.08 - Ability to (a) predict the impacts of the following on the RECIRCULATION SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those	3.1	34									
												abnormal conditions or operations: Recirculation flow mismatch: Plant-Specific		
259001 Reactor Feedwater									x			A3.10 - Ability to monitor automatic operations of the REACTOR FEEDWATER SYSTEM including: Pump trips	3.4	35
234000 Fuel Handling Equipment										x		A4.02 - Ability to manually operate and/or monitor in the control room: Control rod drive system	3.4	36
290001 Secondary CTMT											x	2.2.37 - Equipment Control: Ability to determine operability and / or availability of safety related equipment.	3.6	37
272000 Radiation Monitoring											x	2.4.47 - Emergency Procedures Plan: Ability to diagnose and recognize trends in an accurate and timely manner utilizing the appropriate control room reference material.	4.2	38
K/A Category Totals:	1	1	1	1	1	1	1	1/1	1	1	<b>2/</b> 2	2 Group Point Total:		12/3

Facility:	Vermont	Yankee Written Date: 07/17/08	3			
Cotogony	\\/\ #	Topio	R	С	SRO	-Only
Calegory	VVA #	Горіс	IR	Q#	IR	Q#
	2.1 <sup>.39</sup>	Knowledge of conservative decision making practices.			4.3	94
	2.1.25	Ability to Interpret reference materials, such as graphs, curves, tables, etc.			4.2	100
1. Conduct	2.1.8	Ability to coordinate personnel activities outside the control room.	3.4	66		
of Operations	2.1.4	Knowledge of individual licensed operator responsibilities related to shift staffing, such as medical requirements, "no-solo" operation, maintenance of active license status, 10CFR55, etc.	3.3	67		
	Subtotal			2		2
	2.2.35	Ability to determine Technical Specification Mode of Operation.			4.5	95
-	2.2.21	Knowledge of pre and post-maintenance operability requirements.			4.1	99
2						
Equipment	2.2.13	Knowledge of tagging and clearance procedures	4.1	68		
Control	2.2.40	Ability to apply technical specifications for a system.	3.4	69		
	2.2.37	Ability to determine operability and/or availability of safety related  equipment.	3.6	75		
	Subtotal			3		2
	2.3.11	Ability to control radiation releases.			4.3	96
3.		Knowledge of Radiological Safety Principles pertaining to licensed operator duties, such as				
Radiation Control	2.3.12	containment entry requirements, fuel handling responsibilities, access to locked high- radiation areas, aligning filters, etc.	3.2	70		
	2.3.4	Knowledge of radiation exposure limits under	3.2	71		
	Subtotal			2		1
	Jubiolai			2		1

	2.4.49	Ability to perform without reference to procedures those actions that require immediate operation of system components and controls.			4.4	97
	2.4.20	Knowledge of operational implications of EOP warnings, cautions, and notes.			4.3	98
4. Emergencia						
Emergency Procedures /						
Plan	2.4.46	Ability to verify that the alarms are consistent with the plant conditions.	4.2	72		
	2.4.42	Knowledge of emergency response facilities.	2.6	73		
	2.4.6	Knowledge of EOP mitigation strategies.	3.7	74		
		· · · · · · · · · · · · · · · · · · ·				
	Subtotal	· · · ·		3		2
Tier 3 Point Total				10		7

Tier / Group	Randomly Selected K/A	Reason for Rejection
1/2	500000 / EA1.05	(#62) EA1.05 - Ability to operate and monitor the following as they apply to HIGH CONTAINMENT HYDROGEN CONTROL: Wetwell sprays Topic does not apply to VY. Randomly selected EA1.03, Ability to operate and monitor the following as they apply to HIGH CONTAINMENT HYDROGEN CONTROL: Containment atmosphere control system
2/2	286000 / A2.02	(#91) A2.02 - Ability to (a) predict the impacts of the following on the FIRE PROTECTION SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: D.C. distribution failure: Plant-Specific Topic does not lend itself to a discriminating question (system function) Randomly selected A2.08, Ability to (a) predict the impacts of the following on the FIRE PROTECTION SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: Failure to actuate when required
2/2	204000 / 2.4.3	(#93) 2.4.3 - Emergency Procedures / Plan: Ability to identify post-accident instrumentation. Topic does not apply to VY. Randomly selected 2.4.6, Emergency Procedures / Plan: Knowledge symptom based EOP mitigation strategies.
2/2	256000 / K3.07	(#29) K3.07 - Knowledge of the effect that a loss or malfunction of the REACTOR CONDENSATE SYSTEM will have on following: Isolation condenser: Plant-Specific Topic does not apply to VY. Randomly selected K3.04, Knowledge of the effect that a loss or malfunction of the REACTOR CONDENSATE SYSTEM will have on following: Reactor Feedwater System
3	2.2.4	(#68) 2.2.4 (multi-unit license) Ability to explain the variations in control board layouts, systems, instrumentation and procedural actions between units at a facility. Not a multi unit license. Randomly selected 2.2.13, Knowledge of tagging and clearance procedures
2/2	201006 / K1.08	(#27) K1.08 - Knowledge of the physical connections and/or cause- effect relationships between ROD WORTH MINIMIZER SYSTEM (RWM) (PLANT SPECIFIC) and the following: Reactor power (turbine first stage pressure): P- Spec(Not-BWR6) Does not apply to VY. Randomly selected K1.04, Knowledge of the physical connections and/or cause- effect relationships between ROD WORTH MINIMIZER SYSTEM (RWM) (PLANT SPECIFIC) and the following: Steam flow/reactor power
2/2	29002 / K5.03	(#31) K5.03 - Knowledge of the operational implications of the following concepts as they apply to REACTOR VESSEL INTERNALS : Burnable poisons Not discriminating at RO level, minutia for licensing decision, generic fundamentals area. Randomly selected K5.07 Knowledge of the operational implications of the following concepts as they apply to REACTOR VESSEL INTERNALS : Safety Limits

2/2	259001 / A3.06	(#35) A3.06 - Ability to monitor automatic operations of the REACTOR FEEDWATER SYSTEM including: Pump discharge pressure VY has electric feed pumps could not write a specific question to match the K/A. Randomly selected A3.10, Ability to monitor automatic operations of the REACTOR FEEDWATER SYSTEM including: Pump trips
1/1	295023 / AK3.05	(#45) AK3.05 - Knowledge of the reasons for the following responses as they apply to REFUELING ACCIDENTS : Initiation of SLC/shut-down cooling: Plant- Specific Does not apply to VY, randomly selected AK3.03 Knowledge of the reasons for the following responses as they apply to REFUELING ACCIDENTS: Ventilation isolation.
1/1	295025 / 2.4.41	(#81) 2.4.41 - Emergency Procedures / Plan: Knowledge of the emergency action level thresholds and classifications. (High Reactor Pressure) There is no E-Plan action level associated with High Reactor Pressure. Randomly selected 2.4.45 Ability to prioritize and interpret the significance of each annunciator or alarm.
1/2	295013 / 2.1.27	(#85) 2.1.27 Knowledge of system purpose and/or function. Low LOD for a discriminating SRO level question for this K/A. Randomly selected 2.1.25 Ability to interpret reference materials, such as graphs, curves, tables, etc.
2/1	262002 / 2.1.28	(#89) 2.1.28 - Conduct of Operations: Knowledge of the purpose and function of major system components and controls. Low LOD for a discriminating SRO level question for this K/A.Randomly selected 2.1.20 Ability to interpret and execute procedure steps.
3	2.2.43	(#99) 2.2.43 - Knowledge of the process used to track inoperable alarms. Same K/A as Common question #75. Randomly selected 2.2.21, Knowledge of pre and post-maintenance operability requirements.
1/1	295003 / AK3.04	Knowledge of the reasons for the following responses as they apply to PARTIAL OR COMPLETE LOSS OF A.C. POWER: Ground isolation. Could not write a discriminating question. Very limited procedural guidance. Randomly selected AK3.01, Manual and auto bus transfer
3	2.2.43	Knowledge of the process used to track inoperable alarms. Used as a JPM on the Audit Exam. Randomly selected 2.2.37, Ability to determine operability and/or availability of safety related  equipment.

ES-301

Facility: Vermont Yankee		Date of Examination: 2/09					
Examination Level:	RO	Ope	rating Test Number:	N09-1			
Administrative Topic (see Note)	Type Code*		rformed				
Conduct of Operations	N, S	<b>2.1.29 (4.1)</b> Knowledge of how to conduct systellineups, such as valves, breakers, etc.		conduct system es, breakers, switches,			
		JPM:	Perform the RHR Sys	tem Valve Lineup			
Equipment Control	N, S	2.2.12 (3.7)	Knowledge of Surveillance Procedures				
		JPM:	Perform a Drywell Temperature Profile				
Dediction Control		<b>2.3.11 (3.8)</b>	Ability to control radiation releases				
Hadiation Control	M, R	JPM:	Determine Offgas Release Rate without ERFIS				
Emergency Procedures/Plan		2.4.43 (3.2)	Knowledge of Emergency Communicati Systems and techniques				
Frocedures/Fiam	D, S	JPM:	Perform Control Room Emergency Communications Checks				
NOTE: All items (5 total) are required for <b>SROs</b> . RO applicants require only 4 items unless they are retaking only the administrative <b>topics</b> , when 5 are required.							
*Type Codes & Criteria:	<b>3)</b> , or Class(R)oom (1) ≤ 4 for SROs & RO retake ≥ 1) (3) nly selected) (0)	es) (1)					

ES-301

				0/00		
Facility: Vermont Yankee		Date of Examination: 2/09		2/09		
Examination Level:	SRO	Ope	rating Test Number:	N09-1		
Administrative Topic (see Note)	Type Code*		Describe activity to be pe	erformed		
Conduct of Operations	N, S	<b>2.1.29 (4.0)</b> Knowledge of how to conduct system lineups, such as valves, breakers, switche etc.		conduct system es, breakers, switches,		
		JPM:	Perform the RHR Sys	stem Valve Lineup		
Conduct of Operations		2.1.7 (4.7)	Ability to evaluate plant performance and make operational judgments based on operating characteristics, reactor behavior, and instrument interpretation			
		JPM:	Perform a Core Thern Evaluation	mal Hydraulic Limits		
Equipment Control N, R		2.2.12 (4.1)	Knowledge of Surveillance Procedures			
		JPM:	Review a Surveillance			
Padiation Control		2.3.11 (4.3)	Ability to control radiation releases			
Radiation Control	M, R	JPM:	Determine Off <b>gas</b> Release Rate without ERFIS			
Emergency Procedures/Plan		2.4.44 (4.4)	Knowledge of Emergency Plan Protective Action Recommendations			
Procedures/Plan	N, S	JPM:	Off-Site Protective Action Recommendations (evacuate)			
NOTE: All items (5 total) are required for <b>SROs</b> . RO applicants require only <b>4</b> items unless they are retaking only the administrative topics, when <b>5</b> are required.						
<ul> <li>*Type Codes &amp; Criteria: (C)ontrol room, (0)(S)imulator, (3) or Class(R)oom (2)</li> <li>(D)irect from bank (≤ 3 for ROs; ≤ 4 for SROs &amp; RO retakes) (1)</li> <li>(N)ew or (M)odified from bank (≥ 1) (4)</li> <li>(P)revious 2 exams (≤ 1; randomly selected) (1)</li> </ul>						

# Control Room/In-Plant Systems Outline

Form ES-301-2

Facility	r: Vermont Yankee	Date of Examination:	2/2009						
Exam	Level (circle one): RO / SRO(I) / SRO (U)	Operating Test No.:	NRC-1						
Contro	Control Room Systems <sup>@</sup> (8 for RO; 7 for SRO-I; 2 or 3 for SRO-U, including 1 ESF)								
	System / JPM Title	Type Cod	e* Safety Function						
S-1	Shift Rx Level Control From The Main Feed Reg Val Auxiliary Feed Reg Valve	ve To The M, A, S	2						
	259002 RX Water Level Control System, K/A: A4.01	3.8/3.6							
S-2 (RO)	Advanced Off Gas System, Vacuum Pump Transfer 271000 OffGas System, K/A: A4.09 3.3/3.2	D, S	3						
S-3	Secure RHR from the Shutdown Cooling Mode 205000 Shutdown Cooling System, K/A: A4.01 3.7/3.7	N, L, S	4						
S-4	Line-up for Primary Containment Spray Using Fire S RHR Loop "A"	System to D, EN, S	5 5						
	226001 RHR/Containment Spray Mode, K/A: A4.02 3	.1/3.1							
S-5	Swap RBCCW & TBCCW Pumps	N, A, S	8						
	400000 Component Cooling Water System, K/A: A2.01	3.3/3.4							
S-6	Initiate SLC to the Vessel	D, A, EN,	S 1						
	211000 Standby Liquid Control System, K/A: A4.02 4.2	/4.2							
S-7	Transfer Station Load from the Auxiliary Transformer to Transformer	the Startup D, S	6						
1	262001 AC Electrical Distribution, K/A: A4.04 3.6/3.7								
S-8	Rx Startup to Criticality	P, A, L, S	5 7						
	215004 SRM System, K/A: A4.01 3.9/3.8								
In-Plar	nt Systems <sup>®</sup> (3 for RO; 3 for SRO-I; 3 or 2 for SRO-U)								
P-1	Place Charger BC-1-1B in Service	D	6						
	263000 DC Electrical Distribution, K/A: A3.01 3.2/3.3								
P-2	Boron Injection from the SLC Tank Using the CRD S	System D, E, R	1						
	APE 295037 Scram Condition Present and Reactor I Above APRM Downscale or Unknown K/A: EA1.10 3	Power 9.7/3.9							
P-3	Line-up for Alternate Vessel Injection Using SLC Test T EPE 295031 Reactor Low Water Level, K/A: EA1.08 3.8	ank D, E, R 3/3.9	2						

Facility:	VERMON	IT YANKEE	Scenario No.: 1 Op Test No.: 2009 NRC					
Examiners	s:		Operators: SRO -					
			RO -					
			BOP -					
Initial Con	ditions: At 1	00% power						
	DG Ope follo 270 RHF and	A has beer trability Test wing a-diese to 2750 kV R Pump B is is tagged of	(Tech Spec) per OP 4126, Sect B. The test is being performed I lube oil change. The test must be run for at least two hours at I and 1600 ± 50 kVAR OUT. OOS for severe vibrations that occurred during surveillance testing t for Maintenance investigation					
	und	io lagged et						
Turnover:	RHF	R Pump B is	OOS for severe vibrations that occurred during surveillance testing t for Maintenance investigation.					
	DG per You	" A is in ope OP 4126, Se are request	ration for the Monthly Diesel Generator Slow Start Operability Test act B. This requires DG A being declared inop IAW T.S. <b>3.10.B.1</b> and to bring voltage to 358 KV by VELCO					
		·						
CriticalTa	Critical Tasks: 1. With a reactor scram required and the reactor not shutdown, INHIBIT ADS to prevent an uncontrolled RPV depressurization to prevent causing a significant power excursion.							
	<ol> <li>During an ATWS with conditions met to perform power/level control TERMINATE AND PREVENT INJECTION into the RPV using appendix GG, until conditions are met to re-establish injection.</li> </ol>							
	3. \ F e	Vith a reacto REDUCE PC exceeding the	r scram required and the reactor not shutdown, TAKE ACTION TO WER by injecting boron <b>and/or</b> inserting control rods, to prevent primary containment design limits.					
Event No.	Malf. No.	Event T <b>ype*</b>	Event Description					
1	N/A	N - BOP	Raise Main Generator output to heavy load schedule and maximum Lagging (OUT) VAR Load IAW OP 2140, Sect. H.					
2		R - RO	Turbine Vibration respond per ARS 7-F-2 (lower power stop test)					
	mt1U_03A 60% over 300 sec.	R SRO	Lower power OP 0105, Reactor Operations (vibrations stop after lowering generator load)					
3	mfAN08G5 SPURIOUS	C BOP C SRO	DG A – Jacket Water Leak requires removing DG from service					
4	mfRR_11B 100% over 600 sec	I-RO I-SRO	"B" Recirc speed controller will fail and will begin to run away requiring the RO to take manual control and rebalance flows.					

Appendix D

5	mfED_05Da	C - HO C - SRO TS - SRO	Loss of MCC-9A with a failure of the Group 3 Isolation (AC-6B will not auto close) Consult Tech Specs			
6	mfED05Cb	C - BOP C <u>- SRO</u> TS - SRO	480V MCC-8B will trip causing a half scram (if RPS B was transferred to its alternate supply) also the loss of the bus will challenge DW pressure by the loss of power to RRUs 1A and 1B, alternate RRUs must be started. (This power lost will affect ATWS recovery by preventing the use of cooling water flow to insert the control rods.) The SRO will address TS			
7	mfRP_02A mf RD-12A mf RD-12B (20120%)	M- ALL	Loss of RPS MG Set A, Hydraulic ATWS with MSIV closure			
8	mfSL_02A	C - RO C <sub>- SRO</sub>	SLC Squib Valve " A failure (the loss of <b>8B</b> takes away SLC Pump B) Candidate must recognize that the Squib Valves must be fired locally using the battery.			
* (N	* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor					

Appendix	ppendix D Scenario Outline Forn						Form ES-D-1
Facility:	VERMO	NT YANKEE		Scenario No.:	2	Op Test No.:	2009 NRC
Examiner	Examiners:			Operato	rs:	SRO -	
						RO -	
						BOP -	
Initial Con	ditions: At - "A" RHI	-1% power, \$ IRM failed u R Pump "C"	Startup in Ipscale du is OOS	progress. OP 010 ring the startup a	)5, P nd is	hase 2.D Step 10 bypassed.	
Turnover:	Inde RHI out RHI MS	efinite LCO o R Pump "C" on previous R Pump "C" IV Isolation 7	due to IRM is OOS fo shift; estir OOS (TS Testing is l	1 "A" OOS (TS Ta r severe vibration nated return to se 3.5.A.3) NOT required	ible 3 ns du ervice	3.1.1 and TRM 3.2. ring surveillance te e is 48 hours, 7-da	5) sting. Tagged y LCO due to
Critical Ta	ask: 1.	Following a manually s	a Loss of N starts " B D	Normal Power dia	ignos 4KV	ses "B" DG failed to ' Bus 4.	auto-start and
	2. 3.	With the re of the low p inches Restore an	eactor shut pressure s nd maintair	down and reacto systems, initiate R n RPV level abov	r pre PV-I e TA	ssure greater than ED BEFORE RPV F (+6 inches)	the shutoff head level reaches –19
Event No.	Malf. No.	Event Type*		E`	vent	Description	
1	N/A	R-RO R-SRO	Withdrav	w control rods to a	conti	nue the startup	
2	mfNM_03C (100%)	I-RO I-SRO TS - SRO	IRM " C	Inop Failure, rest	ults i	n half scam.	
3	N/A	N - RO N - SRO	Transfer	Reactor Mode S	witch	n to RUN and <b>con</b> ti	nue the startup.
4	MfRD_15	I-RO I-SRO	Failure	of CRD Flow Con	trolle	er Automatic Outpu	t Signal
5	mfHP_03 mfHP_04	C-BOP C-SRO TS-SRO	HPCI ina (low – to HPCI inj T.S. 3.5	advertently injects o prevent a reacto jection is spurious .E entry	s to t or scr s and	he vessel with a co ram). The crew wil I trip the HPCI turb	ntroller failure I confirm that the ine. Requires
6	mfED_02A mfED-02B	M - ALL	Loss of t reactor s	the startup transfo scram.	orme	ers which will result	in a LNP and
7	mfDG_05A mfDG_08B	C - BOP C-SRO	Both DG	is fail to auto star ually started.	t, DC	G " A cannot be sta	rted, DG " B can

Ap	pendix	D
/ \p	poriain	

# Scenario Outline

8	mfRR_01A OVRD ANN	M <b>- A</b> LL	Core spray line "B" break in the Drywell between the RPV and injection check valve resulting in a LOCA and loss of the remaining Core Spray system.			
9	mfRC_03 - RCIC flow controller failure mfRC_05 - RCIC inadvertent Isolation	C – BOP C-SRO	RCIC Controller Fails in AUTO, then isolates			
1) *	* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor					

Appendix D

Scenario Outline

Form ES-D-1

Facility:		VERMONT YANKEE			Scenario	No.:	3	Op Test	No.:	2009 NRC
Examiners:					Operators: 		SRU -			
							RO -			
	-							BOP -		
Initial Conditions: 85 "A			85% power IC-807 "A" RHR OOS for severe vibration, maintenance is investigating.							
Turnover:		RHF tagg due Perf	RHR Pump "A" is OOS while maintenance investigates high vibration. It was tagged out on the previous shift; estimated return to service is 48 hours, 7-day LCO due to RHR Pump "A" OOS (TS 3.5.A.3) Perform OP 4160 Once/Week Pump Performance Test Section 1.a and b.							
Critical Tasks: 1. When drywell temperature cannot be restored and maintained below 280°F, initiate RPV-ED (and/or anticipate ED and use bypass valves).								pelow 280ºF,		
<ol> <li>IF Reactor water level cannot be determined, Enters EOP-6, RPV Flooding, opens all SRVs and commences injection using Shutdown RPV Flooding Systems until the Main Steam lines are flooded. OR</li> </ol>								PV Flooding, / Flooding		
3. Restores RPV water level and containment parameters with Condensate injecting directly into the RPV AND/OR aligns alternate injection systems such as RHR.										
Event No.	Malf. No.		Event Type*	Event Description						
1	N/A		N - RO N <sub>- SRO</sub> R - SRO	Perform OP 4160 Once/Week Pump Performance Test Sectio 1.a and b.				e Test Section		
2	mfFW_28A		l - RO	Feedwater flow transmitter slow failure upscale, causing the crev					causing the crew	
50% over sec		ver 60	!- SRO	to take manual control of feedwater in order to recover and stabilize RPV level.				cover and		
3	mfRH_ neces	01B (if sary)	SRO - TS	Call from lower m Specs S plant sh	m the So notor bea Sections nutdown	outheast aring oil i 3.5 and has bee	RHR indicat detern en ente	Corner Roo ing sight gla nine that a ered.	m that l ass is e 24 houi	RHR Pump "B" mpty. Tech r LCO, requiring a

4	IOR RRI0042AS7B IOR RRdi042AS7B IOR RRI0042AS7B IRF rfRR_12	C - BOP C <b>- SRO</b> R-RO R-SRO	"B" Recirc Pump discharge valve full open indication fails causing the "B" Recirc Pump to runback to minimum flow. Insert control rods to get below MELLA			
5	mfED06A	C - R O C-SRO TS - SRO	Trip of CRD Pump B with a loss of 125 VDC Bus 1 (Inops 4 KV Bus 3 ECCS equipment). The crew will implement ON 3159, Loss of Bus DC 1. The SS/SRO will review Tech Specs Sections 3.10 and 3.5 and determine that a second 24 hour LCO, requiring a plant shutdown, has been entered. (STG 04)			
6	mfTC_04A	I - BOP I - SRO	EPR Oscillations OT 3115, Reactor Pressure Transients – Place MPR in service.			
7	mfMS_06	M-CREW	Main Steam Line Break in the Drywell			
8	mfFW_08A mfFW_08B mfFW_08C mfCS_03A	C - BOP U - SRO	Failure of the Reactor Feedwater Pumps and Core Spray Pump A Injection Valve require lining up Condensate Pumps to restore RPV water level.			
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor						