

Effluent and Waste Disposal

Semi-Annual Report

January 1, 1988 - June 30, 1988

Facility Indian Point 3
Licensee New York Power Authority

This information is provided in accordance with the requirements of Regulatory Guide 1.21. The numbered sections of this report reference corresponding sections of the subject Regulatory Guide, pages 1.21-10 to 12.

A. Supplemental Information

1. Regulatory Limits

Indian Point 3 is presently subject to limits on radioactive waste releases that are set forth in sections 2.3.1, 2.3.2, 2.3.3, 2.4.1, 2.4.2, 2.4.3 and 2.4.4 of Appendix B to Docket #50-286 entitled "Environmental Technical Specification Requirements Part II Radiological Environmental". The percentages of the technical specification limits reported in Tables 1A and 2A are the percent of the quarterly limits specified in the ETSR. If more than one limit applies to the release, the most restrictive limit is reported.

2. Maximum Permissible Concentration

a. Fission and Activation Gases

The quarterly dose resulting from release of fission and activation gases is calculated in accordance with the methodology stated in the Off Site Dose Calculation Manual (ODCM). The specific isotopes listed in Table 1C are used to determine the effective dose factors for the time period.

b&c. Iodines, Tritium and Particulates

The quarterly organ dose limit for Iodine 131, tritium and particulates with half-lives greater than eight days is calculated in accordance with the methodology stated in the ODCM.

d. Liquid Effluents

The quarterly dose limit for liquid isotopic releases is calculated in accordance with the methodology stated in the ODCM. The instantaneous concentration limit for noble gases dissolved in liquid releases is calculated based upon a maximum permissible concentration of $2.00E-4$ $\mu\text{Ci/ml}$ as required by section 2.3.1.A of the ETSR.

8809070328 880630
PDR ADCK 05000284
R PDC

JEYR
1/1

3. Average Energy

The average energies (\bar{E}) of the radionuclide mixture in releases of fission and activation gases were as follows:

1st Quarter	$E_{\beta} = 1.40E-01$	Mev/dis	$E_{\gamma} = 4.63E-02$	Mev/dis
2nd Quarter	$E_{\beta} = 1.42E-01$	Mev/dis	$E_{\gamma} = 5.01E-02$	Mev/dis

4. Measurements and Approximations of Total Radioactivity

a. Fission and Activation Gases

Analysis of effluent gases has been performed in compliance with the requirements of Table 3.4-1 of the ETSR. In the case of isolated tanks (batch release) the total activity discharged is based on an isotopic analysis of each batch with the volume of gas in the batch corrected to standard temperature and pressure.

Vapor containment purge discharges that are less than 150 hours/quarter in duration have been treated as batch releases and pressure relief discharges have been treated as continuous releases (> 500 hrs/year and as defined in NUREG 0133, Section 3.3). At least one complete isotopic concentration analysis of containment air is performed monthly. This analysis is used in conjunction with a process monitor to obtain the isotopic mixture and quantification of each pressure relief. Isotopic analyses for each vapor containment purge are taken prior to and during the purge. This information is combined with the volume of air in each discharge to calculate the quantity of activity released from these discharges.

The continuous building discharges are based on weekly samples of ventilation air for isotopic content. This information is combined with total air volume discharged and the process radiation monitor readings to determine the quantity of activity from continuous discharges.

b&c. Iodines and Particulates

Iodine-131 and particulate releases are quantified by collecting a continuous sample of ventilation air on a TEDA impregnated activated charcoal cartridge and a glass-fiber filter paper. These samples are changed weekly as required in Table 3.4-1 of the ETSR and the concentration of isotopes found by analysis of these samples is combined with the volume of air discharged during the sampling period to calculate the quantity of activity discharged.

For other iodine isotopes the concentration of each isotope is determined monthly on a 24-hour sample. The concentration of the isotopes found by analysis is combined with the volume of air discharged during the sampling period to calculate the quantity of activity discharged.

d. Liquid Effluents

A sample of each batch discharge is taken and an isotopic analysis is performed in compliance with requirements specified in Table 3.3-1 of the ETSR. This isotopic concentration data is combined with the information on volume discharged to determine the amount of each isotope discharged.

Proportional composite samples of continuous discharges are taken and analyzed in compliance with Table 3.3-1 of the ETSR. This concentration data is combined with the volume discharged to calculate the total activity discharged.

5. Batch Releases

a. Liquid

	<u>1988</u>	
	<u>1st Quarter</u>	<u>2nd Quarter</u>
Number of Batch Releases	40	47
Total Time Period Batch Releases (Min.)	7031	9057.0
Maximum " " " " "	275	795.0
Average " " " " "	175.8	192.7
Minimum " " " " "	125	15.0
Average Stream Flow (cfs)		

b. Gaseous

Number of Batch Releases	2	18
Total Time Period Batch Releases (Min.)	16	6093.0
Maximum " " " " "	12	2185.0
Average " " " " "	8	338.5
Minimum " " " " "	4	30.0

6. Abnormal Releases

a. Liquid
None

b. Gaseous
None

7.0 Radiological Environmental Technical Specifications

The Radiological Environmental Technical Specifications require reporting of prolonged outage of effluent monitoring equipment (Sections 2.1.C and 2.2.B) and significant changes in the land use census, Radiological Environmental Monitoring Program or exceeding the total curie content limitations in outdoor tanks. (Sections 2.8.A, 2.8.B, 2.7.C and 2.3.4.B). There were no reportable events during the first and second quarter 1988.

Indian Point 3
EFFLUENT AND WASTE DISPOSAL
SEMI-ANNUAL REPORT
B. GASEOUS EFFLUENTS
FIRST AND SECOND QUARTERS 1988

TABLE 1A
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1988)
 GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

	UNIT	QUARTER 1st	QUARTER 2nd	EST. TOTAL Error %
A. Fission & Activation Gases				
1. Total Release	Curies	7.89E+01	1.05E+02	2.50E+01
2. Average release rate for period	uCi/sec	1.00E+01	1.33E+01	
3. Percent of technical specification limit.	%	8.18E-01	1.10E-00	
B. Iodines				
1. Total Iodine - 131	Ci	9.79E-05	6.43E-04	2.50E+01
2. Average release rate for period	uCi/sec	1.25E-05	8.18E-05	
3. Percent of technical specification limit.	%	3.24E-02	1.36E-01	
C. Particulates				
1. Particulates with half-lives >8 days	Ci	0.00E-00	1.87E-06	2.50E+01
2. Average release rate for period	uCi/sec	0.00E-00	2.37E-07	
3. Percent of technical specification limit.	%	3.24E-02	1.36E-01	
4. Gross alpha radioactivity	Ci	<3.95E-07	<3.19E-07	
D. Tritium				
1. Total release	Ci	2.25E-00	1.35E-00	2.50E+01
2. Average release rate for period	uCi/sec	2.86E-01	1.71E-01	
3. Percent of technical specification limit.	%	3.24E-02	1.36E-01	

TABLE 1C
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1988)
 GASEOUS EFFLUENTS-GROUND RELEASES

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		1st Quarter	2nd Quarter	1st Quarter	2nd Quarter
1. Fission Gases					
Krypton (Kr) 85m	Ci	6.86E-03	6.51E-03		5.04E-03
Krypton (Kr) 85	Ci	1.19E-00	4.08E-01		1.24E-00
Krypton (Kr) 87	Ci	1.27E-04	1.58E-04		
Krypton (Kr) 88	Ci				
Xenon (Xe) 131m	Ci	6.92E-00	1.90E-01		6.14E-01
Xenon (Xe) 133m	Ci	1.09E-01	7.92E-02		1.12E-00
Xenon (Xe) 133	Ci	6.96E+01	3.18E+01	1.69E-04	6.68E+01
Xenon (Xe) 135m	Ci	1.16E-04	1.66E-03		
Xenon (Xe) 135	Ci	1.07E-00	9.75E-01	6.55E-05	1.43E-00
Argon (Ar) 41	Ci	2.88E-02	2.89E-02		
TOTAL FOR PERIOD	Ci	7.89E+01	3.35E+01	2.35E-04	7.12E+01
2. Iodines					
Iodine (I) 131	Ci	7.07E-05	5.18E-04	2.72E-05	1.25E-04
Iodine (I) 133	Ci		1.70E-06	2.13E-05	1.34E-04
Iodine (I) 135	Ci				
TOTAL FOR PERIOD	Ci	7.07E-05	5.20E-04	4.85E-05	2.59E-04

TABLE 1C
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1988)
 GASEOUS EFFLUENTS - GROUND RELEASES

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		1st Quarter	2nd Quarter	1st Quarter	2nd Quarter
3. Particulates					
Antimony (Sb) 125	Ci				
Barium (Ba) 133	Ci				
Cadmium (Cd) 109	Ci				
Cerium (Ce) 139	Ci				
Cerium (Ce) 141	Ci				
Cerium (Ce) 144	Ci				
Cesium (Cs) 134	Ci				
Cesium (Cs) 137	Ci				
Cobalt (Co) 57	Ci				
Cobalt (Co) 58	Ci		1.87E-06		
Cobalt (Co) 60	Ci				
Chromium (Cr) 51	Ci				
Iron (Fe) 55	Ci				
Niobium (Nb) 95	Ci				
Strontium (Sr) 89	Ci				
Strontium (Sr) 90	Ci				
Tin (Sn) 113	Ci				
TOTAL	Ci		1.87E-06		

Indian Point 3
EFFLUENT AND WASTE DISPOSAL
SEMI-ANNUAL REPORT

C. LIQUID EFFLUENTS
FIRST AND SECOND
QUARTERS, 1988

TABLE 2A
 EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1988)
 LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

ERROR %	<u>UNIT</u>	<u>QUARTER</u> 1st	<u>QUARTER</u> 2nd	EST. TOTAL
A. Fission and activation products				
1. Total release (not including tritium, gases, alpha)	Ci	1.90E-02	8.33E-02	2.50E+01
2. Average diluted concentration during period	uCi/ml	8.12E-11	3.00E-10	
B. Tritium				
1. Total release	Ci	1.41E+02	2.10E+02	2.50E+01
2. Average diluted concentration during period	uCi/ml	6.06E-07	7.58E-07	
C. Dissolved and entrained gases				
1. Total release	Ci	9.99E-02	3.60E-01	2.50E+01
2. Average diluted concentration during period	uCi/ml	4.28E-10	1.30E-09	
D. Gross alpha radioactivity				
1. Total release	Ci	<8.74E-05	<1.20E-04	2.50E+01
E. Volume of waste released (prior to dilution)				
	liters	1.35E+06	2.08E+06	1.00E+01
F. Volume of dilution water used during period				
	liters	2.34E+11	2.77E+11	1.00E+01
G. Percent of liquid effluent limit				
	%	7.00E-02	3.75E-01	2.50E+01

TABLE 2B
 LIQUID EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT (1988)

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		1st Quarter	2nd Quarter	1st Quarter	2nd Quarter
Antimony (Sb) 122	Ci				
Antimony (Sb) 124	Ci				2.38E-04
Antimony (Sb) 125	Ci			1.59E-03	3.16E-03
Barium (Ba) 140	Ci				
Cadmium (Cd) 109	Ci				
Cerium (Ce) 139	Ci				
Cerium (Ce) 141	Ci				
Cerium (Ce) 144	Ci				
Cesium (Cs) 134	Ci		1.72E-04	1.31E-04	3.91E-03
Cesium (Cs) 137	Ci		3.47E-04	3.21E-04	4.86E-03
Cesium (Cs) 138	Ci				
Chromium (Cr) 51	Ci				6.12E-03
Cobalt (Co) 57	Ci				
Cobalt (Co) 58	Ci		1.03E-06	1.02E-03	8.65E-03
Cobalt (Co) 60	Ci			1.95E-03	6.82E-03
Iodine (I) 131	Ci		1.13E-04	2.23E-03	8.21E-05
Iodine (I) 132	Ci		4.10E-06		
Iodine (I) 133	Ci		1.02E-04	5.48E-05	9.04E-06
Iodine (I) 135	Ci				
Iron (Fe) 55	Ci			8.93E-03	3.70E-02
Iron (Fe) 59	Ci				1.20E-03
Lanthanum(La) 140	Ci			4.12E-05	8.87E-05
Mercury (Hg) 203	Ci				

TABLE 2B

LIQUID EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT (1988)

Nuclides	Unit	CONTINUOUS MODE		BATCH MODE	
		1st Quarter	2nd Quarter	1st Quarter	2nd Quarter
Manganese (Mn) 54	Ci			6.73E-05	5.75E-04
Molybdenum(Mo) 99	Ci				
Nickel (Ni) 63	Ci			1.51E-03	1.44E-03
Copper (Cu) 64	Ci				
Niobium (Nb) 95	Ci				3.66E-04
Rubidium (Rb) 88	Ci				
Ruthenium (Ru) 103	Ci				
Ruthenium (Ru) 105	Ci				
Ruthenium (Ru) 106	Ci				
Silver (Ag)110m	Ci			1.12E-03	7.93E-03
Sodium (Na) 24	Ci				
Strontium (Sr) 85	Ci				
Strontium (Sr) 89	Ci				
Strontium (Sr) 90	Ci				
Technetium(Tc) 99m	Ci				4.91E-05
Tin (Sn) 113	Ci				6.48E-05
Tungsten (W) 187	Ci				
Yttrium (Y) 91m	Ci				
Yttrium (Y) 92	Ci				
Zinc (Zn) 65	Ci				
Zirconium (Zr) 95	Ci				6.31E-05
TOTAL FOR PERIOD			7.39E-04	1.90E-02	8.26E-02

TABLE 2B

LIQUID EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT (1988)

Nuclides	Unit	CONTINUOUS MODE		BATCH MODE	
		1st Quarter	2nd Quarter	1st Quarter	2nd Quarter
Argon	(Ar) 41 Ci				2.45E-05
Xenon	(Xe) 131m Ci			7.41E-04	1.17E-02
Xenon	(Xe) 133 Ci		2.62E-05	9.76E-02	3.46E-01
Xenon	(Xe) 133m Ci			9.51E-04	1.65E-03
Xenon	(Xe) 135 Ci		2.18E-06	5.24E-04	3.64E-04
Krypton	(Kr) 85m Ci				
Krypton	(Kr) 85 Ci				
Krypton	(Kr) 88 Ci				
<u>TOTAL DISSOLVED AND ENTRAINED GASES</u>			2.84E-05	9.98E-02	3.60E-01

Indian Point 3
EFFLUENT AND WASTE DISPOSAL
SEMI-ANNUAL REPORT

D. SOLID WASTE
FIRST AND SECOND
QUARTERS, 1988

TABLE 3

EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT
January 1 - June 30, 1988

SOLID WASTE SHIPMENTS

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not irradiated fuel)

1. Type of Waste	Unit	6 Month Period		Est. Total Error, %
		Class A	Class B	
a. Spent resins, filter sludges, etc.	m ³	0	3.70E+0	± 25%
	Ci	0	3.11E+2	
b. Dry compressible, contam. equipment for burial	m ³	0	0	N/A
	Ci	0	0	
c. Irradiated Components	m ³	0	0	N/A
	Ci	0	0	
d. Other: Dry compressible, contaminated equip. for volume reduction at offsite facility	m ³	5.80E+1	0	± 25%
	Ci	8.30E-1	0	

2. Estimate of major nuclide composition (by type of waste)

NUCLIDE	UNIT	a. Resin	d. Dry-Vol. Reduction
		CLASS B	CLASS A
H-3	%	0	1
Mn-54	%	4	0
Fe-55	%	6	59
Co-58	%	10	5
Co-60	%	34	28
Ni-63	%	13	5
Cs-134	%	12	0
Cs-137	%	21	2

Percentage of nuclides and total activities are based on a combination of direct measurements and scaling for non-gamma emitting nuclides.

3. Solid Waste Disposition

<u>Number of Shipments</u>	<u>Mode of Transport</u>	<u>Destination</u>
1	Truck	Barnwell, SC
1	Truck	U.S. Ecology, Memphis, Tenn.
2	Truck	Alaron, Wampum, Pa.

4. Containers Shipped

<u>Container</u>	<u>Class A</u>		<u>Class B</u>	
	<u>Number</u>	<u>Solid. Media</u>	<u>Number</u>	<u>Solid. Media</u>
For Burial:				
Poly HIC	0	none	1	none

For Volume Reduction:

Drums	87	none	0	N/A
Crates	14	none	0	N/A

Indian Point 3
EFFLUENT AND WASTE DISPOSAL
SEMI-ANNUAL REPORT

E. RADIOLOGICAL IMPACT ON MAN

(Not required to be submitted during this reporting period. This section will be submitted with the third and fourth quarter 1988.)

Indian Point 3
EFFLUENT AND WASTE DISPOSAL
SEMI-ANNUAL REPORT

F. METEOROLOGICAL DATA

(Not required to be submitted during this reporting period. This section will be submitted with the third and fourth quarter 1988.)

Indian Point 3
EFFLUENT AND WASTE DISPOSAL
SEMI-ANNUAL REPORT

G. OFFSITE DOSE CALCULATION MANUAL CHANGES
FIRST AND SECOND
QUARTERS, 1988

(There were no revisions to the ODCM during this reporting period)

Indian Point 3
Nuclear Power Plant
P.O. Box 215
Buchanan, New York 10511
914 736.8001



William A. Josiger
Resident Manager

August 30, 1988
IP3-88-054

Docket No. 50-286
License No. DPR-64

Mr. William T. Russell, Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Dear Mr. Russell:

Enclosed is the Semi-Annual Report of Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents for Indian Point 3 as required by Section 5.3.3.1 of the Environmental Technical Specifications. The enclosed report covers the period January 1, 1988 through June 30, 1988 for Indian Point 3 and includes those releases from Indian Point 2 which resulted from processing liquid waste from Indian Point 3 when this pathway is utilized. The receiving stream flow has not yet been received from the Department of the Interior and will be supplied when available.

Sincerely,

A handwritten signature in cursive script, appearing to read 'W. A. Josiger', written over the typed name.

W. A. Josiger
Resident Manager
Indian Point 3
Nuclear Power Plant

WAJ:MK:lh

Enclosure

cc: Document Control Desk (original)
U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555

Resident Inspector's Office
Indian Point 3
U.S. Nuclear Regulatory Commission
P.O. Box 337
Buchanan, NY 10511

IE48
||