

Crystal River Nuclear Plant Docket No. 50-302 Operating License No. DPR-72

Ref: 10 CFR 50.55a

March 20, 2009 3F0309-01

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555-0001

Subject: Crystal River Unit 3 – Third Ten-Year Inservice Inspection (ISI) Interval Relief Requests #09-001-II, #09-002-II and #09-003-II

Dear Sir:

Pursuant to 10 CFR 50.55a(g)(5)(iii), Florida Power Corporation (FPC), doing business as Progress Energy Florida, Inc., hereby submits Relief Requests #09-001-II and #09-002-II. In addition, pursuant to 10 CFR 50.55a(g)(6)(ii)(A)(5) and 10 CFR 50.55a(a)(3)(i), FPC hereby submits Relief Request #09-003-II. The purpose of these relief requests is to seek approval for limited volumetric examinations performed on ASME Code Class 1 piping and nozzles, ASME Code Class 2 piping and nozzles, and on the ASME Code Class 1 Reactor Pressure Vessel Shell, respectively, during the Crystal River Unit 3 (CR-3) Third Ten-Year Inservice Inspection (ISI) Interval. These examinations covered less than 90 percent of the weld volume required to be examined by the ASME Boiler and Pressure Vessel Code, Section XI, 1989 Edition, no Addenda. These examinations were limited due to geometry or by interferences with other components.

The Third Ten-Year ISI Interval for CR-3 ended on August 13, 2008. FPC is requesting approval of these relief requests prior to August 14, 2009.

No new regulatory commitments are made in this submittal.

If you have any questions regarding this submittal, please contact Mr. Dan Westcott, Supervisor, Licensing and Regulatory Programs at (352) 563-4796.

Sincerely,

1. Chill

Stephen J. Cahill Manager, Engineering Crystal River Nuclear Plant

SJC/dwh

Enclosures: 1. Relief F

- 1. Relief Request #09-001-II
- 2. Relief Request #09-002-II
- 3. Relief Request #09-003-II

xc: NRR Project Manager Regional Administrator, NRC Region II Senior Resident Inspector

A047 NFR

Progress Energy Florida, Inc. Crystal River Nuclear Plant 15760 W. Power Line Street Crystal River, FL 34428

PROGRESS ENERGY FLORIDA, INC.

CRYSTAL RIVER UNIT 3

DOCKET NUMBER 50 - 302 / LICENSE NUMBER DPR - 72

ENCLOSURE 1

INSERVICE INSPECTION RELIEF REQUEST #09-001-II THIRD TEN-YEAR ISI INTERVAL

10 CFR 50.55a Request #09-001-II Relief Request in Accordance with 10 CFR 50.55a(g)(5)(iii)

--Inservice Inspection Impracticality--

1. ASME Code Component(s) Affected

ASME Code Class 1 Piping and Nozzles

Categories: B-D, B-J, B-M-1 and R-A

Items: B3.110, B3.120, B3.130, B3.140, B9.21, B12.40 and R1.20.

2. Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME), Boiler and Pressure Vessel Code, Section XI, 1989 Edition, no Addenda

3. Applicable Code Requirement

ASME Code, Section XI, Sub-article IWB-2500, states, in part, "Components shall be examined and tested as specified in Table IWB-2500-1." Table IWB-2500-1 requires an examination of applicable Class 1 pressure retaining-welds, which includes 100 percent of weld length once during the ten-year ISI interval for the following Code Categories:

Category B-D:	Items B3.110, B3.120, B3.130 and B3.140
Category B-J:	Items B9.21
Category B-M-1:	Items B12.40
Category R-A:	Items R1.20

A risk-informed in-service inspection (RI-ISI) program for Crystal River Unit 3 (CR-3) was approved by the NRC on September 20, 2005. The RI-ISI was developed for Class 1 piping welds for the Category B-F and B-J circumferential piping welds in a manner consistent with ASME Code, Section XI, Code Case N-578. Code Case N-578 requires 100 percent of the required volume of the weld and adjacent base material to be examined for Examination Category R-A, Item R1.20.

Code Case N-460 permits a reduction in examination coverage of Class 1 and Class 2 welds, provided the coverage reduction is less than 10 percent. CR-3 has adopted Code Case N-460 in the Inservice Inspection (ISI) Program Plan, as permitted by NRC Regulatory Guide 1.147, Revision 15, "Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1."

4. Impracticality of Compliance

At the time CR-3 was constructed, the ASME Boiler and Pressure Vessel Code only addressed nuclear vessels and associated piping up to and including the first isolation valve. The piping codes of record were USAS B31.7, 1968 Edition for nuclear piping, and USAS B31.1.0-1967 Edition for non-nuclear piping.

10 CFR 50.55a recognizes the limitations to in-service inspection of components in accordance with Section XI of the ASME Code that are imposed due to early plants design and construction, as follows: 10 CFR 50.55a(g)(1), "For a boiling or pressurized water-cooled nuclear power facility whose construction permit was issued prior to January 1, 1971, components (including supports) must meet the requirements of paragraphs (g)(4) and (g)(5) of this section to the extent practical." 10 CFR 50.55a(g)(1) is applicable since the CR-3 construction permit was dated September 25, 1968.

10 CFR 50.55a(g)(4) states, "Throughout the service life of a boiling or pressurized water-cooled nuclear power facility, components (including supports) which are classified as ASME Code Class 1, Class 2, and Class 3 must meet the requirements, except design and access provisions and pre-service examination requirements, set forth in Section XI of editions of the ASME Boiler and Pressure Vessel Code ... to the extent practical within the limitations of design, geometry and materials of construction of the components."

10 CFR 50.55a(g)(5)(iii) states, "If the licensee has determined that conformance with certain code requirements is impractical for its facility, the licensee shall notify the Commission and submit, as specified in § 50.4, information to support the determinations." CR-3 has determined that the following welds were limited from achieving greater than 90 percent of the required examination volume for in-service examinations due to component configuration or physical barriers, which would require a major modification to the existing hardware.

Therefore, relief is being sought from coverage requirements set forth in ASME Code, Section XI, Sub-article IWB-2500, in accordance with 10 CFR 50.55a(g)(5)(iii). Relief is requested from performing volumetric examinations of the welds listed in Table A to the extent required by the Code. These examinations are limited by part geometry or interferences with other components such that the reduction in coverage is greater than 10 percent.

-00/3 - 00	au carbon st	eel				<u> 3/3 - Sla</u>	iniess steel
Category	Item	Summary Number	Diameter	Thickness	Material	Coverage Percentage	Description
B-D	B3.110	B2.2.1A	N/A	4.75"	CC/S*	50	Nozzle To Head Welds
		B2.2.2A	N/A	4.75"	CC/S	50	Nozzle To Head Welds
		B2.2.3A	N/A	4.75"	CC/S	50	Nozzle To Head Welds
		B2.2.4A	N/A	4.75"	CC/S	56	Nozzle To Head Welds
	B3.120	B2.2.1B	N/A	5.0"	CC/S	42	Nozzle Inner Radius
		B2.2.2B	N/A	5.0"	CC/S	42	Nozzle Inner Radius
		B2.2.3B	N/A	5.0"	CC/S	42	Nozzle Inner Radius

TABLE A

*CC/S = clad carbon steel

**S/S = stainless steel

U. S. Nuclear Regulatory Commission 3F0309-01

Category	Item	Summary Number	Diameter	Thickness	Material	Coverage Percentage	Description
		B2.2.4B	N/A .	5.0"	CC/S	48	Nozzle Inner Radius
	B3.130	B3.2.1	N/A	8.4"	CC/S	46	Steam Generator Nozzle To Head Weld.
		B3.2.2	N/A	8.4"	CC/S	63	Steam Generator Nozzle To Head Weld.
		B3.2.3	N/A	8.4"	CC/S	50	Steam Generator Nozzle To Head Weld.
		B3.2.4	N/A	8.4"	CC/S	46	Steam Generator Nozzle To Head Weld.
		B3.2.5	N/A	8.4"	CC/S	63	Steam Generator Nozzle to Head Weld
		B3.2.6	N/A	8.4"	CC/S	49	Steam Generator Nozzle to Head Weld
	B3.140	B3.2.1.1	N/A	8.4"	CC/S	61	Nozzle Inner Radius
		B3.2.2.1	N/A	8.4"	CC/S	48	Nozzle Inner Radius
		B3.2.3.1	N/A	8.4"	CC/S	43	Nozzle Inner Radius
		B3.2.4.1	N/A	8.4"	CC/S	61	Nozzle Inner Radius
		B3.2.5.1	N/A	8.4"	CC/S	48	Nozzle Inner Radius
		B3.2.6.1	N/A	8.4"	CC/S	43	Nozzle Inner Radius
B-J	B9.21	B4.5.62	2.5"	.375"	S/S**	50	Valve to Pipe
		B4.5.71.3	2.5"	.375"	S/S**	50	Valve To Pipe
		B4.5.71.4	2.5"	.375"	S/S	50	Pipe to Safe End
		B4.5.79.4	2.5"	.375"	S/S	50	Valve to Pipe
;		B4.5.79.5	2.5"	.375"	S/S	50	Pipe To Safe End
		B4.5.84.2	2.5"	.375"	S/S	50	Valve to Pipe
		B4.5.84.4	2.5"	.375"	S/S	50	Pipe to Safe End
		B4.5.151	2.5"	.375"	S/S	50	Pipe to Tee

Category	ltem	Summary Number	Diameter	Thickness	Material	Coverage Percentage	Description
		B4.5.165	2.5"	.375"	S/S	50	Valve To Pipe
B-M-1	B12.40	B6.6.7	14"	.750"	S/S	0	Valve Body To Canopy
R-A	R1.20	B4.5.108.17 (RI-ISI)	4.0"	.438"	S/S	50	Elbow To Valve

Examination Details

B3.110 Pressurizer Nozzle-to-Head Welds: B2.2.1A, B2.2.2A, B2.2.3A and B2.2.4A

The pressurizer nozzle-to-vessel head welds are accessible only from the head side, based on the nozzle curvature. The scanning surface of the nozzle is perpendicular to the head surface, which prohibits the ultrasonic wave entering the Code required examination volume at an angle that will integrate the weld volume for in-service flaws. The non-destructive examination (NDE) techniques and procedures used incorporate examination techniques qualified under Appendix VIII of the ASME Section XI Code by the Performance Demonstration Initiative (PDI) for examination of the subject vessel welds. (See Attachment A for the cross-sectional view of the weld and limitations.)

B3.120 Pressurizer Nozzle Inside Radius: B2.2.1B, B2.2.2B, B2.2.3B and B2.2.4B

The pressurizer nozzle inside radii are accessible only from the head side, based on the nozzle curvature. The scanning surface of the nozzle is perpendicular to the head surface, which prohibits the ultrasonic wave entering the Code required examination volume at an angle that will integrate the area volume for in-service flaws. The NDE techniques and procedures used incorporate examination techniques qualified under Appendix VIII of the ASME Section XI Code by the PDI for examination of the subject vessel welds. (See Attachment A for the cross-sectional view of the weld and limitations.)

B3.130 Steam Generator Nozzle-to-Head Welds: B3.2.1, B3.2.2, B3.2.3, B3.2.4, B3.2.5 and B3.2.6

The steam generator nozzle-to-vessel head welds are accessible only from the head side, based on the designed nozzle configuration. The proximity of the nozzle radius prevented examination coverage from the nozzle side. Scanning was performed from the nozzle. However, the ultrasonic waves did not cover the Code required examination volume at an angle that will integrate the weld volume for in-service flaws. The NDE techniques and procedures used incorporate examination techniques qualified under Appendix VIII of the ASME Section XI Code by the PDI for examination of the subject welds. (See Attachment A for the cross-sectional view of the weld and limitations.)

B3.140 Steam Generator Nozzle Inside Radius: B3.2.1.1, B3.2.2.1, B3.2.3.1, B3.2.4.1, B3.2.5.1 and B3.2.6.1

The steam generator nozzle inside radii are accessible only from the head side, based on the designed nozzle configuration. The proximity of the nozzle outer radius prevented examination coverage from the nozzle side. Scanning was performed from the nozzle. However, the ultrasonic waves did not cover the Code required examination volume at an angle that will integrate the area volume for in-service flaws. The NDE techniques and procedures used incorporate examination techniques qualified under Appendix VIII of the ASME Section XI Code by the PDI for examination of the subject welds. (See Attachment A for the cross-sectional view of the weld and limitations.)

<u>B9.21 Circumferential Pipe Welds: B4.5.62, B4.5.71.3, B4.5.71.4, B4.5.79.4, B4.5.79.5,</u> B4.5.84.2, B4.5.84.4, B4.5.151 and B4.5.165

The ultrasonic examination of the above pipe welds was limited in coverage due to component configuration and/or immovable physical barriers. It is not possible to perform the ultrasonic examination from both sides of the weld since one side of the weld was not suitable for scanning based on the scanning surface angle of the component. Therefore, the welds only received a single sided examination or partial single sided examination resulting in less than 90 percent coverage of the required examination volume. The percentage of coverage reported represents the aggregate coverage from all examination angles and scans performed on the weld and adjacent base material. The NDE techniques and procedures used incorporate examination techniques qualified under Appendix VIII of the ASME Section XI Code by the PDI for examination of the pipe welds. (See Attachment A for the cross-sectional view of the weld and limitations.)

B12.40 Valve body Weld: B6.6.7

Ultrasonic examination of the above valve to body weld could not be performed due to being inaccessible. The valve would require disassembly for access to the weld. Relief is being sought on the basis that, due to the design of the valve, disassembly of DHV-3 is required for access to the weld, including the removal of a weld joining the clamp to the yoke holding the upper assembly. DHV-3 had a history of pressure seal ring leakage. Due to the significant consequences of the leakage (DHV-3 is the first isolation valve between the Reactor Coolant System and the Decay Heat System and contains the only weld of this type at CR-3), a modification was implemented during the Third Ten-Year ISI Interval to eliminate the pressure seal ring joint. A canopy was installed over the pressure seal ring joint with Summary Number B6.6.7 being the identifier of the resultant valve body weld. Preservice examinations consisting of ultrasonic and liquid penetrant were performed satisfactorily with no indications. (See Attachment A for representative drawings of DHV-3.)

R1.20 Circumferential Pipe Weld: B4.5.108.17 (RI-ISI)

Ultrasonic examination of the above pipe weld was limited in coverage due to component configuration and/or immovable physical barriers. It is not possible to perform the ultrasonic examination from both sides of the weld since one side of the weld was not suitable for scanning, based on the scanning surface angle of the component. Therefore, the weld only received a single sided examination or partial single sided examination resulting in less than 90 percent coverage of the required examination volume. The percentage of coverage reported represents the aggregate coverage from all examination angles and scans performed on the weld and adjacent base material. The NDE techniques and procedures used incorporate examination techniques qualified under Appendix VIII of the ASME Section XI Code by the PDI for examination of the pipe welds. (See Attachment A for the cross-sectional view of the weld and limitations.)

U. S. Nuclear Regulatory Commission 3F0309-01

5. Burden Caused by Compliance

In order to scan all of the required volume for these welds and inside radii, the components would have to be redesigned to allow scanning from both sides of the weld and inside radii, which is impractical. There were no recordable indications, other than geometric indications, found during the inspection of these welds and inside radii. Based on the components' designed configuration, the coverage obtained did not meet the requirements of the ASME Code, Code Case N-578 or Code Case N-460.

In accordance with 10 CFR 50.55a(g)(5)(iii), relief is requested for the components listed in Table A on the basis that the required examination coverage of essentially 100 percent is impractical due to physical obstructions and the limitations imposed by design, geometry, and materials of construction. CR-3 utilized examination techniques qualified to meet the requirements of ASME Section XI, Appendix VIII, as required in 10 CFR 50.55a(g)(6)(a)(c), that achieved the maximum practical amount of coverage obtainable within the limitations imposed by the design of the components and examination techniques. Additionally, VT-2 examinations are performed on the subject components of the Reactor Coolant Pressure Boundary during system pressure tests on a refueling outage frequency. Those examinations were completed each refueling outage and no evidence of leakage was identified for these components.

The mandated requirement in 10 CFR 50.55a(b)(2)(xv)(A)(2) states, "Where examination from both sides is not possible on austenitic welds, full coverage credit from a single side may be claimed only after completing a successful single sided Appendix VIII demonstration using flaw on the opposite side of the weld." The Appendix VIII techniques applied at CR-3 and within the U. S. nuclear industry, (PDI-UT-2), are not qualified for "Detection or length sizing of circumferentially oriented flaw indications when only single side access is available and the flaw is located on the far side of the weld."

Based on the design configuration of the components and available examinations techniques, CR-3 was not able to achieve greater than 90 percent Code coverage of the required examination volume for the components listed above without major modifications to the components.

6. **Proposed Alternative and Basis for Use**

No alternative examinations were planned for these welds during the Third Ten-Year ISI Interval. The use of radiography as an alternate volumetric examination for the above listed components is not practical due to component thickness and geometric configurations. Other restrictions making radiography impractical are the physical barriers prohibiting access for placement of source, film, image quality indicator, etc. Additionally, inside radius exams of Class 1 nozzles on pressurizers and steam generators are no longer required by the Code.

Based on the above, with due consideration of the earlier plant design, the underlying objectives of the Code required volumetric examinations have been met. The examinations were completed to the extent practical and evidenced no unacceptable flaws present. VT-2 examinations performed on the subject Class 1 components during system pressure testing each refueling outage provide continued assurance that the structural integrity of the subject components is maintained.

Ultrasonic examination of these welds was conducted using personnel qualified in accordance with ASME Section XI, Appendix VII of the 1998 Edition, no Addenda. Ultrasonic procedures complied with the requirements of ASME Section V, Article 4 of the 1989 Edition, as amended by Section XI, Appendix I. IWB-2500, Table IWB-2500-1, Examination Category B-P System Leakage Tests and VT-2 visual examinations performed each refueling outage provide adequate assurance of pressure boundary integrity. In addition to the above Code required examinations (volumetric and pressure test), there are other activities which provide a high level of confidence that, in the unlikely event that leakage did occur through these welds, it would be detected and proper action taken. Specifically, system leak rate limitations are imposed by Improved Technical Specification 3.4.12, "RCS Operational LEAKAGE," and reactor building normal sump rate monitoring provides additional assurance that any leakage would be detected prior to gross failure of the component. The component welds were inspected by volumetric and surface NDE methods during construction and verified to be free from unacceptable fabrication defects.

Therefore, reasonable assurance of quality and safety is based on the achieved coverage and results of the volumetric and/or surface and the pressure testing VT-2 examinations performed.

7. Duration of Proposed Alternative

Relief is requested for the Third Ten-Year ISI Interval for CR-3, which was effective from August 14, 1998, ending August 13, 2008.

8. **Precedents (Optional)**

9. References (Optional)

ENCLOSURE 1

ATTACHMENT A

COVERAGE DATA

INSERVICE INSPECTION RELIEF REQUEST #09-001-II THIRD TEN-YEAR ISI INTERVAL

EXAMINATION COVERAGE FOR RELIEF NOZZLE: B2.2.1

AGGREGATE COVERAGE OBTAINED:

Weld 45%

AGGREGATE COVERAGE OBTAINED FOR INSIDE RADIUS: 42%

Inside Radius: 42%

Zone Coverage Obtained Adjacent Base Me 55%

50%

			UPPE	R SECTI	ON EVA	UATION	<u> </u>	· · ·
與思想派		World St.	Exe	mination.	Jolume De	finition 🔅	en her i	nia Mantania Ale
		Weld	Diameter:	9.53	in.	Nozzle Bo	re Diameter:	2.5 in.
[Area Mea	surement				Volume C	alculation	
Weld		10.48	sq. in.		Weld		. 156.9	cu.in
Adjacent I	Base Meta	27.77	sq. in.		Adjacent I	Base Meta	415.7	cu. in.
Inside Rad	ius	2.9	są. in,		Inside Ra	dius	11.2	cu. in.
Binanout	S filmer?	ta contra da	Se Exam	nation Co	verage Ca	louiations	deren service	energy and a second second
Weld								
	Exam.		Area	Degrees	emuloV	Volume		
1	Angle	Beam	Examined	Examined	Examined	Required	Percent	
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined	
	0	n/a	0.0	180.0	0.0	156.9	0%	
2	45	1	4.3	180.0	63.8	156.9	41%	
3	45	2	0.0	180.0	0.0	156.9	0%	
4	45	3	0.5	180.0	7.6	156.9	5%	
5	45	4	0.5	180.0	7.6	156.9	5%	
6	60	1	7.2	180.0	107.8	156.9	69%	
7	60	2	0.0	180.0	0.0	156.9	0%	
8	60	3	4.4	180.0	65.3	156.9	42%	
9	60	4	4.4	180.0	65.3	156.9	42%	
				Totals:	317.4	1411.9	22%	
Adjacent	Base Meta	3		_				
	Exam.	_	Area	Degrees	Volume	Volume	. .	
	Angle	Beam	Examined	Examined	Examined	Required	Percent	
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined	
1	0	n/a	7.7	180.0	114.8	415.7	28%	
2	45	182	14.6	180.0	218.0	415.7	52%	:
3	45	3	7.7	180.0	114.8	415.7	28%	
4	45	4	7.7	180.0	114.8	415.7	28%	
5	60	182	17.6	180.0	263.0	415.7	63%	· •
6	60	3	16.9	180.0	252.7	415.7	61%	
7	60	4	16.9	180.0	252.7	415.7	61%	
				Totals:	1330.8	2910.0	45%	
inside Ra	dius		•		M-1	1 da 1		
	Exam.	-	Area	Degrees	voiume	voiume		
	Angle	Beam	Examined	Examined	Examined	Required	Percent	
Entry #	(deg.)	Direction	(sq. in.)	(In.)	(cu. in.)	(cu. in.)	Examined	
	45	axial	0.2	180.0	0.9	11.2	0%	
2	45	CIFC	0.1	180.0	0.4	11.2	3% 579/	
3	60	axial	1.5	180.0	5.9	11.2	32%	
1 4	60	CILC	1.4	180.0	5.5	11.2	49%	
				i qta/\$;	72.7	44.9	20%	

	LOWER SECTION EVALUATION											
12 . 24	A. AREA STATE		Exa Exa	mination	/olume De	Inition	"我们的是是"					
L		Weld	Diameter:	9.53	in.	Nozzle Bore	e Diameter:	2.5 in.				
	Area Mea	surement				Volume Ca	lculation					
Weld		7.93	sq. in.		Weld		118.7	cu. in.				
Adjacent E	Base Meta	21.71	sq. in.	1	Adjacent E	lase Metal	325.0	cu, in.				
Inside Rac	li⊔s	2.5	sq. in.		Inside Rac	lius	9.7	cu. in.				
								· · · · · · · · · · · · · · · · · · ·				
FEFERENCE.	Charles and the	L. Constant	taina Examp	nation.Co	verage Cal	culations	charlishphy.	states - a training				
Weld												
l	Exam.		Area	Degrees	Volume	Volume	. .					
	Angle	8eam	Examined	Examined	Examined	Required	Percent					
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined					
1	0	n/a	5.5	180.0	81.7	118.7	69%					
2.	45	1	7.1	180.0	105.7	118.7	89%	•				
3	45	2	0.0	180.0	0.0	118.7	0%					
4	45	з	6.7	180.0	100.1	118.7	84%					
5	45	4	6.7	180.0	100.1	118.7	84%					
6	60	1	7.3	180.0	109.3	118.7	92%					
7	60	2	0.0	180.0	0.0	118.7	0%					
8	60	3	7.2	180.0	107.6	118.7	91%					
9	60	4	7.2	180.0	107.6	118.7	91%					
1				Totals:	712.3	1068.4	67%					
Adjacent	Base Meta	al										
	Exam.		Area	Degrees	Volume	Volume						
	Angle	Beam	Examined	Examined	Examined	Required	Percent					
Entry #	(deg.)	Direction	(sg. in.)	(in.)	(cu. in.)	(cu. in.)	Examined					
1		n/a	11.3	180.0	169.2	325.0	52%					
2	45	182	16.0	180.0	239.8	325.0	74%	1				
3	45	3	11.3	180.0	169.2	325.0	52%					
4	45	4	11.3	180.0	169.2	325.0	52%	· · · · · · · · · · · · · · · · · · ·				
5	60	182	17.1	180.0	256.6	325.0	79%					
6	60	3	15.0	180.0	224.1	325.0	69%					
7	60	4	15.0	180.0	224.1	325.0	69%					
				Totals:	1452.1	2274.9	64%					
Inside Rad	dius											
ŧ	Exam.		Area	Degrees	Volume	Volume						
	Angle	Beam	Examined	Examined	Examined	Required	Percent					
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined					
1	45	axial	.1.6	180.0	6.4	9.7	66%					
2	45	circ	0.6	180.0	2.2	9.7	23%					
3	60	axiał	2.1	180.0	8.1	9.7	84%					
4	60	circ	1.2	180.0	4.7	9.7	49%					
¥.				Totais:	21.4	38,6	55%					

PRESSURIZER RELIEF NOZZLE TO UPPER HEAD (WELD WP-33) B2.2.I UPPER LOWER

· .

EXAMINATION COVERAGE FOR RELIEF NOZZLE: B2.2.2

AGGREGATE COVERAGE OBTAINED: 50%

Weld 45%

AGGREGATE COVERAGE OBTAINED FOR INSIDE RADIUS 42%

Zone Coverage Obtained Adjacent Base Metal: 55%

Inside Radius: 42%

			UPP	ER SECT	ION EVA	LUATIO	V	
199137	177578	TRACE BAS	SHOP LE	camination	Volume D	efinitions	加快省。是不同时,	154 DEFENSE
		Weld	Diameter:	9.53	in.	Nozzle Bor	e Diameter:	2.5 in.
	Area Mea	surement				Volume Ci	alculation	
Weld		10.48	sq. in.		Weld		156.9 cu. in.	
Adjacent	Base Metal	27.77	sq. in.		Adjacent E	Base Metai	415.7 cu. in.	
Inside Ra	dius	2.9	sq. in.		Inside Rad	lius	11.2 cu. in.	
				_				
1-14 1 pr.		的高级运动	sea the Exam	nination C	overage:C	alculations	Supplication and a second	ARTINE STREET
weid	-							
	Exam.	_	Area	Degrees	volume	volume		
	Angle	Beam	Examined	Examined	Examined	Required	Percent	
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu, in.)	(cu. in.)	Examined	· · · · · · · · · · · · · · · · · · ·
1	0	n/a	0.0	180.0	0.0	156,9	0%	
2	35/45	1	4.3	180.0	63.8	156.9	41%	
3	35/45	2	0.0	180.0	0.0	156,9	0%	
4	35/45	3	0.5	180.0	7.6	156.9	5%	
5	35/45	4	0.5	180.0	7.6	156.9	5%	
6	60	1	7.2	180.0	107.8	156.9	69%	
7	60	2	0.0	180.0	0.0	156.9	0%	
8	60	3	4.4	180.0	65.3	156.9	42%	
9	60	4	4.4	180.0	65.3	156.9	42%	
				Totals:	317.4	1411,9	22%	
Adjacent	: Base Meta	1						•
	Exam.		Area	Degrees	Volume	Volume		
	Angle	Beam	Examined	Examined	Examined	Required	Percent	
Entry #	(deg.)	Direction	_(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined	
1	0	n/a	7.7	180.0	114.8	415.7	28%	
2	35/45	182	14,6	180.0	218.0	415.7	52%	
3	35/45	3	7.7	180.0	114.8	415.7	28%	
4	35/45	4	7.7	180.0	114.8	415.7	28%	
5	60	1&2	17.6	180.0	263.0	415.7	63%	
6	60	3	16.9	180.0	252.7	415.7	61%	
7	60	4	16.9	180.0	252.7	415.7	61%	
				Totais:	1330.8	2910.0	46%	
Inside Ra	Idius							
	Exam.		Area	Degrees	Volume	Volume		
	Angle	Beam	Examined	Examined	Examined	Required	Percent	
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. <u>In.</u>)	(cu. in.)	Examined	
1	45	axial	0.2	180.0	0.9	11.2	8%	
2	45	circ	0.1	180.0	0.4	11.2	3%	
3	60	axial	. 1.5	180.0	5.9	11,2	52%	
4	60	circ	1.4	180.0	5.5	11.2	49%	
				Totals:	12.7	44.9	28%	

			LOWE	R SECTI	ON EVAL	UATION		
941 (S. 25)	379 R H	<u> (2230)</u> 3	S. Exe	mination \	olume Del	Inition 🖉		
		Weld	Diameter:	9.53	in.	Nozzle Bore	Diameter:	2.5 in.
	Area Mea	surement				Volume Ca	lculation	
Weld		7.93	sq. in.		Weld		118.7	cu, in.
Adjacent I	Base Metal	21.71	sq. in.		Adjacent E	lase Metal	325.0	cu. in.
inside Ra	dius	2.5	sq. in,		Inside Rad	lius	9.7	cu. in.
ne state div	en commune		see exam	nation Go	verage Gal	cuiations ; 🕸	As shirts as	ST. W. BY CO
Weid	E.em		A	0		Valuma		
	Exam.	D	Area	Degrees	Volume	Volume	D	
P	Angle	Beam	Examined	Examined	Examined	Required	Percent	
	(aeg.)	Urection	(sq. in.)	(In.)	<u>(cu. in.)</u>	(cu, in.)	examined	
1	0	n/a	5.5	180.0	81.7	118.7	69%	
2	35/45	1	7.1	180.0	105.7	118.7	89%	
3	35/45	2	0.0	180.0	. 0.0	118.7	0%	
. 4	35/45	3	6.7	180.0	100.1	118.7	84%	
5	35/45	4	6.7	180.0	100.1	118.7	84%	
6	60	· 1	7.3	180.0	109.3	118.7	92%	
7	60	2	0.0	180.0	0,0	118.7	0%	
8	60	- 3	7.2	180.0	107.6	118.7	91%	
9	60	4	7.2	180.0	107.6	118.7	91%	
				Totals:	712.3	1068.4	67%	
Adjacent	Base Meta			_				
	Exam.		Area	Degrees	Volume	Volume		
•	Angle	Beam	Examined	Examined	Examined	Required	Percent	
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined	
1	0	n/a	11.3	180.0	169.2	325.0	52%	
2	35/45	182	16.0	180.0	239.8	325.0	74%	
3	35/45	3	11.3	180.0	169.2	325.0	52%	
4	35/45	· 4	11.3	180.0	169.2	325.0	52%	
5	60	182	17:1	180.0	256.6	325.0	79%	
6	60	3	15.0	180.0	224.1	325.0	69%	
7	60	4	15.D	180.0	224.1	325.0	69%	
				Totais:	1452.1	2274.9	64%	
nside Ra	dius							
	Exem.		Area	Degrees	Volume	Volume		
	Angle	Beam	Examined	Examined	Examined	Required	Percent	
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined	
1	45	axial	1.6	180.0	6.4	9.7	66%	
2	45	circ	0.6	180.0	2.2	9.7	23%	
3	60	axial	2.1	180.0	8.1	9.7	84%	
4	60	circ	1.2	180.0	4.7	9.7	49%	
				Totels	21.4	38.6	55%	



EXAMINATION COVERAGE FOR RELIEF NOZZLE: B2.2.3

AGGREGATE COVERAGE OBTAINED: 50%

Weld 45%

AGGREGATE COVERAGE OBTAINED FOR INSIDE RADIUS 42%

Zone Coverage Obtained Adjacent Base Me 55%

Inside Radius: 42%

	_					111 110 11			and the second design of the
			UPPE	R SECTI	ON EVAL	UATION		·	
347 N 24			E E	mination	/oiume De	finition	(1. 1. CT. 14)	Date A.	S.U.S. 400.000
		Weld	Diameter:	9.53	in.	Nozzle Bo	re Diameter:	2.5	in.
	Area Mea	surement		_		Volume C	alculation		
Weld		10.48	sq. in.		Weld		156.9	cu, in,	
Adjacent I	Base Meta	27.77	sq. in.		Adjacent I	Base Meta	415.7	cu, in,	
Inside Rad	dius	2.9	sq. in.		Inside Rad	dius	11.2	cu, in,	
	•		• •						
h \$ 4.00 - \$1	a entrange a un	1211222	s Exam	nation Co	verage Ca	culations	Level and the	in the second second	The Lines
Weld									
	Exam.		Area	Degrees	Volume	Volume			
1	Angle	Beam	Examined	Examined	Examined	Required	Percent		
Entry #	(deg)	Direction	(sq. in.)	(in.)	(cu, in.)	(cu, in,)	Examined		
<u> </u>	0	r/a	0.0	180.0	0.0	156.9	0%		
2	35/45	1	4.3	180.0	63.8	156.9	41%		
3	35/45	2	0.0	18D.D	0.0	156.9	0%		
4	35/45	3	0.5	180.0	7.6	156.9	5%		
5	35/45	4	0.5	180.0	7.6	156.9	5%		
6	60	1	7.2	180.0	107.8	156.9	69%		
7	60	2	0.0	180.0	0.0	156.9	0%		
Å	60	3	4 4	180.0	65.3	156.9	42%		
ă	60	4	44	180.0	65.3	156.9	42%		
1 1		-		Totals:	317.4	1411.9	22%		
Adjacent	Rase Meta	al							
	Exam	-	Area	Degrees	Volume	Volume			
	Angle	Beam	Fxamined	Examined	Examined	Required	Percent		
Entry #	(dea.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined		
1	0	n/a	7.7	180.0	114.8	415.7	28%		
2	35/45	182	14.6	180.0	218.0	415.7	52%		
3	35/45	3	7.7	180.0	114.8	415.7	28%		
4	35/45	4	7.7	180.0	114.8	415.7	28%		
5	60	182	17.6	180.0	263.0	415.7	63%		
6	60	3	16.9	180.0	252.7	415,7	61%		
7	60	4	16.9	180.0	252.7	415.7	61%		
l '				Totals:	1330.8	2910.0	46%		
Inside Ra	dius							_	
	Exam		Area	Decrees	Volume	Volume			
1	Angle	Beam	Examined	Examined	Examined	Required	Percent		
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined		-
1	45	axial	02	180.0	0.9	11.2	8%		
2	45	circ	01	180.0	0.4	11.2	3%		
	60	avial	1.5	180.0	5.9	11.2	52%		
Ĭ Ă	60	circ	1.4	180.0	5.5	11.2	49%		
	••		1.3	Totals:	12.7	44.9	28%		

	_		LOWE	R SECTI	ON EVAL	UATION		
v so di N	rpi stra se	N3223	Exa	mination.V	olume De	Inition	1997	
		Weld	Diameter:	9,53	in	Nozzle Bor	e Diameter:	2.5 in.
	Area Mea	surement				Volume C	aculation	
Weld		7.93	sq. in.		Weld		118.7	çu.in.
Adjacent	Base Meta	21.71	sq. in.		Adjacent E	Base Metal	325.0	cu.in.
Inside Ra	dius	2.5	sq. in.		Inside Rad	tius	9.7	cu. in.
and the second	ent and single the	WARD SAME		nillion con	avada cun	culationa		A RECEIPTING A PROPERTY.
Neld								
	Exam.		Area	Degrees	Volume	Volume		
	Angle	Beam	Examined	Examined	Examined	Required	Percent .	
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu, in.)	(cu. in.)	Examined	
1	0	n/a	5.5	180.0	81.7	118.7	69%	
2	35/45	1	7.1	180.0	105.7	118.7	89%	
3	35/45	2	0.0	180.0	0.0	118.7	0%	
4	35/45	3	67	180.0	100.1	118.7	84%	
5	35/45	4	6.7	180.0	100.1	118.7	84%	
5	60	1	7.3	180.0	109.3	118.7	92%	
7	60	2	0.0	180.0	0.0	118.7	0%	
Ŕ	60	3	7.2	180.0	107.6	118.7	91%	
ă	60	4	72	180.0	107.6	118.7	91%	
°,				Totals:	712.3	1068.4	67%	
Adjacent	Base Metz	1						
	Exam.		Area	Degrees	Volume	Volume		
	Angle	Beam	Examined	Examined	Examined	Required	Percent	
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu, in.)	Examined	
1	0	n/a	11.3	180.0	169.2	325.0	52%	
2	35/45	182	16.0	180.0	239.8	325.0	74%	
3	35/45	з	11.3	180.0	169.2	325.0	52%	
. 4	35/45	4	11.3	160.0	169.2	325.0	52%	
5	60	1&2	17.1	180.0	256.6	325.0	79%	
6	60	3	15.0	180.0	224.1	325.0	69%	
7 ·	60	4	15.0	180.0	224.1	325,0	69%	
				Totals:	1452.1	2274.9	64%	
inside Ra	idius							
	Exam.		Area	Degrees	Volume	Volume		
	Angle	Beam	Examined	Examined	Examined	Required	Percent	
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined	
1	45	axial	1.6	180,0	6.4	9.7	66%	
2	45	circ	0.6	180.0	2.2	9.7	23%	
3	60	axial	2.1	180,0	8.1	9.7	84%	
4	60	circ	1.2	180.0	4.7	9.7	49%	
				Totals:	21.4	38.6	55%	



EXAMINATION COVERAGE FOR WELD: B2.2.4 PRESSURIZER SPRAY NOZZLE TO HEAD & INNER RADIUS AGGREGATE COVERAGE OBTAINED: AGGREGATE COVERAGE OBTAINED: 56%

			Zon	e Covera	ige Obtai	ined			
Weld:	52%		Adjacent I	Base Metal	58%		Inner Rad	ius:	48%
	2-69252		T, Exan	ination Vo	lume Defi	nition	Star-Last	staal saa	1921-115-1994)
		We	d Length:	27.49	in.			BORE	
	Area Mea	surement				Volume C	alculation	•	
vveid	-	0,01	sq. in.		vveid		181.7089	cu. in.	
Adjacent I	Base Metal	24.36	sq. in.		Adjacent E	sase Metal	669.6564	cu. in:	
Inner Rad	ius	2.38	sq. in.		Inner Radi	us	9.52	cu. m.	
al tabaaces	The second states	and the second	Examin	ation Cove	rage Calc	ulations		an ganalana	
Weld	,								
	Exam.		Area	Length	Volume	Volume			
	Angle	Beam	Examined	Examined	Examined	Required	Percent		
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined		
1	Ō	n/a	3.6	27.49	99.8	181.7	55%		
.2	45	1	6.1	27.49	168.5	181.7	93%		
3	45	2	0.0	27.49	0.0	181.7	0%		
4	45	3	3.6	27.49	99.8	181.7	55%		
5	45	4	3.6	27.49	99.8	181.7	55%		
6	60	1	6.4	27.49	174.8	181.7	96%		
7	60	2	0.0	27.49	0.0	181.7	0%		
8	60	3	3.6	27.49	99.8	181.7	55%		
9	60	4	3.6	27.49	99.8	181.7	55%		
				Totals:	842.3	1635.4	52%		
Adjacent	Base Meta	1							
-	Exam.		Area	Length	Volume	Volume			
	Angle	Beam	Examined	Examined	Examined	Required	Percent		
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined		,
1	Ì O É	n/a	12.4	27.49	339.8	669.7	51%		
2	45	1&2	18.3	27.49	503.1	669.7	75%		
3	45	3	12.4	27.49	339.8	669.7	51%		
4	45	4	12.4	27.49	339.8	669.7	51%		
5	60	1&2	19.7	27.49	541.8	669.7	81%		•
6	60	3	12.4	27.49	339.8	669.7	51%		
7	60	4	12.4	37.7	466.0	918.4	51%		
-		-		Totals:	2870.0	4936.3	58%		
Inner Rac	lius								
	Exam.		Area	Length	Volume	Volume			
	Angle	Beam	Examined	Examined	Examined	Required	Percent .		
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined		
1	45	axial	1.0	12.6	12.6	29.9	42%		
2	45	circ	. 0.6	12.6	7.4	29.9	25%		
3	60	axial	1.6	12.6	20.6	29.9	69%		
4	60	circ	1.3	12.6	16.7	29.9	56%		
				Totals:	57.3	119.6	48%		





	Nuclear	Sup	plem	ental Rep	oort			
<i>(</i> NGG	Generation Group					Report No	<u> </u>	Г-03-137
						Page	2	of <u>3</u>
Summary No	<u>B3 2 1</u>	-						
Examiner	Brannın, Michael MR	Level		Reviewer	N/A		Date	
Examiner	Dittrich, Victor W Ang	Level		Site Review	Hecht, Jeff W / LV	<u> </u>	Date	11-13-03
Other	<u>N/A</u>	Level	<u>N/A</u>	ANII Review	C. Colarte	cse	Date	12-8-03

Comments Examination Coverage for Weld: B3 2.1

Sketch or Photo L \Shared\ISIdata\IDDEAL Documentation\RO13\UT_03_137a JPG

EXAMINATION COVERAGE FOR WELD B3.2 1 STEAM GENERATOR 'A' INLET NOZZLE 'WG25' & INNER RADIUS AGGREGATE COVERAGE OBTAINED 46%

			Zor	e Covan	age Obta	ined			
Weld	29%		Adjacent B	lase Melai	51%		Inner Radiu	5	61%
			Exam	V notitani	olume Defi	nition			
		We	ld Length	179 54	۱ŋ.	(57 54*PI)	[BORE	45 1
	Area Mea	surement				Volume Cal	culation		
Weld		18 62	50, KN		Weld		3343 035	u n	
Adjacent	Base Metal	84 18	sq in		Adjacent B	ase Metal	15113 68 0	cu in	
nner Ra	dius	4 56	sq iñ		Inner Rødu	us	205 7928	cu in	
			Examir	ution Cov	erage Calc	ulations			
Neid									
	Exam		Area	Longth	Volume	Volume	_		
	Angle	Beam	Examined	Examined	Examined	Required	Percent		
Entry #	(deg)	Direction	(sq in)	(in.)	(cuini)	(cuin)	Examined		
1	0	n/a	34	179 5	610 4	3343 0	18%		
2	45	1	15 5	179 5	2782 9	3343 0	83%		
3	45	2	00	179 5	00	3343 0	0%		
4	45	3	34	179 5	610 4	3343 0	18%		
5	45	4	34	179 5	610 4	3343 0	18%		
6	60	1	16 5	179 5	2962 4	3343 0	89%		
7	60	2	00	179 5	00	3343 0	0%		
8	60	3	34	179 5	61D 4	3343 0	18%		•
9	60	4	34	179 5	610 4	3343 0	18%		
				Totals	8797 5	30087 3	29%	•	
Adjacen	t Base Meta	it			-		•		
•	Exam		Area	Length	Volume	Volume			
	Angle	Beam	Examined	Examined	Examined	Required	Percent		
Entry #	(deg)	Direction	(sq.in)	(in)	(cuin)	(cum)	Examined		
1	0 [°]	n/a	38 2	179 5	8858 4	151137	45%		
2	45	182	51 2	179 5	9192 4	151137	61%		
3	45	3	38 2	179 5	6858 4	151137	45%		
4	45	4	38 2	179 5	6858 4	151137	45%		
5	50	182	58 8	179 5	10557 0	151137	70%		
6	60	3	38 2	179 5	6858 4	151137	45%		
7	60	4	38 2	179 5	6858 4	151137	45%		
				Totals	54041 5	105795 7	51%		
Inner Ra	dius								
	Exam		Area	Length	Volume	Volume	_		
1	Angle	Beam	Examined	Examined	Examined	Required	Percent		
Entry #	(deg)	Direction	(sq. in.)	{m}	(cum)	(cuini)	Examined		
1	45860	axial	28	141 8	397 0	646 5	61%		
2	458.60	tangent	28	141 8	397 0	646 5	61%		
		_		Tota/s	794 0	1293 0	61%		

Nuclear		Sup			•				
NGG Generation Group						Report No	<u> </u>	T-03-1	37
						Page	3	of	3
Summary No	B3 2.1	-				·			
Examiner	Brannin, Michael M/5	Level		Reviewer	N/A		Date		
Examiner	Dittrich, Victor W. Ang	Level		Site Review	Hecht, Jeff W / LV	<u> </u>	Date	11-1	3-03
Other	N/A	Level	<u>N/A</u>	ANII Review	C Colarte	ux	Date	12 8	03

Comments Steam Generator (A) Inlet Nozzle B3.2 1 / B3.2.1.1

Sketch or Photo L \Shared\SIdata\IDDEAL Documentation\RO13\UT_03_137b JPG

STEAM GENERATOR (A) INLET NOZZLE B3 2 1783 2 1 1

This Coverage data is representative of B3.2.4 Steam Generator B Inlet Nozzle and B3.2.4.1 Nozzle Inner Radius as well.

Nuclear				Supplemental Report										
Seneration Group					Report N	lo _	U.	T-03-1	34					
	12-16-	53			Pa	ge _	2	_ of	3					
B3.2.1	H for													
Tomlinson, Robert	RT	Level		Reviewer	Larson, Scott / Level III ≰	[Date	10/22	/2003					
Wilkey, Carl J	ciu	Level		Site Review	Hecht, Jeff W. / LV III	_ (Date	10/22	/2003					
N/A	,	Level	N/A	ANII Review	C Colarte UK	<u> </u>	Date	12-6-	.03_					
	uclear eneration roup B3.2.1 Tomiinson, Robert Wilkey, Carl J N/A	ucbar eneration roup B3.2.1 بلا جه: Tomlinson, Robert RT Wilkey, Carl J C س N/A	uctoar eneration roup B3.2.1 <u>بلا جوب</u> Tomiinson, Robert RT Level Wilkey, Carl J <u>C</u> Level N/A Level	Include Inc	Supplemental Rep Supplemental Rep roup IZ-16-0-3 B3.2.1 IF Tomlinson, Robert RT Level II Reviewer Wilkey, Carl J Cub N/A Level N/A Level	Supplemental Report Report N roub roub roub Report N Pa Milesy Colspan="2">Colspan="2"	Supplemental Report roup Report No roup Report No roup Page B3.2.1 H - For Tomilinson, Robert Final Level II Reviewer Larson, Scott / Level III £ Wilkey, Carl J Cou Level II N/A Level	Supplemental Report Report No U roup roup Page 2 roup roup Page 2 B3.2.1 H for Tomilnson, Robert RT Level II Reviewer Larson, Scott / Level III £ Date Wilkey, Carl J C col Level II Site Review Hecht, Jeff W. / LV III £ Date N/A Level N/A ANil Review C Colarte	Supplemental Report Report No UT-03-1: roub Page 2 of Tominson, Robert R1 Level II Report No UT-03-1: Mileo 3 Page 2 of B3.2.1 # For Tominson, Robert R1 Level II Report No UT-03-1: Mileo 3 Page 2 of Tomilinson, Robert R1 Level II Report No UT-03-1: Wilkey, Carl J Level II Site Review Level, N/A ANII Review C Colarte Date 10/22 N/A Level N/A ANII Review C Colarte Date 12-6					

Comments Examination Coverage for Weld B3.2.1

.

Sketch or Photo L\Shared\SIdata\IDDEAL Documentation\RO13\UT_03_134a JPG

.

EXAMINATION COVERAGE FOR WELD. B3 2 1 STEAM GENERATOR 'A" INLET NOZZLE "WG25" & INNER RADIUS AGGREGATE COVERAGE OBTAINED 48%

Lrea Meas ase Metal s	We surament 18 62 84 18 4 56	Adjacent E Exar Id Length sq in	Base Metel pination V 179 54	51% olume Defl	nition 57 54*Pl)	Inner Radi	BORE	61%
krea Meai isé Metal s	We surement 18 62 84 18 4 56	Exam Id Length	179 54	olume Defi	nition 57 54*Pl)		BORE	45 13
Area Meai Ise Metal Is	We surement 18 62 84 18 4 56	sq in	179 54	'n	(57 54 Pl)		80RE	45 13
krea Meai ase Metal is	surement 18 62 84 18 4 56	sq in						
ase Metal Is	18 62 84 18 4 56	sq in		4	Volume Cal	culation		
asė Metal IS	84 18 4 56		,	Weld		3343 035	cu in	
15	4 56	so in	1	Adjacent B	ase Metal	15113 68	cu in	
		sq in		Inner Rødu	, 15	205 7928	CU IN	
the second se		Examin	netion Cov	erace Calc	ulations			
Exam		Area	Length	Volume	Volume	- ·.		
Angle	Beam	Examined	Examined	Examined	Required	Percent		
(deg)	Direction	(sq in)	(in)	(cum)	(cuin)	Examined		
0	n/a	34	179 5	610.4	3343 0	18%		
45	.1	15.5	1795	2782 9	3343 0	83%		· .
45	2	00	179 5	00	3343 0	0%		
45	3	34	179 5	61D 4	3343 0	18%		
45	4	34	179 5	610 4	3343 0	18%		
60	1	16 5	179 5	2962 4	3343 0	89%		
60 ·	2	00	179 5	00	3343 0	0%		
60	3	34	179 5	610.4	3343 0	18%		
60	4	34	179 5	610.4	3343 0	18%		
	.'		Totals	8797 5	30087 3	29%	. <u> </u>	
iase Meta	Ĵ.						_	
Exam		Area	Length	Volume	Volume			
Angle	Beam	Examined	. Examined	Examined	Required	Percent		
(deg)	Direction	(sq in)	(m)	(cuini)	(cu in)	Examined		
O O	n/a	38 2	179 5	6858 4	151137	45%	-	
45	182	51 2	179 5	9192.4	151137	61%		
45	3	38 2	179 5	6858 4	151137	45%		
45	4	38 2	179 5	6858 4	151137	45%		
60	182	58 B	. 179 5	10557 0	151137	70%		
60	3	38 2	179 5	6858 4	151137	45%		
60	4	38 2	. 179 5	6858 4	151137	45%		
			Totals	54041 5	105795 7	51%		
45	·····							
Exam		Area	Length	Volume	Volume			
Angle	Beam	Examined	i Examined	Examined	Required	Percent		
(deg)	Direction	(sq.in.)	(in)	(cuin)	(cuini)	Examined		
458.60	BX(B)	28	141 8	397 0	646 5	i 61%		
45860	tangent	28	141 8	397 0	646 5	i 61%		
·••••-			Totals	794 0	1293 (61%		
	Exam Angle (deg) 0 45 45 45 45 60 60 60 60 60 60 60 45 45 60 60 45 45 60 60 60 80 60 80 60 80 60 80 45 45 45 45 45 45 45 45 45 45	Exam Angle Beam (deg) Direction 0 n/a 45 1 45 2 45 3 45 4 60 1 60 2 60 3 60 4 ase Metal Exam (deg) Direction 0 n/a 45 1 860 3 60 4 ase Metal Exam 45 1 45 3 45 4 60 1 0 n/a 45 4 80 1 0 2 80 3 60 4 US Exam Angle Beam (deg) Direction 0 a/a 45 4 80 3 60 4 US Exam Angle Beam (deg) Direction 45 6 45 3 45 3	Exam Area Angle Beam Examined (deg) Direction (sq in) 0 n/a 34 45 1 155 45 2 00 45 3 34 45 1 165 60 2 00 60 1 165 60 2 00 60 4 34 60 4 34 ase Metal Exam Area Exam Area 382 45 1&2 512 45 3 382 45 1&2 512 45 3 382 60 1&2 58 80 3 382 60 1&2 58 80 3 382 60 1&2 58 80 3 382 60 4	Examination Area Length Angle Beam Examined Examined Angle Beam Examined Examined 0 n/a 3.4 179 5 45 1 15 5 179 5 45 2 0.0 179 5 45 3 3.4 179 5 45 3 3.4 179 5 45 3 3.4 179 5 60 1 16 5 179 5 60 2 0.0 179 5 60 4 3.4 179 5 60 4 3.4 179 5 60 4 3.4 179 5 60 4 3.4 179 5 70tals 38.2 179 5 45 1&2 51 2 179 5 45 1&2 51 2 179 5 60 1&2 58 179 5 50 3 60 1&2 58 8 </td <td>Examination Coverage Calc Exam Area Length Volume Angle Beam Examined Examined Examined Examined (deg) Direction (sq in) (in) (cu m) 0 0 n/a 3 4 179 5 610 4 45 1 15 5 179 5 2762 9 45 2 0.0 179 5 0.0 45 3 3 4 179 5 610 4 60 1 16 5 179 5 2962 4 60 2 0.0 179 5 610 4 60 1 16 5 179 5 610 4 60 3 3 4 179 5 610 4 60 4 3 4 179 5 610 4 70tals 8797 5 ase Metal Examined Exam Area Length Volume Argle Beam Examined Examined (deg) Direc</td> <td>Examination Area Length Volume Volume Angle Beam Examined Examined</td> <td>Exam Area Length Volume Volume Angle Beam Examined Examined Examined Required Percent (deg) Direction (sq in) (in) (cu in) (cu in) Examined 45 1 155 1795 2782.9 3343.0 83% 45 2 0.0 1795 610.4 3343.0 18% 45 3 3.4 1795 610.4 3343.0 18% 45 3 3.4 1795 610.4 3343.0 18% 60 1 165 179.5 2962.4 3343.0 18% 60 2 0.0 179.5 610.4 3343.0 18% 60 3 3.4 179.5 610.4 3343.0 18% 60 4 3.4 179.5 610.4 3343.0 18% 70tals 8797.5 30087.3 29% ase Metal Examine</td> <td>Examination Area Length Volume Volume Angle Beam Examined Examined Examined Required Percent (deg) Direction (sq in) (in) (cu in) (cu in) Examined 45 1 155 1795 2782.9 3343.0 83% 45 2 0.0 1795 0.0 3343.0 0% 45 3 3.4 1795 610.4 3343.0 18% 45 3 3.4 1795 610.4 3343.0 18% 60 1 165 179.5 2962.4 3343.0 18% 60 1 165 179.5 610.4 3343.0 18% 60 3 3.4 179.5 610.4 343.0 18% 60 4 3.4 179.5 610.4 343.0 18% 60 4 3.4 179.5 6858.4 15113.7 45%</td>	Examination Coverage Calc Exam Area Length Volume Angle Beam Examined Examined Examined Examined (deg) Direction (sq in) (in) (cu m) 0 0 n/a 3 4 179 5 610 4 45 1 15 5 179 5 2762 9 45 2 0.0 179 5 0.0 45 3 3 4 179 5 610 4 60 1 16 5 179 5 2962 4 60 2 0.0 179 5 610 4 60 1 16 5 179 5 610 4 60 3 3 4 179 5 610 4 60 4 3 4 179 5 610 4 70tals 8797 5 ase Metal Examined Exam Area Length Volume Argle Beam Examined Examined (deg) Direc	Examination Area Length Volume Volume Angle Beam Examined Examined	Exam Area Length Volume Volume Angle Beam Examined Examined Examined Required Percent (deg) Direction (sq in) (in) (cu in) (cu in) Examined 45 1 155 1795 2782.9 3343.0 83% 45 2 0.0 1795 610.4 3343.0 18% 45 3 3.4 1795 610.4 3343.0 18% 45 3 3.4 1795 610.4 3343.0 18% 60 1 165 179.5 2962.4 3343.0 18% 60 2 0.0 179.5 610.4 3343.0 18% 60 3 3.4 179.5 610.4 3343.0 18% 60 4 3.4 179.5 610.4 3343.0 18% 70tals 8797.5 30087.3 29% ase Metal Examine	Examination Area Length Volume Volume Angle Beam Examined Examined Examined Required Percent (deg) Direction (sq in) (in) (cu in) (cu in) Examined 45 1 155 1795 2782.9 3343.0 83% 45 2 0.0 1795 0.0 3343.0 0% 45 3 3.4 1795 610.4 3343.0 18% 45 3 3.4 1795 610.4 3343.0 18% 60 1 165 179.5 2962.4 3343.0 18% 60 1 165 179.5 610.4 3343.0 18% 60 3 3.4 179.5 610.4 343.0 18% 60 4 3.4 179.5 610.4 343.0 18% 60 4 3.4 179.5 6858.4 15113.7 45%

. . .

ς.

KIOD		Supplemental Report										
	Generation					Report I	٧٥	<u>U</u> .	T-03- 1	34		
		14-16-	03			Pa	ige	3	of	_3		
Summary No	B3 2 1	H-501	,						_			
Examiner	Tomlinson, Robert	RT	Level		Reviewer	Larson, Scott / Level III 4	Dat	te	10/22	/2003	1	
Examiner	Wilkey, Carl J.	4 ew	Level	<u> </u>	Site Review	Hecht, Jeff W. / LV III	Dal	le	10/22	/2003	,	
Other	N/A	_	Level	_N/A	ANII Review	C. Colarte crc	Dai	le	12-01	3.05		

Comments Steam Generator (A) Inlet Nozzle B3 2.1 / B3.2.1.1

۰.

Sketch or Photo L \Shared\ISIdata\IDDEAL Documentation\RO13\UT_03_134b JPG

STEAM GENERATOR (A) INLET NOZZLE B3 2 1/B3 2 1 1

This Coverage data is representative of B3.2.4 Steam Generator B Inlet Nozzle and B3.2.4.1 Nozzle Inner Radius as well.

EXAMINATION COVERAGE FOR WELD: B3.2.2/B3.2.2.1 STEAM GENERATOR "A" LOWER HEAD TO NOZZLE "WG50" & INNER RADIUS AGGREGATE COVERAGE OBTAINED: 63%

Zone Coverage Obtained									
Weld	: 65%		Adjacent f	Base Metal	63%		Inner Radi	us:	48%
142310703		SP PASSA	Exan	nination V	lume Defi	nilion	14-14-14-14-14-14-14-14-14-14-14-14-14-1	17.150 P	
		We	ld Length:	118.88	in	(37.84*PI)		BORE	90.26
	Area Mea	surement			14/-1-1	Volume C	alculation		
Adjacent	Roco Motal	109.64	sy. III.		Adjacant F	lasa Matal	2400.97	CU. In.	
Projaceni Donor Par	base wietai	100.04	sų. m. egin		Aujacent E	ase metai	12913.12	cu, in.	
	103	4.55	3 4 . III.			us	440.707	Cu. 11.	
12/2010 (CAS	the states of	anter al car	Examin	ation Cov	arage Calc	ulations			
Weld									
	Exam.		Area	Length	Volume	Volume			
	Angle	Beam	Examined	Examined	Examined	Required	Percent		
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined		
1	0	n/a	18.4	118.88	2192.1	2487.0	88%		
2	45	1	17.3	. 76.88	1330.0	1608.3	83%		· · · ·
3	45	1	10.6	42	445.2	878.6	51%		
4	45	2	0.0	118.88	0.0	2487.0	0%		
5	45	3	18.4	118.8	2190.7	2485.3	88%		
6	45	4	18.4	118.8	2185.9	2485.3	88%		
	60	1	17.3	60.88	1055.7	12/3.6	83%		
8	60	1	13.0	140.00	752.3	1213.4	62%		
9	60	2	10.0	110.00	0.0	2407.0	0%		
	60	3	10.4	110.00	2107.4	2407.0	0076		
	00	4	10.4	Totals:	14526 7	2407.0	65%		
Adjacent	Rase Meta			10(8/3.	14520.7	22313.4	0070	·	
Lagacon	Fram	•	Area	Length	Volume	Volume			
	Angle	Beam	Examined	Examined	Examined	Required	Percent		
Entry #	(deg.)	Direction	(so, in.)	(in.)	(cu. in.)	(cu. in.)	Examined		
1	0	n/a	77.4	100.88	7804.1	10959.6	71%		
2	0	n/a	59.2	. 18	1065.6	1955.5	54%		
3	45	182	76.4	76.88	5873.6	8352.2	70%		
4 '	45	1&2	54.5	58	3158.1	6301.1	50%		
5	45	3	68.6	100.88	6916.3	10959.6	63%		
6	45	3	59.2	18	1065.6	1955.5	54%		
7	45	4	68.6	100.88	6916.3	10959.6	63%		[
8	45	4	59.2	18	1065.6	1955.5	54%		
9	60	1&2	84.6	60.88	5150.4	6614.0	78%		
10	60	1&2	51.5	58	2984.1	6301.1	47%		
11	60	3	68.6	100.88	6916.3	10959.6	63%		
12	60	3	59.2	18	1065.6	1955.5	54%		
13	60	4	68.6	100.88	6916.3	10959.6	63%		
14	60	4	59.2	18	1065.6	1955.5	54%		
				Totals:	57963.7	92144.1	63%		
inner Ra	aius		A	lor-th	1/-1	Val			х.,
1	Exam.	Baam	Evoning	Evomina	Volume	Volume	Dorecet		
Entry #	(dog)	Direction	(co io)	Contraction (in)	(cu in)		Evaminor		
Chuy#	(ueg.)	avial	(sy. III.) 2 A	(iii.) 60 A	(UU, III.) 109 E	(cu. III.) 200 A	60%		
2	40	axial	0. 4 0.0	31 0	190.0	200.9 157 0	03%		
2	-1-J -1-J	avial	0.0 3 3	9.10 AR 2	153.1	220 0	67%		
4	60	avial	0.0	40.3	100.1	217 8	0%		
5	45	tangent	2 R	90.3	252.7	446 8	57%		
6	60	tangent	2.0	90.3	252.7	446.8	57%		Ì
Ť				Totals	857.0	1787.1	48%		
					201.0				
4									

.



EXAMINATION COVERAGE FOR WELD: B3.2.3/B3.2.3.1 STEAM GENERATOR "A" OUTLET NOZZLE "WG50" & INNER RADIUS AGGREGATE COVERAGE OBTAINED: 50%

. .

Weid	d: 51%		Ined	Inner Radi	ius:	s: 43%			
152152-50				ingalate ing V			a sana sa		
ļ	Area Mea	We	la Length:	118.88	<u>in.</u>	(37.84*Pl)	alculation	BORE	90.28
Weld		20.92	sa. in.		Weld	Volume C	2486.97	cu. in	
Adiacen	t Base Metal	108.64	sq. in.		Adjacent 8	Base Metal	12915.12	cu. in.	
Inner Ra	idius	4.95	sq. in.		Inner Radi	ius	446.886	cu. in.	
P. C.	a de la companya de La companya de la comp		S Development	allour 2001	15 M State	<u> Halippaa</u> t			
Weld	Even		A.m.n	Length		Volumo		•	
	Angle	Beam	Framined	Examined	Examined	Required	Percent		
Entry #	(deg.)	Direction	(sa. in.)	(in.)	(cu. in.)	(cu. in.)	Examined		
T 1	0	n/a	18.4	93.88	1731.1	1964.0	88%		•
2	0	n/a	0.0	25	0.0	523.0	0%		
3	35	1	17.3	73.88	1281.1	1545.6	83%		
4	35	1	13.0	20	259.4	418.4	62%		
5	35	1	0.0	25	0.0	523.0	0%		
6	35	2	10.0	118.88	1629.0	2487.0	0%		
/ a	40 45	3	10.4 1) 10	00.00 30	1030.9 U U	1009.4 627 6	00% በ%		
a a	45	4	18.4	88 88	1638.9	1859 4	88%		
10	45	4	0.0	-30	0.0	627.6	0%		
11	45860	1	17.3	73.88	1281.1	1545.6	83%		
12	45&60	1	13.0	20	259.4	418.4	62%		
13	45&60	1	0.0	25	0.0	523.0	0%		
14	45&60	2	0.0	118.88	0.0	2487.0	0%		
15	60	3	18.4	88.88	1638.9	1859.4	88%		
16	60	3	10.0	30	1628.0	627.6 1950 A	0%		
1/	60	4	10.4	00.00	0.0	627.6	00%		
10	00	. *	0.0	Totals	11.367 0	22382.7	51%		
Adiacen	t Base Meta	1						······	
	Exam.		Area	Length	Volume	Volume			
	Angle	Beam	Examined	Examined	Examined	Required	Percent		
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined		
1	0	n/a	77.4	88.88	6875.8	9655.9	71%		
2	25	18.2	75 4	73.99	0.U 6643 0	3259.2	0% 70%		
	35	182	38.2	20	763.8	2172.8	35%		
5	35	182	0.0	25	0.0	2716.0	0%		
6	45	3	68.6	88.88	6093.6	9655.9	63%		
7	45	3	0.0	30	0.0	3259.2	0%		
8	45	4	68.6	88.88	6093.6	9655.9	63%		
9	45	4	0.0	30	0.0	3259.2	0%		
10	45860	182	84.6	73.88	6252.5	8026.3	78%		
11	45860	182	39.7	20	793.6	2172.8	3/%		
12	40000 20	1042	0.0 A RA	C2 88.89	0.0	27 10.0	U% 63%		
13	00	3	0.00	30.00	0.0800	3259.2	0%		
15	60	4	68.6	88.88	6093.6	9655.9	63%		
16	60	4	0.0	30	0.0	3259.2	0%		
				Totals:	44703.0	90405.9	49%		
Inner Ra	dius		•						
1	Exam.	Da	Area	Length	Volume	Volume	D	÷.,	
Coto, 4	Angle	Direction	Contraction (source)	⊂xainine0		rcequired	Fremend		
	(ueg.)	avial	(su. µc) A A	(III.) 58 0	(CUL 111.) 188 P	(נעט, ווו.) ס דדר 2	EXAMPLEO 68%		
2	45	axial	0.0	34.3	0.001	169.8	0%		
3	60	axial	3.3	56.0	185.2	277.0	67%		
4	60	axial	0.0	34.3	0.0	169.8	0%		
5	45	tangent	2.8	71.3	199.7	353.0	57%		
6	45	tangent	0.0	19.0	0.0	94.1	0%		
7	60	tangent	2.8	71.3	199.7	353.0	57%		
8	60	tangent	0.0	19.0	0.0	94.1	0%		
				rotals:	773.1	1/0/.0	4376	-	

......

EXAMINATION COVERAGE FOR WELD: B3.2.6 STEAM GENERATOR "B" OUTLET NOZZLE "WG50" & INNER RADIUS AGGREGATE COVERAGE OBTAINED: 49% B3.2.6/B3.2.6.1

			Zon	e Covera	ge Obtai	ned			
Weld	l: 49%		Adjacent B	ase Metal:	49%		Inner Radi	ius:	43%
			State Sectors in the sector of	Long Lines Lines	111	-	1000 Million 100 Million 100 Million	Sectore . / 2004.0	
l -	21.755 W PROPERTY.	M/n	d Length	118 88	in USH	(37 84+DIN	12077. Sp25991	BORE	00.26
 	Area Meas	surement	a congui.	10.00		Volume C	alculation	DUNE	30.20
Weld	va medi	20.92	sq. in.		Weld		2486.97	cu: in.	
Adiacent	Base Metal	108.64	sq. in.		Adjacent P	ase Metal	12915.12	cu. in.	
Inner Rad	dius	4.95	sq. in.		Inner Radi	us	446.787	cu. in.	
L			-						
The second	Martin Contra	y an early a second	Examin	ation Cove	rage Calci	ulations .	VICE SAME	397 S. L.	in the same
Weld	- -			1	N	V_1			
	Exam.	D	Area	Length	Volume	Volume	Dercani	-	
Enter #		Beam		Examined	Examined	required	Freent	·	
1 1 1 CIUY #	(ueg.) A	00000011U	(54.111.) 18.4	(111) 93 89	(Cu. III.) 1731 1	1064 0	88%		
2	n	n/a	0.4	25.00	0.0	523.0	0%		
3	35	1	17.3	73.88	1281.1	1545.6	83%		
4	35	1	13.0	20	259.4	418.4	62%		
5	35	1	0.0	25	0.0	523.0	0%	•	
6	35	2	0.0	118.88	0.0	2487.0	0%		*
7	45	3	18.4	83.88	1546.7	1754.8	88%		
8	45	3	· 0.0	35	0.0	732.2	0%		
9	45	4	18.4	83.88	1546.7	1754.8	88%		•
10	45	4	0.0	35	0.0	732.2	0%		
11	45&60	1	17.3	73.88	1281.1	1545.6	83%		
12	45&60	1	13.0	20	259.4	418.4	62%		
13	45&60	1.	0.0	25	0.0	523.0	U%		
14	45860	2	0.0	118.88	46407	2481.0	U% 999/		
15	60	<u>ა</u>	18.4	03.00 25	1040.7	1/04.8	00% N%		
10	60 00	Л	0.U 19 4	22 00 22	15/6 7	1751 9	88%		
18	60 60	4	10.4 በ በ	35 00.00	1.0 4 0.7 0.0	732.2	0%		,
	. UU ,	. –	0.0	Totals	10999 1	22382 7	49%		
Adiacen	t Base Meta								
	Exam.	×	Area	Length	Volume	Volume			
1	Angle	Beam	Examined	Examined	Examined	Required	Percent		
Entry #	(deg.)	Direction	(sq. in.)	(in.)	(cu. in.)	(cu. in.)	Examined		
1	0	n/a	77.4	88.88	6875.8	9655.9	71%		
2	0	n/a	0.0	30	0.0	3259.2	0%		•
3	35	1&2	76.4	73.88	5643.0	8026.3	70%		
4	35	1&2	38.2	20	763.8	2172.8	35%		
5	35	182	0.0	25	0.0	2/16.0	·U%		
67	45	3	68.6	88.88	0093.6	3050.9	00% 0%		
	40 - A6		0.0	90 00 88	0.U 6003 e	0656 0	63%		
ő	40 AK	4	00.0 0.0	00.00 nr	0.090.0	3250.2	0%		
10	45860	182	84 A	73 88	6252.5	8026 3	78%		,
11	45&60	1&2	39.7	20	793 6	2172.8	37%		
12	45860	1&2	0.0	25	0.0	2716.0	0%		
13	60	3	68.6	88.88	6093.6	9655.9	63%		
14	60	3	0.0	30	0.0	3259.2	0%		
15	60	4	68.6	88.88	6093.6	9655.9	63%		
16	60	4	0.0	30	0.0	3259.2	0%		
				Totals:	44703.0	90405.9	49%		
unnør Ra	adius		Δ	1	V-1	1/-1			,
1	Exam.	D • • •	Area	Length	volume	volume	Dorn		
	Angle	Direction	Examined	⊏xamined	Examined	required	Frencent		
	(aeg.)	Unection aviat	्रध्यः (ग.) २४	(III.) • हह о	נכט. וח.) 199 פ	(uu. In.) 277 A	EXAMINED 68%		
	40 45	axial	ა. 4 იი	24.2	0.001 0 0	160.9	0%°		
1 2	40 40	axial	3.3	56.0	185.2	277 A	67%		
1 4	60	axial	0.0	34 3	0.0	169.8	0%		
5	45	tangent	2.8	71.3	199.7	353.0	57%		
6	45	tangent	0.0	19.0	0.0	93.9	0%	e1	
7	60	tangent	2.8	71.3	199.7	353.0	57%		
8	60	tangent	0.0	19.0	0.0	93.9	0%		
		,		Totals:	773.1	1787.2	43%		
Ι.									



FLOW H is <u>45° 60° 70°</u>

<u>B4.5.165</u> COVERAGE PLOT

This drawing is representative for the following Summary Numbers; B4.5.71.3, B4.5.79.4, B4.5.84.2 and B4.5.108.17.



This drawing is representative for the following Summary NumbersB4.5.71.4, B4.5.79.5, and B4.5.84.4.







PROGRESS ENERGY FLORIDA, INC.

CRYSTAL RIVER UNIT 3

DOCKET NUMBER 50 - 302 / LICENSE NUMBER DPR - 72

ENCLOSURE 2

INSERVICE INSPECTION RELIEF REQUEST #09-002-II THIRD TEN-YEAR ISI INTERVAL

10 CFR 50.55a Request #09-002-II

Relief Request in Accordance with 10 CFR 50.55a(g)(5)(iii)

--Inservice Inspection Impracticality--

1. ASME Code Component(s) Affected

ASME Code Class 2 Piping and Nozzles

Categories: C-A, C-B, C-F-1 and C-F-2

Items: C1.10, C2.21, C5.11, C5.21, C5.51 and Augmented 7.1

2. Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME), Boiler and Pressure Vessel Code, Section XI, 1989 Edition, no Addenda.

3. Applicable Code Requirement

ASME Code, Section XI, Sub-article IWC-2500 states, in part, "Components shall be examined and tested as specified in Table IWC-2500-1." Table IWC-2500-1 requires an examination of applicable Class 2 pressure retaining-welds, which includes 100 percent of weld length once during the ten-year ISI interval for the following Code Categories:

Category C-A: Item C1.10

Category C-B: Item C2.21

Category C-F-1: Items C5.11, C5.21 and Augmented 7.1

Category C-F-2: Item C5.51

Code Case N-460 permits a reduction in examination coverage of Class 1 and Class 2 welds provided the coverage reduction is less than 10 percent. CR-3 has adopted Code Case N-460 in the Inservice Inspection (ISI) Program Plan, as permitted by NRC Regulatory Guide 1.147, Revision 15.

4. Impracticality of Compliance

At the time CR-3 was constructed, the ASME Boiler and Pressure Vessel Code only addressed nuclear vessels and associated piping up to and including the first isolation valve. The piping codes of record were USAS B31.7, 1968 Edition for nuclear piping, and USAS B31.1.0-1967 Edition for non-nuclear piping.

10 CFR 50.55a recognizes the limitations to in-service inspection of components in accordance with Section XI of the ASME Code that are imposed due to early plants

design and construction. 10 CFR 50.55a(g)(1) states, "For a boiling or pressurized water-cooled nuclear power facility whose construction permit was issued prior to January 1, 1971, components (including supports) must meet the requirements of paragraphs (g)(4) and (g)(5) of this section, to the extent practical." 10 CFR 50.55a(g)(1) is applicable since the CR-3 construction permit was dated September 25, 1968.

10 CFR 50.55a(g)(4) states, "Throughout the service life of a boiling or pressurized water-cooled nuclear power facility, components (including supports) which are classified as ASME Code Class 1, Class 2, and Class 3 must meet the requirements, except design and access provisions and pre-service examination requirements, set forth in Section XI of editions of the ASME Boiler and Pressure Vessel Code ... to the extent practical within the limitations of design, geometry and materials of construction of the components."

10 CFR 50.55a(g)(5)(iii) states, "If the licensee has determined that conformance with certain code requirements is impractical for its facility, the licensee shall notify the Commission and submit, as specified in § 50.4, information to support the determinations."

CR-3 has determined that the following welds were limited from achieving greater than 90 percent of the required examination volume for in-service examinations due to component configuration or physical barriers which would require a major modification to the existing hardware. Therefore, relief is being sought from coverage requirements set forth in ASME Code, Section XI, Sub-article IWC-2500 in accordance with 10 CFR 50.55a(g)(5)(iii).

Relief is requested from performing volumetric examinations of the welds listed in Table A to the extent required by the Code. These examinations are limited by part geometry or interferences with other components such that the reduction in coverage is greater than 10 percent.

Tal	ble	А
-----	-----	---

<u>*S/S = st</u>	ainless ste	el		**C/S = carbon steel				
Category	Item	Summary Number	Diameter	Thickness	Material	Coverage Percentage	Description	
C-A	C1.10	C1.1.5	N/A	1.50"	S/S*	42.5	Shell to flange	
С-В	C2.21	C1.2.3	N/A	1.50"	S/S	45.5	Nozzle to Shell Weld	
C-F-1	Augment	C2.1.190	18"	.375"	S/S	50	Reducer to Flange	
	7.1	C2.1.192A	10"	.365"	S/S	50	Pipe to Valve	
		C2.1.605	10"	.365"	S/S	50	Valve to Elbow	
		C2.1.625	8.0"	.322"	S/S	50	Elbow to Valve	
		X121.020	10"	.365"	S/S	50	Pipe to Valve	
	C5.11	C2.1.104	10"	1.0"	S/S	50	Valve to Pipe	
		C2.1.1477	14"	.375"	S/S	50	Elbow to Valve	
		C2.1.163	14"	.375"	S/S	50	Valve to Elbow	
		C2.1.167	14"	.375"	S/S	50	Elbow to Valve	
		C2.1.170	14"	.375"	S/S	50	Pipe to Valve	
		C2.1.184	12"	.375"	S/S	50	Valve to Elbow	

. . .
U. S. Nuclear Regulatory Commission 3F0309-01

Category	Item	Summary Number	Diameter	Thickness	Material	Coverage Percentage	Description
		C2.1.503	14"	.375"	S/S	50	Elbow to Valve
		C2.1.507	14"	.375"	S/S	50	Flange to Reducer
		C2.1.526	10"	.365"	S/S	50	Flange to Pipe
		C2.1. 527	10"	.365"	S/S	50	Pipe to Flange
		C2.1.542	14"	.375"	S/S	50	Reducer to valve
		C2.1.543	14"	.375"	S/S	50	Tee to Pipe
		C2.1.548	14"	.375"	S/S	50	Elbow to Valve
		C2.1.600	18"	.375"	S/S	50	Flange to Reducer
	C5.21	C2.1.1018	3.0"	.438"	S/S	50	Pipe to Valve
		C2.1.1031	4"	.531"	S/S	50	Tee to Tee
		C2.1.1040	2.5"	.375"	S/S	50	Pipe to Valve
		C2.1.1047	4.0"	.531"	S/S	50	Valve to Pipe
		C2.1.1060	2.5"	.375"	S/S	87.5	Tee to Elbow
		C2.1.1067	3.0"	.438"	S/S	50	Pipe to Valve
		C2.1.1070	3.0"	.438"	S/S	86.5	Elbow to Pipe
		C2.1.1084	3.0"	.438"	S/S	50	Valve to Reducer
		C2.1.1096	4.0"	.531"	S/S	50	Pipe to Valve
		C2.1.1097	4.0"	.531"	S/S	50	Valve to Pipe
		C2.1.1098	4.0"	.531"	S/S	50	Pipe to Tee
		C2.1.1207	2.5"	.375"	S/S	50	Valve to Pipe
		C2.1.1223	2.5"	.375"	S/S	50	Valve to Pipe
		C2.1.1272	2.5"	.375"	S/S	50	Tee to Pipe
		C2.1.2073	2.5"	.375"	S/S	50	Elbow to Flange
		C2.1.2078	4.0"	.237"	S/S	50	Elbow to Flange
		C2.1.2117	3.0"	.438"	S/S	80	Elbow to Pipe
		C2.1.2136	3.0"	.438"	S/S	50	Pipe to Valve
		C2.1.2137	3.0"	.438"	S/S	50	Valve to Pipe
		C2.1.2162	3.0"	.438"	S/S	50	Pipe to Valve
		C2.1.2164	3.0"	.438"	S/S	50	Tee to Valve
		C2.1.2169	3.0"	.438"	S/S	50	Valve to Pipe
		C2.1.2173	3.0"	.438"	S/S	50	Pipe to Valve
		C2.1.2174	3.0"	.438"	S/S	50	Tee to Pipe
		C2.1.2175	3.0"	.438"	S/S	50	Pipe to Valve
		C2.1.2176	3.0"	.438"	S/S	50	Valve to Pipe
		C2.1.2199	3.0"	.438"	S/S	50	Tee to Pipe
		C2.1.2200	3.0"	.438"	S/S	50	Pipe to Tee
		C2.1.2202	3.0"	.438"	S/S	50	Pipe to Valve
		C2.1.2238	4.0"	.531"	S/S	50	Pipe to valve
		C2.1.2240	4.0"	.531"	S/S	50	Valve to Pipe
C-F-2	C5.51	C2.1.118	6.0"	.8"	C/S**	74	Sweepolet to Flange
		C2.1.121	24.0"	.969"	C/S	50	Pipe to Valve
		C2.1.122	6.0" ·	.8"	C/S	79.86	Sweepolet to Flange
		C2.1.132	10.0"	.5"	C/S	50	Valve to Pipe
		C2.1.290	6.0"	.8"	C/S	74	Sweepolet to Flange
		C2.1.8	24.0"	.969"	C/S	75	Pipe to Valve

Examination Details

C1.10 Shell to Flange Weld: Summary Number C1.1.5

Ultrasonic examination of the subject weld was limited in coverage due to component configuration and/or immovable physical barriers. It is not possible to perform a 100 percent ultrasonic examination from both sides of the weld since one side of the weld was not suitable for scanning based on the scanning surface angle of the component (Flange). Therefore, the weld only received a single sided examination or partial single sided examination resulting in less than 90 percent coverage of the required examination volume. The percentage of coverage reported represents the aggregate coverage from all examination angles and scans performed on the weld and adjacent base material. The NDE techniques and procedures used incorporate examination techniques qualified under Appendix VIII of the ASME Section XI Code by the PDI for examination of the pipe welds. (See Attachment A for the cross-sectional view of the weld and limitations.)

C2.21 Nozzle to Shell Weld: Summary Number C1.2.3

Ultrasonic examination of the subject weld was limited in coverage due to component configuration and/or immovable physical barriers. It is not possible to perform a 100 percent ultrasonic examination from both sides of the weld since scanning was performed on the shell side only. The scanning surface of the pipe is perpendicular to the shell surface which prohibits the ultrasonic wave entering the Code required examination volume at an angle that will integrate the weld volume for in-service flaws. Therefore, the weld only received a single sided examination or partial single sided examination resulting in less than 90 percent coverage of the required examination volume. The percentage of coverage reported represents the aggregate coverage from all examination angles and scans performed on the weld and adjacent base material. The NDE techniques and procedures used incorporate examination techniques qualified under Appendix VIII of the ASME Section XI Code by the PDI for examination of the pipe welds. (See Attachment A for the cross-sectional view of the weld and limitations.)

C5.11, C5.21, C5.51 and Augmented 7.1 Circumferential Pipe Welds: Summary Numbers C-F-1 and C-F-2

Ultrasonic examination of the above pipe welds was limited in coverage due to component configuration and/or immovable physical barriers. It is not possible to perform a 100 percent ultrasonic examination from both sides of the weld since one side of the weld was not suitable for scanning based on the scanning surface angle of the component. Therefore, the welds only received a single sided examination or partial single sided examination resulting in less than 90 percent coverage of the required examination volume. The percentage of coverage reported represents the aggregate coverage from all examination angles and scans performed on the weld and adjacent base material. The NDE techniques and procedures used incorporate examination techniques qualified under Appendix VIII of the ASME Section XI Code by the PDI for examination of the pipe welds. (See Attachment A for the cross-sectional view of the weld and limitations.)

5. Burden Caused by Compliance

In order to scan all of the required volume for these welds, the components would have to be redesigned to allow scanning from both sides of the weld, which is impractical. There were no recordable indications (other than geometric indications) found during the inspection of these welds. Based on the components designed configuration, the available coverage will not meet the requirements of the ASME Code, Code Case N-578 or Code Case N-460.

In accordance with 10 CFR 50.55a(g)(5)(iii), relief is requested for the components listed in Table A on the basis that the required examination coverage of "essentially 100 percent" is impractical due to physical obstructions and the limitations imposed by design, geometry, and materials of construction. CR-3 utilized examination techniques qualified to meet the requirements of ASME Section XI, Appendix VIII, as required in 10 CFR 50.55a(g)(6)(a)(c), that achieved the maximum practical amount of coverage obtainable within the limitations imposed by the design of the components and examination techniques. Additionally, VT-2 examinations are performed on the subject components of the Reactor Coolant Pressure Boundary during system pressure tests on a periodic frequency. Those examinations were completed and no evidence of leakage was identified for these components.

The mandated requirement in 10 CFR 50.55a(b)(2)(xv)(A)(2) states, "Where examination from both sides is not possible on austenitic welds, full coverage credit from a single side may be claimed only after completing a successful single sided Appendix VIII demonstration using flaw on the opposite side of the weld." The Appendix VIII techniques applied at CR-3, (PDI-UT-2), are not qualified for "Detection or length sizing of circumferentially oriented flaw indications when only single side access is available and the flaw is located on the far side of the weld."

Based on the design configuration of the components and available examinations techniques, CR-3 was not able to achieve greater that 90 percent Code coverage of the required examination volume for the components listed above without major modifications to the components.

6. **Proposed Alternative and Basis for Use**

No alternative examinations were performed for these welds during the Third Ten-Year ISI Interval. The use of radiography as an alternate volumetric examination for all the above listed components is not practical due to component thickness and geometric configurations. Other restrictions making radiography impractical are the physical barriers prohibiting access for placement of source, film, image quality indicator, etc.

With due consideration of the earlier plant design, the underlying objectives of the Code required volumetric examinations have been met. The examinations were completed to the extent practical and evidenced no unacceptable flaws present. VT-2 examinations performed on the subject Class 2 components during periodic system pressure testing provide continued assurance that the structural integrity of the subject components is maintained.

Ultrasonic examination of the welds was conducted using personnel qualified in accordance with ASME Section XI, Appendix VII of the 1998 Edition, no Addenda.

Ultrasonic procedures complied with the requirements of ASME Section V, Article 4 of the 1989 Edition as amended by Section XI, Appendix I. IWC-2500, Table IWC-2500-1, Examination Category C-H System Leakage Tests and VT-2 visual examinations performed on a periodic basis provide adequate assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), there are other activities which provide a high level of confidence that, in the unlikely event that leakage did occur through these welds, it would be detected and proper action taken. Specifically, system leak rate limitations imposed by Improved Technical Specification 3.4.12, "RCS Operational LEAKAGE," and reactor building normal sump rate monitoring, provide additional assurance that any leakage would be detected prior to gross failure of the component. The component weld was inspected by volumetric and surface NDE methods during construction and verified to be free from unacceptable fabrication defects.

Therefore, reasonable assurance of quality and safety is based on the achieved coverage and results of the volumetric and/or surface and the pressure testing VT-2 examinations performed.

7. Duration of Proposed Alternative

Relief is requested for the Third Ten-Year ISI Interval for CR-3, which was effective from August 14, 1998, ending August 13, 2008.

8. Precedents (Optional)

9. References (Optional)

ENCLOSURE 2

ATTACHMENT A

COVERAGE DATA

INSERVICE INSPECTION RELIEF REQUEST #09-002-II THIRD TEN-YEAR ISI INTERVAL

Group				F	'age: of
Summary No.: <u>C</u> Examiner: D	1.1.5 owns, William R.	Level: III-PDI	Damen A Reviewer: Kelly, Brac	RIESTLEY C	Date:
Examiner: <u>N</u> Other: <u>N</u>	I/A I/A	Levei: N/A Levei: N/A	Site Review: Myatt, The	mas W. M. M. Martin	Date: _// Date: _///
Comments: Co	overage Plot	······································			
Sketch or Photo: L:\	Shared/ISIDATA/IDDEAL Documentation/	RF015\Linked Documents\UT-07-0	01b.jpg		
• •		45" 660	- 		
				N	- - -
	6.11	ARIAL	CIRC	COVER ADE	
	JHELL SIDE	45 5170	100%	45° 3 8%	[•]
		60° 87 %	10070	co° 4770	
· · · · ·	FLANCE SIDE	4500	0	TOTHL 42.5%	
		60° 0	0	COVERACE	
				. ,	

.

UT-07-005 (2.21)imm C1.2.3 450 600 AXIAL CIRC. SHELL SIDE 10070 65 70 450 1 6 5 70 41% 45 ° 100% 600 10070 NOZZLE SIDE 45. " 0 600 20090 = 50% ø 4 600 0 0 45.5% coven HGE

.



Supplemental Report

Report No.: UT-07-240

Page: 2 of

2

Summary No.: X121.020

Sketch or Photo: L:\Shared\ISIDATA\IDDEAL Documentation\RFO15\Linked Documents\UT-07-240.tif



.398 .397 .395 .394 .400 .533.598 .556

WELD	LENGTH	34.7"
WELD	WIDTH	0,6"

PROFILE TAKEN & O'TOL

and a second Paul 5 Blecha II 11-26-07



Didrey Michrael 8-22-01

. .

	ear ration		Supplement	al Report		Report No.:	UT-07-115
Summary No.:	C2.1.1060					Page:	<u> </u>
Examiner:	Gahan, Timothy L.	TG	Level: (I-PD)	Reviewer:	DAMON PRIGSTIES	t/al-	- Date: 12/1
Examiner:	N/A		Level: N/A	Site Review:	Michael Brannis	The the	- Date: 12/2/2
Other:	N/A		Level: N/A	ANII Review:	Wyatt, Thomas W.	Nation	Date: <u>(2/3/0</u>
Comments:	Coverage Calculations	(Calculations provided	i by Shearer, Nichola	as H. 11/16/07)			
	•						
etch or Photo:	L:\Shared\ISIDATA\IDDEA	Documentation\RF015\Lir	ked Documents\UT-07-	115b.jpg			
		Summer at	0711060				
		S O H (HAR I					
		COMP. 1D.	MU-105 F				
		LIMITED UT	COVERAGE	CALCULAT	TON		
		TEE TO EI	BOW				
	,	SCAN	7. COVERACE				
		Avia US	570				
		AXIAL DS	100				
		CIRC US	100				
•		CIRC DS	100				
			350 + 4 =	. 87.57.	TOTAL COVERAGE		
· .							
*.				1	1 1		
<i>*</i> .		N SHO	FAREN LAI	9Bhn_	11/16/07		X

÷. .

1976 testi in 1.

	ouppionental report	Report No.:	UT-07-115		i
· · ·		Page:	2	of	3
1.1060	_	Do-			
an, Timothy L.	Level: 11-PDI Reviewer: DAMON RIESTL	er d'al	-Date:	12/1	<u> 07</u>
·	Level: N/A Site Review: M.Branin Man	Apro	Date:	12/2	67
·	Level: N/A ANII Review: Wyatt, Thomas W.	MALLETO	Date:	12/3/	ÔZ
	.1060 an, Timothy L. TG	.1060 an, Timothy L. TG Level: II-PDI Reviewer: DAmon Rifestu Level: N/A Site Review: MBreadia Level: N/A ANII Review: Wyatt, Thomas W.	.1060 an, Timothy L. TG Level: II-PDI Reviewer: DAmon Rifstury Dan Level: N/A Site Review: MBraain Market Level: N/A ANII Review: Wyatt, Thomas W. MMM	.1060 an, Timothy L. TG Level: II-PDI Reviewer: DAmon Rifstury Date: Level: N/A Site Review: Morragia Interpreted Date: Level: N/A ANII Review: Wyatt, Thomas W. MAUDIO Date:	Page: 2 of .1060 an, Timothy L. C. Level: II-PDI Reviewer: DAmon Refestury Date: 12/1 Level: N/A Site Review: Morgania Marchine Date: 12/2 Level: N/A ANII Review: Wyatt, Thomas W. MAUDIO Date: 12/3/1



N.SHEAREN LTD 775hm 11/10/07



.



.452 .460 .465 .464 .652 .715 .945

WELD LENGTH: 11.5" CAP WIDTH: 0,95"

PROFILE TAKEN & O'TOL

Paul 5 Bleche II 11/18/07

UT-07-110 C2.1.1070 20F2

MLI 86 C2.1.1084

Value

Flow

roander

Dichers Michael 8-7-01



· · ·

C2.1.2117

Group					Page: 2 of 3
Summary No.: C2.1.1	118				
Examiner: Down:	s, William R. A.	Level: III-PDI	Reviewer: Damos F	RIESTLEY Jul	Date: 11/28/07
Examiner: N/A	<u></u>	Level: N/A	Site Review: <u>HW DIE</u>	w Marken	- Date: 11/28/07
Other: <u>N/A</u>		Lever:A	ANII Review: wyaπ, The	omas w.	<u>270</u> Date: <u>72/9/01</u>
Comments: Weld F	Profile				
Sketch or Photo: L:\Share	ed\ISIDATA\IDDEAL Documentation\RFO15	5\Linked Documents\UT-07-	092a and UT-07-093a.jpg		
	/				
	Language and the second s			•	
			S.	WEEPOLET	
			/		
		<u>.</u>			
. :		45° TUE	7.8 45.	• •	
		E	77		
			<i>/</i>		
	PROFILE AT	RT "O" MARK			
	(WORST CASE) TYPICAL	PROFILE FOR C	2,1,290	
	AND CZ. 1. 1	18.		-	· .

•

Generation Group		ouppientent	arneport		Report No	D.: UT-07-092	
C.					Pag	e: <u>3</u> of	3
Summary No.: C2.1.11	B			٨	$ \land \land$	LI	
Examiner: Downs,	William R. BP:	Level: III-PDI	Reviewer: Dare	N PRIESTLEY	mi	Date: 11/28	67
Examiner: <u>N/A</u>		Level: N/A	Site Review: <u><i>L</i></u>	des man	Sen .	Date: 11/281	67
Other: <u>N/A</u>		Level: <u>N/A</u>	ANII Review: Wyat	t, Thomas W.	ARIAND	Date: /2/4/	01
Comments: Coverag	e Calculation		······				~~~~
,	·						
Sketch or Photo: L:\Shared\	ISIDATA\IDDEAL Documentation\RFO15\L	.inked Documents\UT-07-0	92b and UT-07-093b.jpg				
	•						
	+						
·.	Covenner F	on C2,1.2	90 AND CT	2, 1, 115			
	Covenser F	or C2,1.2	90 AND 62	2 , 1 , 11 8			
	COVENALE F CIRCUMFERENTIA	CZ,1.2 CSCHN	90 AND 62	2 , 1 , 11 8	•		
•. •	COVENALE F CIRCUMFERENTIA URSTREAM	C2,1.2 C5CHM	90 AND 62	2 , 1 , 11 8 .			
	COVENNEE F CIRCUMFERENTIA UNSTREAM	CZ, 1. Z SCHM 100%	90 AND 62	2, / , // 8*		· · ·	
	COVENNER F CIRCUMFERENTIA UNSTREAM DOWNSTREAM	0 R CZ.1.2 C SCHN 10070 10070	90 AND 62	2, / , // 8*			
•	COVENNEE F CIRCUMFERENTIA UNSTREAM DOWNSTREAM	0 P CZ.1.2 C SCHN 10070 10070	90 AND 62	2, , ; \$*	· · ·		
	COVENNER F CIRCUMFERENTIA UNSTREAM DOWNSTREAM AXIAL SCAMM	оп С2.1.2 с 5 с нт 10070 10070 :же 4890	90 AND 62	2, /, // 8*			
	COVENSLE F CIRCUMPERENTIA UNSTREAM DOWNSTREAM AXIAL SCAMM	02 CZ.1.2 5 CHN 10070 10070 10070 10070	90 AND 62	2, /, // 8			
	COVENNEE F CIRCUMFERENTIA UNSTREAM DOWNSTREAM AXIAL SCANN GU [°] (30" E 40	оп С2.1.2 с 5 с нм 1 0 0 % 1 0 0 % 1 0 0 % іме 4 8 % Асн wonst сл % сочепляте	90 AND CZ	2. 1. 11 8°	on EmT)		
	Сочениск Г Сіксим релентія ир 5 тлеят Ооша 5 тлеят Ахіяс 5 с ята 40 300° (30° Е 40	оп С2.1.2 с 5 с нм 1 0 0 % 1 0 %	90 AND CZ SE AREA, TH N AND DOWN	2, 1, 11 8 20 PER COMP STREAM	o n E w T)		





Paul S Blecher II 11-14-07

C2, 1, 122

Page los 2

SUMMARY NO: CZ.1.122 COMPONENT ID: MS-42C

TOTAL EXAM COVERAGE = 8.29 IN^3 on 100% H = .26 W = 1.5 .26 × 1.5× 21.25 = 8.29 IN^3 L = 21.25

MISSED 2 DIRECTIONAL AXIAL COVERAGE FROM O° 1/80° QUADRANTS.

H = 0.26 W = 0.4 $\frac{0.26 \times 0.4}{2} = 0.052$ L = 10.6 $0.052 \times 10.62 = 0.55 \text{ in}^{3}$ OR $\frac{13.9^{\circ}6}{86.1^{\circ}6} \text{ Missed Coverable}$ $86.1^{\circ}6 \text{ (EAXIAL DIRECTIONAL)}$ COVERSUE

MISSED 2 DIRECTIONAL AXIAL COVERAGE FROM 90° + 270° QUADRANTS. H = 0.26

 $\omega = 1.0$, $26 \times 1.0 \times 10.6 = 2.76 \text{ in}^3$ or <u>66.67</u> % missed coverable L = 10.633.33% (2 AXIAL DIRECTIONAL COVERABLE

(W SCAN = 100% (W SCAN = 100%

0"+180" QUADRANT SCANS = 86.1%

90+270 QUADRAWT SCAUS = 33,33%

319.43 + 4 = 79.86% CODE COVERAGE

Page 2 of 2.

Paul 5 Blut IS 11-14-07

NGG Gener	par ration D	Supplement	al Report	Report F	t No.: <u>UT-07-093</u> Page: <u>2</u> of <u>3</u>
Summary No.: Examiner: Examiner: Other:	C2.1.290 Downs, William R. <u>M.S.</u> N/A N/A	Level: III-PDI Level: N/A Level: N/A	Reviewer: <u>Darron Rics</u> Site Review: <u>UU Blew</u> ANII Review: <u>Wyatt, Thomas W.</u>	MAMARK	$\begin{array}{c} & \mathcal{L} \cdot \mathcal{II} \\ & \text{Date:} \mathcal{I} / \mathcal{28} / 07 \\ & \text{Date:} \mathcal{I} / \mathcal{28} / 07 \\ & \text{Date:} \mathcal{I} / \mathcal{28} / 07 \\ & \text{Date:} \mathcal{I} / \mathcal{2} / \mathcal{I} / / 07 \end{array}$
Comments:	Weld Profile	· · · · · · · · · · · · · · · · · · ·			·····
Sketch or Photo:	L:\Shared\ISIDATA\IDDEAL Documentation\RFO15\L	Linked Documents\UT-07-0	92a and UT-07-093a.jpg	· ·	
		Flow			
	FLANGE	Fiow	SWEC	206 T	
	FLANGE	Fiow +5' Tot T	S W & C	°06 (†	۰. ۱
	FLANGE	Fiow 45' ToE T E	S W & C	Pol C T	۰. ۱
	FLANGE PROFILE AT	FLOW FLOW RT "O" MARK	S W E E	206 C T	

NGG Gene	ar ration J	Supplemer	ntal Report		Report No.: Page:	UT-07-093 3 of 3
Summary No.: Examiner: Examiner; Other:	C2.1.290 Downs, William R. BP 1 N/A	Level: III-PDI Level: N/A Level: N/A	Reviewer: Site Review: ANII Review:	<u>Mw Blew</u> Wyatt, Thomas W.	TUNUMPUN	Date: Date: 11 28/0 Date: /2/4//7
Comments:	Coverage Calculation		-		/	
Sketch or Photo:	L:\Shared\ISIDATA\IDDEAL Documentation\RFO15\Lir	nked Documents\UT-07	7-092b and UT-07-0	93b.jpg		
· ·	COVERNEE FO	5 C Z , I .	290 AND	2 62,1,118		
	UPSTREAM DOWNSTREAM	100%				
	AXING SCHMM.	inc 48%	90			
	60° (30° EA 40)	COVENAE	ASE ARE.	A, TWO PER C	om Run EnT)	·
	500 .50%	, 01.21.12	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			

	ar ation		Supplement	al Report		Report No.: Page:	<u>UT-0</u> 2	7-094 of 2	
Summary No.:	C2.1.8		_		n /	11.			
Examiner;	Downs, William R.	BP.	Level: III-PDI	Reviewer:	DAMON PRIESTIEY	nf	Date: /	1/24/07	
Examiner:	<u>N/A</u>		Level: <u>N/A</u>	Site Review:	Mart Thomas W	ATTA DA	Date: 1	128/67	
Other.				ANII HEVIEW:	wyatt, momas w ////	apren_	Date: <u>74</u>	44102	
Comments:	Weld Profile and Coverage	e Calculation							•
									•
Sketch or Photo:	L:\Shared\ISIDATA\IDDEAL Do	ocumentation\RF015\l	inked Documents\UT-07-0	94a.jpg		· · · ·			
		2	· · · · · · · · · · · · · · · · · · ·		بست				
. ·			FLOW						
		•							
	VALVE								
					PIPE				
			۔ ن						
			£ 45						
		· · · · ·							
	· .								
	•				HXING 100%	2			
					cinc 507	, 2	•		
	•				COVERHEE 75				
					-				

• •

.

This drawing is representative of the following Summary Numbers; C2.1.543, C2.1.1031, C2.1.1098, C2.1.1272,C2.1.2174, C2.1.2199, and C2.1.2200. The cast Tee material causes the same limitations as a pipe to valve configuration. Only 50 percent coverage is credited for each exam. The drawing is not to scale.



A. . . .

The following drawing is representative of the following summary numbers; C2.1.190, C2.1.526, C2.1.527, C2.1.600, C2.1.2073, and C2.1.2078. The drawing is not to scale.



.

.

This drawing is representative of the following Summary Numbers; C2.1.192A, C2.1.605, C2.1.625, C2.1.104, C2.1.1477, C2.1.163, C2.1.167, C2.1.170, C2.1.184, C2.1.503, C2.1.542, C2.1.548, C2.1.1018, C2.1.1040, C2.1.1047, C2.1.1067, C2.1.1096, C2.1.1097, C2.1.1207, C2.1.1223, C2.1.2136, C2.1.2137, C2.1.2162, C2.1.2164, C2.1.2169, C2.1.2173, C2.1.2175, C2.1.2176, C2.1.2202, C2.1.2238, and C2.1.2240. The drawing is not to scale.



PROGRESS ENERGY FLORIDA, INC.

CRYSTAL RIVER UNIT 3

DOCKET NUMBER 50 - 302 / LICENSE NUMBER DPR - 72

ENCLOSURE 3

INSERVICE INSPECTION RELIEF REQUEST #09-003-II THIRD TEN-YEAR ISI INTERVAL

10 CFR 50.55a Request #09-003-II

Proposed Alternative In Accordance with 10 CFR 50.55a(g)(6)(ii)(A)(5) and 10 CFR 50.55a(a)(3)(i)

--Reactor Pressure Vessel Shell Weld Examination--

1. ASME Code Component(s) Affected

Reactor Pressure Vessel Lower Shell-to-Transition Piece Weld, Unique Identifier B1.2.1

Reactor Pressure Vessel Nozzle Belt Intermediate Shell Weld, Unique Identifier B1.2.3

Reactor Pressure Vessel Lower Shell to Lower Head Weld, Unique Identifier B1.2.2

Reactor Pressure Vessel Long Seam at 247 degrees, Unique Identifier B1.1.5

Reactor Pressure Vessel Long Seam at 67 degrees, Unique Identifier B1.1.6

Reactor Pressure Vessel Outlet Nozzle-to-Shell Weld, Unique Identifier B1.4.7A

Reactor Pressure Vessel Outlet Nozzle-to-Shell Weld, Unique Identifier B1.4.8A

2. Applicable Code Edition and Addenda

American Society of Mechanical Engineers (ASME), Boiler and Pressure Vessel Code, Section XI, 1989 Edition, no addenda.

3. Applicable Code Requirement

ASME Code, Section XI, Sub-article IWB-2500 states, in part, "Components shall be examined and tested as specified in Table IWB-2500-1." Table IWB-2500-1 requires an examination of applicable Class 1 pressure retaining-welds, which includes essentially 100 percent of weld length once during the ten-year ISI interval for the following Code Categories:

Category B-A: Item Numbers B1.11 and B1.12 Category B-D: Item Number B3.90

10 CFR 50.55a(g)(6)(ii)(A)(2) requires licensees to implement the examination requirements of the 1989 Edition of ASME Section XI for reactor vessel shell welds. Subsection IWB, Table IWB-2500-1, "Examination Category B-A," Item B1.11, requires a 100 percent volumetric examination of all shell welds for the third ten-year ISI interval. As defined in 10 CFR 50.55a(g)(6)(ii)(A)(2), 100 percent, as used in Table IWB-2500-1, means more than 90 percent of the examination volume of each weld, where the reduction in coverage is due to interference by another component, or part geometry.

Code Case N-460 permits a reduction in examination coverage of Class 1 and Class 2 welds provided the coverage reduction is less than 10 percent. CR-3 has adopted Code Case N-460 in the Inservice Inspection (ISI) Program Plan, as permitted by NRC Regulatory Guide 1.147, Revision 15.

4. Determination of Limits of Weld Volume Examination

Examinations were performed using two Trans World System manipulators and AREVA's Automated Data Acquisition and Analysis System, ACCUSONEX. All ultrasonic examinations were performed using examination procedures and personnel qualified by demonstration in accordance with the requirements of Appendix VIII of the ASME Boiler and Pressure Vessel Code, Section XI, 1995 Edition with Editions up to and Addenda through 2000, as modified by the Performance Demonstration Initiative (PDI) program. These examinations were performed to the acceptance standards of ASME Boiler and Pressure Vessel Code, Section XI, 1989 edition, no addenda. These examinations were performed to the maximum extent possible.

Examinations of the reactor vessel circumferential, longitudinal, and nozzle-to-shell welds, scanned from the vessel shell, were performed using 45 degree shear wave, 45 degree longitudinal wave and 70 degree longitudinal wave transducers. The circumferential and longitudinal welds were examined by scanning from four opposing beam directions such that the sound energy from the angle beams pass through the weld material and adjacent base material from each direction to the maximum extent possible. The nozzles to shell welds (inlet and outlet) were scanned from the vessel shell using four opposing beam directions and from the bore with beams looking radially. The scans from the bore used 45 degree shear wave and 15 degree longitudinal wave transducers. The inside radius sections of the inlet and outlet nozzles were also examined by enhanced visual testing.

For each required scan, the amount of sound beam that passed though the required examination volume has been plotted on scaled cross sectional drawings of each component configuration (see Attachment B). The examination coverages reported in the following table have been determined by averaging the amount of coverage obtained from each of the required scans for the required examination volume. These examinations are limited by part geometry or interferences with other components, such that the reduction in coverage is greater than 10 percent.

ldentifier	Description	Category	ltem	Coverage	Limitation
B1.2.1	RPV Lower Shell to- Transition Piece	B-A	B1.11	46	The core guide lugs and flow distributors interfere with scan paths.
B1.2.3	RPV Nozzle Belt Intermediate Weld	B-A	B1.11	90	Inlet and outlet nozzles interfere with the scan paths.
B1.2.2	RPV Transition Piece to Bottom Head	B-A	B1.11	0	Core guide lugs and flow distributors prevent inspection
B1.1.5	RPV Long Seam, at 247 degrees	B-A	B1.12	88.1	Core guide lugs and flow stabilizers prevented full movement of the head

ldentifier	Description	Category	ltem	Coverage	Limitation
B1.1.6	RPV Long Seam, at 67 degrees	B-A	B1.12	88.1	Core guide lugs and flow stabilizers prevented full movement of the head
B1.4.7A	A Outlet Nozzle to RPV Shell Weld	B-D	B3.90	69.8	Surface Geometry
B1.4.8A	B Outlet Nozzle to RPV Shell Weld	B-D	B3.90	69.8	Surface Geometry

Examination Details

Component B1.2.1: Reactor Pressure Vessel Lower Shell-to-Transition Piece Weld

The pre-service records reported the examination coverage as "best effort" due to the interferences with core guide lugs and flow stabilizer vanes (see Attachment A, FPC Drawing 135546E, for lug and vane locations). No preservice indications were recorded.

During the First Ten-Year ISI Interval examination, the core guide lugs and flow stabilizer vanes were reported as limitations and no indications were recorded.

During the Second Ten-Year ISI Interval examination, the average amount of coverage was calculated to be 29 percent.

During the Third Ten-Year ISI Interval examination, the average amount of coverage has been calculated to be 46 percent. Twelve (12) sections of the weld between the 12 lugs were accessible for examination. No unacceptable indications have been recorded.

Although the weld area beneath the lugs received no ultrasonic examination coverage, no flaws were identified during a remote VT-3 visual examination of the lug areas. This weld is located outside of the area of highest irradiation in the reactor vessel. (See Attachment B for coverage data.)

Component B1.2.3: Reactor Pressure Vessel Nozzle Belt Intermediate Weld

No limitation areas were reported during the pre-service examination of this component. The weld was examined to the maximum extent possible. No relevant pre-service indications were recorded.

During the First Ten-Year ISI Interval examination, only 5 percent of the weld length was examined to satisfy the requirements of Table IWB-2500 of the 1974 Edition of ASME Section XI through Summer 1975 Addenda. No indications were recorded.

During the Second Ten-Year ISI Interval examination, a total of 75 percent of the weld was examined. No unacceptable indications were recorded.

During the Third Ten-Year ISI Interval examination, a total of 90 percent of the weld was examined. The remaining ten percent was not accessible due to scanning interferences with the inlet nozzle openings and the outlet nozzle boss extensions. (See Attachment B for coverage data.)

Component B1.2.2: Reactor Vessel Transition Piece to Bottom Head Weld

The subject weld is the reactor vessel transition-piece-to-bottom-head-weld. This weld is located below the beltline region and is not subject to the majority of the neutron flux escaping from the core. An evaluation of neutron embrittlement as a potential damage mechanism has been performed with the conclusion that service induced degradation of the transition-piece-to-bottom-head-weld as a result of corrosion, fatigue, nuclear or thermal embrittlement mechanisms is extremely unlikely.

This weld has been visually and ultrasonically inspected once during pre-service inspection (essentially 100 percent coverage). The volumetric examination method utilized during the pre-service inspection was performed with the manual contact method. There were no reportable or recordable indications detected during this inspection.

During the First Ten-Year ISI Interval vessel inspection, the weld was partially inspected (approximately 5 percent) using the immersion method of ultrasonic inspection. This was acceptable as per the ASME Boiler and Pressure Vessel Code, Section XI, 1974 Edition through the Summer of 1975 Addenda, and Regulatory Guide 1.150. The extent of this examination was acceptable since the 1974 Edition of ASME Section XI, Table 2500-1, Category B-A, only required the examination of 5 percent of this weld. The examination was performed using the ARIS II remote scanner, a device that utilized immersion ultrasonic techniques. The examination revealed no baseline indications, no reportable indications and no recordable indications.

Although the use of immersion testing allowed the weld to be inspected with inspection equipment at a distance of up to twenty inches away from the weld, access for examination of this weld was limited by the flow stabilizers, the core support lugs and the incore instrumentation nozzles.

Since that inspection was performed, improvements in volumetric examination methods have shown the contact method to be much more accurate and reliable than the immersion method. As a result, equipment designed to use the immersion technique has been abandoned and modern reactor vessel inspection equipment has been designed to utilize the contact examination method.

Relief was granted from this inspection during the Second Ten-Year ISI Interval under Relief Request #95-030 (TAC NO. M93755).

The Third Ten-Year ISI Interval volumetric inspections were not able to be performed using modern automated reactor vessel inspection equipment. The implementation of the requirements of Appendix VIII of the ASME Boiler and Pressure Vessel Code, Section XI, 1995 Edition with Editions up to and Addenda through 2000, as modified by the PDI program, place stringent controls on the methodology utilized in performing this inspection.

Access to the weld from the vessel exterior presents safety and As Low As Reasonably Achievable hazards. Access to the weld to perform the inspection from the outside using a manual contact ultrasonic method would require concrete removal in the cavity and suspension of an inspection team between the exterior of the vessel and inside the shield wall by harnesses.

The reactor vessel interior was subject to VT-1 and VT-3 inspections in Refueling Outage 15 during the Fall of 2007 which included all welds and interior attachments. VT-2 inspections on the exterior of the vessel were performed during the inservice leak test performed during start-up. No indications were identified during these inspections.

Components B1.1.5 and B1.1.6: RPV Long Seam

The Reactor Pressure Vessel (RPV) long seam welds on the lower head to lower shell section are limited by the geometry of the core positioning lugs and the flow stabilizers(see Attachment A, FPC Drawings 135544E and 135546E).

The location of the obstructions prevented the scanning head of the inspection tool to achieve required coverage. During the Second Ten-Year ISI Interval, 94 percent coverage was achieved using a different inspection methodology that was not approved through the PDI process.

Inspections performed as directed by Appendix VIII of the ASME Boiler and Pressure Vessel Code, Section XI, 1995 Edition with Editions up to and Addenda through 2000, as modified by the PDI program, are more stringent in transducer selection which allowed for 88.1 percent required coverage for these longitudinal welds. No unacceptable indications have been identified during the Pre-service, First Ten-Year ISI Interval, Second Ten-Year ISI Interval, or Third Ten-Year ISI Interval examinations of these longitudinal welds. (See Attachment B for coverage data.)

Components B1.4.7A and B1.4.8A: Reactor Pressure Vessel Outlet Nozzle to Shell Welds

The outlet nozzle extension geometry has provided the same limitation area during the Pre-service, First Ten-Year ISI Interval, and Second Ten-Year ISI Interval volumetric examinations of these nozzle welds (see Attachment A, FPC Drawing 135540E). The boss extension limits the circumferential scan coverage to 26 percent. However, 100 percent of the required weld volume and adjacent base material has received 2 axial angle beam scans from the nozzle bore. No unacceptable indications have been identified during the Pre-service, First Ten-Year ISI Interval, Second Ten-Year ISI Interval or Third Ten-Year ISI Interval examinations of these outlet nozzle-to-shell welds. (See Attachment B for coverage data.) U. S. Nuclear Regulatory Commission 3F0309-01

5. Proposed Alternative and Basis for Use

None. In lieu of the ASME Code requirement of essentially 100 percent volumetric examination, CR-3 proposes ultrasonic inspections of accessible areas to the maximum extent practical, given the design configuration of the Reactor Pressure Vessel Welds, and VT Inspections of all accessible areas sufficient for continued safe operation. Additionally, system leak rate limitations are imposed by Improved Technical Specification 3.4.12 and reactor building normal sump rate monitoring provides additional assurance that any leakage would be detected prior to gross failure of the component.

6. Duration of proposed Alternative

Relief is requested for the Third Ten-Year ISI Interval of the Inservice Inspection Program for CR-3 which was effective from August 14, 1998, ending August 13, 2008.

7. Precedents (Optional)

NRC granted relief for Augmented Reactor Vessel Shell Weld Examination under Relief Request #98-009-II on August 5, 1999 (TAC NO. MA1642).

NRC granted relief for RPV Lower Head to Bottom Shell Weld under Relief Request #95-030 on April 14, 1996 (TAC NO. M93755).

8. References (Optional)

ENCLOSURE 3

ATTACHMENT A

VESSEL DRAWINGS

INSERVICE INSPECTION RELIEF REQUEST #09-003-II THIRD TEN-YEAR ISI INTERVAL

<u>126951E</u>	Arrangement Reactor Vessel Long Section
<u>135540E</u>	Reactor Vessel Detail and Sub-Assembly Outlet Nozzles
<u>135543E</u>	Vessel Radiographic Outline
<u>135544E</u>	Vessel Head and Support Assembly Detail
<u>135546E</u>	Vessel Assembly and Final Machining








e y e





ENCLOSURE 3

ATTACHMENT B

COVERAGE DATA

INSERVICE INSPECTION RELIEF REQUEST #09-003-II THIRD TEN-YEAR ISI INTERVAL

Coverage Layout & Calculations

Weld Description: Lower Shell to Lower Head ASME Code Item No. B1.11 CR-3 Weld ID: B1.2.1 ASME Code Figure No :: IWB-2500-1 TWS Weld Designator: W09 AREVA Drawing No.: 8019749

AGGREGATE COVERAGE: 46.0%

Zone Coverage Obtained

14 1				Examina	tion Volum	Definition)		
		Weld.	Length	535/25	in				
	Area	Measureme	nt		Volume Ca	lculation			
Inner:15%T			7:84:	rsq. in:	Inner 15%1	•.•		4196.4	cũ. (n.
Outer 85%T			41:68	sq. in:	Outer 85%			22309.2	,cu; in:
Limita	tions	Lin	nits scan b	y: Aren aren a	Basis	Yania diaman.	Compe	nsation(s)	e and a second second
LUGS & FIOW	Stannizers	Fiexening i	un noveme	incol neac	Diraviir	Chic Scan i	inder standing	erediona in i	uaximize scan coverage.
h	Ē	xamination C	overage C	alculations	(CW & CC	N Treated a	s Single Side	d Examinatic	in))
INNER 15	5%T "UP	PER" (LII	VITATIC	NS)	ericijanski drževsti do	e na sterensk kra Linder og steresk kra	n synder of the second s	n uasyskin i skrii I	
	Exam.		Area	Lenath	Volume	Volume:			2 d.
	Angle	Beam	Examined	Examined	Examined	Required	Percent	·	
Entrys#	(deg.)	Direction	(sq. in.)	(in.);	(cu. In.)	(cu. ln.)	Examined	Limited	Limitations
- 1	70L/45L	Up	<i>ā</i> .84	54/98	430.9	4196,4	10.3%	Yes	Lugs & Flow Stabilizers
2	706456	Down	7:84	54,96	430.9	4196:4	10.3%	Yes	Lugs & Flow Stabilizers
3.8.4	70L/45L	CW & CCW	7.84	97.20	762,0	4196.4	18:2%	Yes	Lugs & Flow Stabilizers
: 		<u></u>		Totals:	1623.8	12589,1	12.9%		· · · · · · · · · · · · · · · · · · ·
OUTER 8	5%T "UF	PER" (L	IMITATI	ONS)					•
r .	Exam.		Area	Length	Volume	Volume	· · · · ·		· · ·
ti da	Anglo;	Beam	Examined	Examined	Examined	Required	Percent	1	5
Entry #	(deg.)	Direction	<u>(sq. in)</u>	(in)	(cu in)	(cu. in.)	Examined	Limited	Limitations
1	45L/45S	Up	41.68	254:95	2290.7	22309.2	10.3%	Yes	Lugs & Flow Stabilizers
	450405	Lown Coursecours	41,08	24,20	2290.7	27309.2	30.3%	Yes	Lugsia Flow Stabilizers
မွှာလူမှ	400400	CAN & CCAN	4,1,00	Totale	11262.6	66027.7	16.8%	165	ILBUS OF THE STRUCTURE STRUCTURE
				10(013)	17203.0	0032777	10.0.0	·	
· · ·		Examinat	ion Covera	de Calcula	tions IAII Tr	eeted/as-Sil	nole Sided Ex	amination)	· · · ·
INNER 1	5%T "1 C	WFR" (1	ΙΜΙΤΔΤΙ	ONSI		. •	e. F	. ¥7.	
	Exam		Area	Lennih	Volume	Volume			
э - х	Angle	Beam	Examined	Examined	Framined	Required	Pernent		
Entriv#	(deg.)	Direction	(sq.in)	and	(cu.°in:).	(cu. in.)	Examined	Limited	Limitations
182	70L/45L	Up/& Down	4.09	301.00	123101	4196:4	29:3%	Yes	Lugs & Flow Stabilizers
3.8.4	701/45L	CW & CCW	4.33	252.84	1094.8	4196,4	26.1%	Yes	Lugs & Flow Stabilizers
				Totals.	2325.9	8392.7	27:7%		
OUTER 8	35%T "LC	OWER" (L	IMITAT	IONS)			· · · · · · · · · · · · · · · · · · ·		
e . ¹	Exam	. <u>.</u>	Area	Length	Volume	Volume			
	Angle	Beam	¹ Examined	Examined	Examined	Required	Percent		
Entry #	- (deg;)	Direction	(sq: in)	(în,)	(cu. in.)	(cu, in,)	Examined	Limited	Limitations
182	45L/45S	Up & Down	27.72	301.00	8343.7	22309.2	37:4%	Yes	Lugs & Flow Stabilizers
3.8 4	45L/45S	CW & CCW	22.66	312.00	7069.9 -	22309.2	31.7%	Yes	Lugs & Flow Stabilizers

Totals:

51-9065750-000

Section E, Tab 2

15413.6

44618.4

34.5%

Page 28 of 53





15% & 85%T Coverage Plot "Limited" Lower Scan in Axial "Z" Direction - Limited in Circumferential "e" Direction "MAP" Scan Not Possible Due to Tool Cable Bundle/Lug Interference (Axial Scan – Perpendicular to weld)

Weld Identification TWS No .: W09 CR-3 No.: B1.2.1

Page 29 of 53

Section E, Tab 2

51-9065750-000





PLOW STABILIZER SCANNING

Weld Identification TWS No: W09 CR-3 No: B1.2.1

15% & 85%T Coverage Plot "Limited" Lower Scan in Axial "Z" Direction - Limited in Circumferential "a" Direction (Circ Scan – Parallel to weld)

Note: The circumferential extent of the MTP & MTN scons are derived by the average distance traveled by the respective (.e., 45° or 70°) beam path. This is shown by the measurements taken from the midpoint of the beam paths.

51-9065750-000

Section E, Tab 2

Page 30 of 53



18.80 -25.08" (1:486"/") by 12 locations vouchs 301.00"



CORE LUG SCANNING

1	Constrainty of the second s
1	Nold Identification
	Saladon and a second and a second
	TWICHIGHNAMO
	CITTO NU. ATUO
	CK-3 NO.: B 2.1
	and the second

15% & 85%T Coverage Plot "Unlimited" Upper Scan in both Axial "Z" and Circumferential "e" Directions (Axial Scan – Perpendicular to weld)

51-9065750-000



14.16"-21.07" (1.486"/) by 12 locations equals 252.84" 17.50"-26.00" (1.486"/) by 12 locations equals 312.0"



CORE LUG SCANNING.

Weld Identification TWS No.: W09 CR-3 No.: B1.2.1



Note: The circumferential extent of the MTP-8 MTN scans are derived by the average distance traveled by the respective. I.e., 45° or 70°) beam path: This is shown by the measurements taken from the midpoint of the beam paths:

51-9065750-000

Section E, Tab 2

Page 32 of 53

Coverage Layout & Calculations

 Weld Description:
 Nozzle Belt to Upper Shell
 ASME Code Item No.: B1:11

 CR-3 Weld ID: B1:2.3
 ASME Code Figure No.: IWB-2500-1

 TWS Weld Designator:
 W02
 AREVA Drawing No.: 8019749

AGGREGATE COVERAGE: 90.0%

Inner 15%T:	Zone 85.4%	Coverage Obtained Outer 85%T: 94.7%		
· · · · · · · · · · · · · · · · · · ·	Examin Weld Length 275.0	nation Volume Definition	۴. 	· · ·
Inner 15%T Outer 85%T	Area Measurement See Notes sq. in See Notes sq. in	Volume Calculation Inner 15%T Outer 85%T	,7194,5 cu ini. 43643 6 cu ini.	с
Limitations Nozzles	Limits scan Reduction in circ scan distance	by:	Compensation(s) None	nden men en kommen die daar van de

		Examina	ition Cover	age Calcul	ations (Tre	ated as Sing	le Sided Exan	vination)	•		
INNER 15	%Т										
	Exam Angle;	Beam	Area Examined	Length Examined	Volume Examined	Volume Required	Percent			timitálishe.	
14100 y.4 3 3 4 2 3	70L/45L 70L/45L 70L/45L	CW CW CW	See I See I See I	Notes Notes Notes Totals:	6244.2 6090.9 6090.9 6090.9	7194.5 7194.5 7194.5 7194.5	86.8% 84.7% 85.4%	Yes Yes		Nozzles Nozzles Nozzles	
OUTER 8	5%T				* , jaite - 19** *	, ,					•
Entry	Exam. Angle (deg?)	Beam	Area Examined (sq. in.)	Lengin Examined (in-)	Volume Examined (cubin.)	Volume Required	Percent Examined	Limitod		Limitations	
3	45L/46S 45L/45S 45L/45S	Up & Down CW CCW	See See	Notes Notes Notes Totals :	37785.4 43072.7 43072.7 37785.4	43643.6 43643.6 43643.6 43643.6	86.6% 98.7% 98.7% 94.7%	Yes Yes Yes		Nozzles Nozzles Nozzles	

51-9065750-000

Support Charts for Area Examined:

		Sex Acres 1	otal Area to	be Examine	ed: , i,*
	Vertical	A Horizon	tal Area	Mon Total N	lolume 👘
Scan Area	Height -	15%	85%	15% M	. 85%;
Z-W & W-X	15 31	86:98	527.62	1331.66	8077.86
0UT Z & Z-W	15.31	74.39	451 27	1138.91	6908.94
Y-Z & OUT Z	15:31	73:59	446,44	1126.66	6835.00
X-Y & Y-Z	15:31	86.98	527.62	1331.66	8077.86
OUT X & X-Y	15.31	73.59	446.44	1126.66	6835.00
W-X & OUT X	15.31	74:39	451.27	1138.91	6908.94
• • •			Total	7194.5	43643.6

		STP & STN					
<u></u>	Vertical	Horizon	tal Area 📃	Total	Volume		
Scan Area	Height	15%	85%	15%	85%		
Z-W & W-X	15.31	77.76	524.67	1190.51	8032.70		
OUT Z & Z-W	15.31	60.58	440.12	927,48	67.38.24		
Y-Z & OUT Z	15.31	60:58	434.30	927.48	6649.13		
X Y & Y-Z	15.31	77 76	539.85	1190,51	8265.10		
OUT X & X Y	15.31	60.58	434.32	927:48	6649.44		
W-X & OUT X	15.31	60.58	440.11	927.48	6738.08		
			Total	6090.9	430727		

			SZP SZP K	MSZN 👘	
· ·	Vertical	Horizon	tal, Area, 😒	Total \	lolume
Scan Area	Height	15%	85%	15%	85%
Z-W & W-X	15:31	78.75	.477.66	1205.66	7312.97
OUT 2:8 2-W	15,31	61/30	371.88	938.50	5693.48
Y-Z& OUT Z	15.31	61.43	37,2.64	940.49	5705.12
X-Y & Y-Z	15.31	83.64	501.32	1280.53	7675:21
OUT X & X-Y	15:31	61.43	372.64	940.49	5705.12
W-X & OUT X	15.31	61.30	371.88	938.50	5693,48
			Total	6244.2	37785 4

51-9065750-000

15.31

15% & 85%T Coverage Plot Typical Cross Section (Both Scans Axial & Circ)

Section E, Tab 2

Page 8 of 53

Weld Identification TWS No: W02 CR-3 No: B12-3



15% & 85%T Coverage Plot (Axial Scan – Perpendicular to weld) View – Gross Section at Nozzle Centerline Elevation

EXTRACTOR AND A CONTRACT OF A

Section E, Tab 2

The same second and the

.



15% & 85%T Coverage Plot (Circumferential Scan - Parallel to weld)

View - Cross Section at Nozzle Centerline Elevation

51-9065750-000



View:= Cross/Section at Nozzle Centerline Elevation

Coverage Layout & Calculations

Weld Description: Long Seam Weld. CR-3 Weld ID: B1:1.5 & B1:1.6 TWS Weld Designator: W06 & W07 ASME Code Item No.: B1.12 ASME Code Figure No.: 1WB-2500-2 AREVA Drawing No.: 8019749

AGGREGATE COVERAGE: 88.1%

Zone Coverage Obtained

Inner 1	5%T	87.2%		0	uter 85%T:	89.0%			
:		Weld	Length	Examina 73.12	tion Volum In	Definition	Ì.		
~	Area	Measureme	nt		Volume Ca	louiation	· · · · · · · · · · · · · · · · · · ·	and desired and	
Inner 15%T Outer 85%T			12.73	sq. in.	Inner 15%1 Older 85%	E.		930,8	cu in.
Limital	tions	di li în	nite scan h	and and a	100,00,00 %		Compar	U. POC	• بالم
Lucis & Flow	Stabilizers	Preventino f	ill moveme	n of Head	Preakir	n clic sean	into multiple.	isayong ta'm	avimize scan coworadau
TER SYSK	anan seria ang ar	. The Constraint of the			encount			-9-04-14-04-14 	overessoner and coalises
		Examin	ation Cove	rage Calcu	lations (Tre	ateo as Du	al Sided Exam	ination)	
INNER 15	5%T	24 (347 (241 (344 - 44 	-120 (201), genter 19 November 1	್ಷ ಸಹಸ್ಥಾನ	995 2020 costs o costs 1	Na serie di ante de la constructione de la constructione de la construction de la construction de la constructio	n lakingketa tana a	an talan tarah	
an na artar astri s	Exam		Area	l'entith.	Volume	VEDROS	· · · ·	· · · · ·	
	Angle	Beam	Examined	Examined	Fxamined	Recuired	Percent		
Entry #	(deg.)	Direction .	(sq. in)	- amh	(cu. m)	(cu:in)	Examined	Limited	Limitations
· · · · · · · · · · · · · · · · · · ·	70L/45L	Up.	12.73	49:12	625.3	930:8	.67.2%	Yes	Lugs & Flow Stabilizers
2	70L/45L	Davin	12.73	49.12	625/3	930.8	67.2%	Yes	Lugs & Flow Stabilizers
· · · · · · · · · · · · · · · · · · ·	70Ľ/45L	QW	1273	47.08	599.3	930.8	64.4%	Yes	Lugs & Flow Stabilizers
벽	70L/45L	CCW1	12.73	47.08	599.3	୍ 930.8	64,4%	Yes	Lugs & Flow Stabilizers
				Totals:	2449.3	3723.3	65.8%		·
OUTER 8	5%T	* 3 [°]			· · ·		· · ·		
•	E Salar		A State	1.075 E.L.S	into A A	134.86.84		2	 A state of the sta
•	America	Distanting of	- 1980 - Elandaria	Lengin	Volume	voiume:	Annalista		
Fatry	Kdea 1	Octorian Ottorian	LACTION OF	CAUTIONST: Div 1	CARONIEL	Yes is t	Frankod	A limiteday.	in the formation
1	4517458	'En:	75.65	40.12	100.00	5531 S	167/294	Yee	Lannidanis
12 B	450458	Down	75.65	49.12	3715.9	6531.5	67 29	Yes	Ligs & Flow Stabilizers
à	45L/45S	CW.	75.65	47.08	3561.6	5531.5	64 4%	Yes	Luce & Flow Stabilizers
<u>.</u> [4]	451455	GCW.	75.65	47:08	3564.6	5531.5	64.4%	Yes	Lugs & Flow Stabilizers
ь.	:-	<u>.</u>		Totals:	14555.1	22126.1	65.8%	* 4* s.	 Sector States and Sector States
			and the second second						
an a	E3 An an An An	camination C	overage 0	alculations	ICW & CC	N Treated a	as Single Side	d Examinati	on)
INNER 15	5%1 (LII	VITATION	15)	•		•	and the second		
			en gran in Staat da	- - 1.5.5555 5	i i i Storingen også i	161 2487	÷ .	,	
ж. 	Exam		Area	Length	Vojume.	Volume	and the State of States		· .
Entire H	Angle	Beam	Examined	Examined	Examined	Required	Percent		1 W. S. 11 & A. S A.
1 /	10000	Line	1\$Q, (47;) 3(1;0;2	(ID))(104.60	(CU., IN.)	(CU,HI),)	Examineo	Limited	Limitations
6	700 745	Dove.	10,50	24.00	237.1	- 900,0°	10/0/0 10/0/0	Jes	CUUS & HOW Stabilizers
3.8.3	701/451	CWECCW	7.70	48:05	125.0	300.0	13.070	185	Lugs & Flow Stabilizers
	2.3495ar2.5475ar		i ita tingt	Totale	500/2	2702 5	21 50	20 00 00	Thes of Inderstein
OUTER 8	5%T (11)	MITATION	JCA			Cherry Arrest	£ 1.6 3B		
			NO I	- Ma -					
· · ·	Eyam		. Arna	I anoth	Tohuma	Valuma			
	Anole	Beam	Framinor	Fyamined	Frammad	Sanufrar [®]	Parcent		
Entry #	(ieo.)	Direction	(so in)	-L'Verbindo	(a) in)	(car, ler)	Fxamined	Innitari	Limitatione
1	45L/45S	.Up*	64:94	-21:69	1408.5	5531.5	25:5%	YAS!	Linne & Firm Stabilizers
Ž	45L/45S	Ócwn.	64.94	21 69	1408:5	5531.5	25.5%	Yes	Litos & Flow Stabilizers
384	45L/45S	CW & CCW	64.60	16:05	1036.8	5531.5	18,7%	Yes	Lugs & Flow Stabilizers
a≯ entities e	an an an an Anti-	 	NUN 20157 59	Totals:	3853.9	16594.6	23.2%	979 - 1979 - 1 1	

51-9065750-000

and the second second

Section E. Tab 2.

Page 19 of 53

The second second second



15% & 85%T Coverage Plot (Axial Scan - Parallel to wold)

51-9065750-000

Page 20 of 53



15% & 85%T Coverage Plot (Circ/Scan - Perpendicular to weld)

51-9065750-000

Section E, Tab 2

Page 21 of 53

75.65 sq in



12.73 sq in

15% & 85%T Total Cross Sectional Area

Weld Identification TWS No.: W06 & W07 CR-3 No.: B1.1.5 & B1.1.6



	The state of the second state of the
	Wold Identification
	Alein inennication
	THINK HIS STAINCH THINK T
-	
	Share and the second
	CP.2 No 9R11592 R1 16

51-9065750-000

Section E, Tab 2

Page 23 of 53



View from Vessel ID looking out "Limited" Lower Scan Region (W06 & W07 circled)

Weld Identification TWS No:: W06 & W07 CR-3 No:: B1-15 & B1-16.

51-9065750-000

Section E, Tab 2

Page 24 of 53

Coverage Layout & Calculations

Neld Description:Outlet Nozzle to Shell @ X axis & Z axisASME Code Item No.:B3.90ASME Code Figure No.:IWB-2500-7CR-3 Weld ID (TWS Weld Designator):B1.4.7A (W15) and B1.4.8A (W23)AREVA Drawing No.:8019749

AGGREGATE COVERAGE: 69.8%

			(ZOI IE	- Coverag		eu.					
inner 1	5%T:	39.6%	Ö	uter 85%T:	100.0%			and the second			
Examination Volume Definition											
Area Measurement Volume Calculation											
Area Mea	surement i	not calculated for n	czżles:	Inner 15%1 Outer 85%	T		1300.0 12859.2	έcuein. «cuein,			
Limitations Yes		Limits sca Weld/scan surfac		Compensation(s)							
·····	1	Examination Co	overage Ca	Iculations (Treated as	Dual Sided Ex	amination)				
INNER 15	5%T			and and a second se							
Sarray - Line - Line	Exam.		Longth	Volume	Volume	,					
	Angle	Beam	Examined	Examined	Required	Percent					
Entry #	(deq.)	Direction	(degs)	(cu. in.)	(cusin)	Examined	Limited	a limitations			
	70L/45L	Bore Radial Out	360	1300.0	1300.0	100.0%	Yes				
2	70L/45L	RVID, Radial In	360	401.6	1300.0	30.9%	Yes				
3	70L/45L	CW	360	180.0	1300.0	13.8%	Yes				
4	70L/45L	COW	360	180.0	1300.0	13.8%	Yes				
i i i i i i i i i i i i i i i i i i i	· · · · · · · · · · · · · · · · · · ·		Totals;	2061.6	5200.0	39.6%	·	· · ·			
OUTER 8	5%T		· · · · ·	an a	· · · · · · · · · · · · · · · · · · ·		• • • • • • •	and a second			
							· · ·				
•	Exam		Lenoth	Volume	Voluine			· .			
	Ancile	Ream	Evenined	Examined	Penuired	Pernent		. '			
Entry 4	(dea.)	Direction	in a	low In Y	(hudna	Examined	Imiled	Innitalions			
1	151/455	Bore Badial Out	360	12859/2	12859.2	100.0%	No	a policy of the stand of the			
· · · · ·	يصريفين أتصايدن	ىرى بەركىرى بەركىيە يەركىيە يەركىيە بەركىيە يەركىيە يەركىيە. يىلى بەركىيە يەركىيە يەر		Secoult -		100-079					
· · · · ·			. ,	анан сайтан с		d starter					
			Totals:	12859.2	12859.2	100:0%					

S. Same C.



15% & 85%T Coverage Plot (Radial Scan - Perpendicular to weld from Nozzle Bore)

Weld Identification CR3 No. ((TWS No.): B1.4-7A (W15), B1.4-8A (W23)

51-9065750-000

Section E, Tab 2

Page 39 of 53



15% T Coverage Plot (Radial Scan – Perpendicular to weld from Shell ID) Beam Direction toward Bore ID

> Weld Identification CR3 No. (TWS No.); B1.4-7A (W15), B1.4-8A (W23)

51-9065750-000

Section E, Tab 2

Page 40 of 53



Weld Identification CR3 No. (TWS No.): B1.4.7A (W15), B1.4.8A (W23)

51-9065750-000

Section E, Tab 2

Page 41 of 53