

PMBelCOL PEmails

From: Tanya Simms
Sent: Monday, March 23, 2009 3:07 PM
To: 'rgrumbir@gmail.com'; 'alsterdis@tva.gov'; 'erg-xl@cox.net'; 'pshastings@duke-energy.com'; 'Ray, Phillip M'; 'kslays@duke-energy.com'; 'Bob Hirmanpour'; 'tespink@tva.gov'
Cc: Joseph Sebrosky; PMBelCOL PEmails
Subject: Draft RAI 2426 Related SRP Section 9.5.1 for Bellefonte Units 3 and 4
Attachments: RAI 2426 draft.doc

To All,

Attached is Draft RAI 2426 related to SRP Section 9.5.1 for Bellefonte Units 3 and 4. Please contact me if you desire a phone conference regarding this RAI. If no response is heard by close of business March 26, 2009, the final RAI will be issued.

Tanya Simms
Project Manager
New Reactor Licensing
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, Maryland 20852-2738
301-415-1387
Tanya.Simms@nrc.gov

Hearing Identifier: Bellefonte_COL_Public_EX
Email Number: 1421

Mail Envelope Properties (B4ECC0E252653F48B3F57C3B833465E80E59E4E391)

Subject: Draft RAI 2426 Related SRP Section 9.5.1 for Bellefonte Units 3 and 4
Sent Date: 3/23/2009 3:06:54 PM
Received Date: 3/23/2009 3:06:55 PM
From: Tanya Simms

Created By: Tanya.Simms@nrc.gov

Recipients:

"Joseph Sebrosky" <Joseph.Sebrosky@nrc.gov>
Tracking Status: None
"PMBelCOL PEmails" <PMBelCOL.PEmails@nrc.gov>
Tracking Status: None
"rgrumbir@gmail.com" <rgrumbir@gmail.com>
Tracking Status: None
"alsterdis@tva.gov" <alsterdis@tva.gov>
Tracking Status: None
"erg-xl@cox.net" <erg-xl@cox.net>
Tracking Status: None
"pshastings@duke-energy.com" <pshastings@duke-energy.com>
Tracking Status: None
"Ray, Phillip M" <pmray@tva.gov>
Tracking Status: None
"kslays@duke-energy.com" <kslays@duke-energy.com>
Tracking Status: None
"Bob Hirmanpour" <bobhirman@live.com>
Tracking Status: None
"tespink@tva.gov" <tespink@tva.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	530	3/23/2009 3:06:55 PM
RAI 2426 draft.doc	27130	

Options

Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 2426 Revision 1
Bellefonte Units 3 and 4
TVA
Docket No. 52-014 and 52-015
SRP Section: 09.05.01 - Fire Protection Program
Application Section: 9.5.1

QUESTIONS from Fire Protection Team (SFPT)

09.05.01-***

Revision 17 of the AP1000 DCD changed the design pressure from 5000 psi to 4000 psi for the High Pressure Air Subsystem that is used to recharge fire brigade's self-contained breathing apparatus (SCBA) cylinders. This design change has a potential impact on the adequacy of the breathing air recharging capability if high-pressure cylinders (4500 psi) are supplied for fire brigade's use. The applicant should review the above DCD change and address the impact on the breathing air system design at Bellefonte and make changes to the COLA as appropriate.