From: Fred Lyon
Sent: Tuesday, March 24, 2009 2:20 PM
To: 'BURMEISTER, BARRY M'
Cc: LORFING, DAVID N
Subject: RE: River Bend Change in Commitment (TAC No. ME0157)

The NRC staff acknowledges the change in commitment and has no objections.

From: BURMEISTER, BARRY M [mailto:BBURMEI@entergy.com]
Sent: Tuesday, March 24, 2009 2:03 PM
To: Fred Lyon
Cc: LORFING, DAVID N
Subject: River Bend

On November 20, 2008 River Bend submitted an amendment request to add a reference to an analytical method that will be used to determine core operating limits to Technical Specification (TS) 5.6.5, Core Operating Limits Report (COLR). Reference TAC ME0157.

In Attachment 3 of this application a commitment was made to:

> "Entergy has not completed analyses to determine whether a change to the TS Minimum Critical Power Ratio (MCPR) safety limits will be required for the RBS reload. <u>If analyses indicate that a change to the MCPR safety limit is required, the TS change will be requested separately.</u>"

The analysis necessary to determine if a change to the TS Minimum Critical Power Ratio (MCPR) safety limits will be required has been completed. The results of this analysis confirm <u>no change to the TS MCPR safety limits will be required for the RBS reload.</u>

If you have any questions please contact;

Barry Burmeister
River Bend Licensing
225-381-4148

E-mail Properties

Mail Envelope Properties ()

Subject: RE: River Bend Change in Commitment (TAC No. ME0157)
Sent Date: 03/24/2009 2:16:19 PM
Received Date: 03/24/2009 2:19:00 PM
From: Fred Lyon

Created By: Fred.Lyon@nrc.gov

Recipients:
BBURMEI@entergy.com ('BURMEISTER, BARRY M')
Tracking Status: None
DLORFIN@entergy.com (LORFING, DAVID N)
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	11111	03/24/2009

Options
Expiration Date:
Priority: olImportanceNormal
ReplyRequested: False
Return Notification: False

Sensitivity: olNormal
Recipients received: