

CCNPP3COLA PEmails

From: John Rycyna
Sent: Tuesday, March 24, 2009 1:24 PM
To: Poche, Robert; McQueeney, Jennifer; katie.thurstin@unistarnuclear.com
Cc: CCNPP3COL Resource; Timothy Steingass; David Terao; Michael Miernicki; Joseph Colaccino; James Biggins; Adam Gendelman
Subject: RAI No 88 CIB1 1924.doc (PUBLIC)
Attachments: RAI No 88 CIB1 1924.doc

Rob,

Attached please find the subject request for additional information (RAI). A draft of the RAI was provided to you on March 10, 2009. No conference call was requested to discuss this RAI. The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a date for receipt of this information will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the published schedule.

John Rycyna, PE
Sr. Project Manager
Division of New Reactor Licensing
Office of New Reactors
U.S. Nuclear Regulatory Commission
301-415-4122

Hearing Identifier: CalvertCliffs_Unit3Cola_Public_EX
Email Number: 607

Mail Envelope Properties (499C2FC6BB962446994CA8682D8ADF33174066915A)

Subject: RAI No 88 CIB1 1924.doc (PUBLIC)
Sent Date: 3/24/2009 1:24:15 PM
Received Date: 3/24/2009 1:24:16 PM
From: John Rycyna

Created By: John.Rycyna@nrc.gov

Recipients:

"CCNPP3COL Resource" <CCNPP3COL.Resource@nrc.gov>
Tracking Status: None
"Timothy Steingass" <Timothy.Steingass@nrc.gov>
Tracking Status: None
"David Terao" <David.Terao@nrc.gov>
Tracking Status: None
"Michael Miernicki" <Michael.Miernicki@nrc.gov>
Tracking Status: None
"Joseph Colaccino" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"James Biggins" <James.Biggins@nrc.gov>
Tracking Status: None
"Adam Gendelman" <Adam.Gendelman@nrc.gov>
Tracking Status: None
"Poche, Robert" <robert.poche@unistarnuclear.com>
Tracking Status: None
"McQueeney, Jennifer" <Jennifer.McQueeney@unistarnuclear.com>
Tracking Status: None
"katie.thurstin@unistarnuclear.com" <katie.thurstin@unistarnuclear.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	767	3/24/2009 1:24:16 PM
RAI No 88 CIB1 1924.doc		23662

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 88
3/24/2009

Calvert Cliffs Unit 3
UniStar
Docket No. 52-016
SRP Section: 01 - Introduction and Interfaces
Application Section: Section 6.6

QUESTIONS for Component Integrity, Performance, and Testing Branch 1 (AP1000/EPR Projects)
(CIB1)

01-3

CCNPP3 FSAR Section 6.6, Table 6.6-1 was submitted for the ASME Class 3 Site-Specific UHS Makeup Water System. The staff notes that Table 6.6-1 differs from Table IWD-2500-1, Examination Category D-A, in the 2004 Edition of the ASME Operation and Maintenance Code, specifically by excluding areas such as Examination Requirements/Fig. No., Acceptance Standard, Frequency or Notes. Since CCNPP3 FSAR Section 6.6 states that Class 2 and 3 components will meet the requirements of the 2004 Edition of the ASME Boiler and Pressure Vessel Code, Section XI and that no relief requests or alternatives are required, please revise Table 6.6-1 to include all of the information listed under Table IWD-2500-1 for Examination Category D-A items or justify an alternative.