




Rancho Seco
Final Status Survey Summary Report
September 29, 2008
Railway External to the IA
Survey Unit F8340021

Prepared By: Dan A. Tallman  Date: September 29, 2008
FSS Engineer

Reviewed By:  Date: 11/17/08
Lead FSS Engineer

Approved By:  Date: 3-3-09
Dismantlement Superintendent, Radiological

FINAL STATUS SURVEY SUMMARY REPORT

Survey Unit:

F8340021, Railway External to the IA

Survey Unit Description:

Operating History: The rail spur passes through two sections of the Non-Impacted portion of the site before entering the Industrial Area. The rail system was used to transport radioactive material from the site to the out of state waste disposal facilities. Even though the packages met DOT requirements for shipment, there is the potential for a small amount of contamination to be deposited along the rail right of way. There were no reports of rail contamination in the HSA and no documented, operational surveys showing evidence of contamination along the rail spur external to the Industrial Area.

Site Characterization: Soil samples were collected along the rail line and analyzed by gamma spectroscopy on site. The mean value was 0.073 pCi/g Cs-137 and the maximum was 0.114 pCi/g. Based on classification procedure (DSIP-0020) and the characterization survey data, the rail spur was classified as Class 3.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were randomly determined and 728 m² were scanned for approximately 12% coverage. Gamma Direct measurements were taken at each direct measurement location and analyzed with ISOCS / GAA. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Table 1. Survey Unit Design Parameters

Survey Design Parameter	Value	Comment
Survey Area:	F834	Railway External to the IA
Survey Unit:	0021	Open Land Area
Class:	3	LTP Table 5-4
SU Area (m²):	5990	
Evaluator:	D.A.Tallman	
DCGL Cs137 surrogate (pCi/g):	51.2	
Area Factor:	N/A	Class 3
Design DCGL_{mc} (pCi/g):	N/A	Class 3
LBGR (pCi/g):	51.1	Adjusted
Design Sigma (pCi/g):	0.018	DTBD-06-001, Table 5-4B
Type I Error:	0.05	
Type II Error:	0.05	
Nuclide:	Cs137	
Sample Area (m²):	N/A	Class 3
Total Area Scanned (m²):	728	
Scan Coverage (%):	12.2%	Class 3
Z_{1-α} :	1.645	
Z_{1-β} :	1.645	
Sign P:	0.99865	
Calculated Relative Shift:	5.5	
Relative Shift Used:	3	Uses 3.0 if Rel Shift >3
N-Value:	11	
Design N-Value + 20%:	14	NUREG-1575 Table 5-5
Grid Spacing L:	N/A	Class 3

Survey Results:

A total of 16 direct measurements were made in F8340021. The results including mean, median, standard deviation and range are shown in Table 2. All of the direct measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity with observed activity below the MDA (0.225 pCi/g Co60, 0.299 pCi/g Cs137). Gamma Direct measurements were counted to the MDC shown in Table 2-1 of Attachment 2.

Table 2. Direct Measurement Results
(all activity values in pCi/g)

Measurement ID	Cs137 MDA	Cs137 Activity	Uncertainty
Mean:		8.47E-01	
Median:		8.55E-01	
Standard Deviation:		7.66E-02	
Range:	6.11E-01 to 9.19E-01		
F8340021 R0001GD	9.09E-01	< 9.09E-01	
F8340021 R0002GD	8.82E-01	< 8.82E-01	
F8340021 R0003GD	9.19E-01	< 9.19E-01	
F8340021 R0004GD	9.17E-01	< 9.17E-01	
F8340021 R0005GD	9.09E-01	< 9.09E-01	
F8340021 R0006GD	6.11E-01	< 6.11E-01	
F8340021 R0007GD	8.28E-01	< 8.28E-01	
F8340021 R0008GD	8.88E-01	< 8.88E-01	
F8340021 R0009GD	8.72E-01	< 8.72E-01	
F8340021 R0010GD	9.04E-01	< 9.04E-01	
F8340021 R0011GD	8.24E-01	< 8.24E-01	
F8340021 R0012GD	8.28E-01	< 8.28E-01	
F8340021 R0013GD	8.38E-01	< 8.38E-01	
F8340021 R0014GD	8.25E-01	< 8.25E-01	
F8340021 R0015GD	8.23E-01	< 8.23E-01	
F8340021 R0016GD	7.73E-01	< 7.73E-01	

Survey Unit Data Assessment:

The survey design required 16 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 3. The sample mean and median values were less than the DCGL. The sample standard deviation was greater than the design standard deviation however, both values result in a relative shift greater than 3.0 so no additional samples were required.

Table 3. Data Assessment Results

Survey Results Parameter	Value	Comment
Actual Direct Measurements (N):	16	
Median (pCi/g):	8.55E-01	
Mean (pCi/g):	8.47E-01	
Standard Deviation (pCi/g):	7.66E-02	
Maximum (pCi/g):	9.19E-01	
Sign Test Final N Value:	16	
S+ Value:	16	
Critical Value:	11	
Sufficient Samples Collected:	Yes	
Maximum Value < DCGL:	Yes	
Median Value < DCGL:	Yes	
Mean Value < DCGL:	Yes	
Maximum Value < DCGL_{emc}:	N/A	Class 3
Standard Deviation <= Sigma:	Investigate	Both values result in relative shifts greater than three therefore, no additional sample measurements necessary.
Pass the Sign Test?	Yes	
Reject the Null Hypothesis?	Yes	
The survey unit passes all conditions?	Yes	

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 3 land survey and the sample results are consistent with that classification. The variability of the survey results was greater than the characterization data used for survey design. Both values result in a relative shift greater than three, therefore no additional sample are required. No potential areas of elevated activity were detected.

Conclusion:

The FSS of this survey unit was properly designed as a Class 3 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. All of the direct measurements were less than the DCGL. No investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.


It is concluded that survey unit F8340021 meets the release criteria of 10CFR20.1402.


Attachment 1

Maps

September 29, 2008

Survey Unit F8340021





SMUD


SACRAMENTO MUNICIPAL
UTILITY DISTRICT


NON-INDUSTRIAL AREA RAILWAY
RANDOM START POINT
GAMMA DIRECT MEASUREMENTS
F8340021-M2


FILE: 810001


SHEET 1 of 4



TC HILL











SMUD

SACRAMENTO MUNICIPAL
UTILITY DISTRICT

NON-INDUSTRIAL AREA RAILWAY
ISOCs GAMMA SCAN
MEASUREMENT LOCATIONS
F8340021-M3

FILE: 810001

SHEET 2 of 2

TC HILL

Attachment 2

Instrumentation

September 29, 2008

Survey Unit F8340021

Table 2-1. Survey Unit Instrumentation

Instrument	Detector Model No.	Detector Serial No.	MDC
Inspector	N/A	08051294	Soil – 0.919 pCi/g Cs-137 Soil – 0.919 pCi/g Co-60
ISOCS	N/A	1983920	Soil – 0.299 pCi/g Cs-137 Soil – 0.225 pCi/g Co-60

Table 2-2. Investigation Criteria and DCGL

Instrument	Parameter	Value
ISOCS	Investigation Criteria - Scan	Soil – 20 pCi/g Cs-137 Soil – 5 pCi/g Co-60
Inspector	Investigation Criteria - Direct	Soil – 51.2 pCi/g Cs-137 _(surr.)
All	DCGL _W	51.2 Cs-137 12.6 Co-60
All	DCGL _{EMC}	N/A

Attachment 3
Investigation
September 29, 2008
Survey Unit F8340021

(none required)

Attachment 4

Data Assessment

September 29, 2008

Survey Unit F8340021

